

Alachua County

License Number: 1102843

CARIBBEAN QUEEN

License Type: Permanent Food Service

507 NW 5 AVE, GAINESVILLE 32601

Inspection Date: 07/02/2009

Inspection Number: 1914073

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code

Observation

Violation Citation

15-27-2

Observed the presence of mesh filters in a hood where grease laden vapors are produced. For reporting purposes only.

NFPA 96, 6.1.3 Mesh filters shall not be used. FOR REPORTING PURPOSES ONLY

Bay County

License Number: 1305177

NEW YORKS FAMOUS PIZZA & PASTA OF PANAMA CITY INC

License Type: Permanent Food Service

1000 EAST 23 ST A-5, PANAMA CITY 32405

Inspection Date: 07/02/2009

Inspection Number: 1902640

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATHIAS, BELINDA

Violation Code

Observation

Violation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Brevard County

License Number: 1502012		BEST HOAGIES	
License Type: Permanent Food Service		225 W HIBISCUS BLVD, MELBOURNE 32901	
Inspection Date: 06/29/2009	Inspection Number: 1914135	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOODS, CRYSTAL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 1505962		SABAI THAI RESTAURANT	
License Type: Permanent Food Service		215 W HIBISCUS BLVD, MELBOURNE 32901	
Inspection Date: 06/29/2009	Inspection Number: 1914134	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOODS, CRYSTAL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 1505847		REID'S TROPICAL SCOOPS	
License Type: Permanent Food Service		4590 BABCOCK ST NE #105, PALM BAY 32905	
Inspection Date: 06/29/2009	Inspection Number: 1914095	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WEIMER, EDWIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 1502713		INDIAN FLAVORS	
License Type: Permanent Food Service		2447 N WICKHAM ROAD #144, MELBOURNE 32935	
Inspection Date: 07/02/2009	Inspection Number: 1914271	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOODS, CRYSTAL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only.light hanging from wires in walkin cooler.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.waitstaff area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1506031		CAFE O BEACH	
License Type: Permanent Food Service		1616 HIGHWAY A1A, SATELLITE BEACH 32937	
Inspection Date: 03/10/2009	Inspection Number: 1878614	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

Brevard County

License Number: 1505577	RIVERVIEW DINER & BAR		
License Type: Permanent Food Service	1390 S US HWY 1, MALABAR 32950		
Inspection Date: 06/30/2009	Inspection Number: 1914207	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHOENLY, BARBARA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 1504088	NSPC		
License Type: Permanent Food Service	9700 SOUTH A1A, MELBOURNE BEACH 32951		
Inspection Date: 07/02/2009	Inspection Number: 1888778	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MAYNARD, DIANE			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.k	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1601590 EL TROPICO
 License Type: Permanent Food Service 701 W HALLANDALE BEACH BLVD, HALLANDALE 33009

Inspection Date: 06/29/2009 Inspection Number: 1828883 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 1621883 BEST WESTERN HALLANDALE INN
 License Type: Permanent Food Service 101 ANSIN BLVD, HALLANDALE 33009

Inspection Date: 06/29/2009 Inspection Number: 1854111 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48	Out of compliance: Gas appliances - properly installed, maintained	NFPA 101, 96, 10 Gas appliances - properly installed, maintained

License Number: 1621896 TRAILER
 License Type: Permanent Food Service 831 N FEDERAL HWY, HALLANDALE 33009

Inspection Date: 07/01/2009 Inspection Number: 1874602 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.11/08	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 1607660 MEZZ HOT GRILL
 License Type: Permanent Food Service 831 N FEDERAL HWY, HALLANDALE 330092410

Inspection Date: 07/01/2009 Inspection Number: 1905539 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.k class	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1612715

KENTUCKY FRIED CHICKEN

License Type: Permanent Food Service

815 W HALLANDALE BEACH BLVD, HALLANDALE 33009-5238

Inspection Date: 07/02/2009

Inspection Number: 1874646

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.boxes blocking Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1614975

ISTANBUL RESTAURANT

License Type: Permanent Food Service

707 N BROADWALK #2, HOLLYWOOD 330191203

Inspection Date: 07/02/2009

Inspection Number: 1905551

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.front counter area

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1617484

JUCI JERK & GRILL

License Type: Permanent Food Service

1657 S 21 AVE, HOLLYWOOD 33020

Inspection Date: 06/26/2009

Inspection Number: 1914075

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CHAPDELAINE, MARIE

Violation CodeObservationViolation Citation

47

Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 1618318

PICCADILLY CAFETERIA

License Type: Permanent Food Service

4500 HOLLYWOOD BLVD, HOLLYWOOD 33021

Inspection Date: 06/29/2009

Inspection Number: 1874677

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CHAPDELAINE, MARIE

Violation CodeObservationViolation Citation

48

Out of compliance: Gas appliances - properly installed, maintained

NFPA 101, 96, 10 Gas appliances - properly installed, maintained

Broward County

License Number: 1621194		PRIMOS PIZZA & PASTA	
License Type: Permanent Food Service		17173 MIRAMAR PKWY, MIRAMAR 33027	
Inspection Date: 07/01/2009	Inspection Number: 1703161	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Violation: 45-41-2 Portable fire extinguisher on floor. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
47-15-2	Violation: 47-15-2 Observed a broken electrical switch cover. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 1612530		DOWNTOWN PIZZA	
License Type: Permanent Food Service		1831 E SAMPLE ROAD, POMPANO BEACH 33064	
Inspection Date: 04/23/2009	Inspection Number: 1825578	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: EARP, NICOLETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
49	Out of compliance: Flammable/combustible materials - properly stored	NFPA 101, 96, 10 Flammable/combustible materials - properly stored	

License Number: 1622275		BELLA ROMA	
License Type: Permanent Food Service		1100 MC NAB RD, FORT LAUDERDALE 33309	
Inspection Date: 06/25/2009	Inspection Number: 1831964	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHNEIDER, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	

License Number: 1620678		BOARS NEST SALOON	
License Type: Catering		381 PROSPECT RD, OAKLAND PARK 33309	
Inspection Date: 06/25/2009	Inspection Number: 1092326	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SCHNEIDER, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	

License Number: 1607700		LA AURORA RESTAURANT & CAFETERIA	
License Type: Permanent Food Service		3023 W DAVIE BLVD, FORT LAUDERDALE 33312	
Inspection Date: 06/29/2009	Inspection Number: 1895157	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair	

Broward County

License Number: 1621408 JOYS DELIGHT
 License Type: Permanent Food Service 3582 W BROWARD BLVD, FORT LAUDERDALE 33312

Inspection Date: 07/02/2009 Inspection Number: 1895148 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 1621940 MIDWAY FISH & CHICKEN
 License Type: Permanent Food Service 1405 W BROWARD BLVD, FORT LAUDERDALE 33312

Inspection Date: 07/02/2009 Inspection Number: 1854220 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1619877 ANTOJITOS MEXICANOS I
 License Type: Permanent Food Service 3943 W DAVIE BLVD, FT LAUDERDALE 33312

Inspection Date: 06/29/2009 Inspection Number: 1854235 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Broward County

License Number: 1614245	PIZZA HUT #55311		
License Type: Permanent Food Service	3924 DAVIE BLVD, FT LAUDERDALE	333123406	
Inspection Date: 06/29/2009	Inspection Number: 1884960	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46	Out of compliance: Exiting system - adequate, good repair		NFPA 101, 96, 10 Exiting system - adequate, good repair
License Number: 1613013	TEXAS HOLDEM BBQ		
License Type: Permanent Food Service	21 SW 7 ST, FORT LAUDERDALE	33315	
Inspection Date: 06/29/2009	Inspection Number: 1826811	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHERY, JOCELYNE			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair		NFPA 101, 96, 10 Electrical wiring - adequate, good repair
License Number: 1616491	MCDONALDS #12396		
License Type: Permanent Food Service	1201 SR 84, FT LAUDERDALE	33315	
Inspection Date: 07/02/2009	Inspection Number: 1895172	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.		NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
License Number: 1616849	LIL REDS COOKIN		
License Type: Permanent Food Service	1705 W SR 84, FT LAUDERDALE	33315	
Inspection Date: 07/02/2009	Inspection Number: 1874708	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.		NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Citrus County

License Number: 1900393

LUIGIS PIZZA

License Type: Permanent Food Service

4538 S SUNCOAST BLVD, HOMOSASSA 344461103

Inspection Date: 07/01/2009

Inspection Number: 1857176

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRAIG, JILL

Violation Code

Observation

Violation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces in prep room. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Clay County

License Number: 2000293

RED LOBSTER

License Type: Permanent Food Service

32 BLANDING BLVD, ORANGE PARK 32073

Inspection Date: 07/01/2009

Inspection Number: 1820992

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code

Observation

Violation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Dade County

License Number: 2302751		VERSAILLES REST	
License Type: Permanent Food Service		3555 SW 8 ST, MIAMI 331354109	
Inspection Date: 07/02/2009	Inspection Number: 1873516	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, BARBARO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.	

License Number: 2326471		EL ATAKAT RESTAURANT	
License Type: Permanent Food Service		9425 SW 40 ST, MIAMI 33165	
Inspection Date: 07/02/2009	Inspection Number: 1853528	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only. Class K	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	

License Number: 2325243		POLLO TROPICAL 25	
License Type: Permanent Food Service		19911 NW 2 AVE, MIAMI 331692903	
Inspection Date: 06/29/2009	Inspection Number: 1831953	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNOLD, RICARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46	Observed emergency exit obstructed.	NFPA 101, 96, 10 Exiting system - adequate, good repair	

Dade County

License Number: 2324443

TROPICAL FEAST REST

License Type: Permanent Food Service

18400 NW 2 AVE #5, MIAMI 331694536

Inspection Date: 07/02/2009

Inspection Number: 1852858

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: UNOLD, RICARDO

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2316538

LOS RANCHOS RESTAURANT

License Type: Permanent Food Service

125 SW 107TH AVE, SWEETWATER 33174

Inspection Date: 07/02/2009

Inspection Number: 1894846

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHOW, ZULEIMA

Violation CodeObservationViolation Citation

45-07-2

Observed misalignment of hood suppression system nozzles. For reporting purposes only. FLAT GRILL

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

License Number: 2321504

FRITANGA MONIMBO

License Type: Permanent Food Service

13710 SW 56 ST, MIAMI 33175

Inspection Date: 07/02/2009

Inspection Number: 1853526

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MORGADANES, DOUGLAS

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2316901

SILVER PALACE CHINESE RESTAURANT

License Type: Permanent Food Service

5771 SW 137 AVE, MIAMI 33183

Inspection Date: 07/01/2009

Inspection Number: 1884245

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MORGADANES, DOUGLAS

Violation CodeObservationViolation Citation

37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
46-13-2	Emergency light does not function when tested. For reporting purposes only.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2607573		MCDONALD'S	
License Type: Permanent Food Service		1768 DAVIS ST, JACKSONVILLE 32209	
Inspection Date: 07/01/2009	Inspection Number: 1860630	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only, FLOOR IN OFFICE.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 2612960		CHURCH'S CHICKEN #10465	
License Type: Permanent Food Service		3007 W EDGEWOOD AVE, JACKSONVILLE 32209	
Inspection Date: 07/01/2009	Inspection Number: 1891404	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only, GARBAGE BAG & BOXES /REAR DOOR.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

License Number: 2613386		TREY'S DELI & GRILL	
License Type: Permanent Food Service		2044 ROGERO RD, JACKSONVILLE 32211	
Inspection Date: 06/29/2009	Inspection Number: 1831893	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

License Number: 2613256		MOTOR WINGS	
License Type: Permanent Food Service		8101-3 OLD KINGS RD S, JACKSONVILLE 32217	
Inspection Date: 07/01/2009	Inspection Number: 1850276	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADSHAW, BONNIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

Duval County

License Number: 2611944		SUSHI N' WOK	
License Type: Permanent Food Service		10916 ATLANTIC BLVD #23, JACKSONVILLE 32225	
Inspection Date: 07/02/2009	Inspection Number: 1860492	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. back prep. area. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2614112		JIMMY FU'S	
License Type: Permanent Food Service		9180 MERRILL ROAD #5, JACKSONVILLE 32225-4320	
Inspection Date: 07/01/2009	Inspection Number: 1871055	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STOREY, MARIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2611273		PIZZA HUT DELIVERY #710224	
License Type: Permanent Food Service		8102 BLANDING BLVD #25, JACKSONVILLE 322445825	
Inspection Date: 07/01/2009	Inspection Number: 1891354	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SILBERMAN, STEPHANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked. For reporting purposes only. Corrected On Site.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 2613854		SONIC DRIVE IN OF BEACH BLVD	
License Type: Permanent Food Service		11110 BEACH BLVD, JACKSONVILLE 32246	
Inspection Date: 06/30/2009	Inspection Number: 1914451	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STOREY, MARIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

Duval County

License Number: 2612665	STONEWOOD GRILL & TAVERN		
License Type: Permanent Food Service	3832 BAYMEADOWS RD #3, JACKSONVILLE 32256		
Inspection Date: 06/30/2009	Inspection Number: 1914520	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADSHAW, BONNIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

License Number: 2614406	JUSTINA SEAFOOD MARKET		
License Type: Permanent Food Service	2944 JUSTINA RD, JACKSONVILLE 32277		
Inspection Date: 06/30/2009	Inspection Number: 1914499	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

Escambia County

License Number: 2705598

VALLARTA

License Type: Permanent Food Service

13584 PERDIDO KEY DR, PENSACOLA 32507

Inspection Date: 06/26/2009

Inspection Number: 1831721

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

46-05-2

Violation: 46-05-2

Observed obstructed exit on porch. For reporting purposes only. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2705613

REEF (THE)

License Type: Permanent Food Service

13595 PERDIDO KEY DR, PENSACOLA 32507

Inspection Date: 06/26/2009

Inspection Number: 1648663

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

45-07-2

Violation: 45-07-2

Observed build up of grease on hood filters. For reporting purposes only.

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

Flagler County

License Number: 2800655

CHICKEN BY THE SEA RESTAURANT

License Type: Permanent Food Service

1916 OCEANSHORE BLVD, FLAGLER BEACH 32136

Inspection Date: 06/30/2009

Inspection Number: 1914531

Inspection Type: Complaint Full

Inspection Disposition: Emergency
order recommended

Inspector Name: SCARPELLI, DAVID

Violation Code

Observation

Violation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Hernando County

License Number: 3700856

KOKOMOS PUB & GRILL

License Type: Permanent Food Service

2109 MARINER BLVD, SPRING HILL 34609

Inspection Date: 07/01/2009

Inspection Number: 1857316

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GLENN, DAVID

Violation Code

Observation

Violation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3910792

PIZZA HUT #4627

License Type: Permanent Food Service

17420 N HWY 41, LUTZ 33549

Inspection Date: 07/02/2009

Inspection Number: 1908666

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-15-2

No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only. Repeat Violation.

NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.(by office)

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3910948

LA HANGOUT

License Type: Permanent Food Service

16411 N FLORIDA AVE, LUTZ 33549

Inspection Date: 07/02/2009

Inspection Number: 1831978

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-15-2

No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.

NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 3909761

RICHARD'S CAFE

License Type: Permanent Food Service

101 FLAGSHIP DR, LUTZ 335495409

Inspection Date: 07/02/2009

Inspection Number: 1857388

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.(front counter)

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3915640		FRIED RICE KING	
License Type: Permanent Food Service		6117 N FLORIDA AVE, TAMPA 33604	
Inspection Date: 06/29/2009	Inspection Number: 1914174	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETERSON, DOUGLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 3900588		CHURCH'S CHICKEN #340	
License Type: Permanent Food Service		3815 ARMENIA AVE, TAMPA 33607	
Inspection Date: 06/29/2009	Inspection Number: 1914222	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 3905671		EMBASSY SUITES TAMPA AIRPORT WESTSHORE	
License Type: Permanent Food Service		555 N WESTSHORE BLVD, TAMPA 33609	
Inspection Date: 06/29/2009	Inspection Number: 1914196	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 3916097		A & J CAFE	
License Type: Permanent Food Service		5804 N 40 ST, TAMPA 33610	
Inspection Date: 06/29/2009	Inspection Number: 1914176	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETERSON, DOUGLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 3901071		PICCADILLY CAFETERIA	
License Type: Permanent Food Service		13702 N 30 ST, TAMPA 33613	
Inspection Date: 07/01/2009	Inspection Number: 1877892	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only.(walk in cooler door)	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	
License Number: 3910059		RJ WINGS N THINGS	
License Type: Permanent Food Service		5025 E FOWLER AVE, TAMPA 33617	
Inspection Date: 06/26/2009	Inspection Number: 1831378	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EDMISTON, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

Hillsborough County

License Number: 3911540

CATERING BY CHEF AMEER

License Type: Catering

4004 W NEPTUNE #103, TAMPA 33629

Inspection Date: 06/29/2009

Inspection Number: 1093338

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 3916369

TOP CHINA

License Type: Permanent Food Service

13306 TELECOM DR, TEMPLE TERRACE 33637

Inspection Date: 07/01/2009

Inspection Number: 1877914

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation Code

Observation

Violation Citation

47-13-2 Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Lee County

License Number: 4605324 COYOTE BLU
 License Type: Permanent Food Service 1924 COMMERCIAL DR, FORT MYERS 33901
 Inspection Date: 06/29/2009 Inspection Number: 1826130 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AHMED, SYED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	OBSERVED EXIT SIGN NOT ILLUMINATED. FOR REPORTING PUPOSE ONLY. EXIT LEFT OF STAGE.	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 4604587 MACDADDY'S
 License Type: Permanent Food Service 8951 DANIELS PKWY, FORT MYERS 33912
 Inspection Date: 06/30/2009 Inspection Number: 1831076 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TORBERT, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	OBSERVED K CLASS EXTINGUISHER UNDER CHARGED.	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 4602890 MICELI'S RESTAURANT
 License Type: Permanent Food Service 3930 PINE ISLAND RD, CAPE CORAL 33993
 Inspection Date: 06/30/2009 Inspection Number: 1830951 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	OBSERVED UNLABELED SPRAY BOTTLE AT WAIT STATION. COS	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 4605642 FUTURO'S
 License Type: Permanent Food Service 4185 BONITA BEACH RD, BONITA SPRINGS 34134
 Inspection Date: 07/01/2009 Inspection Number: 1893408 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TORBERT, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K class extinguisher on kitchen floor. Repeat Violation. Corrected On Site.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Leon County

License Number: 4702293

SOUTHGATE SERVICE CAFETERIA

License Type: Permanent Food Service

675 W JEFFERSON ST, TALLAHASSEE 323048013

Inspection Date: 07/02/2009

Inspection Number: 1902324

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARGROVE, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. EXPIRED 06/06/09. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Levy County

License Number: 4800472

LADY LUCK CAFE

License Type: Permanent Food Service

157 N HATHAWAY AVE, BRONSON 32621

Inspection Date: 06/29/2009

Inspection Number: 1809398

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

46 Out of compliance: Exiting system - adequate, good repair

NFPA 101, 96, 10 Exiting system - adequate, good
repair

License Number: 4800550

SUWANNEE GUIDES

License Type: Permanent Food Service

11650 NW 115 ST, CHIEFLAND 32626

Inspection Date: 07/01/2009

Inspection Number: 1910963

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and
sufficient

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good
repair

License Number: 4800469

ANGELINA MIA PIZZERIA RISTORANTE

License Type: Permanent Food Service

214 W NOBLE AVE, WILLISTON 32696

Inspection Date: 06/25/2009

Inspection Number: 1830220

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WRENNE, LILYANN

Violation CodeObservationViolation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and
sufficient

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good
repair

Manatee County

License Number: 5103902	PIZZA HUT #4608		
License Type: Permanent Food Service	3132 53 AVE EAST, BRADENTON	34203	
Inspection Date: 06/26/2009	Inspection Number: 1914081	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONTEH, FATIMAH			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	EXIT DOOR BLOCKED BY CARD BOARD BOXES: BACK DOOR	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 5104411	TEJANO CAFE		
License Type: Permanent Food Service	12345 N US HWY 301, PARRISH	34219	
Inspection Date: 06/27/2009	Inspection Number: 1659798	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BAGLEY, VICTORIA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	HAS LOCK IN USE ON KITCHEN INTERIOR DOOR - FOR REPORTING PURPOSES	NFPA 101, 96, 10 Exiting system - adequate, good repair

NOTE: FULL KITCHEN IS LICAED AT TIME OF ISNEPCTION. IS NOT IN USE. OPERATOR MUST MAKE KITCHEN AREA AVAILABLE FOR INSPECTION.

Marion County

License Number: 5202731 JERSEY GIRL CREAMERY
 License Type: Permanent Food Service 22050A N HWY 441, MCINTOSH 32664

Inspection Date: 06/29/2009 Inspection Number: 1914558 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 5202259 BURGER KING #12454
 License Type: Permanent Food Service 4976 E SILVER SP BLVD, OCALA 34470

Inspection Date: 06/29/2009 Inspection Number: 1830794 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 5202501 PIZZA FACTORY
 License Type: Permanent Food Service 2425 NE 18 PLACE # 104, OCALA 34470

Inspection Date: 06/29/2009 Inspection Number: 1914546 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 5202129 CICI'S PIZZA
 License Type: Permanent Food Service 2427 SW 27 AVE, OCALA 34474

Inspection Date: 06/30/2009 Inspection Number: 1914515 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

Martin County

License Number: 5300480

ONE WAY OR THE OTHER/ NATURE'S WAY CAFE

License Type: Permanent Food Service

8767 SE BRIDGE RD, HOBE SOUND 33455

Inspection Date: 07/01/2009

Inspection Number: 1819324

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

46-09-2

Violation: 46-09-2

Exit signs not properly illuminated. For reporting purposes only. rear.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-04-2

Violation: 47-04-2

Observed frayed/spliced electrical wires. For reporting purposes only. behind bar area.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5300777

SCOOTERS FUN FOODS&SPIRITS INC

License Type: Permanent Food Service

8913 SE BRIDGE RD, HOBE SOUND 334555312

Inspection Date: 07/01/2009

Inspection Number: 1855536

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. service line.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Martin County

License Number: 5301662

AJ'S GRILL

License Type: Permanent Food Service

10314 SE FEDERAL HWY, HOBE SOUND 33455-7367

Inspection Date: 07/02/2009

Inspection Number: 1828918

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. cooler.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5301096

JENSEN BEACH GRILL & WINGS

License Type: Permanent Food Service

995 NE JENSEN BEACH BLVD, JENSEN BEACH 34957

Inspection Date: 07/01/2009

Inspection Number: 1906978

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

47-15-2 Observed an uncovered electrical box. For reporting purposes only... walk-in freezer fan unit.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5300262

BASIL GARDEN II

License Type: Permanent Food Service

2655 SW FEROE AVE, PALM CITY 34990

Inspection Date: 07/01/2009

Inspection Number: 1896537

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only... back door.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5301562

N Y CHINESE RESTAURANT OF PALM CITY

License Type: Permanent Food Service

1365 SW MARTIN HWY, PALM CITY 34990

Inspection Date: 06/29/2009

Inspection Number: 1835168

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

Martin County

License Number: 5301576

SUBWAY #34062

License Type: Permanent Food Service

1345 SW MARTIN HWY, PALM CITY 34990

Inspection Date: 06/29/2009

Inspection Number: 1835118

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

Monroe County

License Number: 5401249		ISLAMORADA TOER OF PIZZA	
License Type: Permanent Food Service		81645 OVERSEAS HWY, ISLAMORADA 33036	
Inspection Date: 07/02/2009	Inspection Number: 1914074	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROWN, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.	

License Number: 5400078		WHALE HARBOR INN	
License Type: Permanent Food Service		83901 OVERSEAS HWY, ISLAMORADA, VLG OF I 33036	
Inspection Date: 07/02/2009	Inspection Number: 1894714	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROWN, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

License Number: 5401433		LA TRATTORIA/ VIRGILIOS	
License Type: Permanent Food Service		524 DUVAL STREET, KEY WEST 33040	
Inspection Date: 06/29/2009	Inspection Number: 1672408	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BOAK, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48	No boiler on site	NFPA 101, 96, 10 Gas appliances - properly installed, maintained	

License Number: 5402475		SEVEN FISH	
License Type: Permanent Food Service		632 OLIVIA ST, KEY WEST 33040	
Inspection Date: 06/29/2009	Inspection Number: 1713405	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BOAK, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48	No boiler on site	NFPA 101, 96, 10 Gas appliances - properly installed, maintained	

License Number: 5401555		COCO'S KITCHEN	
License Type: Permanent Food Service		BIG PINE SHOPPING PL, BIG PINE KEY 33043	
Inspection Date: 06/29/2009	Inspection Number: 1682423	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	

Nassau County

License Number: 5500554

ISLAND BARBECUE

License Type: Permanent Food Service

2045 S FLETCHER AVE, FERNANDINA BCH 32034

Inspection Date: 07/02/2009

Inspection Number: 1911699

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PHELAN, JOHN

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. Kitchen

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5500922

LUCKY WOK

License Type: Permanent Food Service

2114 SADLER RD, FERNANDINA BEACH 32034

Inspection Date: 07/02/2009

Inspection Number: 1901521

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PHELAN, JOHN

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Missing hood filter

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

46-09-2 Exit signs not properly illuminated. For reporting purposes only. Rear door

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. Chest freezer

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Nassau County

License Number: 5500833		MURRAY'S GRILLE	
License Type: Permanent Food Service		463852 STATE ROAD 200, YULEE 32097	
Inspection Date: 04/23/2009	Inspection Number: 1648346	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Powering tea Machine; waitress station;	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only. Light hanging by its wires; upstairs storage room	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. cook's line;	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 5500842		BURGER KING #11309	
License Type: Permanent Food Service		149 E STATE ROAD 200, YULEE 32097	
Inspection Date: 04/27/2009	Inspection Number: 1648328	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. ABC by the walk-in	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Orange County

License Number: 5808480		EL KORITA RESTAURANT	
License Type: Permanent Food Service		3107 N HWY 441, ZELLWOOD 32798	
Inspection Date: 07/01/2009	Inspection Number: 1858758	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-27-2	Portable fire extinguisher blocked/not easily accessible. For reporting purposes only. Block by white freezer.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 5803130		CHRISTOS CAFE	
License Type: Permanent Food Service		1815 EDGEWATER DR, ORLANDO 328045845	
Inspection Date: 06/30/2009	Inspection Number: 1914209	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GORDON, NORMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 5804120		CHICK-FIL-A	
License Type: Permanent Food Service		8001 S ORANGE BLOSSOM TRAIL, BELLE ISLE 32809	
Inspection Date: 06/29/2009	Inspection Number: 1914181	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 5804122		NATURE'S TABLE	
License Type: Permanent Food Service		8001 S ORANGE BLOSSOM TRL, ORLANDO 328097654	
Inspection Date: 06/29/2009	Inspection Number: 1914178	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 5808056		AUTHENTIC NY PIZZA #2	
License Type: Permanent Food Service		2753 N HIAWASSEE ROAD, ORLANDO 32818	
Inspection Date: 06/29/2009	Inspection Number: 1831258	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, ALEX			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 5811094		CENTERPLATE @ SOUTHWEST FOOD COURT	
License Type: Permanent Food Service		9800 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 06/26/2009	Inspection Number: 1914246	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RIVERA, JESICA M			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	

Orange County

License Number: 5808469

MARKETPLACE

License Type: Permanent Food Service

5925 AVENIDA VISTA, ORLANDO 32821

Inspection Date: 07/02/2009

Inspection Number: 1889816

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation Code

Observation

Violation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5808536 GRAND VISTA RESORT FOOD COURT
 License Type: Permanent Food Service 5925 AVENIDA VISTA, ORLANDO 32821

Inspection Date: 07/02/2009 Inspection Number: 1838505 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 5808971 BENNIGANS #1099
 License Type: Permanent Food Service 13520 S APOPKA VINELAND RD, ORLANDO 32821

Inspection Date: 07/01/2009 Inspection Number: 1838493 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-2	Boiler certificate not posted in boiler room. For reporting purposes only.	69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5812317

ICE CREAM PARLOR

License Type: Permanent Food Service

5925 AVENIDA VISTA, ORLANDO 32821

Inspection Date: 07/02/2009

Inspection Number: 1889766

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation Code

Observation

Violation Citation

48-12-2 No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 5811102

PIZZERIA ROMANA

License Type: Permanent Food Service

12701 S JOHN YOUNG PKWY #117, ORLANDO 32837

Inspection Date: 07/01/2009

Inspection Number: 1830726

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation Code

Observation

Violation Citation

47-07-2 Observed scorch marks around electrical outlet by pizza make table. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5805669 CABARET INTERNATIONALE
 License Type: Permanent Food Service 5581 S ORANGE BLOSSOM TR, ORLANDO 328392663

Inspection Date: 07/02/2009 Inspection Number: 1909584 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: GORIS, WILBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. UNIT BY THE BAR. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5812300 AMC THEATRES WEST OAKS 14
 License Type: Permanent Food Service 9415 WEST COLONIAL DR, OCOEE 34761

Inspection Date: 07/01/2009 Inspection Number: 1869457 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHIU, ALEX

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Osceola County

License Number: 5910006

UPPER CRUST PIZZA CAFE

License Type: Permanent Food Service

606 MARKET STREET SUITE #160, CELEBRATION 34747

Inspection Date: 07/02/2009

Inspection Number: 1837125

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation Code

Observation

Violation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reach cooler located at back kitchen. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6019057

HOT PIE PIZZA

License Type: Permanent Food Service

123 SOUTH OLIVE AVE, WEST PALM BEACH 33401

Inspection Date: 07/02/2009

Inspection Number: 1914637

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHAPIRO, STEWART

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K & ABC

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6010669

ONE STOP JAMAICAN RESTAURANT

License Type: Permanent Food Service

1736 W 45 ST, WEST PALM BEACH 33407-2165

Inspection Date: 07/01/2009

Inspection Number: 1865770

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

47-16-2

Violation: 47-16-2

Electrical outlet missing cover plate. For reporting purposes only. next to rear door.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6007696

LUTINA'S

License Type: Permanent Food Service

10800 N MILITARY TRL STE 114, PALM BEACH GARDENS 33410

Inspection Date: 07/01/2009

Inspection Number: 1906862

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.kitchen

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 6007801

SBARRO #279 THE GARDENS

License Type: Permanent Food Service

3101 PGA BLVD, PALM BEACH GARDENS 33410

Inspection Date: 06/29/2009

Inspection Number: 1855433

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

47

Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

Palm Beach County

License Number: 6019189 JOY LUCK CHINESE RESTAURANT
 License Type: Permanent Food Service 1684 S CONGRESS AVE, PALM SPRINGS 33461

Inspection Date: 06/29/2009 Inspection Number: 1906655 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PIERI, CYNTHIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 6019232 LYDE'S RESTAURANT
 License Type: Permanent Food Service 7102 SOUTH MILITARY TRAIL, LAKE WORTH 33463

Inspection Date: 06/10/2009 Inspection Number: 1831974 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PONCE, NUARETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 6013294 GOLDEN CHOPSTICKS
 License Type: Permanent Food Service 644 N US HWY 1, TEQUESTA 33469

Inspection Date: 07/02/2009 Inspection Number: 1896477 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DERVIN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 6020201 LOBSTER HOUSE LLC
 License Type: Permanent Food Service 716 US HIGHWAY ONE NORTH, TEQUESTA 33469

Inspection Date: 07/02/2009 Inspection Number: 1896523 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: DERVIN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. thru ceiling in kitchen.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. thru ceiling in kitchen.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6020330

BAGEL BISTRO INC

License Type: Permanent Food Service

173 N US 1, TEQUESTA 33469

Inspection Date: 07/02/2009

Inspection Number: 1831430

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation Code

Observation

Violation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6102245

BAGELS GALORE

License Type: Permanent Food Service

7303 STATE ROAD 52, HUDSON 34667

Inspection Date: 07/02/2009

Inspection Number: 1908586

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6113197

THE PHILLY CHEESESTEAK & SUB FACTORY

License Type: Permanent Food Service

7414 SR 52 SUITE 5, HUDSON 34667-6700

Inspection Date: 07/02/2009

Inspection Number: 1820535

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

45-31-2

Violation: 45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small deep fryer not under hood system.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6102766

MY WAY PIZZERIA

License Type: Permanent Food Service

7810 HWY 19 N, PORT RICHEY 34668

Inspection Date: 06/29/2009

Inspection Number: 1914476

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BASAK, JOHN

Violation CodeObservationViolation Citation

45

Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Pasco County

License Number: 6101803

THE HAYLOFT

License Type: Permanent Food Service

8954 SR 52, HUDSON 34669

Inspection Date: 07/02/2009

Inspection Number: 1847027

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation Code

Observation

Violation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6216225 OLD NORTHEAST PIZZERIA
 License Type: Permanent Food Service 718 2 ST N, ST. PETERSBURG 33701

Inspection Date: 07/02/2009 Inspection Number: 1907426 Inspection Type: Training Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WAGNER, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6214728 NEW CHINA RESTAURANT
 License Type: Permanent Food Service 928 58 ST N, ST PETERSBURG 33710

Inspection Date: 07/02/2009 Inspection Number: 1886475 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURKE, LAWRENCE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 6211711 CHECKERS RESTAURANT
 License Type: Permanent Food Service 201 N FT HARRISON AVE, CLEAR WATER 33755

Inspection Date: 07/01/2009 Inspection Number: 1866412 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WINSOR, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.----at grill--all hood filters missing.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6208765 KFC 024
 License Type: Permanent Food Service 2537 COUNTRYSIDE BLVD, CLEARWATER 33761

Inspection Date: 07/01/2009 Inspection Number: 1835731 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CRAIG, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. in two different locationsFor reporting purposes only. Repeat Violation.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6211737 JO TO JAPANESE RESTAURANT
 License Type: Permanent Food Service 2549 COUNTRYSIDE BLVD, CLEARWATER 33761

Inspection Date: 06/29/2009 Inspection Number: 1914281 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRAIG, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48	Out of compliance: Gas appliances - properly installed, maintained	NFPA 101, 96, 10 Gas appliances - properly installed, maintained

Pinellas County

License Number: 6216472 M&N GOODIES LLC
 License Type: Permanent Food Service 1901 WEST BAY DRIVE #13, LARGO 33770

Inspection Date: 07/02/2009 Inspection Number: 1820839 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: OLSEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. several abc fire extinguishers	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6201341 PIZZA HUT #4652
 License Type: Permanent Food Service 8380 SEMINOLE BLVD, SEMINOLE 33772

Inspection Date: 07/01/2009 Inspection Number: 1856028 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: OLSEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. class k sitting on floor in kitchen area	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6215191 ITALIAN VILLA
 License Type: Permanent Food Service 7155 SEMINOLE PLZ, SEMINOLE 33772

Inspection Date: 06/29/2009 Inspection Number: 1914465 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: OLSEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 6212781 CM'S PLACE
 License Type: Permanent Food Service 10754 N 70 AVE, SEMINOLE 337726350

Inspection Date: 07/01/2009 Inspection Number: 1886675 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: OLSEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. to a tv in pool room area	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6212607 CHUBBY CHEF INC
 License Type: Permanent Food Service 11411 STARKEY ROAD, LARGO 33773

Inspection Date: 06/29/2009 Inspection Number: 1914279 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PORTER, LINDSAY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 6216002 SARDO'S PIZZA
 License Type: Permanent Food Service 10839 ULMERTON RD, LARGO 33778

Inspection Date: 07/02/2009 Inspection Number: 1866276 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: OLSEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed an uncovered electrical box. For reporting purposes only. in office area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6216360 BURGER KING
 License Type: Permanent Food Service 7930 US 19, PINELLAS PARK 33781

Inspection Date: 07/02/2009 Inspection Number: 1896783 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURKE, LAWRENCE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 6213652 GINO NY STYLE PIZZERIA REST
 License Type: Permanent Food Service 35977 US HWY 19, PALM HARBOR 346841523

Inspection Date: 06/29/2009 Inspection Number: 1914282 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRAIG, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

Putnam County

License Number: 6400614

TACO BELL

License Type: Permanent Food Service

3306 CRILL AVE, PALATKA 321774160

Inspection Date: 07/02/2009

Inspection Number: 1914072

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code

Observation

Violation Citation

15-40-2

No metal container installed for catching grease from hood drip tray. For reporting purposes only. Repeat Violation.

NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

Sarasota County

License Number: 6804907

SIESTA KEY SANDWICH SHOP

License Type: Permanent Food Service

5027 OCEAN BLVD, SARASOTA 34242

Inspection Date: 06/25/2009

Inspection Number: 1829581

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: POSA, ANTHONY

Violation Code

Observation

Violation Citation

46

EXIT SIGNS NO ILLUMANATED

NFPA 101, 96, 10 Exiting system - adequate, good repair

Seminole County

License Number: 6903844

ORLANDO ALE HOUSE

License Type: Permanent Food Service

477 E. ALTAMONTE DR., ALTAMONTE SPRINGS 32701

Inspection Date: 07/02/2009

Inspection Number: 1914267

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WATSON, DENNIS

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6902298

KOREA HOUSE RESTAURANT

License Type: Permanent Food Service

1155 W SR 434 STE 121, LONGWOOD 32750

Inspection Date: 06/29/2009

Inspection Number: 1914502

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

46

Out of compliance: Exiting system - adequate, good repair

NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 6903947

COLOMBIA LA BELLA RESTAURANT

License Type: Permanent Food Service

600 N HWY 1792 STE 160, LONGWOOD 32750

Inspection Date: 06/29/2009

Inspection Number: 1914501

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

45

Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

St. Johns County

License Number: 6501939

T & A PETROLEUM INC / BRUNO'S NY STYLE PIZZA

License Type: Permanent Food Service

2530 SR 207, SAINT AUGUSTINE 32086

Inspection Date: 06/29/2009

Inspection Number: 1914524

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

