

Alachua County

License Number: 1100731		WAFFLE HOUSE #171	
License Type: Permanent Food Service		7611 NW 8 AVE, GAINESVILLE 32601	
Inspection Date: 07/15/2009	Inspection Number: 1849659	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: BROWNING, JULIANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Repeat Violation.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1102437		HARRYS SOF GAINESVILLE	
License Type: Permanent Food Service		110 SE 1 ST, GAINESVILLE 326016825	
Inspection Date: 07/13/2009	Inspection Number: 1870997	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DOHERTY, BRENDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 1102748		KENTUCKY FRIED CHICKEN	
License Type: Permanent Food Service		7605 W NEWBERRY RD, GAINESVILLE 32605	
Inspection Date: 07/15/2009	Inspection Number: 1900801	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROWNING, JULIANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 1101474		PERKIN'S FAMILY REST & BAKERY	
License Type: Permanent Food Service		6825 NW 8 AVE, GAINESVILLE 326051910	
Inspection Date: 07/14/2009	Inspection Number: 1849891	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: HENTGES, JUDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Repeat Violation.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 1101879		SUBWAY SANDWICHES & SALADS	
License Type: Permanent Food Service		6666 W NEWBERRY RD, GAINESVILLE 326054311	
Inspection Date: 07/16/2009	Inspection Number: 1890640	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENTGES, JUDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. trash in front of rear exit door	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

Alachua County

License Number: 1101214

WENDYS OLD FASHIONED HAMBURGER

License Type: Permanent Food Service

6700 NEWBERRY RD, GAINESVILLE 326054313

Inspection Date: 07/16/2009

Inspection Number: 1849859

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HENTGES, JUDY

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
trash in front of rear exit doorNFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of
egress shall be continuously maintained free of all
obstructions or impediments to full instant use in the
case of fire or other emergency. Means of access must
permit unobstructed travel at all times and be
maintained free of obstructions and fire hazards. Halls,
entrances and stairways shall be clean, ventilated and
well-lighted day and night. Hall and stair runners shall
be kept in good condition. Hand rails shall be installed
on all stairways and guard rails around all porches and
steps. Adequate means of exit shall be provided
pursuant to NFPA 101. FOR REPORTING
PURPOSES ONLY.

License Number: 1102274

BALLYHOO GRILL

License Type: Permanent Food Service

3700 NEWBERRY, GAINESVILLE 32607

Inspection Date: 06/25/2009

Inspection Number: 1915260

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WRENNE, LILYANN

Violation CodeObservationViolation Citation

45

Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and
sufficient

License Number: 1102672

EL RANCHO VIEJO

License Type: Permanent Food Service

4320 SW 20 AVE, GAINESVILLE 32607

Inspection Date: 07/13/2009

Inspection Number: 1849821

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WRENNE, LILYANN

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For
reporting purposes only.NFPA 96, 6.2.3.3 Grease filters shall be arranged so
that all exhaust air shall pass through the grease filters.
For reporting purposes only.

Baker County

License Number: 1200144

WINGS GALORE & MORE

License Type: Permanent Food Service

1441 S 6 ST, MACCLENNY 32063

Inspection Date: 07/09/2009

Inspection Number: 1901001

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher over charged. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 1200132

SANDWICH USA

License Type: Permanent Food Service

364 W MCCLENNY AVE, MACCLENNY 32604

Inspection Date: 07/09/2009

Inspection Number: 1849897

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HENTGES, JUDY

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Bay County

License Number: 1305181 THE CURRY POT
 License Type: Permanent Food Service 10440 FRONT BEACH ROAD, PANAMA CITY 32401

Inspection Date: 07/14/2009 Inspection Number: 1851021 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DESHAZIER, ERNEST

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only. Observed two 20 pounds LP cylinder in the restaurant next to the gas waterheater.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 1301821 ALL AMERICAN DINER
 License Type: Permanent Food Service 10590 W HWY 98A, PANAMA CITY BCH 324073516

Inspection Date: 07/13/2009 Inspection Number: 1871427 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DESHAZIER, ERNEST

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 1303081 KFC L747002
 License Type: Permanent Food Service 10272 W FRONT BEACH RD, PANAMA CITY BCH 324073808

Inspection Date: 07/13/2009 Inspection Number: 1841005 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MATHIAS, BELINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 1304894 PO FOLKS
 License Type: Permanent Food Service 400 OHIO AVE, LYNN HAVEN 32444

Inspection Date: 04/21/2009 Inspection Number: 1819417 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: TALLEY, BELINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Brevard County

License Number: 1504776		ROUNDERS BAR & GRILL	
License Type: Permanent Food Service		2204 S WASHINGTON AVE, TITUSVILLE 32780	
Inspection Date: 07/17/2009	Inspection Number: 1890026	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZALESKI, AMY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed hasp lock on walk-in cooler door. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
License Number: 1502915		SHORE LANES #2	
License Type: Permanent Food Service		4851 S DAIRY RD, MELBOURNE 32904	
Inspection Date: 07/15/2009	Inspection Number: 1847317	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate./back wall bar area For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet cracked cover plate. For reporting purposes only./back dish area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1505475		SMOKEY BONES BAR & FIRE GRILL #7521	
License Type: Permanent Food Service		1510 W NEW HAVEN AVE, MELBOURNE 32904	
Inspection Date: 07/13/2009	Inspection Number: 1898653	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only./take out area	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 1506118		MCDONALDS RESTAURANTS NAT 33138	
License Type: Permanent Food Service		235 PALM BAY RD, WEST MELBOURNE 32904	
Inspection Date: 07/14/2009	Inspection Number: 1915344	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged/by back handsink . For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Brevard County

License Number: 1504956		I95 520 BURGER KING	
License Type: Permanent Food Service		4600 HWY 520, COCOA 32926	
Inspection Date: 07/15/2009	Inspection Number: 1910593	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PFISTER, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge above deep fryer line. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 1503860		THE WINNER'S CLUB	
License Type: Permanent Food Service		1100 N WICKHAM RD, MELBOURNE 32935	
Inspection Date: 07/17/2009	Inspection Number: 1915413	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOODS, CRYSTAL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.2 in kitchen Corrected On Site. Repeat Violation.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1504720		NEW HONG KONG RESTAURANT	
License Type: Permanent Food Service		198 BARTON BLVD, ROCKLEDGE 32955	
Inspection Date: 07/14/2009	Inspection Number: 1898581	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1503053		KITCHEN	
License Type: Permanent Food Service		625 BAREFOOT BLVD, BAREFOOT BAY 329767305	
Inspection Date: 07/15/2009	Inspection Number: 1898857	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-12-2	Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1621199 MCDONALDS
 License Type: Permanent Food Service 835 W HALLANDALE BEACH BLVD, HALLANDALE 33009

Inspection Date: 07/14/2009 Inspection Number: 1905557 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.boxes Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1618442 BOARDWALK ICE CREAM
 License Type: Permanent Food Service 1504 N BROADWALK, HOLLYWOOD 33019

Inspection Date: 07/14/2009 Inspection Number: 1843937 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1620164 AIZIA AND BARSU
 License Type: Permanent Food Service 3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 07/06/2009 Inspection Number: 1905560 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Broward County

License Number: 1621272		SUBWAY	
License Type: Permanent Food Service		1800 S UNIVERSITY DR, MIRAMAR 33025	
Inspection Date: 07/16/2009	Inspection Number: 1894958	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view, plant blocking access, dining room. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 1607843		MCDONALD'S #4401	
License Type: Permanent Food Service		3306 S UNIVERSITY DR, MIRAMAR 330253018	
Inspection Date: 07/16/2009	Inspection Number: 1843757	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 1621978		IRIE ISLE BAKERY AND TAKEOUT RESTAURANT	
License Type: Permanent Food Service		1480 S PALM AVE, PEMBROKE PINES 33026	
Inspection Date: 07/16/2009	Inspection Number: 1843759	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 1609636		MCLEAN'S BAR & GRILL	
License Type: Permanent Food Service		2160 MEARS PARKWAY, POMPANO BEACH 33063	
Inspection Date: 07/16/2009	Inspection Number: 1829893	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIEHL, TERENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. AT BAR. Corrected On Site.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1617617	STEAK SHOP & DELI REST (THE)	
License Type: Permanent Food Service	1801 E SAMPLE RD, POMPANO BEACH 330646604	
Inspection Date: 07/14/2009	Inspection Number: 1885457	
Inspector Name: EARP, NICOLETTE	Inspection Type: Routine - Food	
	Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1617179	BLUE MOON FISH COMPANY	
License Type: Permanent Food Service	10317 ROYAL PALM BLVD, CORAL SPRINGS 33065	
Inspection Date: 07/16/2009	Inspection Number: 1885329	
Inspector Name: BECKER, ROBERT	Inspection Type: Routine - Food	
	Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. In kitchen under cooks line.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1620457	ASAHI RESTAURANT	
License Type: Permanent Food Service	8152 W MCNAB RD, N LAUDERDALE 33068	
Inspection Date: 07/16/2009	Inspection Number: 1864818	
Inspector Name: WILLIAMS, NOVELETTE	Inspection Type: Routine - Food	
	Inspection Disposition: Warning Issued	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period, with microwave. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1620078	EL RACHO BAKERY & RESTAURANT 1	
License Type: Permanent Food Service	6023 KIMBERLY BLVD, NORTH LAUDERDALE 33068	
Inspection Date: 07/14/2009	Inspection Number: 1885193	
Inspector Name: WILLIAMS, NOVELETTE	Inspection Type: Routine - Food	
	Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Broward County

License Number: 1621094 EL NOPAL
 License Type: Permanent Food Service 6025 KIMBERLY BLVD, NORTH LAUDERDALE 33068

Inspection Date: 07/14/2009 Inspection Number: 1854536 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY
47-06-2	Observed extension cord in use for non-temporary period, with reachin cooler by frontline. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1621399 THE DUTCH POT JAMACIAN RESTAURANT #2
 License Type: Permanent Food Service 6029 KIMBERLY BLVD, NORTH LAUDERDALE 33068

Inspection Date: 07/14/2009 Inspection Number: 1844209 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated and in disrepair by rear door. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 1612182 SUBWAY #737
 License Type: Permanent Food Service 8050 W MCNAB RD, N LAUDERDALE 330684254

Inspection Date: 07/16/2009 Inspection Number: 1885219 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-2	Sprinkler head spray pattern obstructed, dusty. For reporting purposes only.	NFPA 25, 5.2.1.2 Unacceptable obstructions to spray patterns shall be corrected. FOR REPORTING PURPOSES ONLY.

License Number: 1620045 DUNKIN DONUTS BASKIN ROBBINS
 License Type: Permanent Food Service 7135 W MC NAB RD, N LAUDERDALE 330685492

Inspection Date: 07/16/2009 Inspection Number: 1854530 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
39-05-2	Ventilation inadequate as evidenced by smoke stains in ceiling by hood system. For reporting purposes only.	NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY

Broward County

License Number: 1618541 CASA D'ANGELO
 License Type: Permanent Food Service 1201 N FEDERAL HWY, FT LAUDERDALE 33304

Inspection Date: 07/16/2009 Inspection Number: 1833986 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: TORRES, LARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. table and chairs obstructing emergency exit in dining room area. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1652476 LIL GIRL BARBEQUE
 License Type: Mobile Food Dispensing Vehicle 1263 NW 31ST AVE, FORT LAUDERDALE 33311

Inspection Date: 07/16/2009 Inspection Number: 1132916 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 1621654 DUNKIN DONUTS
 License Type: Permanent Food Service 7340 W COMMERCIAL BLVD, LAUDERHILL 33319

Inspection Date: 07/14/2009 Inspection Number: 1854502 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
39-05-2	Ventilation inadequate as evidenced by smoke stained ceiling tiles in kitchen area. For reporting purposes only.	NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY

License Number: 1609342 BANQUET KITCHEN
 License Type: Permanent Food Service 1711 N UNIVERSITY DR, PLANTATION 33322

Inspection Date: 07/17/2009 Inspection Number: 1874944 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALECIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1614617		CLUB MIRAGE	
License Type: Permanent Food Service		1711 N UNIVERSITY DR, PLANTATION 33322	
Inspection Date: 07/17/2009	Inspection Number: 1864780	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALECIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 1610222		JADE GARDEN RESTAURANT	
License Type: Permanent Food Service		244 S UNIVERSITY DR, PLANTATION 33324	
Inspection Date: 07/14/2009	Inspection Number: 1854280	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, FERNANDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.rear area	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1617259		BOSTON MARKET #279	
License Type: Permanent Food Service		330 S UNIVERSITY DR, PLANTATION 333243344	
Inspection Date: 07/14/2009	Inspection Number: 1905695	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, FERNANDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.rear door.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1622104		SLICE & MORE PIZZERIA	
License Type: Permanent Food Service		6870 SW 195 AVE, PEMBROKE PINES 33332	
Inspection Date: 07/15/2009	Inspection Number: 1806684	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Violation: 45-36-2 Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
45-41-2	Violation: 45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
49-06-2	Violation: 49-06-2 Observed flammable material stored around water heater. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 1613678		THE PASTRAMI CLUB	
License Type: Permanent Food Service		5240 N UNIVERSITY DR, LAUDERHILL 33351	
Inspection Date: 07/16/2009	Inspection Number: 1915334	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: WILLIAMS, ALECIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY	
License Number: 1619139		SUPER MUNCHIES RASPAOS	
License Type: Permanent Food Service		3800 N UNIVERSITY SUNRISE, SUNRISE 33351	
Inspection Date: 07/10/2009	Inspection Number: 1829890	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALECIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Broward County

License Number: 1613528

HALFTIME BAR @ GRILL

License Type: Permanent Food Service

3996 W HILLSBORO BLVD, DEERFIELD BEACH 33442

Inspection Date: 07/14/2009

Inspection Number: 1895800

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIEHL, TERENCE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. COOK LINE.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1616993

WENDY'S OLD FASHION HAMBURGERS

License Type: Permanent Food Service

1197 S MILITARY TRL, DEERFIELD BEACH 33442

Inspection Date: 07/14/2009

Inspection Number: 1854846

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIEHL, TERENCE

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. REAR KIT DOOR.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 1621719

LENNY'S SUB SHOP #108

License Type: Permanent Food Service

1101 S POWERLINE RD, DEERFIELD BEACH 33442

Inspection Date: 07/10/2009

Inspection Number: 1821223

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: DIEHL, TERENCE

Violation CodeObservationViolation Citation

46-05-2

Violation: 46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. WEST KIT DOOR.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Citrus County

License Number: 1900001 GRAMMY'S SOUL FOOD HEAVEN
 License Type: Permanent Food Service 104 S HWY 41, INVERNESS 34450

Inspection Date: 07/13/2009 Inspection Number: 1887930 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRAIG, JILL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 1901168 HOLLYWOOD PIZZA
 License Type: Permanent Food Service 455 E HIGHLAND BLVD, INVERNESS 34452

Inspection Date: 07/15/2009 Inspection Number: 1898199 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRAIG, JILL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only. Corrected On Site.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

Clay County

License Number: 2000225

SONNYS REAL PIT BAR B Q

License Type: Permanent Food Service

1976 KINGSLEY, ORANGE PARK 320734442

Inspection Date: 07/14/2009

Inspection Number: 1849933

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DOHERTY, BRENDEN

Violation Code

Observation

Violation Citation

45-22-2

Portable fire extinguisher(s) obstructed from view. For reporting purposes only.
NEAR SMOKER IN TEAR OF KITCHEN Corrected On Site.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

Collier County

License Number: 2102654

MESON OLE JR

License Type: Permanent Food Service

770 FIFTH AVE S, NAPLES 34102

Inspection Date: 07/15/2009

Inspection Number: 1862509

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MORRIS, CHARLES

Violation CodeObservationViolation Citation

49-06-2 Observed flammable material stored around water heater. For reporting purposes only.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 2102884

EDGEWATER BEACH HOTEL COAST RESTAURANT

License Type: Permanent Food Service

1901 GULF SHORE BLVD N, NAPLES 34102

Inspection Date: 07/13/2009

Inspection Number: 1872744

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MORRIS, CHARLES

Violation CodeObservationViolation Citation

45 PIPING LOOSE - FIRE SUPPRESSION SYSTEMS - COOKLINE

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 2103040

LA QUINTA INN AND SUITES

License Type: Permanent Food Service

1555 5TH AVENUE SOUTH, NAPLES 34102

Inspection Date: 07/15/2009

Inspection Number: 1841962

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MORRIS, CHARLES

Violation CodeObservationViolation Citation

48-01-2 Boiler certificate not posted in boiler room. For reporting purposes only.

69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

48-12-2 No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Collier County

License Number: 2101909		CALIFORNIA PIZZA KITCHEN	
License Type: Permanent Food Service		5555 N TAMIAMI TRL, NAPLES 34103	
Inspection Date: 07/14/2009	Inspection Number: 1862527	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MORRIS, CHARLES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 2101986		MESON OLE RESTAURANT	
License Type: Permanent Food Service		3126 N TAMIAMI TRAIL, NAPLES 34103	
Inspection Date: 07/14/2009	Inspection Number: 1862475	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: MORRIS, CHARLES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Violation: 46-09-2	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
	Exit signs not properly illuminated. For reporting purposes only. to outside seating area		
46-09-2	Exit signs not properly illuminated. For reporting purposes only. to outside seating area	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 2102283		OHANA RESTAURANT & LOUNGE	
License Type: Permanent Food Service		2624 E TAMIAMI TRL, NAPLES 34112	
Inspection Date: 07/10/2009	Inspection Number: 1883051	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MORRIS, CHARLES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	

Columbia County

License Number: 2200403

ARBY'S #5984

License Type: Permanent Food Service

I 75 & U S 90 W, LAKE CITY 32055

Inspection Date: 07/16/2009

Inspection Number: 1890318

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: FULTON, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. RUNS THROUGH CEILING , ETC.For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. RUNS THROUGH CEILING , ETC.For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Columbia County

License Number: 2200546 PORTERHOUSE GRILL (THE)
 License Type: Permanent Food Service 894 SW MAIN BLVD, LAKE CITY 32055

Inspection Date: 07/15/2009 Inspection Number: 1849569 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: FULTON, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Violation: 46-05-2 Observed obstructed exits, stairs, hallways or egress. EASTSIDE .For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress. EASTSIDE .For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-09-2	Violation: 46-09-2 Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2200635 BROOKLYN BOYS
 License Type: Permanent Food Service 4196 W US HWY 90, LAKE CITY 32055

Inspection Date: 07/16/2009 Inspection Number: 1859536 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: FULTON, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cords in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Columbia County

License Number: 2200643

LITTLE MIAMI CUBAN CAFE

License Type: Permanent Food Service

4196 W US HWY 90 STE 101, LAKE CITY 32055

Inspection Date: 07/16/2009

Inspection Number: 1869959

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: FULTON, DANIEL

Violation Code

Observation

Violation Citation

45-36-2

Hood suppression system tag out-of-date.04/08. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2356545 ORLANDO HOT DOGS
 License Type: Mobile Food Dispensing Vehicle 2517 NW 21 TERR, MIAMI 33002

Inspection Date: 07/13/2009 Inspection Number: 1135775 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NUNEZ, ANDRES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-19-2	Mobile food dispensing vehicle lacking a two-stage regulator on the LP-gas line. For reporting purposes only.	NFPA 58, 3.2.12.1 and 3.8.2.7(b) A two-stage regulator system, an integral two-stage regulator, or a two-psi regulator system shall be required on all fixed piping systems that serve 1/2 -psig appliance systems [normally operated at 11 in. w.c. pressure]. The regulators utilized in these systems shall meet the requirements of 2.5.7. This requirement includes fixed piping systems for appliances on RVs (recreational vehicles), mobile home installations, manufactured home installations, catering vehicles, and food service vehicle installations. Single-stage regulators shall not be installed in fixed piping systems after June 30, 1997. Exception No. 1: This requirement does not include small portable appliances and outdoor cooking appliances with input ratings of 100,000 Btu/hr or less. Exception No. 2: Gas distribution systems utilizing multiple second-stage regulators shall be permitted to use a high-pressure regulator installed at the container provided a first-stage regulator is installed downstream of the high-pressure regulator and ahead of the second-stage regulators. Exception No. 3: High-pressure regulators with an overpressure protection device and a rated capacity of more than 500,000 Btu/hr shall be permitted to be used in two-stage systems where the second-stage regulator incorporates an integral or separate overpressure protection device. This overpressure protection device shall limit the outlet pressure of the second-stage regulator to 2.0 psig when the regulator seat disc is removed and with an inlet pressure equivalent to the maximum outlet pressure setting of the high-pressure regulator Exception No. 4: Systems consisting of listed components that provide an equivalent level of overpressure protection. (b) A two-stage regulator system or an integral two-stage regulator in accordance with 3-2.12.1 shall be installed on all vapor withdrawal systems. Regulators shall be protected from the elements in accordance with 3-2.12.4. FOR REPORTING PURPOSES ONLY.

License Number: 2327768 CAFE TROPICAL
 License Type: Permanent Food Service 12535 W OKEECHOBEE RD, HIALEAH GDNS 330166026

Inspection Date: 07/09/2009 Inspection Number: 1873648 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: SIMANEK, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Out of compliance: Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2321221		REDLANDS SUBS & STUFF	
License Type: Permanent Food Service		24814 SW 177 AVE, HOMESTEAD 330311824	
Inspection Date: 07/13/2009	Inspection Number: 1843521	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROWN, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.back	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

License Number: 2330402		OPALOCKA CAFETERIA	
License Type: Permanent Food Service		14700 NW 22 AVE, MIAMI 33054	
Inspection Date: 07/13/2009	Inspection Number: 1832223	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIERRE, KEVON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 2328622		HOME STYLE REST	
License Type: Permanent Food Service		14905 NW 22 AVE, OPALOCKA 33054	
Inspection Date: 07/10/2009	Inspection Number: 1832221	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PIERRE, KEVON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 2323167		OCEAN DELIGHT'S CAFE	
License Type: Permanent Food Service		782 NW 42 AVE, MIAMI 33126	
Inspection Date: 07/10/2009	Inspection Number: 1874448	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Out of compliance: Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

Dade County

License Number: 2324399 RESTAURANT EL FAMILIAR
 License Type: Permanent Food Service 1003 W FLAGLER ST, MIAMI 33130

Inspection Date: 07/15/2009 Inspection Number: 1884069 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: KHAN, MOHAMMAD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

License Number: 2326760 MCDONALDS
 License Type: Permanent Food Service 299 SW 8 ST, MIAMI 33130

Inspection Date: 07/16/2009 Inspection Number: 1853314 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KHAN, MOHAMMAD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2313308 MASAYITA
 License Type: Permanent Food Service 973 W FLAGLER ST, MIAMI 331301139

Inspection Date: 07/13/2009 Inspection Number: 1894232 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: KHAN, MOHAMMAD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
15-25-2	Violation: 15-25-2 Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
15-25-2	Violation: 15-25-2 Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2315893 WENDY'S INTL #1711-142
 License Type: Permanent Food Service 200 SW 8 ST, MIAMI 331303514

Inspection Date: 07/16/2009 Inspection Number: 1863641 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: KHAN, MOHAMMAD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2328143

L C IN THE GROVE

License Type: Permanent Food Service

2890 SW 27 AVE, MIAMI 33133

Inspection Date: 07/13/2009

Inspection Number: 1864220

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CONYERS,

Violation CodeObservationViolation Citation

46-14-2

Emergency lighting in disrepair Notified Fire AHJ. For reporting purposes only.

NFPA 101, 7.9.1.1 Emergency lighting facilities for means of egress shall be provided in accordance with Section 7.9 for the following: (1) Buildings or structures where required in Chapter 11 through Chapter 42 (2) Underground and limited access structures as addressed in Section 11.7 (3) High-rise buildings as required by other sections of this Code (4) Doors equipped with delayed-egress locks (5) Stair shaft and vestibule of smokeproof enclosures, for which the following also apply: (a) The stair shaft and vestibule shall be permitted to include a standby generator that is installed for the smokeproof enclosure mechanical ventilation equipment. (b) The standby generator shall be permitted to be used for the stair shaft and vestibule emergency lighting power supply. FOR REPORTING PURPOSES ONLY.

License Number: 2301278

LA CARRETA REST

License Type: Permanent Food Service

3632 SW 8 ST, MIAMI 331354112

Inspection Date: 07/13/2009

Inspection Number: 1852954

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, BARBARO

Violation CodeObservationViolation Citation

15-39-2

Hood drip tray not pitched to drain into metal container. For reporting purposes only.

NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2327538

WISH CAFE

License Type: Permanent Food Service

801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 07/15/2009

Inspection Number: 1842290

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RICHARD, DICKSON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 2320234

MI BOHIO RESTAURANT

License Type: Permanent Food Service

7950 SW 8 ST, MIAMI 33144

Inspection Date: 07/16/2009

Inspection Number: 1894328

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: STERLING, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-13-2	Emergency light does not function when tested. For reporting purposes only.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2323284

FRANK'S PIZZA

License Type: Permanent Food Service

8150 SW 8 ST #111, MIAMI 331444264

Inspection Date: 07/16/2009

Inspection Number: 1853436

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STERLING, DANIEL

Violation CodeObservationViolation Citation

47-04-2

Observed taped electrical wires. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2326724

CHANCHAMAYO CORP

License Type: Permanent Food Service

1721 SW 22 ST, MIAMI 33145

Inspection Date: 07/13/2009

Inspection Number: 1915228

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GANDOLFF, JORGE

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

48-13-2

Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.

NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2316876

EL TARMARINDO

License Type: Permanent Food Service

10117 NW 27 AVE, MIAMI 331471758

Inspection Date: 07/10/2009

Inspection Number: 1904613

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DE LOS SANTOS, JUAN

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2319253 MARINA'S BAR RESTAURANT
 License Type: Permanent Food Service 1186 NW 103 ST, MIAMI 33150

Inspection Date: 07/16/2009 Inspection Number: 1873156 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2320723 MAMA LIZ DUNN A YARD RESTAURANT
 License Type: Permanent Food Service 122 NW 79 ST, MIAMI 33150

Inspection Date: 07/15/2009 Inspection Number: 1873152 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2327533 CAFETERIA 79 STREET
 License Type: Permanent Food Service 47 NW 79 STREET, MIAMI 33150

Inspection Date: 07/15/2009 Inspection Number: 1893616 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49	Hood system tag expired. Class K extinguisher Not tagged	NFPA 101, 96, 10 Flammable/combustible materials - properly stored

Dade County

License Number: 2331318 CEIBA CAFE
 License Type: Permanent Food Service 280 NW 79TH STREET, MIAMI 33150
 Inspection Date: 07/15/2009 Inspection Number: 1842392 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Using extention cord in kitchen	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 2332007 WINGSTOP
 License Type: Permanent Food Service 651 NW 62 STREET, MIAMI 33150
 Inspection Date: 07/16/2009 Inspection Number: 1852638 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 2322592 CREATIVE KITCHEN
 License Type: Permanent Food Service 650 NW 71 ST, MIAMI 331503815
 Inspection Date: 07/13/2009 Inspection Number: 1883431 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2317901

BETTY'S BEST BURGERS

License Type: Permanent Food Service

7800 SW 104 ST, MIAMI 331562631

Inspection Date: 07/15/2009

Inspection Number: 1894502

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

45-36-2 Hood suppression system tag out-of-date. For reporting purposes only.

NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2326037

DI NAPOLI RESTAURANT

License Type: Permanent Food Service

11755 DIXIE HWY, MIAMI 331564438

Inspection Date: 07/15/2009

Inspection Number: 1853628

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2319316

MUFFIN TIN THE

License Type: Permanent Food Service

12655 S DIXIE HWY, MIAMI 331565931

Inspection Date: 07/15/2009

Inspection Number: 1884333

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

15-25-2 Hood filters not equipped with a drip tray. For reporting purposes only.

NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2322257 ANACAPRI ITALIAN REST
 License Type: Permanent Food Service 12669 S DIXIE HWY, MIAMI 331565931

Inspection Date: 07/15/2009 Inspection Number: 1884337 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2312404 STEVE'S PIZZA
 License Type: Permanent Food Service 18063 SOUTH DIXIE HWY, MIAMI 33157

Inspection Date: 07/10/2009 Inspection Number: 1874108 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Out of compliance: Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2330320 LOUIS SNACK DEPOT CAFE
 License Type: Permanent Food Service 19400 SW 106 AVE, MIAMI 33157

Inspection Date: 07/13/2009 Inspection Number: 1884349 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2330365 SUBSTANTIAL SUBS
 License Type: Permanent Food Service 19100 SW 106 AVE #1, MIAMI 33157

Inspection Date: 07/13/2009 Inspection Number: 1863946 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2325744 DEERING BAY
 License Type: Permanent Food Service 13610 DEERING BAY DR, CORAL GABLES 33158

Inspection Date: 07/16/2009 Inspection Number: 1894520 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. Corrected On Site.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 2325707 LATINO GRILL
 License Type: Permanent Food Service 8827 SW 40 ST, MIAMI 33165

Inspection Date: 07/16/2009 Inspection Number: 1915319 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANDOLFF, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Class K	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2328523 BRISA DE ESPANA
 License Type: Permanent Food Service 8770 CORAL WAY, MIAMI 33165

Inspection Date: 07/16/2009 Inspection Number: 1874034 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANDOLFF, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2330329

BIJON RESTAURANT

License Type: Permanent Food Service

827 NW 119TH, MIAMI 33168

Inspection Date: 07/13/2009

Inspection Number: 1883543

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PIERRE, KEVON

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2330703

CALI CAFE

License Type: Permanent Food Service

2600 NW 87 AVENUE #17, MIAMI 33172

Inspection Date: 07/13/2009

Inspection Number: 1843194

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STERLING, DANIEL

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2318666 LACARRETA RESTAURANT
 License Type: Permanent Food Service 10633 NW 12 ST, MIAMI 331722730

Inspection Date: 07/15/2009 Inspection Number: 1843174 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STERLING, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. ONLY THE CITY OF DORAL: ISSUED ON 06/04/2009. REGISTRATION NUMBER: BR0772.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only. EXPIRED: 04/2009. STATE OF FLORIDA.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2315369		LUCHO'S RESTAURANT	
License Type: Permanent Food Service		5628 SW 102 AVENUE, MIAMI 33173	
Inspection Date: 07/13/2009	Inspection Number: 1864000	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: VALDERRAMA, ELISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-40-2	Violation: 45-40-2 Portable fire extinguisher with no approved inspection tag. For reporting purposes only.class k	61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.	
45-41-2	Violation: 45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.all tags marked 1/08	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 2323355		JASMINE SUSHI THAI RESTAURANT	
License Type: Permanent Food Service		1429 SW 107 AVE, MIAMI 33174	
Inspection Date: 07/15/2009	Inspection Number: 1884665	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only. OBSERVED EXTINGUISHERS NOZZLES WITH OIL SLUDGE	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
39-03-2	Exhaust system off during the operation of cooking equipment. For reporting purposes only. EXHAUST SYSTEM/HOOD NOT WORKING	NFPA 96, 11.1.1 Exhaust systems shall be operated whenever cooking equipment is turned on. For reporting purposes only.	
License Number: 2324444		CARY'S CAFFE	
License Type: Permanent Food Service		11865 SW 26 ST J-10, MIAMI 33175	
Inspection Date: 07/16/2009	Inspection Number: 1843246	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: MORGADANES, DOUGLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2330338		MC DONALDS	
License Type: Permanent Food Service		12185 SW 26 STREET, MIAMI 33175	
Inspection Date: 07/13/2009	Inspection Number: 1843208	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MORGADANES, DOUGLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-02-2	Observed gas-powered equipment containing gas stored inside the establishment. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	

Dade County

License Number: 2320187 EL CANTONES REST
 License Type: Permanent Food Service 11865 SW 26 ST E3, MIAMI 331752400

Inspection Date: 07/13/2009 Inspection Number: 1843224 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MORGADANES, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2326102 LA TIA FINA
 License Type: Permanent Food Service 2756 SW 137 AVE, MIAMI 331756638

Inspection Date: 07/16/2009 Inspection Number: 1894398 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MORGADANES, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2317352 RUBEN'S CUBAN RESTAURANT
 License Type: Permanent Food Service 8281 SW 124 ST, MIAMI 33177

Inspection Date: 07/16/2009 Inspection Number: 1863914 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2330139		CHICKEN KITCHEN	
License Type: Permanent Food Service		13507 BISCAYNE BLVD, MIAMI 33181	
Inspection Date: 07/15/2009	Inspection Number: 1893678	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIERRE, KEVON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 2331873		LUCCA PIZZA & FINE ITALIAN FOOD	
License Type: Permanent Food Service		13531 BISCAYNE BLVD, MIAMI 33181	
Inspection Date: 07/15/2009	Inspection Number: 1829865	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIERRE, KEVON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 2323202		CUTLER BAY SPORTS BAR	
License Type: Permanent Food Service		20305 OLD CUTLER RD, MIAMI 33189	
Inspection Date: 07/16/2009	Inspection Number: 1713213	Inspection Type: Routine - Food	Inspection Disposition: Admin. Complaint Callback Complied
Inspector Name: BROWN, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-1	Out of compliance: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.	NFPA 96, 6.2.3.3:: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.	

License Number: 2331889		SUBWAY #40690	
License Type: Permanent Food Service		14608 SW 8 ST, MIAMI 33194	
Inspection Date: 07/16/2009	Inspection Number: 1894356	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STERLING, DANIEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only. TAG: 04/2008.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

Dixie County

License Number: 2500148

ELAINE'S

License Type: Permanent Food Service

660 NW HWY 19, CROSS CITY 32628

Inspection Date: 07/16/2009

Inspection Number: 1719263

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: BROWNING, JULIANNE

Violation Code

Observation

Violation Citation

48-06-2

Violation: 48-06-2

Observed a gas appliance without proper venting.oven For reporting purposes only.

61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2600252		COTTEN'S BAR B QUE	
License Type: Permanent Food Service		2623 MAIN ST, JACKSONVILLE 322062945	
Inspection Date: 07/13/2009	Inspection Number: 1839922	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, DERRICK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. Behind coffee pot	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2600351		CHECKERS BAR B QUE & SEAFOOD	
License Type: Permanent Food Service		3566 ST AUGUSTINE RD, JACKSONVILLE 32207	
Inspection Date: 07/16/2009	Inspection Number: 1911517	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. 2 in storage room Repeat Violation.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 2612381		SOUTHERN GRILL OF JAX (THE)	
License Type: Permanent Food Service		800 FLAGLER AVE, JACKSONVILLE 32207	
Inspection Date: 07/17/2009	Inspection Number: 1709505	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. ABC on floor at bar	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only. Repeat Violation.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	

Duval County

License Number: 2612095

GOLDEN EGGROLL

License Type: Permanent Food Service

7412 LEM TURNER RD, JACKSONVILLE 32208

Inspection Date: 07/15/2009

Inspection Number: 1881254

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVIS, MOSES

Violation CodeObservationViolation Citation

45-33-2

Current hood suppression system report lists violations. Notified Fire AHJ. For reporting purposes only,
NO DRIP PAN FOR GREASE REAR HOOD###%TGFT

NFPA 96, 4.1.2, 4.1.3, 4.1.4 and 4.1.5 All such equipment and its performance shall be maintained in accordance with the requirements of this standard during all periods of operation of the cooking equipment. The following equipment shall be kept in good working condition: (1) Cooking equipment (2) Hoods (3) Ducts (if applicable) (4) Fans (5) Fire-extinguishing systems (6) Special effluent or energy control equipment All airflows shall be maintained. Maintenance and repairs shall be performed on all components at intervals necessary to maintain these conditions. FOR REPORTING PURPOSES ONLY.

License Number: 2609909

REWIS RESTAURANT & CATERING

License Type: Permanent Food Service

7633 N MAIN ST, JACKSONVILLE 322084127

Inspection Date: 07/15/2009

Inspection Number: 1901744

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: DAVIS, MOSES

Violation CodeObservationViolation Citation

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only,
REAR STORAGE ROOM.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only,
REAR STORAGE ROOM.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2614064 J J'S CRAB HOUSE
 License Type: Permanent Food Service 1963 KINGS RD UNIT 3, JACKSONVILLE 32209

Inspection Date: 07/09/2009 Inspection Number: 1914791 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only, LOBBY / BUG ZAPPER.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-15-2	Violation: 47-15-2 Observed an uncovered electrical box. For reporting purposes only, OVER SHELF IN KITCHEN .	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
47-15-2	Violation: 47-15-2 Observed an uncovered electrical box. For reporting purposes only, NEAR DISPLAY CASE.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2614160 SIDESTREET BAR & GRILL
 License Type: Permanent Food Service 2035 ROGERO RD, JACKSONVILLE 32211

Inspection Date: 07/09/2009 Inspection Number: 1860466 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: YOUNG, DERRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Backroom Repeat Violation.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2612360 TINSELTOWN USA
 License Type: Permanent Food Service 4535 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 07/13/2009 Inspection Number: 1850701 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STOREY, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2614062 LOS PORTALES MEXICAN GRILL
 License Type: Permanent Food Service 4100 BELFORT RD STE 4, JACKSONVILLE 32216

Inspection Date: 07/17/2009 Inspection Number: 1880802 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. by water heater	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2600154 PIZZA HUT #622010
 License Type: Permanent Food Service 4311 S UNIVERSITY BLVD, JACKSONVILLE 322164909

Inspection Date: 07/13/2009 Inspection Number: 1914165 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only. Repeat Violation.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY

License Number: 2607845 WOODY'S BAR B-Q
 License Type: Permanent Food Service 1638 S UNIVERSITY BLVD, JACKSONVILLE 322168927

Inspection Date: 07/13/2009 Inspection Number: 1880830 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only. small panel box	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. white one by fryer Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2608586 DENNYS RESTAURANT #8006
 License Type: Permanent Food Service 14697 DUVAL RD, JACKSONVILLE 32218

Inspection Date: 07/11/2009 Inspection Number: 1850615 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-08-2	Exit signs not visible from any direction. For reporting purposes only, IN EGESS. Repeat Violation. Corrected On Site.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment. For reporting purposes only., STORAGE ROOM. Corrected On Site.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2609085		JAX MARKET PLACE - MAIN RESTAURANT	
License Type: Permanent Food Service		614 PECAN PARK RD, JACKSONVILLE 32218	
Inspection Date: 07/11/2009	Inspection Number: 1850601	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only, REAR.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
Inspection Date: 07/12/2009		Inspection Number: 1850601	
Inspector Name: DAVIS, MOSES		Inspection Type: Routine - Food	
		Inspection Disposition: Call Back - Complied	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Violation: 46-09-2 Exit signs not properly illuminated. For reporting purposes only, REAR.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 2609087		JAX MARKET PLACE TAKE OUT #2	
License Type: Permanent Food Service		614 PECAN PARK RD, JACKSONVILLE 32218	
Inspection Date: 07/11/2009	Inspection Number: 1850603	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K-SERIES FIRE EXTINGUISHER ON THE FLOOR NEAR LARGE ICE MACHINE	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 2609106		BEST WESTERN JACKSONVILLE AIRPORT	
License Type: Permanent Food Service		1170 AIRPORT RD, JACKSONVILLE 32218	
Inspection Date: 07/12/2009	Inspection Number: 1870927	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2613154		NEW DRAGON	
License Type: Permanent Food Service		11565 N MAIN ST #230, JACKSONVILLE 32218	
Inspection Date: 07/14/2009	Inspection Number: 1891390	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only, FRONT.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

Duval County

License Number: 2613171

MAI OUI GOURMET

License Type: Catering

3611 ST JOHNS BLUFF RD S, UNIT #103, JACKSONVILLE 32224

Inspection Date: 07/14/2009

Inspection Number: 1092675

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STOREY, MARIE

Violation CodeObservationViolation Citation

45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
new stove installed

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2612641

BUFFALOS SOUTHWEST CAFE

License Type: Permanent Food Service

6055 YOUNGERMAN CIR, JACKSONVILLE 32244

Inspection Date: 07/14/2009

Inspection Number: 1911859

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2613629

APPLEBEES #4309

License Type: Permanent Food Service

8635 BLANDING BLVD, JACKSONVILLE 32244

Inspection Date: 07/14/2009

Inspection Number: 1840014

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.
Repeat Violation.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 2610905

LA FRONTERA RC1

License Type: Permanent Food Service

11041 BEACH BLVD, JACKSONVILLE 32246

Inspection Date: 05/23/2009

Inspection Number: 1915431

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: STOREY, MARIE

Violation CodeObservationViolation Citation

45

Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Inspection Date: 07/14/2009

Inspection Number: 1915222

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STOREY, MARIE

Violation CodeObservationViolation Citation

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2611625

LYNCH'S IRISH PUB

License Type: Permanent Food Service

514 N 1ST ST, JACKSONVILLE 32250

Inspection Date: 07/16/2009

Inspection Number: 1860536

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CARANGIAN, REYNALDO

Violation CodeObservationViolation Citation

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only./
blocked with bread rack/ kitchen. Repeat Violation.NFPA 70, 110.32 Work Space about Equipment.
Sufficient space shall be provided and maintained about
electrical equipment to permit ready and safe operation
and maintenance of such equipment. In all cases, the
work space shall be adequate to permit at least a
90-degree opening of doors or hinged panels. FOR
REPORTING PURPOSES ONLY.

License Number: 2608576

FRONT PAGE GRILL & BAR

License Type: Permanent Food Service

9150 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 07/09/2009

Inspection Number: 1839592

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TUCKER, CATHY

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
Hasp lock on walkin coolerNFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of
egress shall be continuously maintained free of all
obstructions or impediments to full instant use in the
case of fire or other emergency. Means of access must
permit unobstructed travel at all times and be
maintained free of obstructions and fire hazards. Halls,
entrances and stairways shall be clean, ventilated and
well-lighted day and night. Hall and stair runners shall
be kept in good condition. Hand rails shall be installed
on all stairways and guard rails around all porches and
steps. Adequate means of exit shall be provided
pursuant to NFPA 101. FOR REPORTING
PURPOSES ONLY.

Escambia County

License Number: 2705159

JORDAN VALLEY CAFE

License Type: Permanent Food Service

128 S PALAFOX ST, PENSACOLA 32501

Inspection Date: 07/16/2009

Inspection Number: 1851401

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

45-39-2

Portable k class fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2701564

LANDRY'S SEAFOOD HOUSE

License Type: Permanent Food Service

905 E GREGORY ST, PENSACOLA 325014330

Inspection Date: 07/16/2009

Inspection Number: 1912835

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

45-39-2

Portable ABC fire extinguisher in dry storage area not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2705136

NORMA'S ON THE RUN

License Type: Permanent Food Service

28 N PALAFOX ST, PENSACOLA 32501-5626

Inspection Date: 07/16/2009

Inspection Number: 1892328

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

45-39-2

Portable ABC fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Escambia County

License Number: 2705070 HALL'S SEAFOOD & CATFISH
 License Type: Permanent Food Service 920 E GREGORY STREET, PENSACOLA 32502

Inspection Date: 07/10/2009 Inspection Number: 1851361 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RILEY, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable ABC fire extinguisher at front door not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exit at side of dining room. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2705808 SUBWAY
 License Type: Permanent Food Service 8102 N DAVIS HWY, PENSACOLA 32571

Inspection Date: 07/14/2009 Inspection Number: 1902002 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CROWLEY, RUSSELL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Flagler County

License Number: 2800594

BOB EVANS RESTAURANT #483

License Type: Permanent Food Service

100 GARDEN ST SOUTH, PALM COAST 32137

Inspection Date: 07/09/2009

Inspection Number: 1870009

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCARPELLI, DAVID

Violation Code

Observation

Violation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Franklin County

License Number: 2901241

CROOKED RIVER GRILL

License Type: Permanent Food Service

151 LAUGHING GULL LANE, CARRABELLE 32322

Inspection Date: 07/14/2009

Inspection Number: 1902510

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRAGER, JOAN

Violation Code

Observation

Violation Citation

45-22-2

Portable fire extinguisher gauge obstructed from view by ball cap, dining area. For reporting purposes only.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

Hamilton County

License Number: 3400137

HUDDLE HOUSE RESTAURANT #387

License Type: Permanent Food Service

8191 SR 6 W, JASPER 32052

Inspection Date: 07/15/2009

Inspection Number: 1890676

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.trash in front of rear exit door Repeat Violation.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Hernando County

License Number: 3701087

BREAKFAST & LUNCH NOOK

License Type: Permanent Food Service

1376 PINEHURST DR, SPRING HILL 34606-4500

Inspection Date: 07/17/2009

Inspection Number: 1846977

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3700757

DEE'S PLACE

License Type: Permanent Food Service

10482 NORTHCLIFFE BLVD, SPRING HILL 34608

Inspection Date: 07/17/2009

Inspection Number: 1877836

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3700943

CHINA ONE SUPER BUFFET

License Type: Permanent Food Service

4241 MARINER BLVD, SPRING HILL 34609

Inspection Date: 07/13/2009

Inspection Number: 1847007

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hernando County

License Number: 3700973

CHINA KITCHEN

License Type: Permanent Food Service

11198 SPRING HILL DR, SPRING HILL 34609

Inspection Date: 07/17/2009

Inspection Number: 1877872

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Fan suction pulling one hood filter into hood.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912545

CICI'S PIZZA #373

License Type: Permanent Food Service

1991 W LUMSDEN RD, BRANDON 33511

Inspection Date: 07/14/2009

Inspection Number: 1836025

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. near cash register

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 3916588

COLUMBIA CAFE AT THE TAMPA BAY HISTORY CENTER

License Type: Permanent Food Service

801 OLD WATER ST, TAMPA 33602

Inspection Date: 07/14/2009

Inspection Number: 1836837

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. electric panel room

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 3903795

WENDY'S

License Type: Permanent Food Service

8330 N FLORIDA AVE, TAMPA 33604

Inspection Date: 07/17/2009

Inspection Number: 1836891

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

15-40-2

No metal container installed for catching grease from hood drip tray. For reporting purposes only. back hoods

NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only. peeling painted surface

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Hillsborough County

License Number: 3911352

FRONT PORCH GRILL (THE)

License Type: Permanent Food Service

5924 N FLORIDA AVE, TAMPA 33604

Inspection Date: 07/15/2009

Inspection Number: 1857504

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912162

DAVANIS CAFE

License Type: Permanent Food Service

802 E WATERS, TAMPA 33604

Inspection Date: 07/14/2009

Inspection Number: 1847207

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

15-42-2

Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.

NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY

Hillsborough County

License Number: 3912874 TC BBQ INC
 License Type: Permanent Food Service 1420 W WATERS AVE STE# 106, TAMPA 33604

Inspection Date: 07/15/2009 Inspection Number: 1857490 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3910226 MS ROSE DINER
 License Type: Permanent Food Service 2916 34 ST, TAMPA 33605

Inspection Date: 07/17/2009 Inspection Number: 1915402 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
39-03-2	Exhaust system off during the operation of cooking equipment. For reporting purposes only. Corrected On Site.	NFPA 96, 11.1.1 Exhaust systems shall be operated whenever cooking equipment is turned on. For reporting purposes only.
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.table top fryer in use not under hood suppression	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
45-37-2	Portable fire extinguisher missing from designated location. For reporting purposes only. no k class, abc extinguishers on site	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912446		COACH RIK CAFE	
License Type: Permanent Food Service		1717 N ALBANY AVE, TAMPA 33607	
Inspection Date: 07/15/2009	Inspection Number: 1907588	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 3912534		PERKINS REST & BAKERY #1246	
License Type: Permanent Food Service		612 S DALE MABRY, TAMPA 33609	
Inspection Date: 07/14/2009	Inspection Number: 1866890	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49	Out of compliance: Flammable/combustible materials - properly stored	NFPA 101, 96, 10 Flammable/combustible materials - properly stored	
License Number: 3915582		ESTELLA'S MEXICAN RESTAURANT	
License Type: Permanent Food Service		4015 S DALE MABRY HWY, TAMPA 33611	
Inspection Date: 07/13/2009	Inspection Number: 1856616	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 3900387		GREEN IGUANA BAR AND GRILL	
License Type: Permanent Food Service		4029 S WESTSHORE BLVD, TAMPA 336111005	
Inspection Date: 07/13/2009	Inspection Number: 1877232	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Hillsborough County

License Number: 3912449

CALIFORNIA TACOS INC

License Type: Permanent Food Service

1450 SKIPPER RD, TAMPA 33613

Inspection Date: 07/16/2009

Inspection Number: 1877888

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-36-2 Hood suppression system tag out-of-date. For reporting purposes only.(10/08)

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.(at entrance)

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912595

LOUIS PAPPAS MARKET CAFE

License Type: Permanent Food Service

14913 BRUCE B DOWNS BLVD, TAMPA 336132860

Inspection Date: 07/14/2009

Inspection Number: 1867622

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.(kitchen)

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3906942 TACO BELL #3663
 License Type: Permanent Food Service 2031 E BEARRS AVE, TAMPA 336135566

Inspection Date: 07/16/2009 Inspection Number: 1877910 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHEW, TEOW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only. Repeat Violation.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 3903747 JUMBO BUFFET
 License Type: Permanent Food Service 8503 W HILLSBOROUGH AVE, TAMPA 33615

Inspection Date: 07/16/2009 Inspection Number: 1830259 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 3912448 SABOR LATINO
 License Type: Permanent Food Service 4810 E BUSCH BLVD #M, TAMPA 33617

Inspection Date: 07/13/2009 Inspection Number: 1877012 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: EDMISTON, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3910771 VALLARTAS MEXICAN RESTAURANT
 License Type: Permanent Food Service 13731 N DALE MABRY, TAMPA 336182417

Inspection Date: 07/17/2009 Inspection Number: 1831977 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-05-2	Observed unprotected gas meter subject to vehicle damage. For reporting purposes only.	NFPA 54, 2.7.2(b) (b) Gas meters shall not be placed where they will be subjected to damage, such as adjacent to a driveway, under a fire escape, in public passages, halls, coal bins, or where they will be subjected to excessive corrosion or vibration. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3904967

SONNYS SANDWICH SHOP

License Type: Permanent Food Service

7315 E BROADWAY AVE, TAMPA 33619

Inspection Date: 07/13/2009

Inspection Number: 1877578

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912912

BEST WESTERN HOTEL & CONF CTR

License Type: Permanent Food Service

9331 ADAMO DR, TAMPA 33619

Inspection Date: 07/15/2009

Inspection Number: 1898041

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

48-12-2 No current boiler certification provided/available. For reporting purposes only.expired 3;09

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3913052

BUDGET CATERING COMPANY

License Type: Catering

9331 E ADAMO DR, TAMPA 33619

Inspection Date: 07/15/2009

Inspection Number: 1092627

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OGDEN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.expired 3/09	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3916333 AMERICAN PIE PIZZA CO
 License Type: Permanent Food Service 9331 ADAMO DRIVE, TAMPA 33619

Inspection Date: 07/15/2009 Inspection Number: 1915071 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: OGDEN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.expired 3/09	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 3916574 GREEN BERRY YOGURT
 License Type: Permanent Food Service 10047 E ADAMO DR, TAMPA 33619

Inspection Date: 07/16/2009 Inspection Number: 1877610 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: OGDEN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912071		WENDY'S	
License Type: Permanent Food Service		13565 CYPRESS GLENN LANE, TAMPA 33637	
Inspection Date: 07/15/2009	Inspection Number: 1847061	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.(11/08)	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 3912328		HILTON GARDEN INN TAMPA NORTH	
License Type: Permanent Food Service		13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637	
Inspection Date: 07/15/2009	Inspection Number: 1857416	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-44-2	Observed dust/grease fire sprinkler head in kitchen. For reporting purposes only.	NFPA 25, 5.2.1.1.1 and 5.4.1.8 Sprinklers shall not show signs of leakage; shall be free of corrosion, foreign materials, paint, and physical damage; and shall be installed in the proper orientation (e.g., upright, pendent, or sidewall). Sprinklers shall not be altered in any respect or have any type of ornamentation, paint, or coatings applied after shipment from the place of manufacture. FOR REPORTING PURPOSES ONLY.	
License Number: 3912750		SUBWAY #14226	
License Type: Permanent Food Service		16047 TAMPA PALMS BLVD, TAMPA 33647	
Inspection Date: 07/15/2009	Inspection Number: 1877896	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.(5/08)	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 3913058		COLDSTONE CREAMERY	
License Type: Permanent Food Service		17519 PRESERVE WALK LN, TAMPA 33647	
Inspection Date: 07/14/2009	Inspection Number: 1847055	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.(9/07)	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3915683

CARUSO'S PIZZA

License Type: Permanent Food Service

10942 CROSS CREEK BLVD, TAMPA 33647

Inspection Date: 07/13/2009

Inspection Number: 1877882

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.(hallway)

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3915888

WESTSHORE PIZZA #53

License Type: Permanent Food Service

18045 HIGHWOODS PRESERVE PKWY, TAMPA 33647

Inspection Date: 07/13/2009

Inspection Number: 1836765

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.(9/08)

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 3915978

SUBWAY-WALMART

License Type: Permanent Food Service

19910 BRUCE B DOWNS, TAMPA 33647

Inspection Date: 07/13/2009

Inspection Number: 1898423

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Holmes County

License Number: 4000136

TOWNHOUSE RESTAURANT

License Type: Permanent Food Service

121 N WAUKESHA ST, BONIFAY 32425

Inspection Date: 07/16/2009

Inspection Number: 1902268

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: HARDING, LINDA

Violation Code

Observation

Violation Citation

49-06-2

Observed screen tent of flammable material used for smokehouse.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

Indian River County

License Number: 4101252

RUBY TUESDAY #7121

License Type: Permanent Food Service

13675 US HWY 1, SEBASTIAN 32958

Inspection Date: 07/15/2009

Inspection Number: 1915281

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

45-12-2

Observed trouble/alarm light lighted on fire alarm control panel./manager fixed with special code For reporting purposes only.

NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.

License Number: 4101171

HUA XING CHINESE FOOD

License Type: Permanent Food Service

2050 58 AVE, VERO BCH 32966

Inspection Date: 07/17/2009

Inspection Number: 1915346

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces./1 missing For reporting purposes only. Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

39-05-2

Ventilation inadequate as evidenced by smoke in kitchen area. For reporting purposes only.

NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY

47-05-2

Observed a splitter/multi-plug adapter in use.by register For reporting purposes only. Repeat Violation.x3

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period./by reach in freezer For reporting purposes only. Repeat Violation.x3

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Indian River County

License Number: 4101121

OASIS REST. AND LOUNGE MOTEL

License Type: Permanent Food Service

6285 85TH. ST., WABASSO 32970

Inspection Date: 07/14/2009

Inspection Number: 1868080

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Jackson County

License Number: 4200478

MALONE CITY CAFE

License Type: Permanent Food Service

5397 10 ST, MALONE 32445

Inspection Date: 07/14/2009

Inspection Number: 1851111

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: HARDING, LINDA

Violation CodeObservationViolation Citation

45-41-2

Portable fire extinguisher tags out-of-date. Observed 2 extinguishers. One had a date of 7-02 and 2-07 on the other. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification.
FOR REPORTING PURPOSES ONLY.

License Number: 4200358

KFC L747004

License Type: Permanent Food Service

4337 LAFAYETTE ST, MARIANNA 32446

Inspection Date: 07/10/2009

Inspection Number: 1914901

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARDING, LINDA

Violation CodeObservationViolation Citation

46-09-2

Exit sign on northeast exit not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Lake County

License Number: 4508187

EL KORITA MEXICAN RESTAURANT, INC.

License Type: Permanent Food Service

256 W. ARDICE AVE., EUSTIS 32726

Inspection Date: 07/14/2009

Inspection Number: 1869389

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, ROBERT KEVIN

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 4508172

LYN OLENSKI ICE CREAM AND SANDWICHES

License Type: Permanent Food Service

824 W. MONTROSE, CLERMONT 34711

Inspection Date: 07/14/2009

Inspection Number: 1900549

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHIU, ALEX

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Lake County

License Number: 4508194 PASTA VINO
 License Type: Permanent Food Service 550 WEST AVE, CLERMONT 34711

Inspection Date: 07/16/2009 Inspection Number: 1915262 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: CHIU, ALEX

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Violation: 45-31-2 Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. [Observed 3 small fryers are used in kitchen at this establishment.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. [Observed 3 small fryers are used in kitchen at this establishment. There are heavy grea	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. [Observed a fire extinguisher stored inside the kitchen handsink cabinet]	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
45-39-2	Violation: 45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. [Observed a fire extinguisher stored inside the kitchen handsink cabinet]	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 4508274 PLANET SMOOTHIE
 License Type: Permanent Food Service 1109 CITRUS TOWER BLVD, CLERMONT 34711

Inspection Date: 07/14/2009 Inspection Number: 1849409 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHIU, ALEX

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-37-2	Portable fire extinguisher missing from designated location. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 4508337 #1 BUFFET
 License Type: Permanent Food Service 1704 CITRUS BLVD, LEESBURG 34748

Inspection Date: 12/02/2008 Inspection Number: 1915291 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MARTIN, ROBERT KEVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-1	Out of compliance: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.	NFPA 96, 6.2.3.3:: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.

Lake County

License Number: 4500320

PIZZA HUT #622058

License Type: Permanent Food Service

1007 N 14 ST, LEESBURG 347483818

Inspection Date: 07/13/2009

Inspection Number: 1838553

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, ROBERT KEVIN

Violation Code

Observation

Violation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
door blocked by oven

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Lee County

License Number: 4603833 CHINESE KITCHEN
 License Type: Permanent Food Service 4901 PALM BEACH BLVD #4 & 5, FORT MYERS 33905
 Inspection Date: 07/15/2009 Inspection Number: 1903749 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BAMBREY, SHAWN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 4603948 WAFFLE HOUSE #870
 License Type: Permanent Food Service 4050 BOATWAY RD, FORT MYERS 33905
 Inspection Date: 07/15/2009 Inspection Number: 1883059 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAMBREY, SHAWN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-13-2	Emergency light does not function when tested. For reporting purposes only. broken warewash area	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

License Number: 4650457 JUANITAS MEXICAN FOOD
 License Type: Mobile Food Dispensing Vehicle 4644 PALM BCH BLVD, FORT MYERS 33905
 Inspection Date: 07/13/2009 Inspection Number: 1138251 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BAMBREY, SHAWN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-29-2	Class K portable fire extinguisher not within 30 feet of high hazard cooking area. For reporting purposes only.	NFPA 10, 5.7.2 Maximum travel distance shall not exceed 30 ft from the hazard to the extinguishers. FOR REPORTING PURPOSES ONLY.
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 4605276 3 FISHERMEN SEAFOOD
 License Type: Permanent Food Service 5100 S CLEVELAND AVE #313, FORT MYERS 33907
 Inspection Date: 07/17/2009 Inspection Number: 1872645 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-06-2	Observed a gas appliance without proper venting. For reporting purposes only.	61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

Lee County

License Number: 4605338

JASON'S DELI

License Type: Permanent Food Service

13550 REFLECTION PWY#1-101, FORT MYERS 33907

Inspection Date: 07/13/2009

Inspection Number: 1852138

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

45-03-2

Observed clearance between sprinkler head and top of storage less than 18 inches--walk-in cooler. For reporting purposes only.

NFPA 13, 5.5.6 The clearance between the deflector and the top of storage shall be 18 inches or greater. FOR REPORTING PURPOSES ONLY.

46-05-2

Observed obstructed exits, stairs, hallways or egress--back kitchen exit blocked by trash containers For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 4606076

POP'S KITCHEN & BBQ

License Type: Permanent Food Service

303 NE 3 AVE #14, CAPE CORAL 33909

Inspection Date: 07/15/2009

Inspection Number: 1829820

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Lee County

License Number: 4650140

PIE'S MOVING MEALS MOBILE

License Type: Mobile Food Dispensing Vehicle

3700 DR MARTIN LUTHER KING BLVD, CAPE CORAL 33914

Inspection Date: 07/15/2009

Inspection Number: 1138156

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORBERT, KIMBERLY

Violation CodeObservationViolation Citation

48-20-2

Observed loose/unsecured LP-gas tank on mobile food dispensing vehicle. For reporting purposes only.

NFPA 58, 3.8.2.4 Containers shall be mounted securely on the vehicle, or within the enclosing recess or cabinet, and shall be located and installed so as to minimize the possibility of damage to containers, their appurtenances, or contents as follows: (a) Containers shall be installed with road clearance in accordance with 8-2.6.5. (b) Fuel containers shall be mounted securely to prevent jarring loose and slipping or rotating, and the fastenings shall be designed and constructed to withstand, without permanent visible deformation, static loading in any direction equal to four times the weight of the container filled with fuel. Where containers are mounted within a vehicle housing, the securing of the housing to the vehicle shall comply with this provision. Any hoods, domes, or removable portions of the housing or cabinet shall be provided with means to keep them firmly in place in transit. Field welding shall comply with 3-2.4.1(e). (c) All container valves, appurtenances, and connections shall be adequately protected to prevent damage from accidental contacts with stationary objects, from loose objects, stones, mud, or ice thrown up from the ground or floor, and from damage due to overturn or similar vehicular accident. In the case of permanently mounted ASME containers, this provision shall be met by the location on the vehicle, with parts of the vehicle furnishing the protection. On cylinders, the protection for cylinder valves and connections shall be attached permanently to the cylinder (see 2-2.4.1 and 2-2.4.2). Such weather protection necessary to ensure safe operation shall be provided for cylinders and systems mounted on the outside of vehicles. FOR REPORTING PURPOSES ONLY.

License Number: 4604259

FIRST ROUND DRAFT SPORTS BAR & GRILLE

License Type: Permanent Food Service

1217 DEL PRADO BLVD, CAPE CORAL 33990

Inspection Date: 07/15/2009

Inspection Number: 1841702

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 4606049

DIAMOND BILLARDS

License Type: Permanent Food Service

1242 SW PINE ISLAND RD UNIT 4, CAPE CORAL 33991

Inspection Date: 07/13/2009

Inspection Number: 1892954

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Leon County

License Number: 4702920

LA HACIENDA

License Type: Permanent Food Service

2207 BANNERMAN RD, TALLAHASSEE 32312

Inspection Date: 07/16/2009

Inspection Number: 1840859

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DODSON, FRED

Violation Code

Observation

Violation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.kitchen

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Levy County

License Number: 4800418

SUBWAY SANDWICHES & SALAD

License Type: Permanent Food Service

2202 N YOUNG BLVD #405, CHIEFLAND 326261956

Inspection Date: 07/14/2009

Inspection Number: 1910993

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWNING, JULIANNE

Violation Code

Observation

Violation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Manatee County

License Number: 5105351

CASA DI PIZZA UNIVERSITY

License Type: Permanent Food Service

8193 TOURIST CENTER DR, BRADENTON 34201

Inspection Date: 07/13/2009

Inspection Number: 1882272

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHRISTENSON, MELISSA

Violation CodeObservationViolation Citation

37-20-2

Hood tiles missing. Tiles currently being cleaned in establishment and will then be put back up.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5103505

SMITTYS BEACHIN CHICKEN

License Type: Permanent Food Service

3812 W MANATEE AVE, BRADENTON 342051714

Inspection Date: 07/13/2009

Inspection Number: 1912939

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KEMPA, ALICE M

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5104216

CASA DEL SOL

License Type: Permanent Food Service

4832 CORTEZ RD W., MANATEE 34210

Inspection Date: 07/17/2009

Inspection Number: 1902686

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: KEMPA, ALICE M

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.[rear door]

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Manatee County

License Number: 5102991

RIVER WILDERNESS CLUB INC

License Type: Permanent Food Service

1 WILDERNESS BLVD, PARRISH 34219-9329

Inspection Date: 07/15/2009

Inspection Number: 1912979

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTENSON, MELISSA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5201311 MINUCCI'S PIZZA & SUBS LLC
 License Type: Permanent Food Service 2502 NE JACKSONVILLE RD #103, OCALA 34470

Inspection Date: 07/13/2009 Inspection Number: 1849987 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-27-2	Silver portable fire extinguisher blocked/not easily accessible by bags. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate behind door leading to restrooms. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5202311 DD'S
 License Type: Permanent Food Service 2507 NE JACKSONVILLE RD, OCALA 34470

Inspection Date: 07/13/2009 Inspection Number: 1870373 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 5200363 LONG JOHN SILVERS
 License Type: Permanent Food Service 1828 E SILVER SPGS BLVD, OCALA 344706921

Inspection Date: 07/13/2009 Inspection Number: 1859982 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit sign not properly illuminated over door near restrooms. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 5202187 CHINA WOK
 License Type: Permanent Food Service 6845 SE MARICAMP RD, OCALA 34472

Inspection Date: 07/16/2009 Inspection Number: 1860050 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. ABC extinguisher sitting on kitchen floor not mounted .	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5202225

LAKE DIAMOND GOLD & COUNTRY CLUB

License Type: Permanent Food Service

16 GOLF VIEW DR, OCALA 34472

Inspection Date: 07/13/2009

Inspection Number: 1911383

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANAZIA, ROLAND

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Bar area .

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5202293

SUBWAY SANDWICHES & SALADS

License Type: Permanent Food Service

6855 SE MARICAMP RD, OCALA 34472

Inspection Date: 07/17/2009

Inspection Number: 1860054

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANAZIA, ROLAND

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Cardboard boxes blocking back exit door .

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 5201850

FAT DADDY'S

License Type: Permanent Food Service

10135 SE SUNSET HARBOR ROAD, SUMMERFIELD 34491

Inspection Date: 07/16/2009

Inspection Number: 1688905

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: ANAZIA, ROLAND

Violation CodeObservationViolation Citation

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Kitchen area .

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5202087 MCDONALDS
 License Type: Permanent Food Service 17890 US HWY 441, SUMMERFIELD 34491

Inspection Date: 07/14/2009 Inspection Number: 1880662 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Back exit door . Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 5202549 SONIC DRIVE IN
 License Type: Permanent Food Service 11211 SE 178 PL, SUMMERFIELD 34491

Inspection Date: 07/14/2009 Inspection Number: 1839506 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only. Corrected On Site.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.

Martin County

License Number: 5301186

DOMINO'S PIZZA

License Type: Permanent Food Service

990 MARTIN DOWNS BLVD, PALM CITY 349902816

Inspection Date: 07/17/2009

Inspection Number: 1855610

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only... back.

61C-1.004(10) FAC Exits shall be clearly marked with
approved illuminated exit signs. FOR REPORTING
PURPOSES ONLY.

License Number: 5301478

MONTANO'S TACO MEXICAN FOOD

License Type: Permanent Food Service

3164 SE DIXIE HWY, STUART 34997

Inspection Date: 07/16/2009

Inspection Number: 1855510

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with
approved illuminated exit signs. FOR REPORTING
PURPOSES ONLY.

Nassau County

License Number: 5500772		HUDDLE HOUSE RESTAURANT #340	
License Type: Permanent Food Service		103 EWING PARK LN, CALLAHAN 32011	
Inspection Date: 07/16/2009	Inspection Number: 1911707	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Kitchen	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 5500364		CEDAR RIVER SEAFOOD&OYSTER BAR	
License Type: Permanent Food Service		401 N KINGS RD, CALLAHAN 320119102	
Inspection Date: 07/14/2009	Inspection Number: 1870715	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. ABC extinguisher kitchen.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K extinguisher on floor.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Kitchen	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Steam unit	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5500813		ANGELS PORCH & JACK AND DIANES	
License Type: Permanent Food Service		708 CENTRE ST, FERNANDINA BEACH 32034	
Inspection Date: 07/14/2009	Inspection Number: 1860426	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. Behind stove	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Nassau County

License Number: 5500966	APPLEBEES #4308		
License Type: Permanent Food Service	2006 S 8 ST, FERNANDINA BEACH	32034	
Inspection Date: 07/15/2009	Inspection Number: 1881036	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Hood filters		NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
License Number: 5501006	MS CAROLYN'S BREAKFAST & DESSERTS		
License Type: Permanent Food Service	1881 S 14 ST #1, FERNANDINA BEACH	32034	
Inspection Date: 07/15/2009	Inspection Number: 1850365	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only. Portable griddle not under fire suppression system.		NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.
License Number: 5501010	HANA SUSHI		
License Type: Permanent Food Service	1930 S 14 ST STE 10, FERNANDINA BEACH	32034	
Inspection Date: 07/15/2009	Inspection Number: 1850363	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Kitchen		61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Okaloosa County

License Number: 5603624 MCDONALDS #6208
 License Type: Permanent Food Service 1300 N FERDON BLVD, CRESTVIEW 32536

Inspection Date: 07/13/2009 Inspection Number: 1871791 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: WIGGINS, GISELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Violation: 47-15-2 Observed an uncovered electrical box. At drivethru soda dispenser cover off exposing wiring to liquids. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5601418 DOMINO'S PIZZA INC
 License Type: Permanent Food Service 656 N BEAL PKY, FT WALTON BCH 32547

Inspection Date: 07/16/2009 Inspection Number: 1850955 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEREZ, FELIPE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Light switch receptacle detached from wall socket. Repeat Violation.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5603364 SUBWAY OF EGLIN
 License Type: Permanent Food Service 161 NE EGLIN PKWY, FT WALTON BCH 32548

Inspection Date: 07/13/2009 Inspection Number: 1902054 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FRANZALIA, CHARLES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed an uncovered electrical box. For reporting purposes only...circuit breaker box...	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5603379 ALI BABA GRILL CAFE
 License Type: Permanent Food Service 550 MARY ESTHER CUTOFF STE 14, FT WALTON BEACH 32548

Inspection Date: 07/10/2009 Inspection Number: 1881576 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FRANZALIA, CHARLES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5810871

BARNHILLS

License Type: Permanent Food Service

325 S MCGEE AVE, APOPKA 32703

Inspection Date: 07/17/2009

Inspection Number: 1915231

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: CHIU, CECILIA

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only. Above fryers

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only. Above stoves

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5811976

PANERA BREAD

License Type: Permanent Food Service

329 PARK AVE, WINTER PARK 32789

Inspection Date: 07/16/2009

Inspection Number: 1879522

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WATSON, DENNIS

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. By back door

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5807795

BOSTON MARKET #0770

License Type: Permanent Food Service

4201 E COLONIAL DR, ORLANDO 328035215

Inspection Date: 07/10/2009

Inspection Number: 1859188

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MOORE, CAROLYN

Violation CodeObservationViolation Citation

46

Out of compliance: Exiting system - adequate, good repair

NFPA 101, 96, 10 Exiting system - adequate, good repair

Orange County

License Number: 5804419

RUBY TUESDAY #2119

License Type: Permanent Food Service

8001 S ORANGE BLOSSOM TR, ORLANDO 328097654

Inspection Date: 07/16/2009

Inspection Number: 1868394

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LAMBERT, LISA

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.
boiler 503,5000 btus.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 5811282

SEITO JAPANESE RESTAURANT

License Type: Permanent Food Service

4898 NEW BROAD ST, BALDWIN PARK VILLAGE, ORLANDO 32814

Inspection Date: 07/14/2009

Inspection Number: 1848763

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHIU, CECILIA

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Orange County

License Number: 5811848		COLD STONE CREAMERY 751	
License Type: Permanent Food Service		4954 NEW BROAD ST E-3, ORLANDO 32814	
Inspection Date: 07/14/2009	Inspection Number: 1900005	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, CECILIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. Repeat Violation.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
45-40-2	Portable fire extinguisher with no approved inspection tag. For reporting purposes only.	61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.	
License Number: 5808287		LI JING CHINESE RESTAURANT	
License Type: Permanent Food Service		7150 W COLONIAL DR, ORLANDO 32818	
Inspection Date: 07/14/2009	Inspection Number: 1858512	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GORDON, NORMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. [Rear exit]. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 5809560		BURGER KING #12905	
License Type: Permanent Food Service		8409 S JOHN YOUNG PKWY, ORLANDO 32819	
Inspection Date: 07/13/2009	Inspection Number: 1849341	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NEGRON, LARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
46-12-2	Emergency lighting illumination insufficient. For reporting purposes only.	NFPA 101, 7.9.2.1 Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 foot-candle and, at any point, not less than 0.1 foot-candles, measured along the path of egress at floor level. FOR REPORTING PURPOSES ONLY.	

Orange County

License Number: 5810428		CICI'S PIZZA	
License Type: Permanent Food Service		8261 JOHN YOUNG PARKWAY, ORLANDO 32819	
Inspection Date: 07/13/2009	Inspection Number: 1869733	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NEGRON, LARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-10-2	Emergency lighting wiring exposed. For reporting purposes only.	NFPA 101, 7.9.2.1 Emergency illumination shall be provided for not less than 1.5 hours in the event of failure of normal lighting. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only,radio	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5811422		ASIAN CAFE	
License Type: Permanent Food Service		5250 INTERNATIONAL DRIVE, ORLANDO 32819	
Inspection Date: 07/14/2009	Inspection Number: 1847969	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 5811676		AMAZONAS LATIN GRILL	
License Type: Permanent Food Service		8273 SOUTH JOHN YOUNG PARKWAY, ORLANDO 32819	
Inspection Date: 07/13/2009	Inspection Number: 1879952	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NEGRON, LARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. foam cooler and plastic jug stored on water heater.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 5811693		GOURMET DIPPIN BREAD CAFE	
License Type: Permanent Food Service		5259 INTERNATIONAL DRVE STE 2, ORLANDO 32819	
Inspection Date: 07/14/2009	Inspection Number: 1909460	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 5806781		TACO BELL #4838	
License Type: Permanent Food Service		5147 S KIRKMAN BLVD, ORLANDO 328197943	
Inspection Date: 07/13/2009	Inspection Number: 1868448	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair	

Orange County

License Number: 5811866 MIL DELICIA
 License Type: Permanent Food Service 2751 S CHICKASAW TRAIL, ORLANDO 32829

Inspection Date: 07/10/2009 Inspection Number: 1828112 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Violation: 47-05-2 Observed a splitter/multi-plug adapter in use, connected to extention cords, behind chest freezers. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period, connected to chest freezer . For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5808698 CAFE LATINO
 License Type: Permanent Food Service 9785 S ORANGE BLOSSOM TRAIL SUITE A, ORLANDO 32837

Inspection Date: 07/14/2009 Inspection Number: 1848889 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate behind freezer. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5811019

KAHUNA GRILL

License Type: Permanent Food Service

13701 JOHN YOUNG PARKWAY, ORLANDO 32837

Inspection Date: 07/13/2009

Inspection Number: 1848883

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor; at west dining room exit. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-13-2	Circuit breaker boxes blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate in bar storage area. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Osceola County

License Number: 5905940		CHECKER'S #3072	
License Type: Permanent Food Service		1939 E OSCEOLA PKWY BLVD, KISSIMMEE 34743	
Inspection Date: 07/10/2009	Inspection Number: 1821598	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: RIVERA, JESICA M			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2 Hood filters are (missing)not tight-fitting and firmly held in place - leaving open spaces . For reporting purposes only. Spacer is now provided however the filters still not held firmly in place.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 5908937		DUNKIN DONUTS/BASKIN ROBBINS	
License Type: Permanent Food Service		1935 OSCEOLA PKWY, KISSIMMEE 34743	
Inspection Date: 07/14/2009	Inspection Number: 1878314	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHAN, MOZHARUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 5910815		SOL DE BORINQUEN BAQUERY	
License Type: Permanent Food Service		2510 MICHIGAN AVE, KISSIMMEE 34744	
Inspection Date: 07/14/2009	Inspection Number: 1837243	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: KHAN, MOZHARUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. Panini grill in the front counter. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5910954		RIVERSIDE CHINESE CAFE	
License Type: Permanent Food Service		1373 E. OSCEOLA PARKWAY, KISSIMMEE 34744	
Inspection Date: 07/16/2009	Inspection Number: 1868000	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RIVERA, JESICA M			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 5900733		PIZZA HUT # 630004	
License Type: Permanent Food Service		5740 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746	
Inspection Date: 07/13/2009	Inspection Number: 1888446	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WRIGHT, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged by back kitchen exit. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Osceola County

License Number: 5910913

ASIA BAGUS

License Type: Permanent Food Service

2923 VINELAND RD, KISSIMMEE 34746

Inspection Date: 07/16/2009

Inspection Number: 1867972

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RIVERA, JESICA M

Violation CodeObservationViolation Citation

45-37-2

Portable fire extinguisher missing from designated location. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5900998

HURRICANE SAM'S

License Type: Permanent Food Service

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Inspection Date: 07/13/2009

Inspection Number: 1888344

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For TV and cable box at bar dining area. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6013826

CAFE SAPORI CATERING

License Type: Catering

205 SOUTHERN BLVD, WEST PALM BEACH 33405

Inspection Date: 07/17/2009

Inspection Number: 1092743

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHAPIRO, STEWART

Violation CodeObservationViolation Citation

48-01-2

Boiler certificate not posted in boiler room. For reporting purposes only. GAVE BOILER INSPECTOR PHONE #

69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

License Number: 6019128

CAFE SAPORI

License Type: Permanent Food Service

205 SOUTHERN BLVD, WEST PALM BEACH 33405

Inspection Date: 07/17/2009

Inspection Number: 1855308

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHAPIRO, STEWART

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only. INSTANT HEAT UNIT SHOWS 300 GALLON

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6005650

CLUB HOUSE PUB

License Type: Permanent Food Service

525 NOTTINGHAM BLVD, WEST PALM BEACH 334052631

Inspection Date: 07/16/2009

Inspection Number: 1834779

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: SHAPIRO, STEWART

Violation CodeObservationViolation Citation

45-11-2

Observed cooking equipment in use while hood suppression/exhaust system is inoperable. Notified Fire AHJ. For reporting purposes only. NO HOOD SUPPRESSION SYSTEM WITH COOKING EQUIPMENT IN USE Repeat Violation.

NFPA 96, 11.1.6 Cooking equipment shall not be operated while its fire-extinguishing system or exhaust system is nonoperational or otherwise impaired. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6012711 IHOP 36-157
 License Type: Permanent Food Service 1503 BELVEDERE RD, WEST PALM BEACH 33406

Inspection Date: 07/14/2009 Inspection Number: 1914287 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONCEPCION, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6011110 CRACKER BARREL COUNTRY STORE
 License Type: Permanent Food Service 2411 METROCENTRE BLVD, WEST PALM BEACH 33407

Inspection Date: 07/16/2009 Inspection Number: 1915351 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JONES, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6005647 MCDONALD'S #5776
 License Type: Permanent Food Service 1775 N MILITARY TRL, WEST PALM BEACH 33409

Inspection Date: 07/14/2009 Inspection Number: 1845171 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JONES, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters out. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. office area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6013750 DUFFYS SPORTS GRILL
 License Type: Permanent Food Service 721 VILLAGE BLVD, WEST PALM BEACH 33409

Inspection Date: 07/16/2009 Inspection Number: 1915349 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JONES, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6011817 CELEBRITY DINER
 License Type: Permanent Food Service 10121 SOUTHERN BLVD #301, ROYAL PALM BEACH 33411

Inspection Date: 07/14/2009 Inspection Number: 1886037 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIDDLETON, ELWYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only. back door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6019921

HURRICANE GRILL AND WINGS

License Type: Permanent Food Service

11071 SOUTHERN BLVD STE 170, ROYAL PALM BEACH 33411

Inspection Date: 07/16/2009

Inspection Number: 1845075

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MIDDLETON, ELWYN

Violation CodeObservationViolation Citation

15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. one filter missing .	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
46-13-2	Emergency light does not function when tested. For reporting purposes only. women's restroom.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. ceiling tiles/cardboard .	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 6019705

JAPAN EXPRESS

License Type: Permanent Food Service

13873 WELLINGTON TRCE B10, WELLINGTON 33414

Inspection Date: 07/16/2009

Inspection Number: 1865534

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MENOR, MICHAEL

Violation CodeObservationViolation Citation

47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. REFRIGERATOR	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
---------	--	--

License Number: 6007632

GUN CLUB CAFE INC

License Type: Permanent Food Service

4631 GUN CLUB RD, WEST PALM BCH 334152850

Inspection Date: 07/15/2009

Inspection Number: 1855288

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
---------	---	--

Palm Beach County

License Number: 6013268 QUIZNO'S
 License Type: Permanent Food Service 5510 PGA BLVD, PALM BCH GARDENS 33418

Inspection Date: 07/14/2009 Inspection Number: 1684067 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Inspector Name: MIDDLETON, ELWYN Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-13-2	Violation: 46-13-2 Emergency light does not function when tested. For reporting purposes only. restroom.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

License Number: 6009962 MCDONALD'S REST #12020
 License Type: Permanent Food Service 7030 W PALMETTO PARK RD, BOCA RATON 33433

Inspection Date: 07/14/2009 Inspection Number: 1844677 Inspection Type: Routine - Food Inspection Disposition: Inspection
 Inspector Name: PIERI, CYNTHIA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. cardboard boxes at both back door fire exits	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6019029 BOCA PITA EXPRESS
 License Type: Permanent Food Service 7185 N BERACASA WAY, BOCA RATON 33433

Inspection Date: 07/14/2009 Inspection Number: 1844659 Inspection Type: Routine - Food Inspection Disposition: Inspection
 Inspector Name: PIERI, CYNTHIA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only. PARTIALLY LIT	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 6019830 QUIZNOS SUBS
 License Type: Permanent Food Service 3932 HYPOLUXO RD, BOYNTON BEACH 33436

Inspection Date: 07/15/2009 Inspection Number: 1906467 Inspection Type: Routine - Food Inspection Disposition: Warning
 Inspector Name: SINGH, GAJENDRA Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. ON FLOOR UNDER HWS	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6011603

SAFFRON FINE DINING FROM INDIA INC

License Type: Permanent Food Service

1061 E INDIAN TOWN RD STE#110, JUPITER 33477

Inspection Date: 07/14/2009

Inspection Number: 1812403

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

45-47-2

Violation: 45-47-2

Fire alarm system inspection records not maintained. For reporting purposes only.
fire alarm panel room locked. no access.NFPA 72, 10.6.2.1 Maintenance, Inspection, and
Testing Records. Records shall be retained until the
next test and for 1 year thereafter. FOR REPORTING
PURPOSES ONLY.

47-13-2

Violation: 47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.
storage in electric roomNFPA 70, 110.32 Work Space about Equipment.
Sufficient space shall be provided and maintained about
electrical equipment to permit ready and safe operation
and maintenance of such equipment. In all cases, the
work space shall be adequate to permit at least a
90-degree opening of doors or hinged panels. FOR
REPORTING PURPOSES ONLY.

License Number: 6011971

TRATTORIA DELFINO RESTAURANT

License Type: Permanent Food Service

185 E INDIANTOWN RD STE 217, JUPITER 33477

Inspection Date: 07/15/2009

Inspection Number: 1914442

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes
only. freezer.61C-1.004(11) FAC Electrical wiring. To prevent fire or
injury, defective electrical wiring shall be replaced and
wiring shall be kept in good repair. No extension cords
shall be used except during cleaning, maintenance and
other temporary activities. Only a wall switch or
approved pull cord shall be permitted in bathrooms. In
accordance with the provisions of NFPA 70, the
National Electrical Code, as adopted by the Division of
State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire
Safety Rules and Standards, sufficient electrical outlets
shall be provided. FOR REPORTING PURPOSES
ONLY.

License Number: 6012439

SPRINKLES OF PALM BCH

License Type: Permanent Food Service

279 ROYAL POINCIANA WAY, PALM BCH 33480

Inspection Date: 07/14/2009

Inspection Number: 1906712

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SHAPIRO, STEWART

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
WIRE HANGING BY BACK DOORNFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of
egress shall be continuously maintained free of all
obstructions or impediments to full instant use in the
case of fire or other emergency. Means of access must
permit unobstructed travel at all times and be
maintained free of obstructions and fire hazards. Halls,
entrances and stairways shall be clean, ventilated and
well-lighted day and night. Hall and stair runners shall
be kept in good condition. Hand rails shall be installed
on all stairways and guard rails around all porches and
steps. Adequate means of exit shall be provided
pursuant to NFPA 101. FOR REPORTING
PURPOSES ONLY.

Palm Beach County

License Number: 6005485

MICHELLE BERNSTEINS

License Type: Permanent Food Service

2842 S OCEAN BLVD, PALM BEACH 33480

Inspection Date: 07/17/2009

Inspection Number: 1811559

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHAPIRO, STEWART

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. 2 180 GALLON STORSGE TANKS & 3 100 GALLON HEATERS	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6102848	PALETERIA RESTAURAN LA PEQUENA		
License Type: Permanent Food Service	37143 LOCK ST, DADE CITY 33523		
Inspection Date: 07/13/2009	Inspection Number: 1898115	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROTHAG, SANDRA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6112925	KINJA JAPANESE RESTAURANT		
License Type: Permanent Food Service	2215 COLLIER PKWY, LAND O' LAKES 34639		
Inspection Date: 07/16/2009	Inspection Number: 1846827	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROTHAG, SANDRA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6100318	HUDSON SQUARE RESTAURANT		
License Type: Permanent Food Service	14150 US 19, HUDSON 34667		
Inspection Date: 07/16/2009	Inspection Number: 1867544	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GLENN, DAVID			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-05-2	Violation: 47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6100991

BLUE DOLPHIN (THE)

License Type: Permanent Food Service

8825 SR 52, HUDSON 34667

Inspection Date: 07/15/2009

Inspection Number: 1915271

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-03-2 Observed unused opening in panel box unprotected. For reporting purposes only.

NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

47-08-2 Observed electrical wiring in disrepair. For reporting purposes only. Wall outlet servicing lift top cooler has a short.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6101792

MUGOOS DINER

License Type: Permanent Food Service

16103 US HWY 19, HUDSON 34667

Inspection Date: 07/15/2009

Inspection Number: 1836745

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. Powering pump on septic tank. Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2 Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Powering pump on septic tank. Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6102658

RON'S BBQ

License Type: Permanent Food Service

9400 SR 52, HUDSON 34669

Inspection Date: 07/15/2009

Inspection Number: 1908576

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-03-2 Observed unused opening in panel box unprotected. For reporting purposes only. Protective cap missing from circuit panel on wall by office.

NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6214921		GREAT WALL CHINESE TAKEOUT	
License Type: Permanent Food Service		1127 N 62 AVE, ST PETERSBURG 33702	
Inspection Date: 07/14/2009	Inspection Number: 1831432	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6207474		ITALIA MIA	
License Type: Permanent Food Service		1163 N 62 AVE, ST PETERSBURG 337027421	
Inspection Date: 07/14/2009	Inspection Number: 1907370	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6214920		PASS-A-CHILLE BURRITO CO	
License Type: Permanent Food Service		118 8TH AVENUE, ST.PETE BEACH 33706	
Inspection Date: 07/13/2009	Inspection Number: 1897977	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BIROCCO, JOSEPH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.Near coke machine.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6215299		QUIZNO'S SUBS STORE 2732	
License Type: Permanent Food Service		6804 N 22 AVE, ST PETERSBURG 33710	
Inspection Date: 07/16/2009	Inspection Number: 1866084	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 6212909		CHECKERS RESTAURANT #332	
License Type: Permanent Food Service		3775 N 66 ST, ST PETERSBURG 337101546	
Inspection Date: 07/13/2009	Inspection Number: 1845527	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	

Pinellas County

License Number: 6251275		CAREBBEAN TASTE	
License Type: Mobile Food Dispensing Vehicle		2619 23 AVE N, ST PETERSBURG 33713	
Inspection Date: 07/16/2009	Inspection Number: 1135883	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlets missing cover plates. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6212869		FRESH GO WILD MARKET & GRILL	
License Type: Permanent Food Service		600 34 ST N, ST. PETERSBURG 33713	
Inspection Date: 07/13/2009	Inspection Number: 1866356	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6215734		KFC/AWR	
License Type: Permanent Food Service		770 34 ST N, ST. PETERSBURG 33713	
Inspection Date: 07/13/2009	Inspection Number: 1876602	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 6215835		EDDIE & AL'S NY PIZZA	
License Type: Permanent Food Service		2325 28 ST N, ST. PETERSBURG 33713	
Inspection Date: 07/10/2009	Inspection Number: 1835613	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlets missing cover plates. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6206650		DOOLY'S PUB	
License Type: Permanent Food Service		2329 N 28 ST, ST PETERSBURG 337134228	
Inspection Date: 07/10/2009	Inspection Number: 1907380	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

Pinellas County

License Number: 6211880		CHECKERS DRIVE INN REST #170	
License Type: Permanent Food Service		1877 HIGHLAND AVE, CLEARWATER 33755	
Inspection Date: 07/16/2009	Inspection Number: 1886821	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WINSOR, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.- -smaller breaker box	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 6212097		CHINA EXPRESS	
License Type: Permanent Food Service		1835 N HIGHLAND AVENUE, CLEARWATER 33755	
Inspection Date: 07/13/2009	Inspection Number: 1897123	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WINSOR, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
39-03-2	Exhaust system off during the operation of cooking equipment. For reporting purposes only.--turned on when woks in use	NFPA 96, 11.1.1 Exhaust systems shall be operated whenever cooking equipment is turned on. For reporting purposes only.	
License Number: 6212798		YA-YA'S FLAME BROILED CHICKEN	
License Type: Permanent Food Service		1764 GULF TO BAY BLVD, CLEARWATER 33755	
Inspection Date: 07/10/2009	Inspection Number: 1876696	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: WINSOR, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-09-2	Pull station for fire suppression system not properly identified/labeled. For reporting purposes only.--2 pull stations need labeled	NFPA 96, 10.5.1 A readily accessible means for manual activation shall be located between 42 inches and 48 inches above the floor, be accessible in the event of a fire, be located in a path of egress, and clearly identify the hazard protected. FOR REPORTING PURPOSES ONLY.	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.---at otis spunkmeyer machine----use 6 outlet powerpad	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Pinellas County

License Number: 6209215

COUNTRYSIDE LANES SNK BAR LNG

License Type: Permanent Food Service

27867 N US HWY 19, CLEARWATER 33761

Inspection Date: 07/16/2009

Inspection Number: 1907504

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRAIG, CHRISTINE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For coffee t For reporting purposes only.
Corrected On Site.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-15-2

Observed an uncovered electrical box. behind beverage station For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6214308

CHIPS DELI

License Type: Permanent Food Service

4500 N 140 AVE STE 107, CLEARWATER 33762

Inspection Date: 07/17/2009

Inspection Number: 1857550

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PORTER, LINDSAY

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.(on table in kitchen)

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6214945

J&J CLEARWATER BEACH SUBWAY #5

License Type: Permanent Food Service

409 N MANDALAY AVE, CLEARWATER 33767

Inspection Date: 07/13/2009

Inspection Number: 1907156

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVIS, CAROL S

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6206896		UNTOUCHABLES PASTA & PIZZA	
License Type: Permanent Food Service		1150 CLEARWATER LARGO RD, LARGO 337704131	
Inspection Date: 07/17/2009	Inspection Number: 1886671	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLSEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. near slicer	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 6212926		TOKYO SUSHI CAFE II	
License Type: Permanent Food Service		10500 ULMERTON RD STE 288, LARGO 33771	
Inspection Date: 07/16/2009	Inspection Number: 1847239	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PORTER, LINDSAY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
39-03-2	Exhaust system off during the operation of cooking equipment. For reporting purposes only.	NFPA 96, 11.1.1 Exhaust systems shall be operated whenever cooking equipment is turned on. For reporting purposes only.	
47-02-2	Observed circuit breaker taped open. For reporting purposes only.(near dish machine)	NFPA 70, 240.80 Circuit breakers shall be tripfree and capable of being closed and opened by manual operation. FOR REPORTING PURPOSES ONLY.	

License Number: 6208570		THE PICKLE BARREL	
License Type: Permanent Food Service		9520 SEMINOLE BLVD, SEMINOLE 33772	
Inspection Date: 07/16/2009	Inspection Number: 1855968	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLSEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. abc front service area on floor	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 6214956		GREAT WALL	
License Type: Permanent Food Service		10797 PARK BLVD, SEMINOLE 33772	
Inspection Date: 07/16/2009	Inspection Number: 1856012	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLSEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Pinellas County

License Number: 6213120

RUDY'S SPORTS BAR

License Type: Permanent Food Service

11100 66 ST N, LARGO 33773

Inspection Date: 07/14/2009

Inspection Number: 1857528

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PORTER, LINDSAY

Violation CodeObservationViolation Citation

47-03-2 Observed unused opening in panel box unprotected. For reporting purposes only.

NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 6209125

PIZZO UNO

License Type: Permanent Food Service

12561 ULMERTON RD, LARGO 33774

Inspection Date: 07/16/2009

Inspection Number: 1907308

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation45-39-2 Violation: 45-39-2
Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. abc in back area sitting on floor

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. abc in back area sitting on floor

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6214895

NEW CHINA CITY RESTAURANT

License Type: Permanent Food Service

13847 WALSINGHAM RD, LARGO 33774

Inspection Date: 07/13/2009

Inspection Number: 1835527

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. to fan in kitchen area

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6208358		PLANET PIZZA OF LARGO	
License Type: Permanent Food Service		14100 WALSINGHAM RD, LARGO 33774-3248	
Inspection Date: 07/15/2009	Inspection Number: 1907318	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: OLSEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. to fan in kitchen area	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. in bathroom	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6211958		TWEDT'S BOWLING CENTER INC	
License Type: Permanent Food Service		13100 SEMINOLE BLVD, LARGO 337782126	
Inspection Date: 07/17/2009	Inspection Number: 1876572	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLSEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. in dinning room area abc	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 6210101		ARBYS RESTAURANT #487	
License Type: Permanent Food Service		12260 SEMINOLE BLVD, LARGO 337782758	
Inspection Date: 07/14/2009	Inspection Number: 1855998	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLSEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. to radio in kitchen area	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6215296		CARMELITA'S MEXICAN RESTAIRANT	
License Type: Permanent Food Service		6218 N 66 ST, PINELLAS PARK 33781	
Inspection Date: 07/15/2009	Inspection Number: 1855760	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-13-2	No proof of hood cleaning performed by cleaning service. For reporting purposes only.	NFPA 96, 11.4.12 When a vent cleaning service is used, a certificate showing date of inspection or cleaning shall be maintained on the premises. FOR REPORTING PURPOSES ONLY.	

Pinellas County

License Number: 6211118

DOMINO'S PIZZA #5033

License Type: Permanent Food Service

3800 TAMPA RD STE 180, OLDSMAR 34677

Inspection Date: 07/17/2009

Inspection Number: 1835697

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CRAIG, CHRISTINE

Violation CodeObservationViolation Citation

47-04-2

Observed frayed/spliced electrical wires. For reporting purposes only.inside cooler

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6212078

SUBWAY #3499

License Type: Permanent Food Service

40188 N US HWY 19, TARPON SPGS 346898334

Inspection Date: 07/17/2009

Inspection Number: 1907560

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open.
For reporting purposes only. tool on bolt on Billy bar,back door

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6307409 HONG KONG RESTAURANT
 License Type: Permanent Food Service 911 WILSON AVE N, BARTOW 33830

Inspection Date: 07/15/2009 Inspection Number: 1856794 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. Broken plates. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6306415 GRAND CHINA BUFFET RESTAURANT
 License Type: Permanent Food Service 43554 US HWY 27, DAVENPORT 33837

Inspection Date: 07/15/2009 Inspection Number: 1846439 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. near dishwashing machine.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6307414 DIROMIO'S PIZZA & GRILL
 License Type: Permanent Food Service 101 DIVINE DR SUITE 2, DAVENPORT 33837

Inspection Date: 07/15/2009 Inspection Number: 1907962 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Violation: 47-16-2 Electrical outlet missing cover plate. For reporting purposes only. on floor near prep table.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. on floor near prep table.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6303668 THE OLIVE GARDEN
 License Type: Permanent Food Service 411 CYPRESS GARDENS BLVD, WINTER HAVEN 33880

Inspection Date: 07/17/2009 Inspection Number: 1846577 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6307673 APPLEBEE'S NEIGHBORHOOD GRILL & BAR
 License Type: Permanent Food Service 200 AMBER SWEET WAY, DAVENPORT 33897

Inspection Date: 07/14/2009 Inspection Number: 1897691 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

Sarasota County

License Number: 6804425		SAM SELTZER'S STEAKHOUSE #4	
License Type: Permanent Food Service		7111 S TAMIAMI TRL, SARASOTA 34231	
Inspection Date: 07/15/2009	Inspection Number: 1882464	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DILLARD, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Hood filters missing over two gas grills at cookline .	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6803986		KENTUCKY FRIED CHICKEN	
License Type: Permanent Food Service		3780 E BEE RIDGE RD, SARASOTA 34233	
Inspection Date: 07/13/2009	Inspection Number: 1882442	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DILLARD, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Over Blodgett oven.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6804825		SAL & TONY'S PIZZERIA	
License Type: Permanent Food Service		545 S TAMIAMI TRL, VENICE 34285	
Inspection Date: 07/15/2009	Inspection Number: 1913133	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: STEVENS, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.rear walkin cooler hallway/ceiling fan	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Sarasota County

License Number: 6804681

MR BASEBALLS PIZZA & PUB

License Type: Permanent Food Service

1001 CORPORATE AVE STE# 103-104, NORTH PORT 34289

Inspection Date: 07/15/2009

Inspection Number: 1882386

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: STEVENS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.rear kitchen /portable fans/callback observed same	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.rear kitchen /portable fans	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Seminole County

License Number: 6903106

ROMANOS MACARONI GRILL

License Type: Permanent Food Service

884 W SR 436, ALTAMONTE SPRINGS 32741

Inspection Date: 07/10/2009

Inspection Number: 1914905

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHIU, CECILIA

Violation CodeObservationViolation Citation

48-01-2

Boiler certificate not posted in boiler room. For reporting purposes only.

69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

48-12-2

No current boiler certification provided/available. For reporting purposes only. Repeat Violation.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6902304

BURGER KING #5566

License Type: Permanent Food Service

4405 W LAKE MARY BLVD, LAKE MARY 32746

Inspection Date: 07/13/2009

Inspection Number: 1879408

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

15-26-2

Observed exhaust system operated with filters removed. For reporting purposes only.

NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.

License Number: 6903657

TIJUANA FLATS BURRITO CO

License Type: Permanent Food Service

3005 W LAKE MARY BLVD, LAKE MARY 32746

Inspection Date: 07/13/2009

Inspection Number: 1869133

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. Main entrance

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Seminole County

License Number: 6904779		DICKKEYS BARBECUE PIT	
License Type: Permanent Food Service		5414 DEEP LAKE RD, OVIEDO 32765	
Inspection Date: 07/16/2009	Inspection Number: 1869947	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PLEICONES, KIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. plastic bags and back pack next to gas water hater	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 6903171		S&S AMERICAN/ WEST INDIAN	
License Type: Permanent Food Service		1407 W 13 ST, SANFORD 327712761	
Inspection Date: 07/17/2009	Inspection Number: 1849447	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. Hasp on front door.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Over front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6902939		FLEA WORLD CAROUSEL RESTAURANT	
License Type: Permanent Food Service		4311 S ORLANDO AVE, SANFORD 327736118	
Inspection Date: 07/17/2009	Inspection Number: 1910109	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-37-2	Portable fire extinguisher missing from designated location. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

St. Lucie County

License Number: 6602732

SIAM #1

License Type: Permanent Food Service

2903 ORANGE AVE SUITE B, FORT PIERCE 34947

Inspection Date: 07/15/2009

Inspection Number: 1878472

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only. Outlet at front counter, under pre packed candy/cookies,gum etc.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6602253

CICI'S PIZZA

License Type: Permanent Food Service

10368 S FEDERAL HIGHWAY, PORT SAINT LUCIE 34952

Inspection Date: 07/13/2009

Inspection Number: 1914735

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PARNASS, LAUREN P

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period, orange cord runs from outlet over hand wash sink and around corner at the pizza make area. For reporting purposes only. Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

49-06-2

Observed flammable material stored around water heater, insulation for portable air conditioner directly against water heater. For reporting purposes only.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 6602291

ZAPATAS RESTAURANT INC

License Type: Permanent Food Service

6700 S US HWY 1, PORT ST LUCIE 34983

Inspection Date: 07/15/2009

Inspection Number: 1878552

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PARNASS, LAUREN P

Violation CodeObservationViolation Citation

45-07-2

Observed misalignment of hood suppression system nozzles, grill not under nozzle coverage. For reporting purposes only.

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

St. Lucie County

License Number: 6600807

CIULLAS PIZZA OVEN INC

License Type: Permanent Food Service

291 SE PORT ST LUCIE BLVD, PORT ST LUCIE 34984

Inspection Date: 07/16/2009

Inspection Number: 1878530

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PARNASS, LAUREN P

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor, ABC extinguisher is on the floor at the pizza make area. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6602900

PANDA EXPRESS

License Type: Permanent Food Service

1780 SW ST LUCIE WEST BLVD, PORT ST LUCIE 34986

Inspection Date: 07/14/2009

Inspection Number: 1899081

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PARNASS, LAUREN P

Violation CodeObservationViolation Citation

39-05-2

Ventilation inadequate as evidenced by smoke in kitchen area. Observed power went off and came back on during inspection, after power came back on hood ventilation wouldn't function properly. For reporting purposes only.

NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY

Volusia County

License Number: 7403687		BURGER KING #5572	
License Type: Permanent Food Service		2453 INT'L SPEEDWAY BLVD, DAYTONA BCH 32114	
Inspection Date: 07/15/2009	Inspection Number: 1848571	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 7405183		TACO BELL #25	
License Type: Permanent Food Service		740 N NOVA RD, DAYTONA BCH 32114	
Inspection Date: 07/16/2009	Inspection Number: 1889440	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-11-2	Observed cooking equipment in use while hood suppression/exhaust system is inoperable. Manager states not working and has called technician and he is on the way. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 11.1.6 Cooking equipment shall not be operated while its fire-extinguishing system or exhaust system is nonoperational or otherwise impaired. FOR REPORTING PURPOSES ONLY.	
License Number: 7405556		CAJUN CAFE	
License Type: Permanent Food Service		1700 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BCH 32114	
Inspection Date: 07/15/2009	Inspection Number: 1909969	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge/over grill. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 7404613		CHECKERS #6260	
License Type: Permanent Food Service		1174 BEVILLE RD, DAYTONA BEACH 32114	
Inspection Date: 07/14/2009	Inspection Number: 1838171	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
46-02-2	Observed a hasp and lock on door inside of ladiesroom. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	

Volusia County

License Number: 7406155		THE AQUARIUM	
License Type: Permanent Food Service		125 BASIN ST #102, DAYTONA BEACH 32114	
Inspection Date: 07/14/2009	Inspection Number: 1889438	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

License Number: 7406609		MEDITERRANEAN EXPERIENCE	
License Type: Permanent Food Service		174 N BEACH ST, DAYTONA BEACH 32114	
Inspection Date: 07/13/2009	Inspection Number: 1909971	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-02-2	Violation: 46-02-2 Observed lock on exit door that requires a key/frontdoor and reardoor. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	

License Number: 7406802		GOLDEN KRUST CARIBBEAN BAKERY AND GRILL	
License Type: Permanent Food Service		1330 WEST INTERNATIONAL SPEEDWAY, DAYTONA BEACH 32114	
Inspection Date: 07/13/2009	Inspection Number: 1869007	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-11-2	Observed cooking equipment in use while hood suppression/exhaust system is inoperable. Notified Fire AHJ. For reporting purposes only. Corrected On Site.	NFPA 96, 11.1.6 Cooking equipment shall not be operated while its fire-extinguishing system or exhaust system is nonoperational or otherwise impaired. FOR REPORTING PURPOSES ONLY.	

License Number: 7404376		EARL STREET GRILL	
License Type: Permanent Food Service		715 EARL ST, DAYTONA BCH 32118	
Inspection Date: 07/13/2009	Inspection Number: 1879192	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BARRETT, KAREN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged.at bar area For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Volusia County

License Number: 7405041 CHINA 1
 License Type: Permanent Food Service 2655 N ATLANTIC AVE, DAYTONA BCH 32118

Inspection Date: 07/15/2009 Inspection Number: 1879218 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BARRETT, KAREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed an uncovered electrical box. in hallway leading to restroomFor reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 7405589 CRUISIN CAFE
 License Type: Permanent Food Service 2 S ATLANTIC AVE, DAYTONA BCH 32118

Inspection Date: 07/06/2009 Inspection Number: 1858606 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BARRETT, KAREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 7403067 CRESS RESTAURANT LLC
 License Type: Permanent Food Service 103 W INDIANA AVE, DELAND 32720

Inspection Date: 07/17/2009 Inspection Number: 1899913 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRASKA, GEORGIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor 3 ABC class extinguishers on the floor by walk in cooler.. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 7406455 MI MEXICO MEXICAN RESTAURANT
 License Type: Permanent Food Service 1570 S. WOODLAND BLVD., DELAND 32724

Inspection Date: 07/14/2009 Inspection Number: 1889526 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRASKA, GEORGIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Walton County

License Number: 7601926		SONIC DRIVE IN #4934	
License Type: Permanent Food Service		1508 U S HIGHWAY 331 SOUTH, DEFUNIAK SPRINGS 32433	
Inspection Date: 07/17/2009	Inspection Number: 1902562	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WIGGINS, GISELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge, above grills. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 7602024		BAREFOOT BBQ	
License Type: Permanent Food Service		2235 E COUNTY HWY 30A, SANTA ROSA BEACH 32459	
Inspection Date: 07/16/2009	Inspection Number: 1861101	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VINCENT, STACEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor...K-class For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 7600372		WHALES TAIL BEACH GRILL	
License Type: Permanent Food Service		1373 E HWY 98, DESTIN 32550	
Inspection Date: 07/10/2009	Inspection Number: 1912343	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VINCENT, STACEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 7600673		FINZ	
License Type: Permanent Food Service		5538 E HWY 98, DESTIN 32550	
Inspection Date: 07/13/2009	Inspection Number: 1891810	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VINCENT, STACEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-13-2	Deep fat fryer installed without 16-inch separation from open flame...facing cookline on right side next to char-grill. For reporting purposes only.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.	

Walton County

License Number: 7601701

BLUE DUNES GRILLE

License Type: Permanent Food Service

9011 HWY 98, DESTIN 32550

Inspection Date: 07/10/2009

Inspection Number: 1851001

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation CodeObservationViolation Citation

45-37-2

Portable fire extinguisher missing from designated location. For reporting
purposes only.NFPA 10, 1.5.2 Portable fire extinguishers shall be
maintained in a fully charged and operable condition
and shall be kept in their designated places at all times
when they are not being used. FOR REPORTING
PURPOSES ONLY.

License Number: 7601679

THEO'S PIZZA

License Type: Permanent Food Service

1688 OLD HWY 98 UNIT A, MIRAMAR BEACH 32550

Inspection Date: 07/16/2009

Inspection Number: 1850985

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation CodeObservationViolation Citation

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open.
..hasp on WIC For reporting purposes only.NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require
the use of a key, a tool, or special knowledge or effort
for operation from the egress side. FOR REPORTING
PURPOSES ONLY.