

Alachua County

License Number: 1103089 VOLTA COFFEE, TEA & CHOCOLATE
 License Type: Permanent Food Service 48 SW 2ND ST, GAINESVILLE 32601

Inspection Date: 08/26/2009 Inspection Number: 1881330 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DOHERTY, BRENDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. FOR CONVECTION OVEN	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1103184 EAST END EATERY
 License Type: Permanent Food Service 1202 NE 8TH AVE, GAINESVILLE 32601

Inspection Date: 08/27/2009 Inspection Number: 1911995 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DOHERTY, BRENDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

License Number: 1101267 FARAH'S
 License Type: Permanent Food Service 1120 W UNIVERSITY AVE, GAINESVILLE 326015110

Inspection Date: 08/27/2009 Inspection Number: 1911955 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DOHERTY, BRENDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. EXPOSED WIRES ABOVE HANDSINK IN KITCHEN	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Alachua County

License Number: 1101889

CARIBBEAN SPICE

License Type: Permanent Food Service

1121 W UNIVERSITY AVE, GAINESVILLE 326015111

Inspection Date: 08/26/2009

Inspection Number: 1860713

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1100090

TACO BELL 594

License Type: Permanent Food Service

826 W UNIVERSITY AVE, GAINESVILLE 326015115

Inspection Date: 08/27/2009

Inspection Number: 1850639

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. REAR KITCHEN EXIT

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 1101218

MCDONALDS RESTAURANT

License Type: Permanent Food Service

6003 NEWBERRY RD, GAINESVILLE 326054301

Inspection Date: 08/26/2009

Inspection Number: 1880444

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. For reporting purposes only. Drive-thru

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Alachua County

License Number: 1101765	FALAFEL KING SANDWICHES
License Type: Permanent Food Service	3252 SW 35 BLVD, GAINESVILLE 326082415
Inspection Date: 08/27/2009	Inspection Number: 1880398
Inspector Name: WRENNE, LILYANN	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed an uncovered electrical box located by Vertical Broiler.For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1102428	T G I FRIDAYS #114
License Type: Permanent Food Service	3598 SW ARCHER RD, GAINESVILLE 326082438
Inspection Date: 07/14/2003	Inspection Number: 1118818
Inspector Name: VON BODUNGEN, STEVEN	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Baker County

License Number: 1200157

WOODY'S BAR-B-Q

License Type: Permanent Food Service

1482 S 6TH STREET, MACCLENNY 32063

Inspection Date: 08/27/2009

Inspection Number: 1859844

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Stairway

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Bradford County

License Number: 1400157		SONIC DRIVE IN #5185	
License Type: Permanent Food Service		825 N TEMPLE AVE, STARKE 32091	
Inspection Date: 08/24/2009	Inspection Number: 1891486	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DOHERTY, BRENDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. BOXES BLOCKING REAR KITCHEN EXIT	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
License Number: 1400161		WHALE TALES	
License Type: Permanent Food Service		301 E CALL ST, STARKE 32091	
Inspection Date: 08/26/2009	Inspection Number: 1840194	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: DOHERTY, BRENDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 1400209		GRANNIES RESTAURANT	
License Type: Permanent Food Service		367 N TEMPLE AVE, STARKE 32091	
Inspection Date: 08/24/2009	Inspection Number: 1911969	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DOHERTY, BRENDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 1400172		KENTUCKY FRIED CHICKEN	
License Type: Permanent Food Service		640 S WALNUT ST, STARKE 320913949	
Inspection Date: 08/26/2009	Inspection Number: 1917455	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DOHERTY, BRENDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

Brevard County

License Number: 1506133

NEW PEKING BUFFET

License Type: Permanent Food Service

725 N WASHINGTON AVE, TITUSVILLE 32796

Inspection Date: 08/27/2009

Inspection Number: 1917511

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: ZALESKI, AMY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	Violation: 48-12-2 No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Brevard County

License Number: 1504737

GOURMET CHEESE STEAK & PIZZA CO INC

License Type: Permanent Food Service

775 S BABCOCK ST, MELBOURNE 32901

Inspection Date: 08/28/2009

Inspection Number: 1915136

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WOODS, CRYSTAL

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.front pizza line.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.waitstaff area

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1550314

MICKEY BROTHERS BBQ

License Type: Mobile Food Dispensing Vehicle

1301 E UNIVERSITY BLVD., MELBOURNE 32901

Inspection Date: 08/28/2009

Inspection Number: 1134075

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SINGH, GAJENDRA

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.INSIDE

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Brevard County

License Number: 1505632 BEEF O'BRADY'S
 License Type: Permanent Food Service 3450 BAYSIDE LAKE BLVD-SUITE#101, PALM BAY 32909

Inspection Date: 08/25/2009 Inspection Number: 1859326 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WEIMER, EDWIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.the rear dinning exit egress has an illuminated exit sign and a this is not an exit sign on the door	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.a 3 way non fused multi plug is in use at the bar Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1505617 QUIZNO'S SUBS - #3209
 License Type: Permanent Food Service 4350 N. ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 08/25/2009 Inspection Number: 1899135 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MAYNARD, DIANE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed an uncovered electrical box. For reporting purposes only.broken plate cover	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1505905 EAGLE NEST SPORTS BAR & GRILL
 License Type: Permanent Food Service 20 N BREVARD AVE, COCOA BEACH 32931

Inspection Date: 08/24/2009 Inspection Number: 1899093 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: MAYNARD, DIANE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-13-2	Emergency light does not function when tested. For reporting purposes only.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

Brevard County

License Number: 1503730

DISCOVERY BEACH CAFE

License Type: Permanent Food Service

300 BARLOW AVE, COCOA BCH 329313906

Inspection Date: 08/25/2009

Inspection Number: 1868328

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MAYNARD, DIANE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1504733

XINDA

License Type: Permanent Food Service

2186 SARNO RD, MELBOURNE 32935

Inspection Date: 08/28/2009

Inspection Number: 1868150

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WOODS, CRYSTAL

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.by dry storage

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1504812

SARNO RESTAURANT

License Type: Permanent Food Service

2110 SARNO RD, MELBOURNE 32935

Inspection Date: 08/28/2009

Inspection Number: 1837335

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOODS, CRYSTAL

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.dining cafe

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Brevard County

License Number: 1505540 (THE) CHRISTIAN CULINARIAN LLC
 License Type: Catering 2600 AURORA RD #G, MELBOURNE 32935

Inspection Date: 08/21/2009 Inspection Number: 1092773 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOODS, CRYSTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only. Repeat Violation. Corrected On Site.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 1506150 SQUID LIPS OVERWATER GRILL #3
 License Type: Permanent Food Service 1477 PINEAPPLE AVE, MELBOURNE 32935

Inspection Date: 08/27/2009 Inspection Number: 1878394 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WOODS, CRYSTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.1 hood filter missing above char grill.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.1 hood filter missing above char grill.open gaps	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only. Repeat Violation.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Brevard County

License Number: 1501960

ITALY ITALY REST & PIZZERIA

License Type: Permanent Food Service

1934 WICKHAM RD, MELBOURNE 329358106

Inspection Date: 08/26/2009

Inspection Number: 1857890

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOODS, CRYSTAL

Violation Code

Observation

Violation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.back door

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1618985		ISLAMORADA FISH COMPANY	
License Type: Permanent Food Service		220 GULFSTREAM WAY, DANIA BCH 33004	
Inspection Date: 08/25/2009	Inspection Number: 1905493	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 1619708		CASA PERU REST	
License Type: Permanent Food Service		822 W HALLANDALE BLVD, HALLANDALE 33009	
Inspection Date: 08/27/2009	Inspection Number: 1833540	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-07-2	Exit signs missing. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.	

License Number: 1609391		ISLAND JERK INC	
License Type: Permanent Food Service		3159 W HALLANDALE BEACH BLVD, PEMBROKE PARK 33009	
Inspection Date: 08/25/2009	Inspection Number: 1843923	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.k class on floor	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 1618203		OMALLEY'S OCEAN PUB	
License Type: Permanent Food Service		101 N OCEAN DR, HOLLYWOOD 33019	
Inspection Date: 08/26/2009	Inspection Number: 1854122	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1612016 SUBWAY
 License Type: Permanent Food Service 6105 W HOLLYWOOD BLVD, HOLLYWOOD 330247937

Inspection Date: 08/21/2009 Inspection Number: 1874576 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: QUINONES, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. backdoor.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1622287 DON TANGO
 License Type: Permanent Food Service 3424 RED ROAD, MIRAMAR 33025

Inspection Date: 08/28/2009 Inspection Number: 1815475 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VASQUEZ, JANNETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag missing. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 1616283 BIG BURRITO
 License Type: Permanent Food Service 11401 PINES BLVD #508, PEMBROKE PINES 33026

Inspection Date: 08/27/2009 Inspection Number: 1874518 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: VASQUEZ, JANNETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1620673

WALL STREET CAFE

License Type: Permanent Food Service

11401 PINES BLVD #522, PEMBROKE PINES 33026

Inspection Date: 08/27/2009

Inspection Number: 1854032

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: VASQUEZ, JANNETH

Violation CodeObservationViolation Citation

45-36-2 Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

45-36-2 Violation: 45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 1615174

LA BROCHETTE

License Type: Permanent Food Service

2635 N HIATUS RD, COOPER CITY 330261372

Inspection Date: 08/26/2009

Inspection Number: 1894894

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: VASQUEZ, JANNETH

Violation CodeObservationViolation Citation

45-07-2 Observed misalignment of hood suppression system nozzles. For reporting purposes only.

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

License Number: 1621899

STIR CRAZY

License Type: Permanent Food Service

14571 SW 5 ST, PEMBROKE PINES 33027

Inspection Date: 08/25/2009

Inspection Number: 1641962

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: VASQUEZ, JANNETH

Violation CodeObservationViolation Citation

15-28-2 Violation: 15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 1613357

PATS PLACE

License Type: Permanent Food Service

635 E ATLANTIC BLVD, POMPANO BEACH 33060

Inspection Date: 08/24/2009

Inspection Number: 1864994

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: NUTTALL, JOHN

Violation CodeObservationViolation Citation

48-06-2 Observed a gas appliance without proper venting. For reporting purposes only. Cooking equipment not situated under hood system.

61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1620206 MONTGOMERY LOUNGE
 License Type: Permanent Food Service 901 HILLSBORO MILE, POMPANO BEACH 33062

Inspection Date: 08/26/2009 Inspection Number: 1844451 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NUTTALL, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Kitchen side door blocked with chairs	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1617917 CARRABBA'S ITALIAN GRILL
 License Type: Permanent Food Service 2501 UNIVERSITY DR, CORAL SPRINGS 33065

Inspection Date: 08/25/2009 Inspection Number: 1885341 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BECKER, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only. Above deep fat fryer.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY

License Number: 1618995 PEPPERONI GRILL
 License Type: Permanent Food Service 9174 WILES RD, CORAL SPRINGS 33065

Inspection Date: 08/24/2009 Inspection Number: 1875120 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BECKER, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. IN DIREPAIR above kitchen rear exit. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
46-09-2	Violation: 46-09-2 Exit signs not properly illuminated. IN DIREPAIR above kitchen rear exit. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 1618625 VOCELLI PIZZA
 License Type: Permanent Food Service 4618 N UNIVERSITY, CORAL SPRINGS 33067

Inspection Date: 08/28/2009 Inspection Number: 1854676 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BECKER, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. Corrected On Site.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1620087		PALADIUM	
License Type: Permanent Food Service		5688 W SAMPLE RD, MARGATE 33073	
Inspection Date: 08/21/2009	Inspection Number: 1673395	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: DIEHL, TERENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
39-03-2	Violation: 39-03-2 Exhaust system off during the operation of cooking equipment. For reporting purposes only. Corrected On Site.	NFPA 96, 11.1.1 Exhaust systems shall be operated whenever cooking equipment is turned on. For reporting purposes only.	
License Number: 1616933		VICTORIA PARK DINER	
License Type: Permanent Food Service		1730 E SUNRISE BLVD, FORT LAUDERDALE 33304	
Inspection Date: 08/21/2009	Inspection Number: 1875032	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: TORRES, LARRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Violation: 45-38-2 Portable fire extinguisher not fully charged. For reporting purposes only. by 3 compartment sink	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 1610710		RUTHS CHRIS STEAK HOUSE	
License Type: Permanent Food Service		2525 N FEDERAL HWY, FT LAUDERDALE 333051620	
Inspection Date: 08/27/2009	Inspection Number: 1833978	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TORRES, LARRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Broward County

License Number: 1600873 CEDAR'S PALACE
 License Type: Permanent Food Service 4060 GALT OCEAN DR, FORT LAUDERDALE 33308

Inspection Date: 08/24/2009 Inspection Number: 1895538 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MERNO, RAHLIBA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. For Boiler FI053469	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 1619568 LAS ORQUIDEAS
 License Type: Permanent Food Service 5630 N FEDERAL HWY, FORT LAUDERDALE 33308

Inspection Date: 08/25/2009 Inspection Number: 1844327 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MERNO, RAHLIBA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 1618282 M&S BEST TROPICAL RESTAURANT
 License Type: Permanent Food Service 3752 N ANDREWS AVE, OAKLAND PARK 33309

Inspection Date: 08/20/2009 Inspection Number: 1684533 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: SCHNEIDER, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Violation: 45-36-2 Hood suppression system tag out-of-date. For reporting purposes only 10/08.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
45-41-2	Violation: 45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only 4/08.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1618893		JOHNNY'S NY PIZZA	
License Type: Permanent Food Service		3701 N ANDREWS AVE, OAKLAND PARK 33309	
Inspection Date: 08/20/2009	Inspection Number: 1664066	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: SCHNEIDER, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Violation: 46-09-2 Exit signs not properly illuminated. For reporting purposes only front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1614812		LITTLE CAESARS ENT INC #213	
License Type: Permanent Food Service		3031 N ANDREWS AVE, WILTON MANORS 333112517	
Inspection Date: 08/27/2009	Inspection Number: 1854338	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, LYNDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
License Number: 1611602		KENTUCKY FRIED CHICKEN	
License Type: Permanent Food Service		401 W BROWARD BLVD, FT LAUDERDALE 333121741	
Inspection Date: 08/27/2009	Inspection Number: 1895166	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1613225

LITTLE CAESAR PIZZA #233

License Type: Permanent Food Service

3229 W DAVIE BLVD, FT LAUDERDALE 333122755

Inspection Date: 08/24/2009

Inspection Number: 1864544

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1619578

CARLS SEAFOOD REST TAKE OUT

License Type: Permanent Food Service

2934 N SR 7, LAUDERDALE LAKES 33313

Inspection Date: 08/21/2009

Inspection Number: 1917291

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALECIA

Violation CodeObservationViolation Citation

45-27-2

Observed nozzel in misalignment over stove.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1620546

DRAGON VILLAGE

License Type: Permanent Food Service

5567 W OAKLAND PARK BLVD, LAUDERHILL 33313

Inspection Date: 08/27/2009

Inspection Number: 1833922

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, NOVELETTE

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

47-06-2

Observed extension cord in use for non-temporary period, with fliptop reachin cooler. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1621474 CHINA GOURMET
 License Type: Permanent Food Service 5963 W OAKLAND PARK BLVD, LAUDERHILL 33313

Inspection Date: 08/27/2009 Inspection Number: 1864848 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use, in front of cookline. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period, in front of cookline. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1606843 VERDIS ITALIAN REST
 License Type: Permanent Food Service 5521 W OAKLAND PARK BLVD, LAUDERHILL 333131411

Inspection Date: 08/27/2009 Inspection Number: 1895444 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate, by rear door. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1614605 WINGS CHINESE RESTAURANTS
 License Type: Permanent Food Service 3752 SW 64 AVE, DAVIE 33314

Inspection Date: 08/24/2009 Inspection Number: 1843881 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: QUINONES, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. filters in disrepair.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 1613269 BURGER KING #5921
 License Type: Permanent Food Service 3 WESTON RD, SUNRISE 333261110

Inspection Date: 08/28/2009 Inspection Number: 1835199 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DURDEN, VICKIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. break room	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Calhoun County

License Number: 1700104

THE OYSTER BAR & SEAFOOD SHACK

License Type: Permanent Food Service

20003 CENTRAL AVE W, BLOUNTSTOWN 32424

Inspection Date: 08/25/2009

Inspection Number: 1871275

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: HARDING, LINDA

Violation CodeObservationViolation Citation

47-16-2

Electrical circuit breaker box missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1700121

WISTERIA CAFE

License Type: Permanent Food Service

16863 NW CHARLIE JOHN ST, BLOUNTSTOWN 32424

Inspection Date: 08/25/2009

Inspection Number: 1831047

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: HARDING, LINDA

Violation CodeObservationViolation Citation

45-31-2

Violation: 45-31-2

Observed the use of flat griddle producing grease laden vapors/smoke with no hood suppression system or ventilation system installed. Observed buildup of grease, and bacon pieces on griddle. Notified Fire AHJ. For reporting purposes

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

Charlotte County

License Number: 1800328

CHARLOTTE HARBOR YACHT CLUB

License Type: Permanent Food Service

4400 LISTER ST, PORT CHARLOTTE 339529761

Inspection Date: 08/27/2009

Inspection Number: 1872265

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LANDMANN, PAUL

Violation Code

Observation

Violation Citation

49-11-2 Observed flammables and debris stored in laundry room. For reporting purposes only.

61C-1.004(7) FAC (7) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. FOR REPORTING PURPOSES ONLY.

Citrus County

License Number: 1901102

TWO DEUCES

License Type: Permanent Food Service

7452 W GROVER CLEVELAND BLVD, HOMOSASSA 34446

Inspection Date: 08/26/2009

Inspection Number: 1908400

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRAIG, JILL

Violation Code

Observation

Violation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress- bar on rear exit during operating hours. For reporting purposes only. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Clay County

License Number: 2000778

CEDAR RIVER SEAFOOD

License Type: Permanent Food Service

2475 BLANDING BLVD #1, MIDDLEBURG 320685183

Inspection Date: 08/25/2009

Inspection Number: 1917494

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

45-36-2 Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2000957

ROSINNA'S PIZZA

License Type: Permanent Food Service

1580 WELLS ROAD #788, ORANGE PARK 32073

Inspection Date: 08/25/2009

Inspection Number: 1870325

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: D'ANTONIO, JANET

Violation CodeObservationViolation Citation

46-09-2 Front Exit sign not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period; power taps used. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Collier County

License Number: 2101924

SUBWAY

License Type: Permanent Food Service

1590 GOODLETTE ROAD N, NAPLES 34102

Inspection Date: 08/25/2009

Inspection Number: 1903579

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MORRIS, CHARLES

Violation Code

Observation

Violation Citation

49-06-2

Observed flammable material stored around water heater. For reporting purposes only.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2328300 LA FOGATA LATIN GRILL
 License Type: Permanent Food Service 1645 W 49 ST #1376, HIALEAH 33012

Inspection Date: 09/26/2003 Inspection Number: 1144600 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BURROWS, LEON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 2315532 BIG CHEESE OF HOMESTEAD LLC
 License Type: Permanent Food Service 350 N HOMESTEAD BLVD, HOMESTEAD 33030

Inspection Date: 08/20/2009 Inspection Number: 1820168 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 2322864 TARIACURI TAQUERIA
 License Type: Permanent Food Service 1226 N KROME ABE, HOMESTEAD 33030

Inspection Date: 08/24/2009 Inspection Number: 1884483 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2331210

FLAGSHIP CINEMAS INC

License Type: Permanent Food Service

2250 NORTHEAST 8TH STREET, HOMESTEAD 33033

Inspection Date: 08/26/2009

Inspection Number: 1864080

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALFONSO, ARELYS

Violation CodeObservationViolation Citation

45-12-2

Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.

NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.

License Number: 2321273

KENTUCKY FRIED CHICKEN

License Type: Permanent Food Service

232 SE 1 AVE, FLORIDA CITY 330345006

Inspection Date: 08/25/2009

Inspection Number: 1853736

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALFONSO, ARELYS

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

49-12-2

Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only. Corrected On Site.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 2322787

CATCH OF THE DAY

License Type: Permanent Food Service

1050 NW 42 AVE, MIAMI 331263645

Inspection Date: 08/28/2009

Inspection Number: 1853964

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHOW, ZULEIMA

Violation CodeObservationViolation Citation

45-07-2

Observed misalignment of hood suppression system nozzles. For reporting purposes only.

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2325423

POLLO TROPICAL 30

License Type: Permanent Food Service

581 NW 57 AVE, MIAMI 331264812

Inspection Date: 08/26/2009

Inspection Number: 1905367

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHOW, ZULEIMA

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. STORAGE AREA

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2332054

FIVE STAR CAFÉ CONVENIENCE STORE

License Type: Permanent Food Service

753 NW 28 ST, MIAMI 33127

Inspection Date: 08/26/2009

Inspection Number: 1832731

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BLAIR, ANTONIO

Violation CodeObservationViolation Citation

48-11-2

Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only. Corrected On Site.

NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 2328218

SUBWAY COURTHOUSE

License Type: Permanent Food Service

201 NW 1 AVE #A, MIAMI 33128

Inspection Date: 08/26/2009

Inspection Number: 1884147

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROWS, LEON

Violation CodeObservationViolation Citation

46-13-2

Emergency light does not function when tested. For reporting purposes only.

NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2323879		LAS TRES B'S INC	
License Type: Permanent Food Service		801 SW 8 ST, MIAMI 33130	
Inspection Date: 08/24/2009	Inspection Number: 1884029	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: KHAN, MOHAMMAD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 2332288		WAXY OCONNORS	
License Type: Permanent Food Service		690 SW 1ST CT, MIAMI 33130	
Inspection Date: 08/24/2009	Inspection Number: 1914805	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHAN, MOHAMMAD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2332360		VICEROY MIAMI	
License Type: Permanent Food Service		485 BRICKELL AVE 15 & 49 FLOOR, MIAMI 33131	
Inspection Date: 08/26/2009	Inspection Number: 1894032	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEREZ, TONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2317939		MIKES AT VENETIA	
License Type: Permanent Food Service		555 NE 15 ST 9 FLR, MIAMI 331321451	
Inspection Date: 08/26/2009	Inspection Number: 1917276	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: PEREZ, TONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Dade County

License Number: 2325056

COCO GELATO INC

License Type: Permanent Food Service

3015 GRAND AVE, MIAMI 331335144

Inspection Date: 09/08/2006

Inspection Number: 1475412

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BURROWS, LEON

Violation CodeObservationViolation Citation

46-09-1

Exit signs not properly illuminated.

61C-1.004(10) FAC:: Exits shall be clearly marked with approved illuminated exit signs.

47-04-1

Observed frayed/spliced electrical wires.

61C-1.004(11) FAC:: Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 4A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided.

47-07-1

Observed scorch marks around electrical outlet.

61C-1.004(11) FAC:: Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 4A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided.

License Number: 2331771

MORTON'S STEAKHOUSE

License Type: Permanent Food Service

2333 PONCE DE LEON, CORAL GABLES 33134

Inspection Date: 08/21/2009

Inspection Number: 1853340

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROWS, LEON

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2319368

LAS VEGAS RESTAURANT #9

License Type: Permanent Food Service

112 GIRALDA AVE, MIAMI 33134

Inspection Date: 08/24/2009

Inspection Number: 1904729

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROWS, LEON

Violation CodeObservationViolation Citation

45-30-2	No Class K portable fire extinguisher provided for high hazard cooking area (for suppression system/equipment installed after June 30, 1998). For reporting purposes only.	NFPA 10, 4.3.2. and 4.3.2.1 Class K Fire Extinguishers for Cooking Oil Fires. Fire extinguishers provided for the protection of cooking appliances that use combustible cooking media (vegetable or animal oils and fats) shall be listed and labeled for Class K fires. Class K fire extinguishers manufactured after January 1, 2002, shall not be equipped with extended wand-type discharge devices. Fire extinguishers installed specifically for the protection of cooking appliances that use combustible cooking media (animal, vegetable oils and fats) prior to June 30, 1998, shall not be required to comply with 4.3.2. (Also see 4.3.2.3.). FOR REPORTING PURPOSES ONLY.
45-35-2	No current hood fire suppression system inspection report available. For reporting purposes only.	NFPA 1, 13.1.5 and 10.2.2 Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and shall be made available upon request for review by the AHJ. The AHJ shall be permitted to require the owner, operator, or occupant to provide tests or test reports, without expense to the AHJ, as proof of compliance with the intent of this Code. FOR REPORTING PURPOSES ONLY.
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only. not properly installed	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 2328050

ADELETA CAFE

License Type: Permanent Food Service

100 SW 17 AVE, MIAMI 33135

Inspection Date: 08/24/2009

Inspection Number: 1832473

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: GARCIA, BARBARO

Violation CodeObservationViolation Citation

15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.
---------	---	--

Dade County

License Number: 2331269 BOTECO
 License Type: Permanent Food Service 916 NE 79TH ST, MIAMI 33138

Inspection Date: 08/21/2009 Inspection Number: 1862949 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-35-2	No current hood fire suppression system inspection report available. For reporting purposes only.	NFPA 1, 13.1.5 and 10.2.2 Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and shall be made available upon request for review by the AHJ. The AHJ shall be permitted to require the owner, operator, or occupant to provide tests or test reports, without expense to the AHJ, as proof of compliance with the intent of this Code. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2330276 GELATO'S PARADISE
 License Type: Permanent Food Service 600 OCEAN DRIVE, MIAMI BEACH 33139

Inspection Date: 08/24/2009 Inspection Number: 1883349 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RICHARD, DICKSON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-30-2	No Class K portable fire extinguisher provided for high hazard cooking area (for suppression system/equipment installed after June 30, 1998). For reporting purposes only.	NFPA 10, 4.3.2. and 4.3.2.1 Class K Fire Extinguishers for Cooking Oil Fires. Fire extinguishers provided for the protection of cooking appliances that use combustible cooking media (vegetable or animal oils and fats) shall be listed and labeled for Class K fires. Class K fire extinguishers manufactured after January 1, 2002, shall not be equipped with extended wand-type discharge devices. Fire extinguishers installed specifically for the protection of cooking appliances that use combustible cooking media (animal, vegetable oils and fats) prior to June 30, 1998, shall not be required to comply with 4.3.2. (Also see 4.3.2.3.). FOR REPORTING PURPOSES ONLY.
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2330376 GO-GO
 License Type: Permanent Food Service 926 ALTON RD, MIAMI BEACH 33139

Inspection Date: 08/25/2009 Inspection Number: 1903957 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RICHARD, DICKSON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-12-2	Emergency lighting illumination insufficient. For reporting purposes only.	NFPA 101, 7.9.2.1 Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 foot-candle and, at any point, not less than 0.1 foot-candles, measured along the path of egress at floor level. FOR REPORTING PURPOSES ONLY.

License Number: 2331570 CJ'S CRAB SHACK
 License Type: Permanent Food Service 600 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 08/24/2009 Inspection Number: 1883361 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RICHARD, DICKSON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2321803 LARIOS ON THE BEACH
 License Type: Permanent Food Service 820 OCEAN DR, MIAMI BEACH 331395801

Inspection Date: 08/25/2009 Inspection Number: 1862865 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RICHARD, DICKSON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use at bar area. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2327551

CASANOVA RESTAURANT

License Type: Permanent Food Service

3010 COLLINS AVE, MIAMI 33140

Inspection Date: 08/25/2009

Inspection Number: 1904057

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIARTE, DENNIS

Violation Code

Observation

Violation Citation

48-12-2 No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2324805 CREEK 28
 License Type: Permanent Food Service 2727 INDIAN CREEK DRIVE, MIAMI BEACH 33140

Inspection Date: 08/25/2009 Inspection Number: 1852640 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 2328550 VERSAILLES CAFE INC
 License Type: Permanent Food Service 3425 COLLINS AVE #C5, MIAMI BEACH 33140

Inspection Date: 08/27/2009 Inspection Number: 1883447 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2330584 CIRCA 39
 License Type: Permanent Food Service 3900 COLLINS AVENUE, MIAMI BEACH 33140

Inspection Date: 08/28/2009 Inspection Number: 1852652 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-2	Boiler certificate not posted in boiler room. For reporting purposes only.	69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2332002

CAFE CHUNG KING

License Type: Permanent Food Service

1250 NW 54 STREET, MIAMI 33142

Inspection Date: 08/26/2009

Inspection Number: 1843135

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DE LOS SANTOS, JUAN

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2316945

CLUB PINK PUSSY CAT

License Type: Permanent Food Service

3890 NW 36 ST, MIAMI 331424918

Inspection Date: 08/25/2009

Inspection Number: 1894299

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURROWS, LEON

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2325455

FLAGLER CHARBROILED BURGERS & CHICKEN

License Type: Permanent Food Service

7795 W FLAGLER ST #58, MIAMI 33144

Inspection Date: 08/24/2009

Inspection Number: 1916767

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STERLING, DANIEL

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. ABC EXTINGUISHER IN KITCHEN .

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2326774		KELLYS ICE CREAM	
License Type: Permanent Food Service		7795 W FLAGLER ST, MIAMI 33144	
Inspection Date: 08/25/2009	Inspection Number: 1843180	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: STERLING, DANIEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Violation: 45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 2330113		LA QUINTA CAFETERIA BBQ	
License Type: Permanent Food Service		7830 SW 24TH STREET, MIAMI 33155	
Inspection Date: 08/27/2009	Inspection Number: 1904921	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	

License Number: 2330763		CASA LATIN CAFE	
License Type: Permanent Food Service		8169 SW 40TH STREET, MIAMI 33155	
Inspection Date: 08/27/2009	Inspection Number: 1874022	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

Dade County

License Number: 2301436 HAVANA SPICE CAFE
 License Type: Permanent Food Service 9050 S DIXIE HWY, KENDALL 33156

Inspection Date: 08/26/2009 Inspection Number: 1874110 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2323259 ROASTERS & TOASTERS
 License Type: Permanent Food Service 9465 S DIXIE HWY, MIAMI 331562933

Inspection Date: 04/22/2009 Inspection Number: 1713141 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: VALDERRAMA, ELISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2330684 MIAMI WINGS SPORT BAR CORP
 License Type: Permanent Food Service 19401 S DIXIE HWY, CUTLER BAY 33157

Inspection Date: 08/25/2009 Inspection Number: 1843363 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2300670

COOPER'S

License Type: Permanent Food Service

16701 SOUTH DIXIE HWY, MIAMI 33157

Inspection Date: 08/28/2009

Inspection Number: 1863952

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. with a rolling cart

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2322852

TACO BELL # 25740

License Type: Permanent Food Service

15295 S DIXIE HWY, MIAMI 33157

Inspection Date: 08/28/2009

Inspection Number: 1833019

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

15-25-2

Hood filters not equipped with a drip tray. For reporting purposes only.

NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

License Number: 2328546

RUSH HOUR SMOOTHIES

License Type: Permanent Food Service

16051 SOUTH DIXIE HWY, MIAMI 33157

Inspection Date: 08/28/2009

Inspection Number: 1843329

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2332153

POLLO CAMPERO RESTAURANT

License Type: Permanent Food Service

18660 S DIXIE HWY, MIAMI 33157

Inspection Date: 08/27/2009

Inspection Number: 1874116

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2316700 GRAND CHINA RESTAURANT
 License Type: Permanent Food Service 18643 S DIXIE HWY, MIAMI 331576804

Inspection Date: 08/26/2009 Inspection Number: 1874086 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2324736 BOSTON MARKET #0190
 License Type: Permanent Food Service 18601 S DIXIE HWY, MIAMI 331576804

Inspection Date: 08/26/2009 Inspection Number: 1833045 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.backdoor with garbage container	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2324017 POLLO TROPICAL 5
 License Type: Permanent Food Service 18670 S DIXIE HWY, MIAMI 331576805

Inspection Date: 08/27/2009 Inspection Number: 1833041 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2315594 CHINA GATE
 License Type: Permanent Food Service 19349 S DIXIE HWY, MIAMI 331577603

Inspection Date: 08/25/2009 Inspection Number: 1874084 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2318719		CHURCHS CHICKEN #1542	
License Type: Permanent Food Service		21595 S DIXIE HWY, MIAMI 33170	
Inspection Date: 08/26/2009	Inspection Number: 1894746	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROWN, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 2327078		FRITANGA EL VOLCAN	
License Type: Permanent Food Service		11865 SW 26 STREET SUITE A8, MIAMI 33175	
Inspection Date: 08/24/2009	Inspection Number: 1853518	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEREZ, TONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2315305		WENDYS INTL #1701-142	
License Type: Permanent Food Service		13901 S DIXIE HWY, MIAMI 331767234	
Inspection Date: 08/27/2009	Inspection Number: 1833087	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VALDERRAMA, ELISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
39-05-2	Ventilation inadequate as evidenced by smoke in kitchen area. For reporting purposes only.	NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY	
License Number: 2319647		RESTAURANT & CAFETERIA EL GALLO PINTO	
License Type: Permanent Food Service		13037 SW 112TH STREET, MIAMI 33186	
Inspection Date: 08/25/2009	Inspection Number: 1874128	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: VALDERRAMA, ELISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not properly charged. For reporting purposes only. class k	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Dade County

License Number: 2330569 EL MESON DEL PARAISO RESTAURANT
 License Type: Permanent Food Service 12820 SW 120 ST, MIAMI 33186

Inspection Date: 04/16/2008 Inspection Number: 1566618 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MARQUEZ, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-1	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge.	NFPA 96, 11.4.2:: Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge.
45-35-1	No current hood fire suppression system inspection report available.	NFPA 1, 13.1.5 and 10.2.2:: Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and shall be made available upon request for review by the AHJ. The AHJ shall be permitted to require the owner, operator, or occupant to provide tests or test reports, without expense to the AHJ, as proof of compliance with the intent of this Code.
45-36-1	Hood suppression system tag out-of-date.	NFPA 96, 11.2.1:: An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons.
47-13-1	Circuit breaker box blocked and/or inaccessible.	NFPA 70, 110.32:: Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels.
47-15-1	Observed an uncovered electrical box.by prep area.	NFPA 70, 300.31:: Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation.

License Number: 2322633 SUBWAY
 License Type: Permanent Food Service 14679 SW 104 ST, MIAMI 331862977

Inspection Date: 08/24/2009 Inspection Number: 1833089 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VALDERRAMA, ELISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2612325 QIU SUSHI ROCK
 License Type: Permanent Food Service 1950 SAN MARCO BLVD SUITE #1, JACKSONVILLE 32207

Inspection Date: 08/25/2009 Inspection Number: 1911533 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. K class	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 2612095 GOLDEN EGGROLL
 License Type: Permanent Food Service 7412 LEM TURNER RD, JACKSONVILLE 32208

Inspection Date: 08/27/2009 Inspection Number: 1917695 Inspection Type: Complaint Partial Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, DERRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 2612110 CRAB HUT
 License Type: Permanent Food Service 7208 LEM TURNER RD, JACKSONVILLE 32208

Inspection Date: 03/15/2005 Inspection Number: 1154854 Inspection Type: Complaint Full Inspection Disposition: Emergency order recommended
 Inspector Name: RIVERA, STEVEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair
49	Out of compliance: Flammable/combustible materials - properly stored	NFPA 101, 96, 10 Flammable/combustible materials - properly stored

License Number: 2609609 KFC
 License Type: Permanent Food Service 2258 W EDGEWOOD AVE, JACKSONVILLE 32209

Inspection Date: 08/25/2009 Inspection Number: 1881236 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2611869 SUBWAY
 License Type: Permanent Food Service 2261 W EDGEWOOD AVE #9, JACKSONVILLE 32209

Inspection Date: 08/25/2009 Inspection Number: 1911901 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2612203 57 AVENUE
 License Type: Permanent Food Service 5577 AVE B, JACKSONVILLE 32209

Inspection Date: 08/21/2009 Inspection Number: 1881256 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. FIRE EXTINGUISHER ON KITCHEN FLOOR.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only, BAR.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only, ELECTICAL OUTLET HANGING BY WIRE/ STORAGE ROOM.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
49-02-2	Observed gas-powered equipment containing gas stored inside the establishment. For reporting purposes only, STORAGE ROOM.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 2614284 TACO BELL
 License Type: Permanent Food Service 5875 NEW KINGS ROAD, JACKSONVILLE 32209

Inspection Date: 08/25/2009 Inspection Number: 1870937 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes onl, REAR DOOR.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2607795

JENKIN'S QUALITY BAR B Q

License Type: Permanent Food Service

5945 NEW KINGS RD, JACKSONVILLE 322092126

Inspection Date: 08/25/2009

Inspection Number: 1850583

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVIS, MOSES

Violation CodeObservationViolation Citation

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only,
BLOCKED BY BOXES;NFPA 70, 110.32 Work Space about Equipment.
Sufficient space shall be provided and maintained about
electrical equipment to permit ready and safe operation
and maintenance of such equipment. In all cases, the
work space shall be adequate to permit at least a
90-degree opening of doors or hinged panels. FOR
REPORTING PURPOSES ONLY.

License Number: 2613751

LANE FISH MARKET & SEAFOOD TAKE-OUT

License Type: Permanent Food Service

1523 S LANE AVE, JACKSONVILLE 32210

Inspection Date: 08/26/2009

Inspection Number: 1831000

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

45-07-2

Violation: 45-07-2

Observed misalignment of hood suppression system nozzles. For reporting
purposes only.
large one eye gas burnerNFPA 96, 10.2 Automatic fire-extinguishing systems
shall be installed in accordance with the terms of their
listing, the manufacturer's instructions, and the following
standards where applicable. (1) NFPA 12, Standard on
Carbon Dioxide Extinguishing Systems (2) NFPA 13,
Standard for the Installation of Sprinkler Systems (3)
NFPA 17, Standard for Dry Chemical Extinguishing
Systems (4) NFPA 17A, Standard for Wet Chemical
Extinguishing Systems. FOR REPORTING
PURPOSES ONLY.

License Number: 2613950

HAM'S RESTAURANT

License Type: Permanent Food Service

4530 ST JOHNS AVE, JACKSONVILLE 32210

Inspection Date: 08/26/2009

Inspection Number: 1891358

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For
reporting purposes only.NFPA 96, 6.2.3.3 Grease filters shall be arranged so
that all exhaust air shall pass through the grease filters.
For reporting purposes only.

Duval County

License Number: 2612016

FONTANA

License Type: Permanent Food Service

7605 BEACH BLVD, JACKSONVILLE 32216

Inspection Date: 08/27/2009

Inspection Number: 1891020

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. lost one, hood over stove

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. plant and container on hallway by men restroom

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

47-16-2 Electrical outlet missing cover plate. For reporting purposes only. behind tea and coffee maker

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2612952

HAPPY WOK

License Type: Permanent Food Service

8595 BEACH BLVD #348, JACKSONVILLE 32216

Inspection Date: 08/27/2009

Inspection Number: 1911531

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-22-2 Portable fire extinguisher(s) obstructed from view. For reporting purposes only. Silver- K class- blocked with shelf by back door

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

License Number: 2607845

WOODY'S BAR B-Q

License Type: Permanent Food Service

1638 S UNIVERSITY BLVD, JACKSONVILLE 322168927

Inspection Date: 08/30/2004

Inspection Number: 1275533

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BRADSHAW, BONNIE

Violation CodeObservationViolation Citation

45-10 Observed portable extinguisher with tag out-of-date./6/03 This violation must be corrected by : 9/13/04.

NFPA 10, 4-4.1 Extinguishers shall be subjected to maintenance, not more than one year apart.

45-17 Observed hood suppression system tag out-of-date. This violation must be corrected by : 9/13/04.

NFPA 96, 8-2 Inspection. An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons.

Duval County

License Number: 2612395 PABLO CREEK CLUB
 License Type: Permanent Food Service 5660 SAN PABLO RD S, JACKSONVILLE 32224

Inspection Date: 08/19/2009 Inspection Number: 1871069 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: STOREY, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2612150 STEAK N SHAKE #310
 License Type: Permanent Food Service 9560 N REGENCY SQ BLVD, JACKSONVILLE 32225

Inspection Date: 08/24/2009 Inspection Number: 1850417 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, DERRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. on management desk	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2612961 KFC #Y309010
 License Type: Permanent Food Service 9551 REGENCY SQ BLVD N, JACKSONVILLE 32225

Inspection Date: 08/24/2009 Inspection Number: 1850421 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, DERRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. K-class	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2609764 CATTLEMENS REAL PIT BBQ
 License Type: Permanent Food Service 10916 ATLANTIC BLVD #24, JACKSONVILLE 322252900

Inspection Date: 08/24/2009 Inspection Number: 1911809 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: CARANGIAN, REYNALDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2612822 CASTILLO DE MEXICO
 License Type: Permanent Food Service 1222 S 3 ST, JACKSONVILLE BCH 32250

Inspection Date: 04/12/2005 Inspection Number: 1155143 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: TUCKER, CATHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01	Observed current hood suppression nozzles not properly centered over two 1 eye burners.	61C-1.004(5) FAC All fire safety, protection and prevention equipment must be installed, approved, maintained and used in accordance with Chapter 509, FS, and the National Fire Protection Association Life Safety Code Chapter 101, as adopted by the Division of State Fire Marshal in Chapter 4A-3, FAC.
45-01	Observed current hood suppression system lists violations. Improper coverage.	61C-1.004(5) FAC All fire safety, protection and prevention equipment must be installed, approved, maintained and used in accordance with Chapter 509, FS, and the National Fire Protection Association Life Safety Code Chapter 101, as adopted by the Division of State Fire Marshal in Chapter 4A-3, FAC.

License Number: 2613620 ELEVEN SOUTH
 License Type: Permanent Food Service 216 11 AVE S, JACKSONVILLE BEACH 32250

Inspection Date: 08/26/2009 Inspection Number: 1850485 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CARANGIAN, REYNALDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.

License Number: 2607836 DENNY'S #8005
 License Type: Permanent Food Service 8215 DIX ELLIS TR, JACKSONVILLE 32256

Inspection Date: 08/27/2009 Inspection Number: 1822437 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TUCKER, CATHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. k class Repeat Violation.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2611979		WASABI SUSHI AND TEMPURA	
License Type: Permanent Food Service		10300 SOUTHSIDE BLVD #312, JACKSONVILLE 32256	
Inspection Date: 08/25/2009	Inspection Number: 1831318	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: TUCKER, CATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2610176		LEE'S SANDWICH SHOPPE BACKSTRE	
License Type: Permanent Food Service		7933 BAYMEADOWS WAY #8, JACKSONVILLE 322567514	
Inspection Date: 08/27/2009	Inspection Number: 1860104	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TUCKER, CATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only. on floor blocked by mopbucket	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 2614200		SHELBY'S COFFEE SHOPPE	
License Type: Permanent Food Service		200 1ST ST, NEPTUNE BEACH 32266	
Inspection Date: 08/24/2009	Inspection Number: 1891290	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Escambia County

License Number: 2705325		CJ'S KITCHEN & GRILLE	
License Type: Permanent Food Service		2100 W GARDEN, PENSACOLA 32501	
Inspection Date: 05/05/2003	Inspection Number: 1103651	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: UNDEFINED, INSPECTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 2705735		CHINA WOK	
License Type: Permanent Food Service		1517 W CERVANTES, PENSACOLA 32501	
Inspection Date: 08/25/2009	Inspection Number: 1851389	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable k class fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 2705467		JACKSON'S	
License Type: Permanent Food Service		400 S PALAFOX ST, PENSACOLA 32502	
Inspection Date: 08/25/2009	Inspection Number: 1840981	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-07-2	Observed buildup of grease on hood filters. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.	
License Number: 2702711		APPLEBEE'S	
License Type: Permanent Food Service		5091 BAYOU BLVD, PENSACOLA 325032523	
Inspection Date: 08/19/2009	Inspection Number: 1917232	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable ABC fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 2702614		TASTE OF INDIA PNS	
License Type: Permanent Food Service		7601 SCENIC HWY, PENSACOLA 32504	
Inspection Date: 08/19/2009	Inspection Number: 1916841	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Escambia County

License Number: 2704967 KENTUCKY FRIED CHICKEN #426
 License Type: Permanent Food Service 5080 N 9 AVE, PENSACOLA 325048720

Inspection Date: 08/24/2009 Inspection Number: 1861573 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RILEY, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-07-2	Observed missing hood filters. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

License Number: 2702603 TACO BELL # 23757
 License Type: Permanent Food Service 8088 N DAVIS HWY, PENSACOLA 32514

Inspection Date: 08/21/2009 Inspection Number: 1891660 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CROWLEY, RUSSELL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2706032 GARDEN INN & SUITES
 License Type: Permanent Food Service 8500 PINE FOREST RD, PENSACOLA 32534

Inspection Date: 08/27/2009 Inspection Number: 1912085 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WINN, RONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected in the service kitchen. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

Franklin County

License Number: 2901143

WICKED WILLIE'S

License Type: Permanent Food Service

600 MARINE ST, CARRABELLE 32322

Inspection Date: 08/27/2009

Inspection Number: 1882010

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DODSON, FRED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.bar	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.kitchen	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.men restroom	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Hamilton County

License Number: 3400155

SUWANNEE RIVER DINER

License Type: Permanent Food Service

16538 SPRING ST, WHITE SPGS 32096

Inspection Date: 04/10/2003

Inspection Number: 1098272

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: VON BODUNGEN, STEVEN

Violation Code

Observation

Violation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Hendry County

License Number: 3600002

CLEWISTON INN COLONIAL DINING ROOM

License Type: Permanent Food Service

108 ROYAL PALM AVE, CLEWISTON 33440

Inspection Date: 08/11/2009

Inspection Number: 1827883

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

48-12-2

Violation: 48-12-2

No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Hernando County

License Number: 3700903

HAMPTON INN BROOKSVILLE FL

License Type: Permanent Food Service

30301 CORTEZ BLVD, BROOKSVILLE 34602

Inspection Date: 08/26/2009

Inspection Number: 1836685

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DANCHO, JOHN

Violation CodeObservationViolation Citation

48-21-1

No carbon monoxide sensor device located in a gas boiler room in a building which also contains sleeping rooms.

Boiler Information: Boiler Jurisdiction Number: FL 051377 / FL 051378, Boiler Expiration Date: 04/14/2011

509.211(5) FS Every enclosed space or room that contains a boiler regulated under chapter 554 which is fired by the direct application of energy from the combustion of fuels and that is located in any portion of a public lodging establishment that also contains sleeping rooms shall be equipped with one or more carbon monoxide sensor devices that bear the label of a nationally recognized testing laboratory and have been tested and listed as complying with the most recent Underwriters Laboratories, Inc., Standard 2034, or its equivalent, unless it is determined that carbon monoxide hazards have otherwise been adequately mitigated as determined by the division.

License Number: 3701001

CHESAPEAKE BAY CRABHOUSE

License Type: Permanent Food Service

3095 ANDERSON SNOW RD, SPRING HILL 34609

Inspection Date: 08/26/2009

Inspection Number: 1846985

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

15-28-2

Violation: 15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Powering bread warmer.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Powering bread warmer.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3911192		CODY'S ORIGINAL ROADHOUSE	
License Type: Permanent Food Service		1414 W BRANDON BLVD, BRANDON 33511	
Inspection Date: 08/24/2009	Inspection Number: 1866792	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment. For reporting purposes only. Corrected On Site.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	

License Number: 3911459		FUEGO	
License Type: Permanent Food Service		1721 BRANDON BLVD, BRANDON 33511	
Inspection Date: 08/24/2009	Inspection Number: 1846289	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LEWIS, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 3915533		DOWN TO THE BONE BBQ	
License Type: Permanent Food Service		110 SOUTH KING'S AVE, BRANDON 33511	
Inspection Date: 08/24/2009	Inspection Number: 1897541	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3916315 SAIGON CORNER
 License Type: Permanent Food Service 518 OAKFIELD DR, BRANDON 33511

Inspection Date: 08/28/2009 Inspection Number: 1866756 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, RICKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 3904216 JESSES
 License Type: Permanent Food Service 524 W BRANDON BLVD, BRANDON 335115004

Inspection Date: 08/25/2009 Inspection Number: 1887223 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, RICKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3915520 LITTLE CAESARS #6166
 License Type: Permanent Food Service 1246 STATE RD. 60, BRANDON 33511-5529

Inspection Date: 08/26/2009 Inspection Number: 1877088 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, RICKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 3910382 POPEYES CHICKEN & BISCUITS#101
 License Type: Permanent Food Service 2005 S FRONTAGE RD, PLANT CITY 335662055

Inspection Date: 08/24/2009 Inspection Number: 1836343 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BOWEN, JEFFREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only. Cover the opening (labelled "Fryer 3") in the main electrical box.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3916050

JAIMES EL MEXICANO

License Type: Permanent Food Service

329 N US HWY 41 BLDG 115, RUSKIN 33570

Inspection Date: 08/24/2009

Inspection Number: 1867278

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3905611

APOLLO FAMILY RESTAURANT

License Type: Permanent Food Service

6046 FLAMINGO DR, APOLLO BCH 33572

Inspection Date: 08/27/2009

Inspection Number: 1867298

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3951463

LOS GORDITOS

License Type: Mobile Food Dispensing Vehicle

9613 US 301 S, RIVERVIEW 33578

Inspection Date: 08/21/2009

Inspection Number: 1138527

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BOWEN, JEFFREY

Violation CodeObservationViolation Citation

45-41-2

Portable fire extinguisher tag out-of-date. For reporting purposes only. Fire extinguishers must be serviced and tagged.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3916249

GALLAGHER'S STEAKHOUSE

License Type: Permanent Food Service

615 CHANNELSIDE DR #203, TAMPA 33602

Inspection Date: 08/27/2009

Inspection Number: 1877944

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 3912103

EL RINCON MEXICANO RESTAURANTE

License Type: Permanent Food Service

4907 N ARMENIA AVE, TAMPA 33603

Inspection Date: 08/27/2009

Inspection Number: 1847211

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.front door

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only. bar

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912191

CAFE LINH

License Type: Permanent Food Service

8502 N ARMENIA AVE #3A, TAMPA 33604

Inspection Date: 08/26/2009

Inspection Number: 1857516

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912947 KFC PIZZA HUT
 License Type: Permanent Food Service 8201 FLORIDA AVE, TAMPA 33604

Inspection Date: 08/27/2009 Inspection Number: 1917444 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

License Number: 3912992 JALAPENOS DE YBOR
 License Type: Permanent Food Service 1604 N 17 ST, TAMPA 33605

Inspection Date: 08/25/2009 Inspection Number: 1916971 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: OGDEN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.resting on floor.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3916303

YBOR CIGARS PLUS

License Type: Permanent Food Service

1725 E 7 AVE, TAMPA 33605

Inspection Date: 08/25/2009

Inspection Number: 1867294

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.resting on kitchen floor

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.kitchen.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3916685

JAMES JOYCE IRISH PUB

License Type: Permanent Food Service

1704.5 E 7TH AVE, TAMPA 33605

Inspection Date: 08/26/2009

Inspection Number: 1917342

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-16-2 Electrical outlet missing cover plate. For reporting purposes only.kitchen

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3904002

TONYS YBOR RESTAURANT

License Type: Permanent Food Service

2001 N 22 ST, TAMPA 336053953

Inspection Date: 08/25/2009

Inspection Number: 1908296

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.behind front counter.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3910842

MANGROVES

License Type: Permanent Food Service

208 S HOWARD AVE, TAMPA 336061727

Inspection Date: 08/26/2009

Inspection Number: 1847135

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. kitchen by steamtables

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

48-13-2

Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.

NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.

License Number: 3905427

THE PALM CAFE

License Type: Permanent Food Service

2502 ROCKY POINT DR, TAMPA 33607

Inspection Date: 08/24/2009

Inspection Number: 1830946

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: MIRABELLA, FRANK

Violation CodeObservationViolation Citation

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. coole

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3907002		CRABBY BILL'S	
License Type: Permanent Food Service		7700 COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607	
Inspection Date: 08/24/2009	Inspection Number: 1876910	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. back line	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 3910983		GREEN IGUNANA AT NORTH WESTSHORE	
License Type: Permanent Food Service		1200 NORTH WESTSHORE BLVD, TAMPA 33607	
Inspection Date: 08/25/2009	Inspection Number: 1897351	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 3912693		SUKI HANA	
License Type: Permanent Food Service		2223 N WESTSHORE BLVD FC205, TAMPA 33607	
Inspection Date: 08/25/2009	Inspection Number: 1897339	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 3916031		EARL OF SANDWICH	
License Type: Permanent Food Service		2223 N WESTSHORE BLVD, INTERNATIONAL PLAZA, TAMPA 33607	
Inspection Date: 08/25/2009	Inspection Number: 1835861	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. abc	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 3910337		BIN 27 BISTRO	
License Type: Permanent Food Service		2702 W KENNEDY BLVD, TAMPA 33609	
Inspection Date: 08/27/2009	Inspection Number: 1866912	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. in disrepair in dry storage area.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3916131		SPOONTINI	
License Type: Permanent Food Service		5404 CYPRESS CENTER DR, TAMPA 33609	
Inspection Date: 08/25/2009	Inspection Number: 1917348	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 3907355		34 ST SEAFOOD MARKET & RESTAURANT	
License Type: Permanent Food Service		3322 E HILLSBOROUGH AVE, TAMPA 33610	
Inspection Date: 08/24/2009	Inspection Number: 1878050	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETERSON, DOUGLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 3911072		TOP CHINA INC	
License Type: Permanent Food Service		2525 E HILLSBOURGH AVE, TAMPA 33610	
Inspection Date: 08/26/2009	Inspection Number: 1878026	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: PETERSON, DOUGLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3951285

CHURROMAN

License Type: Mobile Food Dispensing Vehicle

11612 NEBRASKA AVE., TAMPA 33612

Inspection Date: 08/28/2009

Inspection Number: 1137167

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DORSEY, KATHY

Violation CodeObservationViolation Citation

45-39-2

Portable k class fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 3910636

T G I FRIDAYS

License Type: Permanent Food Service

2501 E FOWLER AVE, TAMPA 336126270

Inspection Date: 08/26/2009

Inspection Number: 1897457

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EDMISTON, ROBERT

Violation CodeObservationViolation Citation

15-28-2

Hood filters are missing - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 3911144

CODYS ORIGINAL ROADHOUSE

License Type: Permanent Food Service

2836 E BEARSS AVE, TAMPA 33613

Inspection Date: 08/27/2009

Inspection Number: 1908654

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-41-2

Portable fire extinguisher tag out-of-date. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only.(beverage walk in cooler)

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 3915678

HAPPI WOK

License Type: Permanent Food Service

13606 UNIVERSITY PLAZA, TAMPA 33613

Inspection Date: 08/27/2009

Inspection Number: 1898375

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

45-03-2

Observed clearance between sprinkler head and top of storage less than 18 inches. For reporting purposes only.(above walk in cooler)

NFPA 13, 5.5.6 The clearance between the deflector and the top of storage shall be 18 inches or greater. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3916318		MR DUNDERBAKS	
License Type: Permanent Food Service		14929 BRUCE B DOWNS BLVD, TAMPA 33613	
Inspection Date: 08/26/2009	Inspection Number: 1847107	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 3905070		MCDONALDS #6295	
License Type: Permanent Food Service		104 W BEARSS AVENUE, TAMPA 336131240	
Inspection Date: 08/27/2009	Inspection Number: 1877902	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only. Repeat Violation.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.	
License Number: 3903840		ABC PIZZA HSE	
License Type: Permanent Food Service		13508 UNIVERSITY PLAZA, TAMPA 336134628	
Inspection Date: 08/24/2009	Inspection Number: 1877908	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. (beverage area)	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 3906942		TACO BELL #3663	
License Type: Permanent Food Service		2031 E BEARRS AVE, TAMPA 336135566	
Inspection Date: 08/26/2009	Inspection Number: 1816908	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-27-2	Portable fire extinguisher blocked/not easily accessible. For reporting purposes only. on front counter	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3904972

AVILA GOLF & COUNTRY CLUB

License Type: Permanent Food Service

943 GUI SANDO DE AVILA, TAMPA 336139969

Inspection Date: 08/27/2009

Inspection Number: 1898385

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 3910634

LEONI'S ITALIAN PIZZA

License Type: Permanent Food Service

7013 N HIMES AVE, TAMPA 33614

Inspection Date: 08/24/2009

Inspection Number: 1917277

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DORSEY, KATHY

Violation CodeObservationViolation Citation

15-24-2

Hood filters are missing . For reporting purposes only.

NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

48-06-2

Observed a gas water heater without proper tools for access b0ltd enclosure . For reporting purposes only.

61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912268

GINZA JAPANESE STEAKHOUSE

License Type: Permanent Food Service

8104 W WATERS AVE, TAMPA 33615

Inspection Date: 08/25/2009

Inspection Number: 1907680

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DORSEY, KATHY

Violation CodeObservationViolation Citation

46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.in dining room.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3910302

LUPTON'S BANQUET CENTRE

License Type: Permanent Food Service

5299 E BUSCH BLVD, TEMPLE TERR 336175403

Inspection Date: 08/25/2009

Inspection Number: 1866726

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EDMISTON, ROBERT

Violation CodeObservationViolation Citation

49-12-2	Observed 20# propane container in rear smoker room. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.
---------	--	--

Hillsborough County

License Number: 3915971		WINSTOP - SOUTH TAMPA	
License Type: Permanent Food Service		1155 S DALE MABRY HWY #3, TAMPA 33629	
Inspection Date: 08/27/2009	Inspection Number: 1846423	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 3906566		TACO BELL # 3272	
License Type: Permanent Food Service		7325 W WATERS AVE, TAMPA 33634	
Inspection Date: 08/25/2009	Inspection Number: 1835917	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 3906569		EUREST DINING @ VERIZON TECH CENTER	
License Type: Permanent Food Service		1 E TELECOM PARKWAY, TAMPA 33637	
Inspection Date: 08/26/2009	Inspection Number: 1867640	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-03-2	Observed clearance between sprinkler head and top of storage less than 18 inches. For reporting purposes only.(paper supply storeroom)	NFPA 13, 5.5.6 The clearance between the deflector and the top of storage shall be 18 inches or greater. FOR REPORTING PURPOSES ONLY.	
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only.(deep fryers)	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.	
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only.(walk in coolers) Repeat Violation.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3916127

TAMARIND TREE CAFE

License Type: Permanent Food Service

8875 HIDDEN RIVER PKWY #125, TAMPA 33637

Inspection Date: 08/26/2009

Inspection Number: 1867634

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. Repeat Violation.3

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3911427

HUNGRY HOWIES PIZZA & SUBS

License Type: Permanent Food Service

15359 AMBERLY DR, TAMPA 33647

Inspection Date: 08/24/2009

Inspection Number: 1908618

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

45-40-2 Portable fire extinguisher with no approved inspection tag. For reporting purposes only.

61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

47-16-2 Electrical outlet with broken cover plate. For reporting purposes only.(back kitchen)

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3911806

CHICK FIL A

License Type: Permanent Food Service

17513 BRUCE B DOWNS, TAMPA 33647

Inspection Date: 08/25/2009

Inspection Number: 1847075

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only. (by drivethru window) Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912034

FUSHIA ASIAN BISTRO

License Type: Permanent Food Service

15317 AMBERLY DR, TAMPA 33647

Inspection Date: 08/26/2009

Inspection Number: 1888064

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.(kitchen)

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Indian River County

License Number: 4101296 TUBBY'S ALL AMERICAN SUBS & BAGELS
 License Type: Permanent Food Service 5212 AVIATION BLVD, VERO BEACH 32960

Inspection Date: 08/26/2009 Inspection Number: 1888642 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. /a/c unit in the front area For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period./tall reach in cooler For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period./fan sandwich line For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 4105150 HOME 4 DINNER LLC
 License Type: Permanent Food Service 1561 OLD DIXIE HWY, VERO BEACH 32960

Inspection Date: 08/27/2009 Inspection Number: 1909050 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period./by 3 compartment sink For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Indian River County

License Number: 4105176

ROSEMARYS CAFE

License Type: Permanent Food Service

1801 27TH STREET #A1-108, VERO BEACH 32960

Inspection Date: 08/26/2009

Inspection Number: 1857872

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ./small portable fryer/also a flat grill with heavy grease residue For reporting purposes only.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 4100895

VERO BOWL

License Type: Permanent Food Service

929 14 LANE, VERO BCH 329604736

Inspection Date: 08/27/2009

Inspection Number: 1868078

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate./by c/o tanks For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 4101115

TGI FRIDAYS

License Type: Permanent Food Service

6200 20 ST, VERO BEACH 32966

Inspection Date: 08/24/2009

Inspection Number: 1898903

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

48-01-2

Boiler certificate not posted in boiler room. For reporting purposes only.

69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

Jackson County

License Number: 4200449

HWY 77 BINGO

License Type: Permanent Food Service

5505 COLLEGE DR, GRACEVILLE 32440

Inspection Date: 08/27/2009

Inspection Number: 1891976

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARDING, LINDA

Violation CodeObservationViolation Citation

46-02-2

Observed locks on exit doors that requires a key, tool or special knowledge to open. Only one exit unlocked when building is occupied. For reporting purposes only.

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 4200513

SAN MARCOS MEXICAN GRILLE

License Type: Permanent Food Service

4867 W PLAZA, MARIANNA 32448

Inspection Date: 08/27/2009

Inspection Number: 1881772

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: HARDING, LINDA

Violation CodeObservationViolation Citation

47-16-2

Electrical switch in stockroom missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Lake County

License Number: 4500365

MCDONALD'S M6652/SS90216

License Type: Permanent Food Service

799 E HWY 50, CLERMONT 34711

Inspection Date: 08/25/2009

Inspection Number: 1900551

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHIU, ALEX

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
[kitchen rear fire egress blocked by a large garbage bin] Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 4508301

AY JALISCO

License Type: Permanent Food Service

580 E HWY 50, CLERMONT 34711

Inspection Date: 08/25/2009

Inspection Number: 1917496

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CHIU, ALEX

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
[in dining room]

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 4501514

CHECKERS #6330

License Type: Permanent Food Service

2508 CITRUS BLVD, LEESBURG 34748

Inspection Date: 08/26/2009

Inspection Number: 1859022

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: MARTIN, ROBERT KEVIN

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.
Repeat Violation.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

47-08-2

Observed electrical light fixtures with standing water by make table

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Lee County

License Number: 4602830

NEW ENGLAND MOORINGS SEA REST

License Type: Permanent Food Service

1326 SE 16 PL, CAPE CORAL 339903817

Inspection Date: 08/20/2009

Inspection Number: 1917560

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TARTAGLIONE, DOMINICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46	OBSERVED EXIT LIGHT NOT LIT ABOVE FRONT DOOR	NFPA 101, 96, 10 Exiting system - adequate, good repair
47	OBSERVED MISSING COVER PLATE ON SWITCH TO WALK-IN COOLER (REPORTING PURPOSES ONLY)	NFPA 101, 96, 10 Electrical wiring - adequate, good repair
47	OBSERVED COVER PLATE MISSING ON LIGHT SWITCH OF WALK-IN	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

Leon County

License Number: 4702853 KING BUFFET
 License Type: Permanent Food Service 2814 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 08/26/2009 Inspection Number: 1881890 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 4702977 QUALITY INN
 License Type: Permanent Food Service 2020 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 08/27/2009 Inspection Number: 1851193 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 4703352 ALOFT
 License Type: Permanent Food Service 150 E CALL ST, TALLAHASSEE 32301

Inspection Date: 08/25/2009 Inspection Number: 1916759 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-2	Boiler certificate not posted in boiler room. For reporting purposes only.	69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

Leon County

License Number: 4702230		LEANING TOWER (THE)	
License Type: Permanent Food Service		2475 APALACHEE PKWY, TALLAHASSEE 323014963	
Inspection Date: 08/27/2009	Inspection Number: 1861361	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SMITH, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 4701379		SONNY'S REAL PIT BAR B Q	
License Type: Permanent Food Service		2707 N MONROE ST, TALLAHASSEE 323034029	
Inspection Date: 08/20/2009	Inspection Number: 1912763	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WEBB, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 4701966		KFC	
License Type: Permanent Food Service		1942 N MONROE ST, TALLAHASSEE 323034747	
Inspection Date: 08/26/2009	Inspection Number: 1914957	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WEBB, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 4702839		BEEF O BRADYS	
License Type: Permanent Food Service		2910 KERRY FOREST PKWY, TALLAHASSEE 32309	
Inspection Date: 11/10/2004	Inspection Number: 1330974	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DODSON, FRED			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	

Leon County

License Number: 4702525

MORI JAPANESE STEAK HOUSE

License Type: Permanent Food Service

2810 SHARER RD, TALLAHASSEE 32312

Inspection Date: 08/28/2009

Inspection Number: 1881960

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DODSON, FRED

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.back door

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 4702670

GREAT WALL CHINESE RESTAURANT

License Type: Permanent Food Service

1400 - 14 VILLAGE SQUARE BLVD, TALLAHASSEE 32312

Inspection Date: 08/25/2009

Inspection Number: 1902454

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DODSON, FRED

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.front door

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-15-2

Observed an uncovered electrical box. For reporting purposes only breaker box

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Manatee County

License Number: 5105128 FAR EAST RESTAURANT
 License Type: Permanent Food Service 8419 HONORE AVE, UNIVERSITY PARK 34201

Inspection Date: 08/26/2009 Inspection Number: 1902762 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHRISTENSON, MELISSA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5105104 QUIZNOS
 License Type: Permanent Food Service 9118 TOWN CENTER PKWY STE 102, LAKEWOOD RANCH 34202

Inspection Date: 08/26/2009 Inspection Number: 1841176 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHRISTENSON, MELISSA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5104526 CHINA ONE
 License Type: Permanent Food Service 5627 W 14 ST, BRADENTON 34207

Inspection Date: 08/25/2009 Inspection Number: 1893334 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONTEH, FATIMAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 5100236 SEAFOOD SHACK
 License Type: Permanent Food Service 4110 W 127 ST, CORTEZ 342152502

Inspection Date: 08/24/2009 Inspection Number: 1892390 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KEMPA, ALICE M

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-2	Boiler certificate not posted in boiler room. On bulletin board, should be by boiler where expired one is posted. For reporting purposes only.	69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5202737

EAGLES NEST CAFE

License Type: Permanent Food Service

4555 W HWY 318, ORANGE LAKE 32681

Inspection Date: 08/27/2009

Inspection Number: 1917642

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRYANT, BENJAMIN

Violation CodeObservationViolation Citation

47-04-2

Observed exposed electrical wires in kitchen area. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5202306

TACO'N MADRE

License Type: Permanent Food Service

80 N PINE AVENUE, OCALA 34475

Inspection Date: 08/24/2009

Inspection Number: 1901113

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRYANT, BENJAMIN

Violation CodeObservationViolation Citation

47-04-2

Observed EXPOSED electrical wires in electrical panel box. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5202176

SAMMYS PIZZA

License Type: Permanent Food Service

6106 S R 200, OCALA 34476

Inspection Date: 08/28/2009

Inspection Number: 1901125

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRYANT, BENJAMIN

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated in dining rooms. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-07-2

Observed scorch marks on exit sign over front door. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5202161	BRANDING IRON OF OCALA
License Type: Permanent Food Service	4201 NE JAX RD, OCALA 34479
Inspection Date: 02/28/2003	Inspection Number: 1090387
Inspector Name: VON BODUNGEN, STEVEN	Inspection Type: Routine - Food
	Inspection Disposition: Not available electronically

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 5201967	HOWARD JOHNSON
License Type: Permanent Food Service	3951 NW BLITCHTON RD, OCALA 344824065
Inspection Date: 08/27/2009	Inspection Number: 1870365
Inspector Name: BRYANT, BENJAMIN	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-27-2	Portable fire extinguisher blocked/not easily accessible. For reporting purposes only. Corrected On Site.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

Martin County

License Number: 5301290

CATFISH HOUSE

License Type: Permanent Food Service

11500 SE FEDERAL HWY, HOBE SOUND 33455

Inspection Date: 08/28/2009

Inspection Number: 1865858

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only. at wic.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5301356

COURTYARD GRILL

License Type: Permanent Food Service

11970 SE DIXIE HWY, HOBE SOUND 33455

Inspection Date: 08/28/2009

Inspection Number: 1896493

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. dining rooms

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 5301477

ROOSTERS DAYTIME CAFE

License Type: Permanent Food Service

891 NE JENSEN BEACH BLVD, JENSEN BEACH 34957

Inspection Date: 08/25/2009

Inspection Number: 1886315

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Martin County

License Number: 5300958

KENTUCKY FRIED CHICKEN

License Type: Permanent Food Service

3315 NE FEDERAL HWY, JENSEN BCH 349574401

Inspection Date: 08/25/2009

Inspection Number: 1845383

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-42-2	Observed 1 hood filter installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY
45-12-2	Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.

License Number: 5301430

BAGEL BITES

License Type: Permanent Food Service

988 SW MARTIN DOWNS BLVD, PALM CITY 34990

Inspection Date: 08/24/2009

Inspection Number: 1886327

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only... front.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 5301245

ARTICHOKE CAFE & BISTRO

License Type: Permanent Food Service

333 SE OCEAN BLVD, STUART 34994

Inspection Date: 08/27/2009

Inspection Number: 1906988

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

Martin County

License Number: 5301583

PELICAN CAFE

License Type: Permanent Food Service

351 SW FLAGLER AVE, STUART 34994

Inspection Date: 08/27/2009

Inspection Number: 1845361

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5301044

SHRIMPERS GRILL & RAW BAR

License Type: Permanent Food Service

4903 SE DIXIE HWY, STUART 349971965

Inspection Date: 08/25/2009

Inspection Number: 1886265

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only. interior of wic.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. wait station

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Monroe County

License Number: 5401021 TOWER OF PIZZA
 License Type: Permanent Food Service US1 AT SUNSET BLVD, KEY LARGO 33037

Inspection Date: 08/27/2009 Inspection Number: 1833170 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5401684 THE MARLIN CUBAN RESTAURANT CORP
 License Type: Permanent Food Service 102770 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 08/27/2009 Inspection Number: 1843477 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5402682 WAFFLE HOUSE #1310
 License Type: Permanent Food Service 100270 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 08/27/2009 Inspection Number: 1874182 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5402787 SU CASA RESTAURANT & CAFE
 License Type: Permanent Food Service 99246 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 08/27/2009 Inspection Number: 1864066 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5427970 THE FISH HOUSE ENCORE
 License Type: Permanent Food Service 102341 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 08/24/2009 Inspection Number: 1905103 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Monroe County

License Number: 5401466 FISH HOUSE (THE)
 License Type: Permanent Food Service 102401 OVERSEAS HWY, KEY LARGO 330374613

Inspection Date: 08/24/2009 Inspection Number: 1905119 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALFONSO, ARELYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5402397 HARD ROCK CAFE
 License Type: Permanent Food Service 313 DUVAL ST, KEY WEST 330406565

Inspection Date: 04/10/2007 Inspection Number: 1523830 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BROWN, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-1	Hood filters are not tight-fitting and firmly held in place - leaving open spaces.	NFPA 96, 6.2.3.3:: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.
48-01-1	Boiler certificate not posted in boiler room. This violation must be corrected by : 5/10/07.	69A-51.025(4) FAC:: (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room.
48-13-1	Deep fat fryer installed without 16-inch separation from open flame. This violation must be corrected by : 5/10/07.	NFPA 96, 12.1.2.4:: All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment.

License Number: 5427984 TASTERS GRILLE AND MARKET
 License Type: Permanent Food Service 91252 OVERSEAS HIGHWAY, TAVERNIER 33070

Inspection Date: 08/25/2009 Inspection Number: 1894692 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BROWN, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 5402082 OCEAN POINTE CAFE
 License Type: Permanent Food Service 500 BURTON, TAVERNIER 330703100

Inspection Date: 08/25/2009 Inspection Number: 1874280 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BROWN, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Nassau County

License Number: 5500534		SHONEYS	
License Type: Permanent Food Service		2709 SADLER RD, FERNANDINA BEACH 32034	
Inspection Date: 08/27/2009	Inspection Number: 1891186	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Kitchen.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 5500302		MCDONALDS	
License Type: Permanent Food Service		1896 8 ST, FERNANDINA BCH 320343061	
Inspection Date: 08/28/2009	Inspection Number: 1911701	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5500506		HUDDLE HOUSE #146	
License Type: Permanent Food Service		1855 S 8 ST, FERNANDINA BCH 320343072	
Inspection Date: 08/26/2009	Inspection Number: 1870717	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PHELAN, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Steam unit rear area.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Okaloosa County

License Number: 5603310		CUVEE BEACH CELLAR & WINE BAR	
License Type: Permanent Food Service		36120 W EMERALD COAST PKWY, DESTIN 32541	
Inspection Date: 08/26/2009	Inspection Number: 1840530	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEREZ, FELIPE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 5603445		HOOTERS OF DESTIN	
License Type: Permanent Food Service		15015 EMERALD COAST PKWY, DESTIN 32541	
Inspection Date: 08/26/2009	Inspection Number: 1912315	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEREZ, FELIPE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit sign not properly illuminated...dining room. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 5603559		JIM-N-NICK'S	
License Type: Permanent Food Service		14073 EMERALD COAST PKWY, DESTIN 32541	
Inspection Date: 08/21/2009	Inspection Number: 1840486	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEREZ, FELIPE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 5600095		BLACK ANGUS	
License Type: Permanent Food Service		455 EGLIN PKY, FT WALTON BCH 325472827	
Inspection Date: 02/12/2003	Inspection Number: 1085557	Inspection Type: Routine - Food	Inspection Disposition: Not available electronically
Inspector Name: UNDEFINED, INSPECTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 5601718		WHATABURGER	
License Type: Permanent Food Service		190 EGLIN PKWY, FORT WALTON BEACH 32548	
Inspection Date: 08/28/2009	Inspection Number: 1914939	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WIGGINS, GISELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only, above grill. Corrected On Site.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

Orange County

License Number: 5809354 TORTILLERIA LA MEXICANA
 License Type: Permanent Food Service 708 ORANGE BLOSSOM TRL, APOPKA 32703

Inspection Date: 08/24/2009 Inspection Number: 1900031 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CHIU, CECILIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. Back kitchen	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5810448 ALBERTINA ITALIAN RESTAURANT
 License Type: Permanent Food Service 2434 E SEMORAN BLVD, APOPKA 32703

Inspection Date: 08/27/2009 Inspection Number: 1879466 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHIU, CECILIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. Class K	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5808409 NICKY'S D
 License Type: Permanent Food Service 452 N PARK AVE, APOPKA 32712

Inspection Date: 08/25/2009 Inspection Number: 1869159 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Operating deep freezer.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5805614 JIMMY'S CAFE AND CATERING LLC
 License Type: Permanent Food Service 601 S LAKE DESTINY RD STE 160, MAITLAND 32751

Inspection Date: 08/24/2009 Inspection Number: 1838381 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WATSON, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. By 3 bay sink	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5808466

JERRODS BLACK ANGUS STEAK HOUSE

License Type: Permanent Food Service

4645 S SEMORAN BLVD, ORLANDO 32801

Inspection Date: 08/24/2009

Inspection Number: 1899595

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces, both hoods. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
45-12-2	Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5810372		PIEZANO PIZZA & PASTA HOUSE	
License Type: Permanent Food Service		2425 E COLONIAL DR, ORLANDO 32803	
Inspection Date: 08/26/2009	Inspection Number: 1849191	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MOORE, CAROLYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
46-08-2	Exit signs not visible from any direction. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.	
46-17-2	Observed required exit for public through high hazard area. Notified Fire AHJ. For reporting purposes only.	NFPA 101, 7.5.2.1 Access to an exit shall not be through kitchens, storerooms other than as provided in Chapter 36 and Chapter 37, restrooms, workrooms, closets, bedrooms or similar spaces, or other rooms or spaces subject to locking, unless passage through such rooms or spaces is permitted for the occupancy by Chapter 18, Chapter 19, Chapter 22, and Chapter 23. FOR REPORTING PURPOSES ONLY.	

License Number: 5803054		CHURCHS FRIED CHICKEN	
License Type: Permanent Food Service		1234 W. CHURCH STREET, ORLANDO 32805	
Inspection Date: 08/25/2009	Inspection Number: 1848134	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: GORIS, WILBERTO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

Orange County

License Number: 5811059

KFC/LJS 4309012

License Type: Permanent Food Service

7825 E. COLONIAL DRIVE, ORLANDO 32807

Inspection Date: 08/24/2009

Inspection Number: 1869567

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOORE, CAROLYN

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5811761

BEST WESTERN AIRPORT INN & SUITES

License Type: Permanent Food Service

8101 AIRCENTER CT, ORLANDO 32809

Inspection Date: 08/25/2009

Inspection Number: 1868410

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LAMBERT, LISA

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. For microwave in kitchen .

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5804454

MCDONALD'S RESTAURANT #10138

License Type: Permanent Food Service

8060 S ORANGE AVE, ORLANDO 328096712

Inspection Date: 08/25/2009

Inspection Number: 1909390

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LAMBERT, LISA

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. 3A40BC at frontline. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5810508

MCDONALD'S #26548

License Type: Permanent Food Service

2944 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 08/26/2009

Inspection Number: 1899179

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LAMBERT, LISA

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. back kitchen door.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5803749

VILLAGE INN #20

License Type: Permanent Food Service

6275 WESTWOOD BLVD, ORLANDO 328218016

Inspection Date: 08/25/2009

Inspection Number: 1917458

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, hallways or egress; at back kitchen exit. Blocked by garbage can and brooms. For reporting purposes only. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 5806886

MCDONALD'S M2316/SS91166

License Type: Permanent Food Service

5498 CENTRAL FLORIDA PKWY, ORLANDO 328218774

Inspection Date: 03/17/2004

Inspection Number: 1218116

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CHIU, CECILIA

Violation CodeObservationViolation Citation

45-30

Observed lack of inspection report from licensed equipment dealer on premise.

4A-21.304 FAC Installation; Service. (1) All pre-engineered systems are to be inspected in accordance with the standards Adopted in 4A-21-302, F.A.C. (2) Whenever a pre-engineered system is installed, inspected, repaired, maintained or otherwise serviced, the permittee shall complete an inspection report containing, at a minimum, the information in paragraphs (a) through (o), in this subsection. One copy shall be signed by and delivered to the owner, or the representative of the owner, of the facility in which the system was installed. The other copy shall be retained in the fire equipment dealer's files. (a) Location of system; business name of facility, street address, city, state, zip code, phone number, and name of the owner or manager; (b) Whether the report is for an annual inspection; semi-annual inspection; a recharge; a new installation; or a renovation; (c) Where the system is located in the facility; (d) Type of system; name of manufacturer; model number; size of bottles; (e) Method and degree of actuation; (f) Reference to drawing number and page number in the manufacturer's manual; (g) Date of last hydrostatic test; (h) Date of last recharge; (i) Serial number; (j) Whether fuel shut off is gas or electric and the size; (k) A drawing of a new installation; a first inspection; or whenever changes are made (the drawing shall include the size of the hood and the size of the ducts); and the size, and type of all appliances protected; (l) Responses to the following questions: 1. Were the inspection and maintenance performed in accordance with the presently adopted editions of NFPA [indicate standard(s)] used - ('No' answers require an explanation); 2. Was the system tagged in accordance with Rule 4A-21.303, F.A.C.? ('No' answers require an explanation) 3. Were the inspection and maintenance performed in accordance with the manufacturer's manual and the manufacturer's specifications? ('No' answers require an explanation), (m) A comments section to allow for explanations if necessary; (n) A statement that the permittee certifies that he personally inspected the system and found the conditions to be as indicated on the report; (o) The permittee's name, signature and permit number; the date; and the customer's signature.

Orange County

License Number: 5810942

FU HUA CHINESE RESTAURANT

License Type: Permanent Food Service

4065 S GOLDENROD RD, ORLANDO 32822

Inspection Date: 08/25/2009

Inspection Number: 1868696

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5812275

TIJUANA FLATS BURRITO CO

License Type: Permanent Food Service

9001 NARCCOSSEE ROAD, SUITE 9161, ORLANDO 32827

Inspection Date: 08/27/2009

Inspection Number: 1837911

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor, class k was stored on floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5804891

LAKE NONA DINING ROOM

License Type: Permanent Food Service

9100 CHILTERN DR, ORLANDO 328277029

Inspection Date: 08/27/2009

Inspection Number: 1889178

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-2	Boiler certificate not posted in boiler room. For reporting purposes only.	69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5804892

GRILL ROOM (THE)

License Type: Permanent Food Service

9100 CHILTERN DR, ORLANDO 328277029

Inspection Date: 08/27/2009

Inspection Number: 1868710

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 5810075

JOE'S CRAB SHACK

License Type: Permanent Food Service

12124 S APOPKA VINELAND RD, LAKE BUENA VISTA 32836

Inspection Date: 08/19/2009

Inspection Number: 1900627

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: O'BRYAN, DARLENE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5807879

STEAK N SHAKE #281

License Type: Permanent Food Service

12163 APOPKA VINELAND RD, ORLANDO 328366802

Inspection Date: 08/27/2009

Inspection Number: 1899435

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TILLEY, GEMMA

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Orange County

License Number: 5807960 SUKI HANNA
 License Type: Permanent Food Service 4060 TOWN CENTER BLVD, ORLANDO 32837

Inspection Date: 08/28/2009 Inspection Number: 1917656 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable ABC fire extinguisher not fully charged, by back kitchen door. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5808385 DYNASTY CHINESE
 License Type: Permanent Food Service 2116 WHISPER LAKES BLVD, ORLANDO 32837

Inspection Date: 08/24/2009 Inspection Number: 1889836 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable Class K fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5810008 A SLICE OF NEW YORK OF ORLANDO
 License Type: Permanent Food Service 13851 S JOHN YOUNG PKWY, SIUITE 106, ORLANDO 32837

Inspection Date: 08/24/2009 Inspection Number: 1916057 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable ABC fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor; inack hallway. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5810534 DUNKIN DONUTS/BASKIN ROBBINS
 License Type: Permanent Food Service 12173 S ORANGE BLOSSOM TRL, ORLANDO 32837

Inspection Date: 08/28/2009 Inspection Number: 1858942 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable ABC fire extinguisher not fully charged at back door of kitchen. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5810993

JW MARRIOTT PRIMO

License Type: Permanent Food Service

4040 CENTRAL FLORIDA PARKWAY, ORLANDO 32837

Inspection Date: 08/27/2009

Inspection Number: 1848901

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation CodeObservationViolation Citation

47-08-2

Observed electrical wiring in disrepair. For reporting purposes only. Behind food waste disposer; capped wires exposed and cord loose at wall.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5811007

JW MARRIOTT BANQUET KITCHEN

License Type: Permanent Food Service

4036 CENTRAL FLORIDA PARKWAY, ORLANDO 32837

Inspection Date: 08/27/2009

Inspection Number: 1838507

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor; in Bodega. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Osceola County

License Number: 5911171 THE NY PIZZA COMPANY
 License Type: Permanent Food Service 3158 BILL BECK BLVD, KISSIMMEE 34744

Inspection Date: 08/25/2009 Inspection Number: 1888544 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KHAN, MOZHARUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5907510 CHINA RESTAURANT
 License Type: Permanent Food Service 2924 VINELAND ROAD, KISSIMMEE 34746

Inspection Date: 08/27/2009 Inspection Number: 1878258 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RIVERA, JESICA M

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 5908945 ATLAS EXPRESS
 License Type: Permanent Food Service 5407 W HWY 192 #D5, KISSIMMEE 34746

Inspection Date: 08/27/2009 Inspection Number: 1878262 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RIVERA, JESICA M

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5900803 DELI BAR
 License Type: Permanent Food Service 7470 W IRLO BRONSON HWY, KISSIMMEE 34747

Inspection Date: 08/27/2009 Inspection Number: 1867900 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For pepsi machine in dining area. For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Osceola County

License Number: 5904439

CICIS PIZZA 797

License Type: Permanent Food Service

7763 W IRLO BRONSON MEM HWY, KISSIMMEE 34747

Inspection Date: 08/27/2009

Inspection Number: 1857706

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For fax machine at front register and for pizza dough roller at back kitchen. For reporting purposes only. Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5900685

SIP N DIP DONUTS

License Type: Permanent Food Service

1001 13 ST, ST CLOUD 347694403

Inspection Date: 08/26/2009

Inspection Number: 1857808

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KHAN, MOZHARUL

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. Filling machine, For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6012905

CHEESE FACTORY

License Type: Permanent Food Service

701 S ROSEMARY AVE, WEST PALM BEACH 33401

Inspection Date: 08/25/2009

Inspection Number: 1906704

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SHAPIRO, STEWART

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.
CALL BOILER INSPECTOR AT 954-653-8094

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6012223

MAR IGUANAS CARIBBEAN BAR AND GRILL

License Type: Permanent Food Service

901 VILLAGE BLVD, WEST PALM BEACH 33401

Inspection Date: 08/20/2009

Inspection Number: 1813341

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

15-28-2

Violation: 15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6006008

CE JAY'S CAFE

License Type: Permanent Food Service

405 US HIGHWAY 1, LAKE PARK 33403

Inspection Date: 08/25/2009

Inspection Number: 1831740

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: MIDDLETON, ELWYN

Violation CodeObservationViolation Citation

15-42-2

Violation: 15-42-2

Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.

NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY

Palm Beach County

License Number: 6004535	FAMILY		
License Type: Permanent Food Service	2717 OLD DIXIE HWY, RIVIERA BEACH	33404	
Inspection Date: 08/20/2009	Inspection Number: 1896391	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.		NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
License Number: 6019950	HOT CURRY		
License Type: Permanent Food Service	1370 AVE E, RIVIERA BEACH	33404	
Inspection Date: 08/27/2009	Inspection Number: 1886117	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.		NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
License Number: 6009797	CHECKER'S #6273		
License Type: Permanent Food Service	2270 S MILITARY TRL, WEST PALM BCH	33406	
Inspection Date: 08/26/2009	Inspection Number: 1830585	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: MIDDLETON, ELWYN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-02-2	Violation: 46-02-2 Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. hasp locks - WIF & WIC.		NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.
License Number: 6019588	LITTLE CAESARS		
License Type: Permanent Food Service	1225 W 45 ST, STE 507, MANGONIA PARK	33407	
Inspection Date: 08/20/2009	Inspection Number: 1834955	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
47-16-2	Electrical outlet cover plate broken. For reporting purposes only. behind reach-in freezer		NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
License Number: 6000647	RED LOBSTER 0033		
License Type: Permanent Food Service	2201 PALM BEACH LAKES BLVD, WEST PALM BEACH	33409	
Inspection Date: 08/24/2009	Inspection Number: 1886159	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. ABC extinguisher		NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6000756		BURGER KING #59	
License Type: Permanent Food Service		4175 OKEECHOBEE BLVD, WEST PALM BEACH 33409	
Inspection Date: 08/24/2009	Inspection Number: 1896345	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-24-2	Hood filters are not clean. For reporting purposes only.	NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6009728		CHECKER'S #6272	
License Type: Permanent Food Service		2529 OKECHOBEE BLVD, WEST PALM BEACH 33409	
Inspection Date: 08/26/2009	Inspection Number: 1917504	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6012918		PARK AVENUE BAR-B-QUE & GRILLE	
License Type: Permanent Food Service		2215 PALM BEACH LAKES BLVD, WEST PALM BEACH 33409	
Inspection Date: 08/27/2009	Inspection Number: 1886115	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6019908		ZAZA MEDITERRANEAN GRILL	
License Type: Permanent Food Service		911 VILLAGE BLVD STE 801, WEST PALM BEACH 33409	
Inspection Date: 08/20/2009	Inspection Number: 1845165	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. missing one hood filter. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6020243		CREPEMAKER	
License Type: Permanent Food Service		110071 SOUTHERN BLVD STE #140, ROYAL PALM BEACH 33411	
Inspection Date: 08/26/2009	Inspection Number: 1831738	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: MIDDLETON, ELWYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Palm Beach County

License Number: 6009752

IRONHORSE COUNTRY CLUB MAIN DINING ROOM

License Type: Permanent Food Service

8055 IRONHORSE BLVD, WEST PALM BEACH 33411

Inspection Date: 08/28/2009

Inspection Number: 1834861

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIDDLETON, ELWYN

Violation CodeObservationViolation Citation

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. hasp locks on WIC & WIF. per manager, pad locks to be kept in locked position while doors unlocked for use.

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 6012117

ISLANDS ROTI DELIGHT

License Type: Permanent Food Service

1480 S MILITARY TRL #A, WEST PALM BCH 33415

Inspection Date: 08/27/2009

Inspection Number: 1875748

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

48-11-2

Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.

NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 6019539

LEOS PIZZA

License Type: Permanent Food Service

4065 N HAVEHILL RD STE# B5, WEST PALM BEACH 33417

Inspection Date: 08/24/2009

Inspection Number: 1822708

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: MIDDLETON, ELWYN

Violation CodeObservationViolation Citation

46-13-2

Violation: 46-13-2

Emergency light does not function when tested. For reporting purposes only. restroom.

NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6006850

SHANGHAI GARDEN

License Type: Permanent Food Service

220 N CONGRESS AVE, BOYNTON BEACH 33426

Inspection Date: 05/13/2009

Inspection Number: 1704233

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: VAVALA, LARRY

Violation Code

Observation

Violation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. AT BAR Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Inspection Date: 07/31/2009

Inspection Number: 1704233

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: VAVALA, LARRY

Violation Code

Observation

Violation Citation

47-06-2 Violation: 47-06-2
Observed extension cord in use for non-temporary period. For reporting purposes only. AT BAR Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6010141

CHINA DUMPLING

License Type: Permanent Food Service

1899 N CONGRESS AVE, BOYNTON BEACH 33426

Inspection Date: 08/27/2009

Inspection Number: 1844837

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SHAPIRO, STEWART

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25	Out of compliance: Grease Removal Devices. Listed grease filters, baffles, or other approved grease removal devices for use with commercial cooking equipment shall be provided. Listed grease filters shall be tested in accordance with UL 1046, Grease Fil	NFPA 96, 3-1 Grease Removal Devices. Listed grease filters, baffles, or other approved grease removal devices for use with commercial cooking equipment shall be provided. Listed grease filters shall be tested in accordance with UL 1046, Grease Filters for Exhaust Ducts. Mesh filters shall not be used.
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only. ONE SIDE	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
46-05	Out of compliance: The emergency lighting system shall be arranged to provide the required illumination automatically.	NFPA 101, 7.9.2.2 The emergency lighting system shall be arranged to provide the required illumination automatically.
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. DINING ROOM EMERGENCY EXIT BLOCKED WITH TABLES , CHAIRS & EQUIPMENT Repeat Violation.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6010377

ORIENTAL EXPRESS

License Type: Permanent Food Service

195 W CAMINO REAL, BOCA RATON 33432

Inspection Date: 08/21/2009

Inspection Number: 1875378

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. --- @ rear door.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6013034

EINSTEIN BROS BAGEL #776

License Type: Permanent Food Service

10 E PALMETTO PARK RD, BOCA RATON 33432

Inspection Date: 08/21/2009

Inspection Number: 1906245

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6009462

BANGKOK IN BOCA

License Type: Permanent Food Service

500 VIA DE PALMAS, BOCA RATON 334327819

Inspection Date: 08/21/2009

Inspection Number: 1885581

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 6019579

CARRABBA'S ITALIAN GRILL

License Type: Permanent Food Service

6909 SW 18 ST, BOCA RATON 33433

Inspection Date: 08/25/2009

Inspection Number: 1916732

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIERI, CYNTHIA

Violation CodeObservationViolation Citation

47-15-2 Observed an ELECTRIC RADIO CORD IN HANDWASH SINK

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6011755

YOKOHAMA INC

License Type: Permanent Food Service

9168 GLADES RD, BOCA RATON 33434

Inspection Date: 08/26/2009

Inspection Number: 1875399

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIERI, CYNTHIA

Violation CodeObservationViolation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only.BACK DOOR

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 6012961

WENDY'S OLD FASHIONED HAMBURGERS

License Type: Permanent Food Service

7400 BOYTON BEACH RD, BOYNTON BEACH 33435

Inspection Date: 08/26/2009

Inspection Number: 1885833

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

47-15-2 Observed an uncovered electrical box. For reporting purposes only.storeroom

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6013858 GOLDEN CORRAL
 License Type: Permanent Food Service 389 WINCHESTER PARK BLVD, BOYNTON BCH 33436

Inspection Date: 08/25/2009 Inspection Number: 1906515 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SHAPIRO, STEWART

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. UNIFORMS & POWER WASHER	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 6006964 DOMINO'S PIZZA #3803
 License Type: Permanent Food Service 10114 MILITARY TRL, BOYNTON BCH 334364048

Inspection Date: 07/29/2009 Inspection Number: 1885841 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: UNDEFINED, INSPECTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only.BY MOPSINK Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.FOR WASHER	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6019063 LUCILLE'S BAD TO THE BONE BBQ
 License Type: Permanent Food Service 6691 W BOYNTON BEACH BLVD, BOYNTON BEACH 33437

Inspection Date: 08/24/2009 Inspection Number: 1906525 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PONCE, NUARETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.K CLASS	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6007740 MCDONALDS REST #7667
 License Type: Permanent Food Service 6760 INDIANTOWN RD, JUPITER 334583978

Inspection Date: 08/27/2009 Inspection Number: 1896431 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.exit door/storeroom	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-08-2	Exit signs not visible from any direction. For reporting purposes only.exit door/storeroom	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated. For reporting purposes only.backdoor	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 6012206 JEROME CARRIBEAN REST
 License Type: Permanent Food Service 1412 LUCERNE AVE, LAKE WORTH 33460

Inspection Date: 08/27/2009 Inspection Number: 1865492 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MORALES, DAMIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6013854 RICHARD'S CATERING COMPANY
 License Type: Catering 522 W LANTANA RD, LANTANA 33462

Inspection Date: 08/26/2009 Inspection Number: 1093346 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MORALES, DAMIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6009482		TACO BELL #4322	
License Type: Permanent Food Service		7035 SEACREST BLVD, LANTANA 334625139	
Inspection Date: 08/26/2009	Inspection Number: 1906569	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MORALES, DAMIAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. k system, For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 6011883		CI CI PIZZA'S	
License Type: Permanent Food Service		3024 JOG RD, GREEN ACRES CITY 33467	
Inspection Date: 08/24/2009	Inspection Number: 1885783	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: PONCE, NUARETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-2	Sprinkler head spray pattern obstructed. For reporting purposes only. DISHROOM_PAINTED Repeat Violation.	NFPA 25, 5.2.1.2 Unacceptable obstructions to spray patterns shall be corrected. FOR REPORTING PURPOSES ONLY.	
License Number: 6012475		PIZZA BARN	
License Type: Permanent Food Service		5030 SEMINOLE PRATT WHITNEY RD, LOXAHATCHEE 33470	
Inspection Date: 08/12/2009	Inspection Number: 1855218	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MENOR, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. MICROWAVE	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6010012		SALA THAI THAI RESTAURANT	
License Type: Permanent Food Service		103 S US 1, JUPITER 33477	
Inspection Date: 08/27/2009	Inspection Number: 1855546	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DERVIN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. rear door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

Palm Beach County

License Number: 6013830		CHINA JADE	
License Type: Permanent Food Service		10150 W INDIANTOWN RD, JUPITER 33478	
Inspection Date: 08/26/2009	Inspection Number: 1865874	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DERVIN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6010615		UGLY MUG	
License Type: Permanent Food Service		5065 W ATLANTIC AVE, DELRAY BEACH 33484	
Inspection Date: 08/27/2009	Inspection Number: 1834437	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MULLINGS, SEANTELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. k class	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 6013439		HILTON GARDEN INN BOCA	
License Type: Permanent Food Service		8201 CONGRESS AVE, BOCA RATON 33487	
Inspection Date: 08/19/2009	Inspection Number: 1875496	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MULLINGS, SEANTELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6011927		BRENDYS ICE CREAM & YOGURT	
License Type: Permanent Food Service		9101 LAKE RIDGE BLVD, BOCA RATON 33496	
Inspection Date: 08/28/2009	Inspection Number: 1885805	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PONCE, NUARETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. OVER CHEST FREEZER_3 COMPARTMENT SINK	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Pasco County

License Number: 6102675

CHINA KING

License Type: Permanent Food Service

5334 LITTLE ROAD, NEW PORT RICHEY 34655

Inspection Date: 08/26/2009

Inspection Number: 1908328

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6112887

CHINA EXPRESS

License Type: Permanent Food Service

2928 LITTLE RD, NEW PORT RICHEY 34655

Inspection Date: 08/26/2009

Inspection Number: 1887830

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

47-15-2 Observed an uncovered electrical box. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2 Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2 Electrical outlet broken over plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6112946

AMICI PIZZA II

License Type: Permanent Food Service

5328 LITTLE RD, NEW PORT RICHEY 34655

Inspection Date: 08/26/2009

Inspection Number: 1857124

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

47-16-2 Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6113020

SEVEN SPRINGS SOUVLAKI

License Type: Permanent Food Service

2313 SEVEN SPRINGS BLVD, NEW PORT RICHEY 34655

Inspection Date: 08/27/2009

Inspection Number: 1877662

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6101199

PIT BOSS BAR B QUE & PUB

License Type: Permanent Food Service

4221 LITTLE RD, NEW PORT RICHEY 346551606

Inspection Date: 08/25/2009

Inspection Number: 1867356

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6101948

MAXIMILIANIANS

License Type: Permanent Food Service

8141 SR 52, HUDSON 34667

Inspection Date: 08/26/2009

Inspection Number: 1867578

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

45-38-2 Portable fire extinguisher not fully charged. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6113197

THE PHILLY CHEESESTEAK & SUB FACTORY

License Type: Permanent Food Service

7414 SR 52 SUITE 5, HUDSON 34667-6700

Inspection Date: 08/27/2009

Inspection Number: 1857314

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6216199		WOK & ROLL	
License Type: Permanent Food Service		1112 94 AVE N, ST. PETERSBURG 33702	
Inspection Date: 08/24/2009	Inspection Number: 1856040	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6206856		SANGWICH BLOCK (THE)	
License Type: Permanent Food Service		9291 N 9 ST, ST PETERSBURG 337023049	
Inspection Date: 08/25/2009	Inspection Number: 1907366	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6211098		SPORTS BAR & GRILL	
License Type: Permanent Food Service		1160 N 94 AVE, ST PETERSBURG 337028411	
Inspection Date: 08/24/2009	Inspection Number: 1907378	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6212004		PARADISE GRILLE	
License Type: Permanent Food Service		900 GULF WAY, ST.PETE BEACH 33706	
Inspection Date: 08/24/2009	Inspection Number: 1887748	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: BIROCCO, JOSEPH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.Soda machine blocking cook line doorway.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

Pinellas County

License Number: 6212933

GRIND HOUSE CAFE BAR

License Type: Permanent Food Service

1500 MCMULLEN BOOTH RD #A13, CLEARWATER 33759

Inspection Date: 08/26/2009

Inspection Number: 1856156

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WINSOR, KIMBERLY

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only...microwave by prep table

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6215688

QUAKER STEAK & LUBE

License Type: Permanent Food Service

10400 49TH ST, PINELLAS PARK 33762

Inspection Date: 08/26/2009

Inspection Number: 1898529

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PORTER, LINDSAY

Violation CodeObservationViolation Citation

45-07-2 Observed misalignment of hood suppression system nozzles. For reporting purposes only.(above flat top on cooks line)

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

License Number: 6215617

GOLDEN WOK BUFFET

License Type: Permanent Food Service

1410 MISSOURI AVE, LARGO 33770

Inspection Date: 08/27/2009

Inspection Number: 1896973

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. in sushi bar area

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6206811

STACEY'S BUFFET

License Type: Permanent Food Service

1451 N MISSOURI AVE, LARGO 337701821

Pinellas County

Inspection Date: 08/24/2009

Inspection Number: 1907330

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: OLSEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed an uncovered electrical box. For reporting purposes only. under desert counter	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
47-15-2	Violation: 47-15-2 Observed an uncovered electrical box. For reporting purposes only. under desert counter	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only. expired 5/4/09	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Pinellas County

48-12-2 Violation: 48-12-2

No current boiler certification provided/available. For reporting purposes only. expired 5/4/09

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6208732

FEOLA'S PASTA FACTORY

License Type: Permanent Food Service

7500 ULMERTON RD, LARGO 33771

Inspection Date: 08/27/2009

Inspection Number: 1847279

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PORTER, LINDSAY

Violation Code Observation

Violation Citation

47-08-2 Observed electrical wiring in disrepair. For reporting purposes only.(near ice machine)

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6215454

PIZZA HUT #4635

License Type: Permanent Food Service

7321 PARK BLVD, PINELLAS PARK 33781

Inspection Date: 08/25/2009

Inspection Number: 1845573

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURKE, LAWRENCE

Violation Code Observation

Violation Citation

46-13-2 Emergency light does not function when tested. For reporting purposes only. [ladies restroom]

NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6209254

BOB EVANS FARM RESTAURANT #145

License Type: Permanent Food Service

7550 N US HWY 19, PINELLAS PARK 337812746

Inspection Date: 08/24/2009

Inspection Number: 1855778

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURKE, LAWRENCE

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6214918

PIZZA HUT #4630

License Type: Permanent Food Service

33505 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 08/25/2009

Inspection Number: 1845979

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRAIG, CHRISTINE

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces.
above fryers For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Polk County

License Number: 6302396		MIKE'S DELI	
License Type: Permanent Food Service		2101 COMBEE RD., LAKELAND 33801	
Inspection Date: 08/28/2009	Inspection Number: 1877356	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 6307388		CHOP SHOP (THE)	
License Type: Permanent Food Service		126 KENTUCKY AVE, LAKELAND 33801	
Inspection Date: 08/25/2009	Inspection Number: 1887446	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	

License Number: 6307376		BELLY'S CAFE	
License Type: Permanent Food Service		1747 E EDGEWOOD DR, LAKELAND 33803	
Inspection Date: 08/28/2009	Inspection Number: 1846491	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 6307865		MY COVERT KITCHEN	
License Type: Permanent Food Service		2076 E EDGEWOOD DR, LAKELAND 33803	
Inspection Date: 08/24/2009	Inspection Number: 1897765	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

Polk County

License Number: 6304079 THE END ZONE
 License Type: Permanent Food Service 6771 N US HWY 98, LAKELAND 33809

Inspection Date: 08/20/2009 Inspection Number: 1829868 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6305719 RED LOBSTER
 License Type: Permanent Food Service 3706 NORTH ROAD 98, LAKELAND 33809

Inspection Date: 08/21/2009 Inspection Number: 1836439 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only./ trash blocking backdoor.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6304219 CHECKERS #222
 License Type: Permanent Food Service 4163 N US HWY 98, LAKELAND 338093830

Inspection Date: 08/24/2009 Inspection Number: 1887700 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Polk County

License Number: 6306512 CLUB AT EAGLEBROOKE (THE)
 License Type: Permanent Food Service 1300 EAGLEBROOKE BLVD, LAKELAND 33813

Inspection Date: 08/25/2009 Inspection Number: 1887476 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHITE, RICKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed hasp style lock on walk in cooler door. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only. Note that note on unit indicates unit exempt FS 554.109.2	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6302963 SOUTH FLORIDA DAIRY QUEEN
 License Type: Permanent Food Service 4114 S FLORIDA AVE, LAKELAND 338131625

Inspection Date: 08/24/2009 Inspection Number: 1867016 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: WHITE, RICKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Violation: 47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6305167 CHINA PEARL RESTAURANT
 License Type: Permanent Food Service 6960 S FLORIDA AVE, LAKELAND 338133317
 Inspection Date: 08/25/2009 Inspection Number: 1897797 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: WHITE, RICKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Violation: 47-16-2 Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6307820 HARDEE'S
 License Type: Permanent Food Service 28199 US HWY 27, DUNDEE 33838
 Inspection Date: 08/27/2009 Inspection Number: 1866966 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6302026 MELONIE'S RESTAURANT
 License Type: Permanent Food Service 209 E MAIN ST, DUNDEE 338384218
 Inspection Date: 08/25/2009 Inspection Number: 1856696 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. near grill.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6305245 DAIRY QUEEN
 License Type: Permanent Food Service 28067 S HWY 27, DUNDEE 338384562
 Inspection Date: 08/27/2009 Inspection Number: 1836195 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-07-2	Observed scorch marks around electrical outlet. For reporting purposes only. near mop sink.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. near mop sink.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6304198	MAXINE'S EATERY & COUNTRY STORE		
License Type: Permanent Food Service	175 E HAINES BLVD, LAKE ALFRED 33850		
Inspection Date: 08/25/2009	Inspection Number: 1877486	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, SHARON			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only./ back storage area.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only./ back storage area leading to a locked door.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6307678	SIZZLING GRILL		
License Type: Permanent Food Service	21400 US HIGHWAY 27, LAKE WALES 33859		
Inspection Date: 08/26/2009	Inspection Number: 1846447	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: ROMANO, JIMMIE			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6307791	SUGAR BAKERY		
License Type: Permanent Food Service	104 W CENTRAL AVENUE, WINTER HAVEN 33880		
Inspection Date: 08/26/2009	Inspection Number: 1908052	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WHITE, CHERYL			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. August 08 For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6301122

NELL'S COUNTRY KITCHEN

License Type: Permanent Food Service

1518 SW 7 STREET, WINTER HAVEN 338803815

Inspection Date: 08/09/2004

Inspection Number: 1285961

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05	Observed portable fire extinguishers not installed in accordance with NFPA 10. stored on the floor	61C-1.004(9)(a) FAC Fire Extinguisher Installation -- Fire extinguishers shall be installed in accordance with NFPA 10, Standard for Portable Fire Extinguishers.
47-01	Observed extension cord in use for non-temporary period. in the kitchen area.	61C-1.004(11) FAC Electrical wiring -- To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 4A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided.

Putnam County

License Number: 6400606

TASTE OF ITALY ON THE ST JOHNS

License Type: Permanent Food Service

133 CRYSTAL COVE DR, PALATKA 32177

Inspection Date: 08/25/2009

Inspection Number: 1917112

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code ObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only. ABC IN BACK HALLWAY

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 6400832

DOWNTOWN BLUES BAR AND GRILLE

License Type: Permanent Food Service

714 ST JOHNS AVE, PALATKA 32177

Inspection Date: 08/25/2009

Inspection Number: 1917428

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code ObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

45-40-2 Portable fire extinguisher with no approved inspection tag. For reporting purposes only. ABC AT BAR

61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

Santa Rosa County

License Number: 6700243		WAFFLE HOUSE REST #377	
License Type: Permanent Food Service		330 CAROLINE ST, MILTON 32570	
Inspection Date: 08/26/2009	Inspection Number: 1850809	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: WIGGINS, GISELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Violation: 46-09-2 Exit signs not properly illuminated, front exit. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
46-09-2	Exit signs not properly illuminated, front exit. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6701139		SHUCKUMS INC	
License Type: Permanent Food Service		5365 STEWART ST, MILTON 32570	
Inspection Date: 08/25/2009	Inspection Number: 1840372	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WIGGINS, GISELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 6701253		SOUTHERN MOTORSPORTS OF MILTON LLC	
License Type: Permanent Food Service		9359 NICHOLS LAKE RD, MILTON 32583	
Inspection Date: 08/28/2009	Inspection Number: 1850775	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WIGGINS, GISELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	

Sarasota County

License Number: 6804204		LONGHORN STEAKS OF SARASOTA	
License Type: Permanent Food Service		5440 FRUITVILLE RD, SARASOTA 34232	
Inspection Date: 08/24/2009	Inspection Number: 1841364	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DILLARD, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Over fryers .	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6801427		GUADALUPANA RESTAURANT	
License Type: Permanent Food Service		1620 N WASHINGTON BLVD, SARASOTA 34236	
Inspection Date: 08/26/2009	Inspection Number: 1892592	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: POSA, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-12-2	Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.	
License Number: 6804449		VENEZIA	
License Type: Permanent Food Service		373 ST ARMANDS CIRCLE, SARASOTA 34236	
Inspection Date: 08/24/2009	Inspection Number: 1917222	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: POSA, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-Small fryer-full of oil-on table in dishwash room.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 6804787		STATION 400	
License Type: Permanent Food Service		400 N LEMON AVE, SARASOTA 34236	
Inspection Date: 08/26/2009	Inspection Number: 1917200	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: POSA, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Sarasota County

License Number: 6804837

CORK

License Type: Permanent Food Service

29 N BLVD OF PRESIDENTS, SARASOTA 34236

Inspection Date: 08/24/2009

Inspection Number: 1841262

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: POSA, ANTHONY

Violation Code

Observation

Violation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Seminole County

License Number: 6903947
 License Type: Permanent Food Service

COLOMBIA LA BELLA RESTAURANT
 600 N HWY 1792 STE 160, LONGWOOD 32750

Inspection Date: 08/26/2009 Inspection Number: 1869113 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	K CLASS Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6903494
 License Type: Permanent Food Service

BAD DOG SALOON
 2485 S PARK AVE, SANFORD 32771

Inspection Date: 08/27/2009 Inspection Number: 1916293 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Fan.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6903690
 License Type: Permanent Food Service

MILLER'S ORLANDO ALE HOUSE
 50 TOWNCENTER CIR., SANFORD 32771

Inspection Date: 08/26/2009 Inspection Number: 1890218 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. in back prep. area	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. plakes of wood near heater	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

Seminole County

License Number: 6950251

DAVID MAUS TOYOTA

License Type: Mobile Food Dispensing Vehicle

1160 RINEHART ROAD, SANFORD 32771

Inspection Date: 08/27/2009

Inspection Number: 1134235

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

48-11-2 Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.

NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

St. Johns County

License Number: 6501244		BARNONE SALOON	
License Type: Permanent Food Service		312 ANASTASIA BLVD, ST AUGUSTINE 32080	
Inspection Date: 08/26/2009	Inspection Number: 1870651	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6500015		DENNY'S #7047	
License Type: Permanent Food Service		1300 N PONCE DE LEON BLVD, SAINT AUGUSTINE 32084	
Inspection Date: 08/25/2009	Inspection Number: 1917371	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. LARGE GAP IN HOOD. REMOVED FOR CLEANING . COOKING IN PROGRESS.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6500090		DAIRY QUEEN #10591	
License Type: Permanent Food Service		100 SAN MARCO AVE, SAINT AUGUSTINE 32084	
Inspection Date: 08/27/2009	Inspection Number: 1917587	Inspection Type: Complaint Full	Inspection Disposition: Emergency order recommended
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. GAP IN HOODFILTERS	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only. SPARKING ELECTRICAL BOX . (LOOSE WIRE) IN KITCHEN BY PREPTABLE	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6500252		WHITE LION TAVERN	
License Type: Permanent Food Service		20 CUNA ST, ST AUGUSTINE 320843604	
Inspection Date: 08/25/2009	Inspection Number: 1901455	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only. Repeat Violation.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	

St. Johns County

License Number: 6501464 TGIFRIDAY'S
 License Type: Permanent Food Service 318 SR 312, SAINT AUGUSTINE 32086

Inspection Date: 08/24/2009 Inspection Number: 1839830 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. GAP IN HOODFILTERS .Repeat Violation.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. LOOSE WIRES IN WAITSTATION ICE BIN. NEAR RESTROOMS	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6500398 KENTUCKY FRIED CHICKEN
 License Type: Permanent Food Service 2515 CR 208, ST AUGUSTINE 32092

Inspection Date: 03/17/2003 Inspection Number: 1092449 Inspection Type: Routine - Food Inspection Disposition: Not available electronically
 Inspector Name: VON BODUNGEN, STEVEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair
49	Out of compliance: Flammable/combustible materials - properly stored	NFPA 101, 96, 10 Flammable/combustible materials - properly stored

License Number: 6501826 BRUCCI'S PIZZERIA
 License Type: Permanent Food Service 540 SR 13, FRUIT COVE 32259

Inspection Date: 08/21/2009 Inspection Number: 1850291 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRADSHAW, BONNIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 6501564 MCDONALD'S
 License Type: Permanent Food Service 1625 W CR 210, JACKSONVILLE 32259

Inspection Date: 08/27/2009 Inspection Number: 1860276 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BRADSHAW, BONNIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

St. Johns County

License Number: 6501596		CRACKERS BAR B QUE	
License Type: Permanent Food Service		1515 CR 210 W #102, JACKSONVILLE 32259	
Inspection Date: 08/27/2009	Inspection Number: 1891082	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADSHAW, BONNIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. chest freezer, etc	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6501705		ST JOHNS GREYHOUND PARK	
License Type: Permanent Food Service		6332 RACE TRACK ROAD, JACKSONVILLE 32259	
Inspection Date: 08/26/2009	Inspection Number: 1911551	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BRADSHAW, BONNIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. chest freezer	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6501629		VINOS PIZZA	
License Type: Permanent Food Service		605 N SR 13 #103, ST. JOHNS 32259	
Inspection Date: 08/26/2009	Inspection Number: 1880920	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADSHAW, BONNIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

St. Lucie County

License Number: 6602453		GUADALAJARA MEXICAN REST	
License Type: Permanent Food Service		1702 DELAWARE AVE, FT PIERCE 34950	
Inspection Date: 10/07/2004	Inspection Number: 1298462	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: DAVIS, DIANNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 6602723		CHAMP FOOD MART & PIZZA	
License Type: Permanent Food Service		4104 OLEANDER AVE., FORT PIERCE 34982	
Inspection Date: 08/27/2009	Inspection Number: 1857972	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PARNASS, LAUREN P			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed, countertop style fryer in use at the steam table area. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 6602224		FRANK & AL'S PIZZA II	
License Type: Permanent Food Service		4955 US HWY 1, FT PIERCE 34982	
Inspection Date: 08/27/2009	Inspection Number: 1847783	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PARNASS, LAUREN P			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box, dining area near video game. For reporting purposes only. Repeat Violation.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6602687		CHINA STAR RESTAURANT	
License Type: Permanent Food Service		5485 NW ST JAMES DRIVE, PORT ST LUCIE 34983	
Inspection Date: 08/24/2009	Inspection Number: 1878532	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PARNASS, LAUREN P			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6602920		PARADISE RESTAURANT & LOUNGE	
License Type: Permanent Food Service		1334 SW BAYSHORE BLVD, PORT ST LUCIE 34983	
Inspection Date: 08/24/2009	Inspection Number: 1837429	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PARNASS, LAUREN P			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

St. Lucie County

License Number: 6602788

SAM SNEAD'S OAK GRILL & TRAVEN

License Type: Permanent Food Service

8540 COMMERCE CENTER DRIVE, PORT ST LUCIE 34986

Inspection Date: 08/25/2009

Inspection Number: 1878540

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY
49-06-2	Observed flammable material stored around water heater. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

Sumter County

License Number: 7000499

HONG KONG TAKE-OUT

License Type: Permanent Food Service

2229 W CR 48, BUSHNELL 33513

Inspection Date: 08/27/2009

Inspection Number: 1857298

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DANCHO, JOHN

Violation Code

Observation

Violation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Volusia County

License Number: 7405294

PIZZERIA UNO CHICAGO BAR & GRILL

License Type: Permanent Food Service

1798 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 08/27/2009

Inspection Number: 1879300

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed a lock and hasp on 2 storage room doors by rear door. Manager states fire inspector is OK with them being there.. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.
46-02-2	Observed hasp type lock on exit door in storage room bt office. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exit door in storage room by office/blocked by TV and high chair. For reporting purposes only. Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated at storage room exit. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 7406819

DAYTONA BEACH KENNEL CLUB CONCESSION

License Type: Permanent Food Service

960 S WILLIAMSON BLVD, DAYTONA BEACH 32114

Inspection Date: 08/26/2009

Inspection Number: 1868983

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 3 1/2feet off the floor/class K. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Volusia County

License Number: 7406864 HOLLYWOOD CANTINA
 License Type: Permanent Food Service 116 NORTH BEACH STREET, DAYTONA BEACH 32114

Inspection Date: 08/21/2009 Inspection Number: 1848577 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Extension given, pending
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
46-02-2	Violation: 46-02-2 Observed 2 locks and hasp on storage room door near restrooms. . For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.
46-05-2	Violation: 46-05-2 Observed obstructed exits, stairs, hallways or egress/observed gate at fence outside of rear exit secured on patio area. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-09-2	Violation: 46-09-2 Exit signs hanging from wires at exit door by restrooms.. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 7405138 CLUBHOUSE RESTAURANT (THE)
 License Type: Permanent Food Service 600 WILDER BLVD, DAYTONA BCH 321146031

Inspection Date: 08/25/2009 Inspection Number: 1889444 Inspection Type: Routine - Food Inspection Disposition: Inspection
 Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-15-2	Observed plug taped to outlet on cookline by chess freezer. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 7405241 CLUBHOUSE SNACK BAR
 License Type: Permanent Food Service 602 WILDER BLVD, DAYTONA BCH 321146031

Inspection Date: 08/25/2009 Inspection Number: 1889446 Inspection Type: Routine - Food Inspection Disposition: Inspection
 Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed a lock and hasp on exit door. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

Volusia County

License Number: 7402489

SCOUTS PIZZA & WINGS

License Type: Permanent Food Service

625 N OLEANDER AVE, DAYTONA BEACH 32118

Inspection Date: 08/25/2009

Inspection Number: 1899733

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARRETT, KAREN

Violation CodeObservationViolation Citation

46-07-2

Exit signs missing back door . For reporting purposes only.

NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.

License Number: 7406464

OCEANSHORE CAFE & DELI

License Type: Permanent Food Service

2451 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/26/2009

Inspection Number: 1916439

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BARRETT, KAREN

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for mixer and beverage air cooler near dishwash area non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Volusia County

License Number: 7406882

BIG KAHUNA BAR AND GRILL

License Type: Permanent Food Service

1010 MAIN ST, DAYTONA BEACH 32118

Inspection Date: 08/26/2009

Inspection Number: 1848428

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARRETT, KAREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher at bar not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated at southeast door. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for TV non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for fan in the ice machine room non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-08-2	Observed electrical wiring in disrepair capped wires extending from ceiling fan near back door.. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Volusia County

License Number: 7403327		STAND #2	
License Type: Permanent Food Service		2987 BELLEVUE RD, DAYTONA BCH	32124
Inspection Date: 08/28/2009	Inspection Number: 1899835	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY	
License Number: 7405828		PRESTWICK GOLF CLUB	
License Type: Permanent Food Service		1044 HAMPSTEAD LN, ORMOND BCH	32174
Inspection Date: 08/24/2009	Inspection Number: 1879154	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BERGSTRESSER, REBECCA L			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 7406892		BRUCE ROSEMEYERS DAYTONA HARLEY DAVIDSON CAFE	
License Type: Permanent Food Service		1637 N US HWY 1, ORMOND BEACH	32174
Inspection Date: 08/27/2009	Inspection Number: 1868901	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BERGSTRESSER, REBECCA L			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer in use.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	

Walton County

License Number: 7601848

FISH OUT OF WATER

License Type: Permanent Food Service

34 GOLDENROD CIR, SANTA ROSA BEACH 32459

Inspection Date: 08/27/2009

Inspection Number: 1871369

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 7601879

BAIT HOUSE RESTAURANT

License Type: Permanent Food Service

238 WATERCOLOR BLVD, SANTA ROSA BEACH 32459

Inspection Date: 08/27/2009

Inspection Number: 1902136

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation CodeObservationViolation Citation

45-37-2

Portable fire extinguisher missing from designated location...K-class extinguisher missing For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.