

Alachua County

License Number: 1102294

PANAMA JOES

License Type: Permanent Food Service

5109 NW 39 AVE, SUITE #6, GAINESVILLE 32606

Inspection Date: 10/12/2009

Inspection Number: 1890486

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. bar

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1102941

CHOP STIX BISTRO INC

License Type: Permanent Food Service

2441 NW 43 ST, GAINESVILLE 32606

Inspection Date: 10/09/2009

Inspection Number: 1900827

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

45-22-2

Portable fire extinguisher(s) obstructed from view aprons on top. For reporting purposes only.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

License Number: 1102738

SONNY'S REAL PIT BAR B Q REST

License Type: Permanent Food Service

9213 NW 39 AVE, GAINESVILLE 326065034

Inspection Date: 10/09/2009

Inspection Number: 1870071

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. back door

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Alachua County

License Number: 1100142

PICCADILLY CAFETERIA

License Type: Permanent Food Service

2620 NW 13 ST, GAINESVILLE 32609

Inspection Date: 10/14/2009

Inspection Number: 1911181

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: FULTON, DANIEL

Violation Code

Observation

Violation Citation

48-12-2

Violation: 48-12-2

No current boiler certification provided/available. For reporting purposes only.
INSPECTION HAS BEEN DONE, CERTIFICATION IS NOT POSTE
AT THIS TIME

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Bradford County

License Number: 1400158

WHATABURGER 917

License Type: Permanent Food Service

2540 COMMERCIAL DR, STARKE 32091

Inspection Date: 10/14/2009

Inspection Number: 1881308

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. BUG LIGHT

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1400159

DOLLY'S BAR-B-Q

License Type: Permanent Food Service

607 BROWNLEE STREET, STARKE 32091

Inspection Date: 10/14/2009

Inspection Number: 1881290

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

45-40-2

Portable fire extinguisher with expired inspection tag. For reporting purposes only.

61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

License Number: 1400181

HUDDLE HOUSE #314

License Type: Permanent Food Service

650 N TEMPLE AVE, STARKE 320912612

Inspection Date: 10/14/2009

Inspection Number: 1860729

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only. MULTIPLEG ADAPTER NEAR FRONT HANDSINK

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. PORTABLE FAN Corrected On Site.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Brevard County

License Number: 1504736		DUFFY'S SPORTS GRILL	
License Type: Permanent Food Service		1700 EVANS RD, MELBOURNE 32904	
Inspection Date: 10/12/2009	Inspection Number: 1898665	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-06-2	Observed a gas on front area grill that is not in use For reporting purposes only Corrected On Site.pilot out	61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.	
License Number: 1503582		WOODYS BAR-B-Q	
License Type: Permanent Food Service		2227 W NEW HAVEN AVE, MELBOURNE WEST 329043805	
Inspection Date: 10/12/2009	Inspection Number: 1898615	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-04-2	Violation: 47-04-2 Observed frayed/spliced electrical wires./marinator front cooks line/have electrical tape on cord still some showing For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 1506183		TROPICAL PITAS	
License Type: Permanent Food Service		1904 S PATRICK DR, INDIAN HARBOUR BEACH 32937	
Inspection Date: 10/16/2009	Inspection Number: 1917709	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 1505071		GINO'S PIZZERIA SUBS & RESTAURANT	
License Type: Permanent Food Service		612 BARNES BLVD, ROCKLEDGE 32955	
Inspection Date: 10/13/2009	Inspection Number: 1888320	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.dining area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Brevard County

License Number: 1506125

BACI

License Type: Permanent Food Service

760 BARNES BLVD SUITE 108-110, ROCKLEDGE 32955

Inspection Date: 10/12/2009

Inspection Number: 1847377

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MAYNARD, DIANE

Violation Code

Observation

Violation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.wait station

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1619473 WAFFLEWORK
 License Type: Permanent Food Service 3265 HOLLYWOOD BLVD, HOLLYWOOD 33021

Inspection Date: 10/13/2009 Inspection Number: 1905595 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHAPDELAINE, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only-behind toaster-use overload protector	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1618873 MI MEXICO
 License Type: Permanent Food Service 6059 JOHNSON ST, HOLLYWOOD 33024

Inspection Date: 10/12/2009 Inspection Number: 1843861 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: QUINONES, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-07-2	Exit signs in disrepair. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.

License Number: 1612654 RED LOBSTER 424
 License Type: Permanent Food Service 296 N UNIVERSITY DR, PEMBROKE PINES 33024

Inspection Date: 10/14/2009 Inspection Number: 1874596 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: QUINONES, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1621370

PARRILLADA EL GAUCHO INC

License Type: Permanent Food Service

11386 MIRAMAR PARKWAY, HOLLYWOOD 33025

Inspection Date: 10/16/2009

Inspection Number: 1919714

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VASQUEZ, JANNETH

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress, back door.. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1622197

RAINBOW BAKERY AND DELI

License Type: Permanent Food Service

11602 CITY HALL PROMENADE, MIRAMAR 33025

Inspection Date: 10/15/2009

Inspection Number: 1884725

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VASQUEZ, JANNETH

Violation CodeObservationViolation Citation

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 1616786

CHAR HUT

License Type: Permanent Food Service

12221 TAFT ST, PEMBROKE PINES 330261900

Inspection Date: 10/16/2009

Inspection Number: 1843765

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DURDEN, VICKIE

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 1617878

LA ANTIOQUENA BAKERY & RESTAURANT

License Type: Permanent Food Service

17041 PINES BLVD, PEMBROKE PINES 33027

Inspection Date: 10/15/2009

Inspection Number: 1884715

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DURDEN, VICKIE

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.cracked

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1619055		LAS VEGAS CUBAN CUISINE	
License Type: Permanent Food Service		15941 PINES BLVD, PEMBROKE PINES 33027	
Inspection Date: 10/12/2009	Inspection Number: 1884731	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DURDEN, VICKIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.back door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1621953		HUNGRY HOWIES PIZZA AND SUBS	
License Type: Permanent Food Service		7304 ROYAL PALM BLVD, MARGATE 33063	
Inspection Date: 10/12/2009	Inspection Number: 1906195	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIEHL, TERRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. OBSERVED RAW STEAKS FOR COOKING IN PIZZA OVEN.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 1622123		ALEXSANDRA'S CARIBBEAN RESTAURANT	
License Type: Permanent Food Service		7326 ROYAL PALM BLVD, MARGATE 33063	
Inspection Date: 10/12/2009	Inspection Number: 1865134	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: DIEHL, TERRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K CLASS IN KITCHEN.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. IN KITCHEN.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1621902

JERK CENTER BAKERY

License Type: Permanent Food Service

193 N SR 7, POMPANO BEACH 33063

Inspection Date: 10/12/2009

Inspection Number: 1865140

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DIEHL, TERENCE

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only. BEHIND FLOOR FREEZERS.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1609577

KOSTAS GREEK EATERY

License Type: Permanent Food Service

5024 N FEDERAL HWY, LIGHTHOUSE POINT 33064

Inspection Date: 10/09/2009

Inspection Number: 1906147

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EARP, NICOLETTE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

49-06-2

Observed flammable material stored around water heater. For reporting purposes only.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 1618359

DIANA FOOD GROUP

License Type: Catering

4020 NE 10 WAY, POMPANO BCH 33064

Inspection Date: 10/14/2009

Inspection Number: 1092871

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EARP, NICOLETTE

Violation CodeObservationViolation Citation

47-03-2

Observed unused opening in panel box unprotected. For reporting purposes only.

NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1609529 RESTAURANTE BRASIL
 License Type: Permanent Food Service 843 W SAMPLE RD, POMPANO BEACH 33064

Inspection Date: 10/14/2009 Inspection Number: 1906157 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EARP, NICOLETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1610778 RED LANTERN
 License Type: Permanent Food Service 805 W SAMPLE RD, POMPANO BEACH 33064

Inspection Date: 10/14/2009 Inspection Number: 1844459 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: EARP, NICOLETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 1621377 DAYS INN
 License Type: Permanent Food Service 4211 N FEDERAL HWY, POMPANO BEACH 33064

Inspection Date: 10/14/2009 Inspection Number: 1895744 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: EARP, NICOLETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1601072 LIGHTHOUSE POINT YACHT & TN CL
 License Type: Permanent Food Service 2701 NE 42 ST, LIGHTHOUSE PT 330648476

Inspection Date: 10/07/2009 Inspection Number: 1895708 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EARP, NICOLETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1621312 PELICAN GRAND BEACH RESORT
 License Type: Permanent Food Service 2000 N OCEAN BLVD, FORT LAUDERDALE 33305

Inspection Date: 10/13/2009 Inspection Number: 1905963 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: TORRES, LARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. in kitchen storage room. For reporting purposes only.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 1619612 MING WOK
 License Type: Permanent Food Service 3200 N FEDERAL HWY, FT LAUDERDALE 33306

Inspection Date: 10/14/2009 Inspection Number: 1844312 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MERNO, RAHLIBA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 1614436 GRANDMA'S CAFE
 License Type: Permanent Food Service 3354 N OCEAN BLVD, FORT LAUDERDALE 33308

Inspection Date: 10/14/2009 Inspection Number: 1905969 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MERNO, RAHLIBA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1618307		CARLUCCI'S ITALIAN RESTAURANT	
License Type: Permanent Food Service		6351 N ANDREWS AVE, FT LAUDERDALE 33309	
Inspection Date: 10/13/2009	Inspection Number: 1919146	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHNEIDER, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1612661		MONTI'S PIZZERIA REST INC	
License Type: Permanent Food Service		2973 W COMMERCIAL BLVD, FT LAUDERDALE 333093502	
Inspection Date: 10/15/2009	Inspection Number: 1876284	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHNEIDER, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only. 1/09	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 1614826		MIAMI SUBS	
License Type: Permanent Food Service		2484 N SR 7, LAUDERDALE LAKES 33313	
Inspection Date: 10/13/2009	Inspection Number: 1833928	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, NOVELETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 1621936		BURGER KING	
License Type: Permanent Food Service		4003 W OAKLAND PARK BLVD, LAUDERDALE LAKES 33313	
Inspection Date: 10/15/2009	Inspection Number: 1885191	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, NOVELETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-13-2	Emergency light does not function when tested in ladies' restroom. For reporting purposes only.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.	

Broward County

License Number: 1619124 LE JARDIN RESTAURANT & TROPICAL GRILL
 License Type: Permanent Food Service 1460 N SR 7, LAUDERHILL 33313

Inspection Date: 10/13/2009 Inspection Number: 1919568 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 1621073 POPEYES CHICKEN AND BISCUITS
 License Type: Permanent Food Service 7050 W COMMERCIAL BLVD, LAUDERHILL 33313

Inspection Date: 10/13/2009 Inspection Number: 1844223 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate, in dry storage area. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1621891 MINJI'S CAFE
 License Type: Permanent Food Service 7151 W OAKLAND PARK BLVD, LAUDERHILL 33313

Inspection Date: 10/15/2009 Inspection Number: 1895440 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period, with reachin cooler. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1615143

RANDALL PROPERTY MANAGEMENT LLC

License Type: Permanent Food Service

5353 S SR 7, DAVIE 33314

Inspection Date: 10/09/2009

Inspection Number: 1874600

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: QUINONES, JOSE

Violation CodeObservationViolation Citation

45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 1600492

LOBBY LOUNGE

License Type: Permanent Food Service

2301 SE 17 ST, FORT LAUDERDALE 33316

Inspection Date: 10/15/2009

Inspection Number: 1844121

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: LITSCHER, JOHN

Violation CodeObservationViolation Citation

48-21-1

Violation: 48-21-1

No carbon monoxide sensor device located in a gas boiler room in a building which also contains sleeping rooms.
Boiler Information: Boiler Jurisdiction Number: f1096906, Boiler Expiration Date: 04/07/2011 Boiler Jurisdiction Number:

509.211(5) FS Every enclosed space or room that contains a boiler regulated under chapter 554 which is fired by the direct application of energy from the combustion of fuels and that is located in any portion of a public lodging establishment that also contains sleeping rooms shall be equipped with one or more carbon monoxide sensor devices that bear the label of a nationally recognized testing laboratory and have been tested and listed as complying with the most recent Underwriters Laboratories, Inc., Standard 2034, or its equivalent, unless it is determined that carbon monoxide hazards have otherwise been adequately mitigated as determined by the division.

Broward County

License Number: 1612635 EMBASSY SUITES HOTEL
 License Type: Permanent Food Service 1100 SE 17 ST, FORT LAUDERDALE 33316

Inspection Date: 10/14/2009 Inspection Number: 1854401 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.bar	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.expired	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 1609960 SIAM HOUSE
 License Type: Permanent Food Service 1392 SE 17 ST, FT LAUDERDALE 333161708

Inspection Date: 10/14/2009 Inspection Number: 1833787 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.k class	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.6/08	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1612610 COFFEE SHOP
 License Type: Permanent Food Service 1100 SE 17 ST, FORT LAUDERDALE 33316-2131

Inspection Date: 10/14/2009 Inspection Number: 1885115 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.expired certificates	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 1621223 COLD STONE CREAMERY
 License Type: Permanent Food Service 6967 W BROWARD BLVD, PLANTATION 33317

Inspection Date: 10/15/2009 Inspection Number: 1905717 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, FERNANDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.rear door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1611878 PHO BINH
 License Type: Permanent Food Service 4461 N SR 7, LAUDERDALE LAKES 33319

Inspection Date: 10/15/2009 Inspection Number: 1905895 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-07-2	Observed misalignment of hood suppression system nozzles, no nozzles over fryers. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.
47-05-2	Observed a splitter/multi-plug adapter in use, with fliptop and frigidaire reachin coolers. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1616817 INVERRARY RESORT
 License Type: Permanent Food Service 3501 INVERRARY BLVD, LAUDERHILL 33319

Inspection Date: 10/14/2009 Inspection Number: 1895490 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed in dining room. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 1600258 WOODLAND COUNTRY CLUB REST
 License Type: Permanent Food Service 4600 WOODLANDS BLVD, TAMARAC 333196198

Inspection Date: 10/14/2009 Inspection Number: 1844219 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, NOVELETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period, by salad prep station with reachin cooler. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Broward County

License Number: 1621484		CHEDDARS CASUAL CAFE	
License Type: Permanent Food Service		7951 W COMMERCIAL BLVD, TAMARAC 33321	
Inspection Date: 10/14/2009	Inspection Number: 1875010	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, NOVELETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate, in employees' restroom. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1618857		CASPIAN PERSIAN GRILL	
License Type: Permanent Food Service		7821 W SUNRISE BLVD, PLANTATION 33322	
Inspection Date: 10/16/2009	Inspection Number: 1885152	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BECKER, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. In mens' bathroom	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 1621801		PIZZA TIME	
License Type: Permanent Food Service		1860 N NOB HILL RD, PLANTATION 33322	
Inspection Date: 10/13/2009	Inspection Number: 1895360	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: WILLIAMS, FERNANDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.rear door light not lit.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1615495		TOWER PIZZA RESTAURANT	
License Type: Permanent Food Service		2060 S UNIVERSITY DR, DAVIE 333245812	
Inspection Date: 10/13/2009	Inspection Number: 1844029	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, FERNANDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical outlet.2 waiter'sstation. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1610139		EAST COAST BURRITO FACTORY	
License Type: Permanent Food Service		261 E COMMERCIAL BLVD, FT LAUDERDALE 333341625	
Inspection Date: 10/13/2009	Inspection Number: 1876272	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SCHNEIDER, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

Citrus County

License Number: 1901163 CHEF ANTHONY'S PIZZA CAFE
 License Type: Permanent Food Service 2780 N FLORIDA AVE UNIT 6, HERNANDO 34442

Inspection Date: 10/09/2009 Inspection Number: 1857200 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRAIG, JILL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-08-2	Observed electrical wiring in disrepair- outlet on wall behind pizza oven falling out of wall. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1901157 LOS COMPADRES MEXICAN RESTAURANT INC
 License Type: Permanent Food Service 8361 S SUNCOAST BLVD, HOMOSASSA 34446

Inspection Date: 10/12/2009 Inspection Number: 1898155 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CRAIG, JILL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period- dishmachine. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-08-2	Observed electrical wiring in disrepair- outlet for dishmachine fallen out of wall. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate- behind canned goods on shelf. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1900966 PATRIOTIC PLACE
 License Type: Permanent Food Service 10605 W YULEE DRIVE, HOMOSASSA 34448

Inspection Date: 10/12/2009 Inspection Number: 1919250 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CRAIG, JILL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Citrus County

License Number: 1900136

TURNER FISH CAMP

License Type: Permanent Food Service

3033 N HOOTY PT, INVERNESS 344531713

Inspection Date: 10/12/2009

Inspection Number: 1846863

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRAIG, JILL

Violation Code

Observation

Violation Citation

47-16-2

Electrical outlet missing cover plate- next to walkin cooler. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Clay County

License Number: 2000734

OUTBACK STEAKHOUSE

License Type: Permanent Food Service

1775 WELLS RD, ORANGE PARK 32073

Inspection Date: 10/13/2009

Inspection Number: 1914387

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: D'ANTONIO, JANET

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 2000953

POMPEII COAL FIRED PIZZA

License Type: Permanent Food Service

2134 PARK AVE, ORANGE PARK 32073

Inspection Date: 10/14/2009

Inspection Number: 1839412

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: D'ANTONIO, JANET

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. To ladies room.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Columbia County

License Number: 2200616	RUBY TUESDAY #4680		
License Type: Permanent Food Service	245 COMMERCE BLVD, LAKE CITY 32025		
Inspection Date: 10/15/2009	Inspection Number: 1890334	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FULTON, DANIEL			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2200629	HARDEE'S		
License Type: Permanent Food Service	SR 100 & BAYA AVE, LAKE CITY 32055		
Inspection Date: 10/13/2009	Inspection Number: 1859560	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FULTON, DANIEL			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress.HASPS ON WIC DOORS. For reporting purposes only. Repeat Violation.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. SURGE SUPPRESSOR IN USE WITH MULTI REFRIGERATION UNITS. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Columbia County

License Number: 2250055

DIANE'S HOUSE OF DOGS

License Type: Mobile Food Dispensing Vehicle

215 SW HOME DEPOT DR, LAKE CITY 32055

Inspection Date: 10/14/2009

Inspection Number: 1133565

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: FULTON, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Violation: 15-25-2 Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2321206 KONGOS PIZZA
 License Type: Permanent Food Service 240 E 1 AVE, HIALEAH 33010

Inspection Date: 10/13/2009 Inspection Number: 1832493 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BRADOR, MOISES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Corrected On Site.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2312196 TROPICAL CAFETERIA
 License Type: Permanent Food Service 652 E 9 ST, HIALEAH 330104552

Inspection Date: 10/08/2009 Inspection Number: 1873560 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BRADOR, MOISES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2328739 RESTAURANT RICO PAN
 License Type: Permanent Food Service 7682 NW 186 ST, MIAMI 33015

Inspection Date: 10/14/2009 Inspection Number: 1919855 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DE LOS SANTOS, JUAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-11-2	Observed cooking equipment in use while hood suppression/exhaust system is inoperable. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 11.1.6 Cooking equipment shall not be operated while its fire-extinguishing system or exhaust system is nonoperational or otherwise impaired. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2328733	ANACAPRI ON PONCE
License Type: Permanent Food Service	2530 PONCE DE LEON BLVD, CORAL GABLES 33134
Inspection Date: 10/08/2009	Inspection Number: 1904733
Inspector Name: BURROWS, LEON	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2331655	NEW PIMENT BOUK RESTAURANT
License Type: Permanent Food Service	5961 NE 2 AVE, MIAMI 33137
Inspection Date: 10/13/2009	Inspection Number: 1863285
Inspector Name: GARCIA, BARBARO	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.
	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2324336	LA DIFFERENCE REST
License Type: Permanent Food Service	5912 NE 2 AVE, MIAMI 331372010
Inspection Date: 10/13/2009	Inspection Number: 1832483
Inspector Name: GARCIA, BARBARO	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.
	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

License Number: 2326640	THE PINEAPPLE BLOSSOM
License Type: Permanent Food Service	8214 BISCAYNE BLVD, MIAMI 33138
Inspection Date: 10/15/2009	Inspection Number: 1852614
Inspector Name: URIARTE, DENNIS	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
45-35-2	Violation: 45-35-2
	No current hood fire suppression system inspection report available. For reporting purposes only.
	NFPA 1, 13.1.5 and 10.2.2 Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and shall be made available upon request for review by the AHJ. The AHJ shall be permitted to require the owner, operator, or occupant to provide tests or test reports, without expense to the AHJ, as proof of compliance with the intent of this Code. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2328979 EL Q-BANO LATIN CAFE & BAKERY
 License Type: Permanent Food Service 8650 BISCAYNE BLVD, MIAMI 33138

Inspection Date: 10/15/2009 Inspection Number: 1904065 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: URIARTE, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Violation: 45-31-2 Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2330959 THE CAFE AT BOOKS & BOOKS
 License Type: Permanent Food Service 933 LINCOLN RD, MIAMI BEACH 33139

Inspection Date: 10/12/2009 Inspection Number: 1832039 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BATISTA, JENNY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-12-2	Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.
45-12-2	Violation: 45-12-2 Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.

Dade County

License Number: 2302873		INTERNATIONAL HOUSE OF PANCAKES 36-11	
License Type: Permanent Food Service		6928 COLLINS AVE, MIAMI BEACH 33141-3206	
Inspection Date: 10/13/2009	Inspection Number: 1832133	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: TORRES-SALGADO, JOSE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 2356676		ELICIA DIAZ	
License Type: Mobile Food Dispensing Vehicle		2517 NW 21 TERR, MIAMI 33142	
Inspection Date: 10/09/2009	Inspection Number: 1137556	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARQUEZ, JOSE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
License Number: 2326322		TWO CHEFS RESTAURANT INC	
License Type: Permanent Food Service		8279 S DIXIE HWY, MIAMI 331437717	
Inspection Date: 10/13/2009	Inspection Number: 1864252	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: CONYERS,			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-10-2	Violation: 48-10-2 Gas appliance lacking seal (AGA/UL, etc.). For reporting purposes only.	61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.	
License Number: 2318285		PIZZA USA	
License Type: Permanent Food Service		3015 NW 79 ST R-9, MIAMI 33147	
Inspection Date: 10/08/2009	Inspection Number: 1919081	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: DE LOS SANTOS, JUAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-37-2	Violation: 45-37-2 Portable fire extinguisher missing from designated location. For reporting purposes only.abc	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 2324521		CANGREJO SEA FOOD CORP	
License Type: Permanent Food Service		7437 SW 24 ST, MIAMI 33155	
Inspection Date: 10/13/2009	Inspection Number: 1919025	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. Corrected On Site.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	

Dade County

License Number: 2320577 HIGHLY FLAVORED HAITIAN CUISINE
 License Type: Permanent Food Service 9479 SW 160 ST, MIAMI 33157

Inspection Date: 10/14/2009 Inspection Number: 1863950 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Violation: 45-36-2 Hood suppression system tag out-of-date. For reporting purposes only.	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
45-41-2	Violation: 45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2321143 CHICKEN 2 GO RESTAURANT INC
 License Type: Permanent Food Service 13970 W DIXIE HWY, NORTH MIAMI 33161

Inspection Date: 10/14/2009 Inspection Number: 1832193 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CHOW, ZULEIMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 2326330 EGGWHITE CATERING
 License Type: Permanent Food Service 1419 NE 129 ST, NORTH MIAMI 33161

Inspection Date: 10/14/2009 Inspection Number: 1919955 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CHOW, ZULEIMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
39-05-2	Ventilation inadequate as evidenced by smoke in kitchen area. For reporting purposes only.	NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2325038 MCDONALDS REST #14164
 License Type: Permanent Food Service 610 NE 125 ST, NORTH MIAMI 331615504
 Inspection Date: 10/13/2009 Inspection Number: 1852736 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALONZO, GUILLERMO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet broken cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2321450 CAYO COCO RESTAURANT
 License Type: Permanent Food Service 9712 SW 24TH STREET, MIAMI 33165
 Inspection Date: 10/16/2009 Inspection Number: 1894488 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GANDOLFF, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2328776 SPORTS GRILL
 License Type: Permanent Food Service 11481 SW 40 ST, MIAMI 33165
 Inspection Date: 10/16/2009 Inspection Number: 1914836 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANDOLFF, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2325048 SHORTY'S BBQ
 License Type: Permanent Food Service 11575 SW 40 ST, MIAMI 331653313
 Inspection Date: 10/12/2009 Inspection Number: 1843319 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANDOLFF, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Dade County

License Number: 2331851		ALBERTO'S PLACE RESTAURANT	
License Type: Permanent Food Service		1105 NW 119 ST, NORTH MIAMI 33168	
Inspection Date: 10/14/2009	Inspection Number: 1883503	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNOLD, RICARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY	
License Number: 2331070		CAULEY SQUARE CAFE	
License Type: Permanent Food Service		12312 SW 224 ST, MIAMI 33170	
Inspection Date: 10/14/2009	Inspection Number: 1853821	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DE LA CRUZ, ADONIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 2302903		WOODY'S FAMOUS STEAK SANDWICH	
License Type: Permanent Food Service		13105 BISCAYNE BLVD, N MIAMI 33181	
Inspection Date: 10/14/2009	Inspection Number: 1904095	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: ALONZO, GUILLERMO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters missing. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2328124		RUMORS A NEIGHBORHOOD BISTRO & BAR	
License Type: Permanent Food Service		20537- 20545 OLD CUTLER RD, CUTLER BAY 33189	
Inspection Date: 10/15/2009	Inspection Number: 1894717	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DE LA CRUZ, ADONIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2331619		JOHNNY ROCKETS	
License Type: Permanent Food Service		20505 S DIXIE HWY, CUTLER BAY 33189	
Inspection Date: 10/16/2009	Inspection Number: 1894683	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DE LA CRUZ, ADONIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Dade County

License Number: 2327645

MEKATO PAISA RESTAURANT CAFETERIA

License Type: Permanent Food Service

20916 SOUTH DIXIE HWY, MIAMI 33189

Inspection Date: 10/15/2009

Inspection Number: 1884522

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DE LA CRUZ, ADONIS

Violation Code

Observation

Violation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2612580 TROPICAL ICE CREAM N MORE
 License Type: Permanent Food Service 5771 BENEY RD, JACKSONVILLE 32207
 Inspection Date: 10/12/2009 Inspection Number: 1860180 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-35-2	No current hood fire suppression system inspection report available. For reporting purposes only. has a home hood, frying empanada and fries	NFPA 1, 13.1.5 and 10.2.2 Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and shall be made available upon request for review by the AHJ. The AHJ shall be permitted to require the owner, operator, or occupant to provide tests or test reports, without expense to the AHJ, as proof of compliance with the intent of this Code. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. by small fryer Repeat Violation.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2609253 WENDY'S
 License Type: Permanent Food Service 3460 BEACH BLVD, JACKSONVILLE 322073808
 Inspection Date: 10/16/2009 Inspection Number: 1860188 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only. panel in office	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2608983 PICCADILLY CAFETERIA
 License Type: Permanent Food Service 3216 S UNIVERSITY BLVD, JACKSONVILLE 32216
 Inspection Date: 10/16/2009 Inspection Number: 1870569 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. cracked by front handsink	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 2612660 PAPA JOHNS PIZZA
 License Type: Permanent Food Service 5921 W UNIVERSITY BLVD #3, JACKSONVILLE 32216
 Inspection Date: 10/15/2009 Inspection Number: 1850205 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. missing hood filters	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Duval County

License Number: 2614427		INTERNATIONAL CAFE	
License Type: Permanent Food Service		5800 PHILIPS HWY, JACKSONVILLE 32216	
Inspection Date: 10/15/2009	Inspection Number: 1917450	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only. 2 open spaces, panel by door	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. Broken cover plate by ice machine and one missing at liquor storage	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 2613645		BOSNIAN ORIENTAL FOOD	
License Type: Permanent Food Service		8083 OLD KINGS ROAD #2, JACKSONVILLE 32217-4101	
Inspection Date: 07/01/2009	Inspection Number: 1901370	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADSHAW, BONNIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48	Out of compliance: Gas appliances - properly installed, maintained	NFPA 101, 96, 10 Gas appliances - properly installed, maintained	
License Number: 2613453		CROSS CREEK STEAKHOUSE & RIBS	
License Type: Permanent Food Service		12123 LEM TURNER, SUITE #1, JACKSONVILLE 32218	
Inspection Date: 10/12/2009	Inspection Number: 1881278	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only, NEAR WAIT AREA.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
46-13-2	Emergency light does not function when tested. For reporting purposes only, MISSING ONE LIGHT/NEAR WALKIN COOLER .	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.	

Duval County

License Number: 2614001 HARDEE'S RESTAURANT #8500086
 License Type: Permanent Food Service 675 NAUTICA DR, JACKSONVILLE 32218

Inspection Date: 10/13/2009 Inspection Number: 1891398 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only, BAG.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment. For reporting purposes only, PANEL C & LARGE PANEL	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 2614052 STICKY FINGERS
 License Type: Permanent Food Service RIVER CITY MARKETPLACE, JACKSONVILLE 32218

Inspection Date: 10/09/2009 Inspection Number: 1840142 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-33-2	Current hood suppression system report lists violations. Notified Fire AHJ. For reporting purposes only, GAP IN FIRE SUPPRESION SYSTEM VENTS	NFPA 96, 4.1.2, 4.1.3, 4.1.4 and 4.1.5 All such equipment and its performance shall be maintained in accordance with the requirements of this standard during all periods of operation of the cooking equipment. The following equipment shall be kept in good working condition: (1) Cooking equipment (2) Hoods (3) Ducts (if applicable) (4) Fans (5) Fire-extinguishing systems (6) Special effluent or energy control equipment All airflows shall be maintained. Maintenance and repairs shall be performed on all components at intervals necessary to maintain these conditions. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only FLOOR IN OFFICE	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2611427 SUBWAY SANDWICHES & SALADS
 License Type: Permanent Food Service 14670 DUVAL RD, JACKSONVILLE 322182460

Inspection Date: 10/16/2009 Inspection Number: 1840108 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DAVIS, MOSES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only, BLOCKED BY TRASH CONTAINER .	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2613004 KFC #Y309083
 License Type: Permanent Food Service 4201 OLDFEILD CROSSING DR, JACKSONVILLE 32223

Inspection Date: 10/09/2009 Inspection Number: 1860265 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRADSHAW, BONNIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-1	Out of compliance: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.	NFPA 96, 6.2.3.3:: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.

License Number: 2613712 VINO'S PIZZA
 License Type: Permanent Food Service 4268 OLDFIELD CROSSING RD #101, JACKSONVILLE 32223

Inspection Date: 10/09/2009 Inspection Number: 1919466 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRADSHAW, BONNIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Out of compliance: Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-06-1	Out of compliance: Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities.	61C-1.004(11) FAC:: Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 4A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided.

License Number: 2610888 ABE'S PIZZA
 License Type: Permanent Food Service 10916 ATLANTIC BLVD #6, JACKSONVILLE 32225

Inspection Date: 10/15/2009 Inspection Number: 1919950 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, DERRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-08-2	LP-gas tanks not protected from vehicle damage. For reporting purposes only.	NFPA 58, 3.2.4.2 LP-gas containers or systems of which they are a part shall be protected from damage from vehicles. FOR REPORTING PURPOSES ONLY.

Duval County

License Number: 2611242

HUNGRY HOWIE'S PIZZA & SUBS #244

License Type: Permanent Food Service

8011 MERRILL RD STE# 20, JACKSONVILLE 32277

Inspection Date: 10/14/2009

Inspection Number: 1860440

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: YOUNG, DERRICK

Violation CodeObservationViolation Citation46-09-2 Exit signs not properly illuminated. For reporting purposes only.
over back door61C-1.004(10) FAC Exits shall be clearly marked with
approved illuminated exit signs. FOR REPORTING
PURPOSES ONLY.

License Number: 2609577

CHECKERS

License Type: Permanent Food Service

5927 UNIVERSITY BLVD, JACKSONVILLE 33216

Inspection Date: 10/15/2009

Inspection Number: 1911485

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and
the top no higher than 5 feet off the floor. For reporting purposes only. K class on
floor
Repeat Violation.NFPA 10, 1.5.10 Fire extinguishers having a gross
weight not exceeding 40 lb shall be installed so that the
top of the fire extinguisher is not more than 5 ft above
the floor. Fire extinguishers having a gross weight
greater than 40 lb (except wheeled types) shall be so
installed that the top of the fire extinguisher is not more
than 3½ ft above the floor. In no case shall the
clearance between the bottom of the fire extinguisher
and the floor be less than 4 in. FOR REPORTING
PURPOSES ONLY.

Escambia County

License Number: 2750192		TACO ROCK TURBO #2	
License Type: Mobile Food Dispensing Vehicle		5454 PENSACOLA BLVD, PENSACOLA 32505	
Inspection Date: 10/09/2009	Inspection Number: 1138095	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WINN, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-37-2	Portable ABC fire extinguisher missing from designated location. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
45-37-2	Portable Class K fire extinguisher missing from designated location. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 2706085		LOST TREASURE GRILL LLC	
License Type: Permanent Food Service		1350 S BLUE ANGEL PKWY, PENSACOLA 32506	
Inspection Date: 10/14/2009	Inspection Number: 1871171	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-07-2	Observed gap in hood filters. For reporting purposes only. Corrected On Site.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.	
License Number: 2704981		KOOTER BROWN'S WEST END	
License Type: Permanent Food Service		7601 W HWY 98, PENSACOLA 325065941	
Inspection Date: 10/13/2009	Inspection Number: 1840284	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit sign in rear of kitchen not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 2701085		PENSACOLA GREYHOUND TRACK REST	
License Type: Permanent Food Service		951 DOG TRACK RD, PENSACOLA 325068236	
Inspection Date: 10/13/2009	Inspection Number: 1881426	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RILEY, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-07-2	Observed missing hood filter. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.	

Escambia County

License Number: 2705818

RYAN'S

License Type: Permanent Food Service

9006 PENSACOLA BLVD, PENSACOLA 32534

Inspection Date: 10/12/2009

Inspection Number: 1840310

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WINN, RONALD

Violation Code

Observation

Violation Citation

47-06-2 Observed extension cord in use for non-temporary period at south wait station. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Gadsden County

License Number: 3000363 THE STATION
 License Type: Permanent Food Service 223 W WASHINGTON ST, CHATTAHOOCHEE 32324

Inspection Date: 10/15/2009 Inspection Number: 1892060 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARGROVE, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3050030 CARROLL'S COUNTRY KITCHEN
 License Type: Mobile Food Dispensing Vehicle 269 RIVER LANDING RD, CHATTAHOOCHEE 32324

Inspection Date: 10/15/2009 Inspection Number: 1133655 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARGROVE, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters needs cleaning. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

License Number: 3000290 ASIAN BUFFET
 License Type: Permanent Food Service 809 NORTH MAIN STREET, HAVANA 32333

Inspection Date: 10/14/2009 Inspection Number: 1915049 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARGROVE, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-27-2	Portable fire extinguisher blocked/not easily accessible. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. BREAKER BOX #2.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
47-15-2	Observed an uncovered electrical box. For reporting purposes only. BREAKER BOX #1.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Gadsden County

License Number: 3000299

MOCKINGBIRD CAFE

License Type: Permanent Food Service

211 NW 1 STREET, HAVANA 32333

Inspection Date: 10/16/2009

Inspection Number: 1881854

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARGROVE, DAVID

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only. Corrected On Site.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3000346

RICHIES CAFE

License Type: Permanent Food Service

8007 N FLORIDA GEORGIA HWY, HAVANA 32333

Inspection Date: 10/16/2009

Inspection Number: 1861293

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARGROVE, DAVID

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Hernando County

License Number: 3700348

KENTUCKY FRIED CHICKEN

License Type: Permanent Food Service

1145 S BROAD ST, BROOKSVILLE 346013111

Inspection Date: 10/13/2009

Inspection Number: 1908490

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DANCHO, JOHN

Violation CodeObservationViolation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and
sufficient

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good
repair

License Number: 3700187

LAS BRISAS

License Type: Permanent Food Service

7385 SPRING HILL DR, SPRING HILL 34606

Inspection Date: 10/14/2009

Inspection Number: 1915664

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-03-2 Violation: 47-03-2

Observed unused opening in panel box unprotected. For reporting purposes only.
Circuit panel on wall in dishroom.NFPA 70, 110.12(a) Unused Openings - Unused
openings in boxes or housings shall be effectively
closed to afford protection substantially equivalent to the
wall of the equipment. FOR REPORTING PURPOSES
ONLY.

47-05-2 Violation: 47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only. By beer
cooler.61C-1.004(11) FAC Electrical wiring. To prevent fire or
injury, defective electrical wiring shall be replaced and
wiring shall be kept in good repair. No extension cords
shall be used except during cleaning, maintenance and
other temporary activities. Only a wall switch or
approved pull cord shall be permitted in bathrooms. In
accordance with the provisions of NFPA 70, the
National Electrical Code, as adopted by the Division of
State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire
Safety Rules and Standards, sufficient electrical outlets
shall be provided. FOR REPORTING PURPOSES
ONLY.

License Number: 3700411

THE RESTAURANT

License Type: Permanent Food Service

3438 COMMERCIAL WAY, SPRING HILL 34606

Inspection Date: 10/14/2009

Inspection Number: 1857350

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-06-2 Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes
only.61C-1.004(11) FAC Electrical wiring. To prevent fire or
injury, defective electrical wiring shall be replaced and
wiring shall be kept in good repair. No extension cords
shall be used except during cleaning, maintenance and
other temporary activities. Only a wall switch or
approved pull cord shall be permitted in bathrooms. In
accordance with the provisions of NFPA 70, the
National Electrical Code, as adopted by the Division of
State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire
Safety Rules and Standards, sufficient electrical outlets
shall be provided. FOR REPORTING PURPOSES
ONLY.

Hernando County

License Number: 3700729
 License Type: Permanent Food Service

TIMBER PINES COMMUNITY ASSOC
 2340 GRAND PINES BLVD, SPRING HILL 34606

Inspection Date: 10/14/2009
 Inspector Name: GLENN, DAVID

Inspection Number: 1908546
 Inspection Type: Routine - Food

Inspection Disposition: Inspection
 Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only. Blocked by rack in dishroom.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. Extinguisher on wall in break/storeroom needs re-charge.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 3700943
 License Type: Permanent Food Service

CHINA ONE SUPER BUFFET
 4241 MARINER BLVD, SPRING HILL 34609

Inspection Date: 10/13/2009
 Inspector Name: GLENN, DAVID

Inspection Number: 1919577
 Inspection Type: Complaint Full

Inspection Disposition: Inspection
 Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. In dishroom.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3701032
 License Type: Permanent Food Service

CHEFS OF NAPOLI INC
 14277 POWELL RD, SPRING HILL 34609

Inspection Date: 10/13/2009
 Inspector Name: GLENN, DAVID

Inspection Number: 1916807
 Inspection Type: Routine - Food

Inspection Disposition: Warning
 Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3915873

EAST COAST PIZZA

License Type: Permanent Food Service

13340 LINCOLN RD, RIVERVIEW 33569

Inspection Date: 10/14/2009

Inspection Number: 1877408

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BOWEN, JEFFREY

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Mount the red-fire extinguisher, in the kitchen, on a wall.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 3913043

WESTSHORE PIZZA XXIII

License Type: Permanent Food Service

6026 US HWY 41, APOLLO BEACH 33572

Inspection Date: 10/14/2009

Inspection Number: 1867330

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. under rear hand sink

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3912061

SONNY'S REAL PIT BBQ

License Type: Permanent Food Service

724 CYPRESS VILLAGE BLVD, SUN CITY CENTER 33573

Inspection Date: 10/15/2009

Inspection Number: 1887610

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BOWEN, JEFFREY

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Do not park baby chairs in front of the dining-room fire-exit door. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 3903008

FAMILY CAYENNE RESTAURANT

License Type: Permanent Food Service

4330 N NEBRASKA AVE, TAMPA 33603

Inspection Date: 10/15/2009

Inspection Number: 1847181

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3911088

BRISAS DEL VALLE

License Type: Permanent Food Service

7532 N ARMENIA AVE, TAMPA 33604

Inspection Date: 10/12/2009

Inspection Number: 1888208

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation Code

Observation

Violation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912194

EL RANCHO TIPICO LLC

License Type: Permanent Food Service

7218 N ARMENIA AVE SUITE B, TAMPA 33604

Inspection Date: 10/16/2009

Inspection Number: 1867734

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-05-2	Violation: 47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-07-2	Observed scorch marks around electrical outlet. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-07-2	Violation: 47-07-2 Observed scorch marks around electrical outlet. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3910680

CHECKER'S #474-7060

License Type: Permanent Food Service

107 W WATERS, TAMPA 336043007

Inspection Date: 10/12/2009

Inspection Number: 1857502

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

47-07-2 Observed scorch marks around electrical outlet. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912412

TEATRO ON SEVENTH

License Type: Permanent Food Service

1600 E 8 AVE C-201, TAMPA 33605

Inspection Date: 10/15/2009

Inspection Number: 1836533

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912510

ROCK-N-SPORTS BAR & GRILLE

License Type: Permanent Food Service

1600 E 8 AVE STE E200, TAMPA 33605

Inspection Date: 10/13/2009

Inspection Number: 1908276

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.behind
bar

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes
only.kitchen

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3909437

BLANCO'S RESTAURANT & CATERING

License Type: Permanent Food Service

3229 W CYPRESS, TAMPA 33607

Inspection Date: 10/14/2009

Inspection Number: 1907600

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MIRABELLA, FRANK

Violation CodeObservationViolation Citation47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes
only. for TV's

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3911821

GOAL LINE STAND 139C

License Type: Permanent Food Service

4116 N HIMES AVE, TAMPA 33607

Inspection Date: 10/15/2009

Inspection Number: 1866632

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MIRABELLA, FRANK

Violation CodeObservationViolation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

Hillsborough County

License Number: 3911833 CLUB DELI / 232C
 License Type: Permanent Food Service 4116 N HIMES AVE, TAMPA 33607
 Inspection Date: 10/09/2009 Inspection Number: 1876892 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIRABELLA, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 3911856 VENDING ROOM 316V
 License Type: Permanent Food Service 4116 N HIMES AVE, TAMPA 33607
 Inspection Date: 10/09/2009 Inspection Number: 1846067 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIRABELLA, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 3911860 FIRST DOWN DELI & DOGS 107C
 License Type: Permanent Food Service 4116 N HIMES AVE, TAMPA 33607
 Inspection Date: 10/15/2009 Inspection Number: 1876902 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIRABELLA, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 3911864 GOAL LINE STAND
 License Type: Permanent Food Service 4116 N HIMES AVE, TAMPA 33607
 Inspection Date: 10/15/2009 Inspection Number: 1846069 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIRABELLA, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 3916461 LILIBETH CUBAN SANDWICH SHOP & RESTAURANT
 License Type: Permanent Food Service 3210 N ARMENIA AVENUE, TAMPA 33607
 Inspection Date: 10/14/2009 Inspection Number: 1919420 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIRABELLA, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. front metal counter.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3916529 LA MICHOCACANA
 License Type: Permanent Food Service 2800 N MCDILL AVENUE STE E, TAMPA 33607

Inspection Date: 10/14/2009 Inspection Number: 1866642 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIRABELLA, FRANK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. for sign in window	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3951540 LA GUAGUITA
 License Type: Mobile Food Dispensing Vehicle 1704 N HOWARD AVENUE, TAMPA 33607

Inspection Date: 10/15/2009 Inspection Number: 1137160 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: DORSEY, KATHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-26-2	Violation: 15-26-2 Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.
45-39-2	Violation: 45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K class	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
48-13-2	Violation: 48-13-2 Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.

License Number: 3911464 WINGHOUSE
 License Type: Permanent Food Service 5003 HWY 301, TAMPA 33610

Inspection Date: 10/14/2009 Inspection Number: 1836927 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. line microwave	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912075

SODEXO AT NETPARK

License Type: Permanent Food Service

5701 E. HILLSBOROUGH AVE, TAMPA 33610

Inspection Date: 10/14/2009

Inspection Number: 1857480

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 3903939

JOYCE SANDWICH SHOP

License Type: Permanent Food Service

2010 E MLK BLVD, TAMPA 336107521

Inspection Date: 10/14/2009

Inspection Number: 1888186

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

47-16-2 Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3915659

DUKES RETIRED SURFERS ISLAND BAR

License Type: Permanent Food Service

5210 W TYSON AVE, TAMPA 33611

Inspection Date: 10/13/2009

Inspection Number: 1887321

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3912303

CJ'S TAVERN

License Type: Permanent Food Service

1318 W LINEBAUGH, TAMPA 33612

Inspection Date: 10/15/2009

Inspection Number: 1897431

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.
45-40-2	Portable fire extinguisher with no approved inspection tag. For reporting purposes only.(Ansul)	61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.(bar)	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet with broken cover plate. For reporting purposes only.(women)	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3916386

MORRISON'S BUFFET & GRILLE

License Type: Permanent Food Service

2920 E BUSCH BLVD, TAMPA 33612

Inspection Date: 10/13/2009

Inspection Number: 1846237

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EDMISTON, ROBERT

Violation CodeObservationViolation Citation

45-39-2	Portable fire extinguisher setting on the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
---------	---	---

Hillsborough County

License Number: 3903766		BURGER KING #93	
License Type: Permanent Food Service		9211 N FLORIDA AVE, TAMPA 336127905	
Inspection Date: 10/15/2009	Inspection Number: 1866720	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 3900747		MCDONALDS 569	
License Type: Permanent Food Service		3411 E BUSCH BLVD, TAMPA 336128741	
Inspection Date: 10/12/2009	Inspection Number: 1846205	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EDMISTON, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 3915677		PEDRO & CARY	
License Type: Permanent Food Service		3529 W WATERS AVE, TAMPA 33614	
Inspection Date: 10/13/2009	Inspection Number: 1846357	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
48-13-2	Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only. Frying in open pot on gas stove.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 3915773		DUNKIN DONUTS	
License Type: Permanent Food Service		7004 N DALE MABRY HWY, TAMPA 33614	
Inspection Date: 10/15/2009	Inspection Number: 1897577	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3910433		BRUNO'S PIZZA #2	
License Type: Permanent Food Service		2615 W WATERS AVE, TAMPA 336141834	
Inspection Date: 10/12/2009	Inspection Number: 1887277	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 3903747		JUMBO BUFFET	
License Type: Permanent Food Service		8503 W HILLSBOROUGH AVE, TAMPA 33615	
Inspection Date: 10/13/2009	Inspection Number: 1919731	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: DECKER, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 3904310		ARBYS #1247	
License Type: Permanent Food Service		8315 W HILLSBOROUGH AVE, TAMPA 336153805	
Inspection Date: 10/13/2009	Inspection Number: 1856378	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DECKER, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 3916281		VOCELLI'S PIZZA	
License Type: Permanent Food Service		5001 E FOWLER AVE STE B, TAMPA 33617	
Inspection Date: 10/12/2009	Inspection Number: 1915798	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EDMISTON, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher setting on the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3905176		MEI WAH CHINESE RESTAURANT	
License Type: Permanent Food Service		10442 N DALE MABRY, TAMPA 33618	
Inspection Date: 10/15/2009	Inspection Number: 1919807	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with some filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
License Number: 3910069		ON THE MARK PROMOTIONS	
License Type: Permanent Food Service		401 S 50 ST, TAMPA 33619	
Inspection Date: 10/12/2009	Inspection Number: 1846771	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OGDEN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.in office	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 3907108		VILLA RINA	
License Type: Permanent Food Service		10073 ADAMO DR, TAMPA 336192619	
Inspection Date: 10/13/2009	Inspection Number: 1867312	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OGDEN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.broken in dining room	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Hillsborough County

License Number: 3912707

ASTON GARDENS AT TAMPA BAY

License Type: Permanent Food Service

11702 LAKE ASTON COURT, TAMPA 33626

Inspection Date: 10/16/2009

Inspection Number: 1866682

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DECKER, RICHARD

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3913044

KANG'S GARDEN CHINESE

License Type: Permanent Food Service

12221 W LINEBAUGH AVE, TAMPA 33626

Inspection Date: 10/14/2009

Inspection Number: 1887073

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DECKER, RICHARD

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 3915482

SUBWAY# 25011

License Type: Permanent Food Service

12235 W LINEBAUGH AVE, TAMPA 33626

Inspection Date: 10/14/2009

Inspection Number: 1919645

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DECKER, RICHARD

Violation CodeObservationViolation Citation

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Hillsborough County

License Number: 3915943

CARVEL ICE CREAM

License Type: Permanent Food Service

11917 SHELDON RD, TAMPA 33626

Inspection Date: 10/16/2009

Inspection Number: 1856416

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DECKER, RICHARD

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 3906744

U N DELI & MORE

License Type: Permanent Food Service

4726 EISENHOWER BLVD, TAMPA 33634

Inspection Date: 10/15/2009

Inspection Number: 1907658

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DECKER, RICHARD

Violation CodeObservationViolation Citation

47-16-2 Electrical outlet missing cover plate. For reporting purposes only. by pan rack

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3915935

PIZZA HUT #4663

License Type: Permanent Food Service

13883 W HILLSBOROUGH AVE, TAMPA 33635

Inspection Date: 10/16/2009

Inspection Number: 1876994

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DECKER, RICHARD

Violation CodeObservationViolation Citation

45-27-2 Portable K class fire extinguisher blocked/not easily accessible. For reporting purposes only.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

License Number: 3915665

CORPORATE DINING SERVICES-BAUSCH & LOMB CAFE

License Type: Permanent Food Service

8500 HIDDEN RIVER PKWY, TAMPA 33637

Inspection Date: 10/14/2009

Inspection Number: 1836823

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CHEW, TEOW

Violation CodeObservationViolation Citation

45-31-2 Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Corrected On Site.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

Indian River County

License Number: 4100791

EAGLES NEST & CC

License Type: Permanent Food Service

101 E AIRPORT DR, SEBASTIAN 329583924

Inspection Date: 10/14/2009

Inspection Number: 1898879

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

47-04-2

Observed frayed/spliced electrical wires/for oven For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 4100332

CAFE 1901

License Type: Permanent Food Service

1901 14TH AVE, VERO BEACH 32960

Inspection Date: 10/13/2009

Inspection Number: 1868100

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. /under table in kitchen For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Indian River County

License Number: 4100335

JACK BAKERS LOBSTER SHANTY

License Type: Permanent Food Service

1 ROYAL PALM POINTE, VERO BEACH 32960

Inspection Date: 10/13/2009

Inspection Number: 1857862

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

48-01-2	Boiler certificate not posted in boiler room. For reporting purposes only.	69A-51.025(4) FAC (4) Certificate of Compliance. The Certificate of Compliance shall be conspicuously placed so it can be readily identified with the certified boiler, preferably in the boiler room. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification (expired). For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 4105068

BANGKOK IN DOWNTOWN

License Type: Permanent Food Service

2227 14TH AVE., VERO BEACH 32960

Inspection Date: 10/13/2009

Inspection Number: 1868046

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

47-04-2	Observed frayed/spliced electrical wires/plug by dishmachine For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
---------	---	--

Indian River County

License Number: 4105170		CHEF LIN'S ASIA BUFFET	
License Type: Permanent Food Service		1850 US HIGHWAY 1, VERO BEACH 32960	
Inspection Date: 10/15/2009	Inspection Number: 1857846	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces also a couple broken For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 4100616		MR MANATEE'S CASUAL GRILLE	
License Type: Permanent Food Service		30 ROYAL PALM BLVD, VERO BCH 329605238	
Inspection Date: 10/15/2009	Inspection Number: 1909072	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces./2 missing For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 4100643		TAQUERIA LA SALUTA	
License Type: Permanent Food Service		2010 S US HWY 1, VERO BEACH 32962	
Inspection Date: 10/09/2009	Inspection Number: 1857959	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, DIANNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only. Repeat Violation.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY	
15-40-2	Violation: 15-40-2 No metal container installed for catching grease from hood drip tray. For reporting purposes only. Grease dripping into plastic pail at end of grill area. No catch/metal container on grill hood.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY	
License Number: 4101055		PEARL	
License Type: Permanent Food Service		2855 OCEAN DRIVE, VERO BEACH 32963	
Inspection Date: 10/14/2009	Inspection Number: 1847737	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, DIANNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only-ice bucket area by wine room.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet/switch plate cracked and chipped away. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Lake County

License Number: 4508260

OUTBACK STEAKHOUSE

License Type: Permanent Food Service

710 US HWY 441 N, THE VILLAGES 32159

Inspection Date: 10/07/2009

Inspection Number: 1889850

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, ROBERT KEVIN

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.
Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 4502036

THE RETRO STEAK HOUSE & GRILL LLC

License Type: Permanent Food Service

31 E MAGNOLIA AVE, EUSTIS 32726

Inspection Date: 10/08/2009

Inspection Number: 1859034

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, ROBERT KEVIN

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.dishwash area

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 4502374

DAM SMOKER BBQ (THE)

License Type: Permanent Food Service

36721 CR 19A, EUSTIS 32726

Inspection Date: 10/08/2009

Inspection Number: 1869405

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, ROBERT KEVIN

Violation CodeObservationViolation Citation

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only.wic

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 4550128

FLORIDA TWIN MKT MOBILE #12

License Type: Mobile Food Dispensing Vehicle

20651 HWY 441, MT DORA 32757

Inspection Date: 10/14/2009

Inspection Number: 1138931

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRISTWELL, HENRY

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Lake County

License Number: 4502286		LATIN DELI	
License Type: Permanent Food Service		482 W HWY 50, CLERMONT 34711	
Inspection Date: 10/12/2009	Inspection Number: 1890182	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: CHIU, ALEX			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 4508188		NAPOLI'S PIZZERIA	
License Type: Permanent Food Service		556 S HWY 27 UNIT C, MINNEOLA 34715	
Inspection Date: 10/15/2009	Inspection Number: 1880004	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CHIU, ALEX			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
48-13-2	Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 4501590		RED LION PUB LLC	
License Type: Permanent Food Service		139 E BROAD ST, GROVELAND 34736	
Inspection Date: 10/12/2009	Inspection Number: 1869843	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, ALEX			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. OBSERVED 3 RESIDENTIAL FRYERS IN USE ON BAR COUNTER. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 4500618		NICKERS	
License Type: Permanent Food Service		10400 CR 48, HOWEY IN THE HILLS 347373000	
Inspection Date: 10/14/2009	Inspection Number: 1890186	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, ALEX			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 4508337		#1 BUFFET	
License Type: Permanent Food Service		1704 CITRUS BLVD, LEESBURG 34748	
Inspection Date: 10/14/2009	Inspection Number: 1919804	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: MARTIN, ROBERT KEVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Lake County

License Number: 4501665 OCEAN'S GRILL
 License Type: Permanent Food Service 2009 N CITRUS BLVD, LEESURG 34748

Inspection Date: 10/12/2009 Inspection Number: 1859012 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, ROBERT KEVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.storage room	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 4508198 CODY JACKS
 License Type: Permanent Food Service 650 N US HIGHWAY 27, MINNEOLA 34755

Inspection Date: 10/09/2009 Inspection Number: 1900525 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: CHIU, ALEX

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Violation: 45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. [in a cabinet by bar]	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Lee County

License Number: 4605448		HUA'S GARDEN	
License Type: Permanent Food Service		4150 HANCOCK BRIDGE PKWY, NORTH FORT MYERS 33903	
Inspection Date: 10/12/2009	Inspection Number: 1903191	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TARTAGLIONE, DOMINICK JR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
License Number: 4605522		PARADISE TIKI HUT BAR & GRILL	
License Type: Permanent Food Service		1502 MIRAMAR ST, CAPE CORAL 33904	
Inspection Date: 10/14/2009	Inspection Number: 1882735	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SOMMERS, KARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 4605770		CHINA DRAGON	
License Type: Permanent Food Service		6810 SHOPPES AT PLANTATION DR STE 2, FT MYERS 33912	
Inspection Date: 09/24/2009	Inspection Number: 1893386	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TORBERT, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit sign not properly illuminated. For reporting purposes only. front door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 4606313		HILTON GARDEN INN FORT MYERS AIRPORT	
License Type: Permanent Food Service		16410 CORPORATE COMMERCE WAY, FORT MYERS 33913	
Inspection Date: 10/12/2009	Inspection Number: 1916395	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BAMBREY, SHAWN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.	

Lee County

License Number: 4605817

GOLD CHINA

License Type: Permanent Food Service

24600 S TAMIAMI TRL STE# 106, BONITA SPRINGS 34134

Inspection Date: 10/12/2009

Inspection Number: 1913979

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORBERT, KIMBERLY

Violation Code

Observation

Violation Citation

46-09-2

Exit sign not properly illuminated. For reporting purposes only. front door

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Leon County

License Number: 4702618		NEW CHINA SUPER BUFFET	
License Type: Permanent Food Service		2698 N MONROE ST, TALLAHASSEE 32303	
Inspection Date: 10/13/2009	Inspection Number: 1918619	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WRIGHT, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-08-2	Observed electrical wiring in disrepair; light under hood has exposed wire and no shield. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 4702923		FOOD GLORIOUS FOOD	
License Type: Permanent Food Service		1950 THOMASVILLE RD C, TALLAHASSEE 32303	
Inspection Date: 10/13/2009	Inspection Number: 1882018	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WRIGHT, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 4701985		BASKIN ROBBINS	
License Type: Permanent Food Service		904 THOMASVILLE RD, TALLAHASSEE 323036220	
Inspection Date: 10/16/2009	Inspection Number: 1902504	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WRIGHT, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. Hasp lock on walk in freezer door. Repeat Violation.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	
License Number: 4703173		SUBWAY	
License Type: Permanent Food Service		2910 KERRY FOREST PKWY UNIT A6, TALLAHASSEE 32309	
Inspection Date: 10/13/2009	Inspection Number: 1902420	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DODSON, FRED			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	

Leon County

License Number: 4703245		SUSHILICIOUS	
License Type: Permanent Food Service		2915 KERRY FOREST PKWY STE 604, TALLAHASSEE 32309	
Inspection Date: 10/13/2009	Inspection Number: 1871683	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DODSON, FRED			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.breaker box open Corrected On Site.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 4703221		BRICKYARD PIZZERIA	
License Type: Permanent Food Service		4819 KERRY FOREST PARKWAY, TALLAHASSEE 32309-2273	
Inspection Date: 10/13/2009	Inspection Number: 1840847	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DODSON, FRED			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.breaker box Corrected On Site.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 4702212		OLD MEXICO AUTHENTIC RESTAURANT & CATINA	
License Type: Permanent Food Service		3212 APALACHEE PKWY, TALLAHASSEE 32311	
Inspection Date: 10/12/2009	Inspection Number: 1892188	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: DODSON, FRED			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.back door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	

Levy County

License Number: 4800467

MCDONALDS

License Type: Permanent Food Service

713 W NOBLE AVE, WILLISTON 32696

Inspection Date: 10/13/2009

Inspection Number: 1890478

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 4800552

GOBBLERS EATERY

License Type: Permanent Food Service

14 HWY 19 N, INGLIS 34449

Inspection Date: 10/16/2009

Inspection Number: 1880282

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: FULTON, DANIEL

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. OUTSIDE .

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 4800556

CAMP HOUSE RESTAURANT

License Type: Permanent Food Service

491 HWY 40 E, INGLIS 34449

Inspection Date: 10/14/2009

Inspection Number: 1859688

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5201134 KENTUCKY FRIED CHICKEN #33 X309033
 License Type: Permanent Food Service 5120 SE ABSHIER BLVD, BELLEVIEW 344203919

Inspection Date: 10/16/2009 Inspection Number: 1870413 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. By back door .	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Cardboard boxes blocking back door exit .	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-13-2	Emergency light does not function when tested. For reporting purposes only. Hallway & dining room .	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.

License Number: 5201372 STUMPKNOCKERS ON THE RIVER
 License Type: Permanent Food Service 13821 SW SR 200, DUNNELLON 34430

Inspection Date: 10/13/2009 Inspection Number: 1915845 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRENNE, LILYANN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 5202208 THE PRESERVE GOLF CLUB
 License Type: Permanent Food Service 13601 SW 115 AVE, DUNNELLON 34432

Inspection Date: 10/13/2009 Inspection Number: 1849769 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: WRENNE, LILYANN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period by large cooer in kitchen.For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Marion County

License Number: 5202387 THE LEVEE
 License Type: Permanent Food Service 20583 W PENNSYLVANIA AVE, DUNNELLON 34432

Inspection Date: 10/13/2009 Inspection Number: 1919672 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WRENNE, LILYANN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period by the tv. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5200270 PIZZA HUT 622061
 License Type: Permanent Food Service 2327 S PINE AVE, OCALA 344715100

Inspection Date: 10/13/2009 Inspection Number: 1839482 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRYANT, BENJAMIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed back door exit obstructed by trash can and cardboard box. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 5202666 EGGS OVER BASELINE
 License Type: Permanent Food Service 5855 SE 5TH STREET #5, OCALA 34472

Inspection Date: 10/12/2009 Inspection Number: 1915157 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Kitchen area .	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5202312 LA COCINA DE PITU
 License Type: Permanent Food Service 166 MARION OAKS BLVD STE# 7, OCALA 34473

Inspection Date: 10/16/2009 Inspection Number: 1916692 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ANAZIA, ROLAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Front /back doors	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Martin County

License Number: 5301543		CACTUS JACKS	
License Type: Permanent Food Service		11220 SE FEDERAL HWY, HOBE SOUND 33455	
Inspection Date: 10/16/2009	Inspection Number: 1845291	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DERVIN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only. propane container in store room. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 5301658		TONINOS PIZZA	
License Type: Permanent Food Service		9024 SE BRIDGE RD, HOBE SOUND 33455	
Inspection Date: 10/16/2009	Inspection Number: 1906926	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DERVIN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only. no tag on portable fryer.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 5301492		RUBY TUESDAY #7122	
License Type: Permanent Food Service		3290 SW MARTIN DOWNS BLVD, PALM CITY 34990	
Inspection Date: 10/09/2009	Inspection Number: 1865938	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Violation: 45-38-2 Portable fire extinguisher not fully charged. For reporting purposes only... kitchen ak-class.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 5301360		WENDYS OLD FASH HMBGR 148-8142	
License Type: Permanent Food Service		3160 SE FEDERAL HWY, STUART 34994	
Inspection Date: 10/09/2009	Inspection Number: 1835135	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only... exterior walk-in freezer. Hasp lock separate from handle release.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.	
License Number: 5300707		ALICE'S FAMILY RESTAURANT	
License Type: Permanent Food Service		2781 E OCEAN BLVD, STUART 349962767	
Inspection Date: 10/15/2009	Inspection Number: 1896583	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETROW, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only... lp tank, was removed. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	

Martin County

License Number: 5300660

BOBBYS MCGEE'S GRILL & SPORTS PUB

License Type: Permanent Food Service

5959 SE FEDERAL HWY, STUART 34997

Inspection Date: 10/12/2009

Inspection Number: 1855504

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DERVIN, RICHARD

Violation Code

Observation

Violation Citation

15-42-2

Observed hood filters installed horizontally, rather than vertically. For reporting purposes only.

NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY

Nassau County

License Number: 5500978

WOODYS BAR-B-Q

License Type: Permanent Food Service

474323 SR 200, FERNANDINA BEACH 32034

Inspection Date: 10/12/2009

Inspection Number: 1839884

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: PHELAN, JOHN

Violation CodeObservationViolation Citation

47-16-2

Violation: 47-16-2

Electrical outlet missing cover plate. For reporting purposes only. By smoker.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 5501015

HORIZONS

License Type: Permanent Food Service

4828 FIRST COAST HWY #1, FERNANDINA BEACH 32034

Inspection Date: 10/12/2009

Inspection Number: 1901485

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PHELAN, JOHN

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Kitchen.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Okaloosa County

License Number: 5601874		THE CAST IRON SKILLET LLC	
License Type: Permanent Food Service		584 N FERDON BLVD, CRESTVIEW 32536	
Inspection Date: 10/09/2009	Inspection Number: 1871793	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZALIA, CHARLES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical light switch. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 5601198		WHATABURGER	
License Type: Permanent Food Service		101 HWY 98 E, DESTIN 32541	
Inspection Date: 10/12/2009	Inspection Number: 1861049	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEREZ, FELIPE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with filters removed...main cook line hood system.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
License Number: 5603612		MAKONG THAI RESTAURANT	
License Type: Permanent Food Service		196 MIRACLE STRIP PKWY UNIT O, FT WALTON BEACH 32548	
Inspection Date: 10/12/2009	Inspection Number: 1902042	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WIGGINS, GISELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 5602109		SHALIMAR MCDONALDS 11184	
License Type: Permanent Food Service		1189 EGLIN PKWY, SHALIMAR 325791252	
Inspection Date: 10/08/2009	Inspection Number: 1902064	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZALIA, CHARLES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5602290		CAFE AMAPOLA LLC	
License Type: Permanent Food Service		481 S JOHN SIMMS PKWY UNIT B, VALPARAISO 32580	
Inspection Date: 10/08/2009	Inspection Number: 1840913	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZALIA, CHARLES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit sign not fully illuminated. For reporting purposes only...front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

Orange County

License Number: 5808516		CHEZ VINCENT INC	
License Type: Permanent Food Service		533 W NEW ENGLAND AVE #A, WINTER PARK 32789	
Inspection Date: 10/13/2009	Inspection Number: 1900089	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WATSON, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
39-03-2	Exhaust system off during the operation of cooking equipment. For reporting purposes only.	NFPA 96, 11.1.1 Exhaust systems shall be operated whenever cooking equipment is turned on. For reporting purposes only.	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. Paper goods, downstairs	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	

License Number: 5802748		WINTER PARK RACQUET CLUB	
License Type: Permanent Food Service		2111 VIA TUSCANY, WINTER PARK 327891299	
Inspection Date: 10/15/2009	Inspection Number: 1889712	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WATSON, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. By cookline	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 5808105		BRAVISSIMO WINE BAR & CAFE	
License Type: Permanent Food Service		337 N SHINE AVE, ORLANDO 32803	
Inspection Date: 10/14/2009	Inspection Number: 1910499	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MOORE, CAROLYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 5853294		TAQUERIA LOS JAROSCHOS	
License Type: Mobile Food Dispensing Vehicle		1206 ROBINSON ST., ORLANDO 32805	
Inspection Date: 10/14/2009	Inspection Number: 1133455	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, CECILIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

Orange County

License Number: 5809177

FOOD WITH CARE

License Type: Catering

6995 VENTURE CIR, ORLANDO 32807

Inspection Date: 10/13/2009

Inspection Number: 1093303

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MOORE, CAROLYN

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5811709

CHITO RESTAURANT

License Type: Permanent Food Service

5649 E COLONIAL DRIVE, ORLANDO 32807

Inspection Date: 10/14/2009

Inspection Number: 1838677

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: MOORE, CAROLYN

Violation CodeObservationViolation Citation

45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5810605

SUNDAY'S COUNTRY COOKIN

License Type: Permanent Food Service

5406 HANSEL AVE, EDGEWOOD 32809

Inspection Date: 08/13/2009

Inspection Number: 1847945

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CAMPBELL, MICHAEL J

Violation CodeObservationViolation Citation

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 5852889

ANGELO'S DINER

License Type: Mobile Food Dispensing Vehicle

6422 MILNER BLVD, ORLANDO 32809

Inspection Date: 10/15/2009

Inspection Number: 1138856

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LAMBERT, LISA

Violation CodeObservationViolation Citation

45-31-2 Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5853349		RAFAEL ROLDAN	
License Type: Mobile Food Dispensing Vehicle		6422 MILNER BLVD, ORLANDO 32809	
Inspection Date: 10/15/2009	Inspection Number: 1138921	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LAMBERT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-17-2	No 10BC portable extinguisher on mobile food dispensing vehicle. For reporting purposes only.	61C-4.0161(8) FAC (8) All units equipped with heat producing appliances for food preparation or maintaining food temperatures shall be provided with at least one approved portable fire extinguisher having a minimum rating of at least 10BC. FOR REPORTING PURPOSES ONLY.	
License Number: 5853389		BORINQUEN BBQ	
License Type: Mobile Food Dispensing Vehicle		6422 MILNER BV., ORLANDO 32809	
Inspection Date: 10/12/2009	Inspection Number: 1138895	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LAMBERT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 5812212		PUFF N STUFF CATERING	
License Type: Permanent Food Service		250 RIO DR, ORLANDO 32810	
Inspection Date: 10/13/2009	Inspection Number: 1848785	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: CHIU, CECILIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only. Back cookline	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. At dish area	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. At dish area	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 5805636		HUNGRY HOWIES PIZZA & SUBS	
License Type: Permanent Food Service		5740 N ORANGE BLOSSOM TRL, ORLANDO 328101023	
Inspection Date: 10/14/2009	Inspection Number: 1848745	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, CECILIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

Orange County

License Number: 5811176		CHIPOTLE	
License Type: Permanent Food Service		2850 S. KIRKMAN ROAD, ORLANDO 32811	
Inspection Date: 10/12/2009	Inspection Number: 1888892	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LAMBERT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 5806022		MILLIS JAMAICAN CAFE	
License Type: Permanent Food Service		12273 UNIVERSITY BLVD., ORLANDO 32817	
Inspection Date: 10/12/2009	Inspection Number: 1858270	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SINGH, GAJENDRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. 2 ON FLOOR UNDER THE OVEN	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 5806868		FUBAR	
License Type: Permanent Food Service		12233 UNIVERSITY BLVD, ORLANDO 32817	
Inspection Date: 10/09/2009	Inspection Number: 1918738	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SINGH, GAJENDRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. AT BAR AND BY BACK DOOR	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 5811565		RUBY TUESDAY #7182	
License Type: Permanent Food Service		11401 UNIVERSITY BLVD, ORLANDO 32817	
Inspection Date: 10/14/2009	Inspection Number: 1878870	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SINGH, GAJENDRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Orange County

License Number: 5812256 GREENS AND GRILLE
 License Type: Permanent Food Service 11325 UNIVERSITY BLVD STE 206, ORLANDO 32817

Inspection Date: 10/14/2009 Inspection Number: 1899375 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.ON FLOOR BY BACK DOOR Corrected On Site.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5804592 DOMINO'S PIZZA #3834
 License Type: Permanent Food Service 12213 UNIVERSITY BLVD, ORLANDO 328172133

Inspection Date: 10/12/2009 Inspection Number: 1899351 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only.BY INSIDE WIC DOOR	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5800701 MARYLAND FRIED CHICKEN
 License Type: Permanent Food Service 9710 E COLONIAL DR, ORLANDO 328174205

Inspection Date: 10/09/2009 Inspection Number: 1868592 Inspection Type: Routine - Food Inspection Disposition: Administrative Complaint Time Extension
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5806199 STAYBRIDGE SUITES- I-DRIVE POOL AREA
 License Type: Permanent Food Service 8480 INTERNATIONAL DRIVE, ORLANDO 32819

Inspection Date: 10/13/2009 Inspection Number: 1910649 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEGRON, LARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only,2 yrs out of date	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

Orange County

License Number: 5803323		CORKROOM (THE)	
License Type: Permanent Food Service		671 S GOLDENROD RD, ORLANDO 32822	
Inspection Date: 10/12/2009	Inspection Number: 1848252	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 5803833		BROOKLYN PIZZA	
License Type: Permanent Food Service		5681 PERSHING AVE, ORLANDO 32822	
Inspection Date: 10/12/2009	Inspection Number: 1858386	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	observed no electrical power. For reporting purposes only. Corrected On Site.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 5810209		TGI FRIDAYS #0318	
License Type: Permanent Food Service		625 N ALAFAYA TRL, ORLANDO 32828	
Inspection Date: 10/15/2009	Inspection Number: 1848111	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SINGH, GAJENDRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Orange County

License Number: 5808159		JELLYROLLS	
License Type: Permanent Food Service		2101 N EPCOT RESORT BLVD, LAKE BUENA VISTA 328301008	
Inspection Date: 10/14/2009	Inspection Number: 1909470	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TILLEY, GEMMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. In recharge zone by back exit door.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 5811872		MR K CHINESE & SUSHI	
License Type: Permanent Food Service		10395 NARCOOSSEE ROAD #400, ORLANDO 32832	
Inspection Date: 10/15/2009	Inspection Number: 1889146	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 5812163		OUTBACK STEAKHOUSE	
License Type: Permanent Food Service		10749 NARCOOSSEE RD, ORLANDO 32832	
Inspection Date: 10/15/2009	Inspection Number: 1899481	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-2	Sprinkler head spray pattern obstructed. For reporting purposes only. Corrected On Site.	NFPA 25, 5.2.1.2 Unacceptable obstructions to spray patterns shall be corrected. FOR REPORTING PURPOSES ONLY.	
License Number: 5808129		GIORDANO'S RESTAURANT & PIZZERIA	
License Type: Permanent Food Service		12151 S APOPKA VINELAND RD, LAKE BUENA VISTA 32836	
Inspection Date: 10/12/2009	Inspection Number: 1858333	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: RIVERA, JESICA M			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. In thr recharge mode by the back door.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 5810550		CHINA 3 RESTAURANT	
License Type: Permanent Food Service		11981 S APOPKA VINELAND ROAD #B4, ORLANDO 32836	
Inspection Date: 10/12/2009	Inspection Number: 1919638	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RIVERA, JESICA M			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

Orange County

License Number: 5811386 MOES SOUTHWEST GRILL
 License Type: Permanent Food Service 4192 CONROY RD STE 115, ORLANDO 32839

Inspection Date: 10/08/2009 Inspection Number: 1899409 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GORIS, WILBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only. SILVER UNIT AT THE FRONT COUNTER	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

License Number: 5800486 WINTER GARDEN RESTAURANT
 License Type: Permanent Food Service 7 S DILLARD, WINTER GARDEN 347873148

Inspection Date: 10/13/2009 Inspection Number: 1919527 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRISTWELL, HENRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Osceola County

License Number: 5910914		CHILIS GRILL & BAR	
License Type: Permanent Food Service		8180 LAURA LN, DAVENPORT 33837	
Inspection Date: 10/12/2009	Inspection Number: 1837065	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. At hood located in fry station. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 5911077		FAWLTY TOWERS TAVERN INC	
License Type: Permanent Food Service		4531 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746	
Inspection Date: 10/13/2009	Inspection Number: 1837153	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHAN, MOZHARUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 5906365		LONGHORN STEAKHOUSE OF KISSIMMEE 5055	
License Type: Permanent Food Service		5351 W IRLO BRONSON MEM HWY, KISSIMMEE 347464711	
Inspection Date: 10/15/2009	Inspection Number: 1857754	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use. In dry storage room behind shelve. For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. Extension cord in dry storage room connected to outlet, coming from ceiling. For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Palm Beach County

License Number: 6013841

RB'S CATERING

License Type: Catering

1516 TAMARIND AVE, WEST PALM BEACH 33401

Inspection Date: 10/15/2009

Inspection Number: 1092369

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6013260

ROMANA PIZZA

License Type: Permanent Food Service

45 E BLUE HERON BOULEVARD, PALM BEACH SHORES 33404

Inspection Date: 10/12/2009

Inspection Number: 1919015

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6051504

SHAWN'S ENDZONE INC

License Type: Mobile Food Dispensing Vehicle

8110 MONETARY DR, RIVIERA BEACH 33404

Inspection Date: 10/13/2009

Inspection Number: 1135229

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. k-class

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

49-07-2

Observed flammable material stored near stove. For reporting purposes only.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6012848

PALM SPRINGS PIZZA & RESTAURAN

License Type: Permanent Food Service

3087 FOREST HILL BLVD, WEST PALM BEACH 33406

Inspection Date: 10/15/2009

Inspection Number: 1865572

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.
GARBAGE ON FLOOR Repeat Violation.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6005703

HOCUS POCUS ENT INC

License Type: Permanent Food Service

865 S CONGRESS AVE, WEST PALM BEACH 334064118

Inspection Date: 10/15/2009

Inspection Number: 1875740

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6051548

THE BEST DAMN RIBS

License Type: Mobile Food Dispensing Vehicle

1736 45TH STREET, WEST PALM BEACH 33407

Inspection Date: 10/15/2009

Inspection Number: 1136493

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6011111

HONG KONG CAFE

License Type: Permanent Food Service

2100 45 ST, WEST PALM BEACH 334072016

Inspection Date: 10/15/2009

Inspection Number: 1834949

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: JONES, ANTHONY

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. For reporting purposes only. k-class

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6013137 FOSTER PUB
 License Type: Permanent Food Service 9339 ALT A1A, LAKE PARK 33408

Inspection Date: 10/12/2009 Inspection Number: 1855466 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-03-2	Observed clearance between sprinkler head and top of storage less than 18 inches. For reporting purposes only.storerroom	NFPA 13, 5.5.6 The clearance between the deflector and the top of storage shall be 18 inches or greater. FOR REPORTING PURPOSES ONLY.

License Number: 6011842 PEPPINOS ITALIAN RESTAURANT
 License Type: Permanent Food Service 1290 N MILITARY TRL, WEST PALM BEACH 33409

Inspection Date: 10/14/2009 Inspection Number: 1906844 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: JONES, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. switch for walm-in freezer	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. walk-in freezer switch	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6008426 JON SMITH SUBS #3
 License Type: Permanent Food Service 1371 N MILITARY TRL, WEST PALM BCH 334096016

Inspection Date: 10/14/2009 Inspection Number: 1886141 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JONES, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-07-2	Observed scorch marks around electrical outlet. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6019473		CECILIA VALIEME	
License Type: Permanent Food Service		2601 S MILITARY TR #41, WEST PALM BEACH 33415	
Inspection Date: 09/21/2009	Inspection Number: 1896210	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONCEPCION, MARIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39	Out of compliance: The stock of spare sprinklers shall be as follows: (a) For protected facilities having under 300 sprinklers -no fewer than 6 sprinklers, (b) For protected facilities having 300 to 1000 sprinklers - no fewer than 12 sprinklers, (c) For p	NFPA 25, 2-4.1.5 The stock of spare sprinklers shall be as follows: (a) For protected facilities having under 300 sprinklers -no fewer than 6 sprinklers, (b) For protected facilities having 300 to 1000 sprinklers - no fewer than 12 sprinklers, (c) For protected facilities having over 1000 sprinklers - no fewer than 24 sprinklers.	
License Number: 6012424		EL MOJITO CUBAN RESTAURANT	
License Type: Permanent Food Service		5760 OKEECHOBEE BLVD, WEST PALM BEACH 33417	
Inspection Date: 10/15/2009	Inspection Number: 1845069	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MIDDLETON, ELWYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6019081		RINALDIS DELI INC	
License Type: Permanent Food Service		5029 A OKEECHOBEE BLVD, WEST PALM BEACH 33417	
Inspection Date: 10/15/2009	Inspection Number: 1896291	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIDDLETON, ELWYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. front door.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6019886		THE BEST JAMACIAN BAKERY AND RESTAURANT	
License Type: Permanent Food Service		6076 OKEECHOBEE BLVD #42 & #43, WEST PALM BEACH 33417	
Inspection Date: 10/13/2009	Inspection Number: 1886029	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIDDLETON, ELWYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Palm Beach County

License Number: 6019680

OLD PALM GOLF COURSE SNACK BAR

License Type: Permanent Food Service

11889 OLD PALM DR, PALM BEACH GARDENS 33418

Inspection Date: 10/14/2009

Inspection Number: 1875928

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIDDLETON, ELWYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. expired 4/27/09.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6019681 OLD PALM GOLF CLUB
 License Type: Permanent Food Service 11889 OLD PALM DR, PALM BEACH GARDENS 33418

Inspection Date: 10/14/2009 Inspection Number: 1896321 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIDDLETON, ELWYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. expired 4/27/09.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6013000 WING WAH EXPRESS
 License Type: Permanent Food Service 115 N CONGRESS AVE, BOYNTON BCH 334261223

Inspection Date: 10/15/2009 Inspection Number: 1834585 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SHAPIRO, STEWART

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6004719 SKEETER'S LOUNGE
 License Type: Permanent Food Service 1403 NW 2 AVE, BOYNTON BCH 334263425

Inspection Date: 10/12/2009 Inspection Number: 1855140 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: SHAPIRO, STEWART

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

Palm Beach County

License Number: 6010956		SNAPPER'S SEAFOOD	
License Type: Permanent Food Service		398 N CONGRESS AVE, BOYNTON BCH 334263466	
Inspection Date: 10/14/2009	Inspection Number: 1844861	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DERVIN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6012445		SUBWAY #20878	
License Type: Permanent Food Service		489 NE 20 ST, BOCA RATON 33431	
Inspection Date: 10/14/2009	Inspection Number: 1865168	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. --- rear exit blocked by empty boxes	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
License Number: 6019354		ANNIES PIZZA	
License Type: Permanent Food Service		3731 FAU BLVD, BOCA RATON 33431	
Inspection Date: 10/16/2009	Inspection Number: 1885611	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.	
License Number: 6020220		SUBPERB INC	
License Type: Permanent Food Service		3350 NW 2 AVE STE# B8, BOCA RATON 33431	
Inspection Date: 10/13/2009	Inspection Number: 1906279	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Palm Beach County

License Number: 6010044

ANNAVINCENZO'S RISTORANTE ITAL

License Type: Permanent Food Service

1930 NE 5 AVE, BOCA RATON 334317702

Inspection Date: 10/14/2009

Inspection Number: 1854880

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. --- ABC on floor at restaurant entry.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. --- hallway to rear exit and public restrooms.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6012494

ADDISON (THE)

License Type: Permanent Food Service

2 E CAMINO REAL, BOCA RATON 33432

Inspection Date: 10/15/2009

Inspection Number: 1885571

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. --- on floor behind service cocktail bar.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6020085

ANATOLIA MEDITERRANEAN CUISINE

License Type: Permanent Food Service

212 S FEDERAL HWY, BOCA RATON 33432

Inspection Date: 10/14/2009

Inspection Number: 1844595

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. --- on floor @ entry to kitchen.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6019204

SUBWAY #15043

License Type: Permanent Food Service

22191 S POWERLINE RD, BOCA RATON 33433

Inspection Date: 10/13/2009

Inspection Number: 1875410

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIERI, CYNTHIA

Violation CodeObservationViolation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. LARGE TRASH CAN IN FRONT OF BACK DOOR

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6012036

TROY'S BBQ

License Type: Permanent Food Service

1017 N FEDERAL HWY, BOYNTON BCH 33435

Inspection Date: 10/09/2009

Inspection Number: 1875618

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PIERI, CYNTHIA

Violation CodeObservationViolation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only. BACK DOOR

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

Palm Beach County

License Number: 6000071		BANANA BOAT	
License Type: Permanent Food Service		739 E OCEAN AVE, BOYNTON BCH 334355101	
Inspection Date: 10/17/2009	Inspection Number: 1865434	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MORALES, DAMIAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6019548		PINEAPPLES	
License Type: Permanent Food Service		1200 TOWN CENTER DRIVE STE 101, JUPITER 33458	
Inspection Date: 10/13/2009	Inspection Number: 1917295	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.dinning room	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6011196		PAPA JOHN'S #491	
License Type: Permanent Food Service		812 N OLD DIXIE HWY, JUPITER 33458-4900	
Inspection Date: 10/09/2009	Inspection Number: 1876060	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.abc/kitchen	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 6005704		FOUR BROTHERS ITALIAN KITCHEN	
License Type: Permanent Food Service		2495 N 10 AVE, LAKE WORTH 33461	
Inspection Date: 09/16/2009	Inspection Number: 1663581	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: CONCEPCION, MARIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-24-2	Hood filters are not easily accessible. For reporting purposes only. NOT INSTALL WHILE COOKING	NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY	
License Number: 6051571		CEE CEE'S HOT DOG DEPOT	
License Type: Mobile Food Dispensing Vehicle		522 W LANTANA RD, LANTANA 33462	
Inspection Date: 10/16/2009	Inspection Number: 1138906	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MORALES, DAMIAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-37-2	Portable fire extinguisher missing from designated location. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

Palm Beach County

License Number: 6004104		ATLANTIS C C REST	
License Type: Permanent Food Service		190 ATLANTIS BLVD, BOYNTON BEACH 33462-1111	
Inspection Date: 10/09/2009	Inspection Number: 1896133	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIERI, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.KITCHEN	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 6006298		ROYAL CAFE	
License Type: Permanent Food Service		75 E INDIANTOWN RD STE 509, JUPITER 33477	
Inspection Date: 10/13/2009	Inspection Number: 1876100	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DERVIN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. 1/broken hood filter.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. k cLass on floor.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. front counter.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6019345		MCDONALDS @ TOWN CENTER	
License Type: Permanent Food Service		21150 S MILITARY TR, BOCA RATON 33486	
Inspection Date: 10/12/2009	Inspection Number: 1885669	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PIERI, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only.PAPER CONTAINER STACKS	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	

Pasco County

License Number: 6113204		COSI	
License Type: Permanent Food Service		28139 PASEO DR #210, WESLEY CHAPEL 33543	
Inspection Date: 10/15/2009	Inspection Number: 1898433	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only. Corrected On Site.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	
License Number: 6102514		TACO BELL #19723	
License Type: Permanent Food Service		22744 SR 54, LUTZ 33549	
Inspection Date: 10/12/2009	Inspection Number: 1888096	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.(ABC)	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 6102535		GOLDEN INN CHINESE REST	
License Type: Permanent Food Service		23042 SR 54, LUTZ 33549	
Inspection Date: 10/12/2009	Inspection Number: 1877924	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.(class - K)	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.(kitchen)	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

Pasco County

License Number: 6102835 CHINA GATE
 License Type: Permanent Food Service 11336 RIDGE RD, NEW PORT RICHEY 34654

Inspection Date: 10/16/2009 Inspection Number: 1908558 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6112937 PANERA BREAD CO #921
 License Type: Permanent Food Service 3234 LITTLE RD, NEW PORT RICHEY 34655

Inspection Date: 10/14/2009 Inspection Number: 1898109 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BROTHAG, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. kitchen area	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. Bakery area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6102883 ANTHONY'S ITALIAN RESTAURANT
 License Type: Permanent Food Service 8809 MITCHELL BLVD, TRINITY 34655

Inspection Date: 10/14/2009 Inspection Number: 1887812 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BROTHAG, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6102563 ARGENTO ITALIAN BISTRO
 License Type: Permanent Food Service 15925 HWY 19, HUDSON 34667

Inspection Date: 10/15/2009 Inspection Number: 1847013 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.
47-03-2	Violation: 47-03-2 Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

License Number: 6102782 INTERNATIONAL HOUSE OF PANCAKES 36-160
 License Type: Permanent Food Service 12426 US HWY 19 N, HUDSON 34667

Inspection Date: 10/15/2009 Inspection Number: 1898297 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
45-10-2	Pull station for fire suppression system inaccessible. For reporting purposes only. Corrected On Site.	NFPA 96, 10.5.1 A readily accessible means for manual activation shall be located between 42 inches and 48 inches above the floor, be accessible in the event of a fire, be located in a path of egress, and clearly identify the hazard protected. FOR REPORTING PURPOSES ONLY.
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only. Large propane tank stored in electrical/water heater room.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 6102847 HURRICANE HANK'S
 License Type: Permanent Food Service 14333 CRABTRAP CT, HUDSON 34667

Inspection Date: 10/10/2009 Inspection Number: 1831185 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Violation: 47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. Used for lighting at dance floor.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pasco County

License Number: 6101271

TOWNE HOUSE PIZZA REST

License Type: Permanent Food Service

9215 SR 52, HUDSON 34669

Inspection Date: 10/15/2009

Inspection Number: 1888046

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GLENN, DAVID

Violation Code

Observation

Violation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only. Behind bar.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-05-2 Violation: 47-05-2
Observed a splitter/multi-plug adapter in use. For reporting purposes only. Behind bar.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6208650

GYROS & SEAFOOD EXPRESS

License Type: Permanent Food Service

1760 9 ST SOUTH, ST. PETERSBURG 33701

Inspection Date: 10/15/2009

Inspection Number: 1897063

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WAGNER, MARGARET

Violation CodeObservationViolation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6212880

BOSTON MARKET #163

License Type: Permanent Food Service

3740 N 4 ST, ST PETERSBURG 337041314

Inspection Date: 10/16/2009

Inspection Number: 1886775

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WAGNER, MARGARET

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. on floor under handwash sink For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6215128

SONNY'S REAL PIT BBQ

License Type: Permanent Food Service

3650 TYRONE BLVD, ST PETERSBURG 33710

Inspection Date: 10/15/2009

Inspection Number: 1886489

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BURKE, LAWRENCE

Violation CodeObservationViolation Citation

45-34-2 Fire alarm control panel has no tag/tag not for most recent service, repair, test or inspection. For reporting purposes only.[expired]

69A-48.006(1) FAC (1) A standard Fire Alarm tag meeting the requirements of this rule shall be securely affixed to the fire alarm control panel of each fire alarm system which is installed, and each time such system is serviced, tested, repaired, inspected, or improved by any person. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6205218		DAIRY QUEEN TYRONE	
License Type: Permanent Food Service		6901 N 22 AVE, ST. PETERSBURG 33710	
Inspection Date: 10/14/2009	Inspection Number: 1876332	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.[under far register]	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 6215615		GOOD FORTUNE BUFFET	
License Type: Permanent Food Service		1030 58 ST, ST. PETERSBURG 33710	
Inspection Date: 10/12/2009	Inspection Number: 1919575	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

License Number: 6213583		SUMMIT BUILDING RESTAURANT	
License Type: Permanent Food Service		13575 58 ST N #200, CLEARWATER 33760	
Inspection Date: 10/15/2009	Inspection Number: 1915039	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: PORTER, LINDSAY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 6215171		BONEFISH GRILL	
License Type: Permanent Food Service		2519 MCMULLEN BOOTH RD, CLEARWATER 33761	
Inspection Date: 10/13/2009	Inspection Number: 1845941	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRAIG, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.by cooler/freezer	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

Pinellas County

License Number: 6210024

MUGS N JUGS RESTAURANT

License Type: Permanent Food Service

14100 US HIGHWAY 19 N, CLEARWATER 33764

Inspection Date: 10/12/2009

Inspection Number: 1866126

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVIS, CAROL S

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6206289

WENDYS OLD FASHION HAMBURGERS

License Type: Permanent Food Service

2290 GULF TO BAY BLVD, CLEARWATER 33765

Inspection Date: 10/08/2009

Inspection Number: 1919585

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WINSOR, KIMBERLY

Violation CodeObservationViolation Citation

39-05-2 Ventilation inadequate as evidenced by smoke in kitchen area. For reporting purposes only....recommended change fryer more frequently

NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY

47-16-2 Electrical outlet missing cover plate. For reporting purposes only...behind office door

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6206763

BURGER KING # 95

License Type: Permanent Food Service

7371 SEMINOLE BLVD, SEMINOLE 337725939

Inspection Date: 10/15/2009

Inspection Number: 1866280

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation

47-16-2 Electrical outlet missing cover plate. For reporting purposes only. in storage area near back door

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Pinellas County

License Number: 6211599

DOMINO'S PIZZA #3159

License Type: Permanent Food Service

12735 STARKEY RD, LARGO 33773

Inspection Date: 10/15/2009

Inspection Number: 1919819

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PORTER, LINDSAY

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.(near microwave)

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6216000

VINNY'S PIZZERIA

License Type: Permanent Food Service

14479 WALSINGHAM RD, LARGO 33774

Inspection Date: 10/16/2009

Inspection Number: 1919359

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning Issued

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation

45-07-2 Observed misalignment of hood suppression system nozzles. For reporting purposes only. several areas not covered over equipment

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. outside back door to equipment

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6209682

MICKEY QUINN'S PUB

License Type: Permanent Food Service

13071 PARK BLVD, SEMINOLE 33776

Inspection Date: 10/14/2009

Inspection Number: 1835569

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only. in kitchen area near deli style cooler

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6305718

CONE N CONEY

License Type: Permanent Food Service

1428 N COMBEE RD, LAKELAND 33801

Inspection Date: 10/13/2009

Inspection Number: 1919066

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WHITE, RICKY

Violation CodeObservationViolation Citation

45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

45-31-2

Violation: 45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 6303161

JULIANNI'S FINE DINING & CATERING

License Type: Permanent Food Service

3125 US HWY 98 S, LAKELAND 33803

Inspection Date: 10/16/2009

Inspection Number: 1810373

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITE, RICKY

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6306905

KFC

License Type: Permanent Food Service

3025 S FLORIDA AVE, LAKELAND 33803

Inspection Date: 10/12/2009

Inspection Number: 1846477

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: WHITE, RICKY

Violation CodeObservationViolation Citation

46-12-2

Violation: 46-12-2

Emergency lighting illumination insufficient. For reporting purposes only.

NFPA 101, 7.9.2.1 Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 foot-candle and, at any point, not less than 0.1 foot-candles, measured along the path of egress at floor level. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6306942

CHINA WOK

License Type: Permanent Food Service

3686 HARDEN BLVD, LAKE LAND 33803

Inspection Date: 10/15/2009

Inspection Number: 1866983

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITE, RICKY

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6302342

ORANGE BOWL LANES / LUCKY'S

License Type: Permanent Food Service

1300 KENNEDY BLVD, LAKE LAND 338103802

Inspection Date: 10/13/2009

Inspection Number: 1836421

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only./outside bar area.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6307793

SUBWAY AT HIGHLAND CITY TOWN CENTER

License Type: Permanent Food Service

5253 HWY 98 SOUTH, STE. 8-E, LAKE LAND 33812

Inspection Date: 10/12/2009

Inspection Number: 1919663

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only./ trash blocking backdoor

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

Polk County

License Number: 6350540

TAQUERIA LA MICHOACANA

License Type: Mobile Food Dispensing Vehicle

1725 W MEMORIAL BLVD, LAKELAND 33815

Inspection Date: 10/14/2009

Inspection Number: 1134018

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only./ across top of pick-up window ledge.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6300259

THE FROSTPROOF DINER

License Type: Permanent Food Service

18 W WALL ST, FROSTPROOF 33843

Inspection Date: 10/15/2009

Inspection Number: 1919059

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WHITE, CHERYL

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6305474

MANNY'S ORIGINAL CHOPHOUSE

License Type: Permanent Food Service

210 SR 60 W, LAKE WALES 33853-4411

Inspection Date: 10/15/2009

Inspection Number: 1897829

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6305665

RED LOBSTER

License Type: Permanent Food Service

230 CYPRESS GARDENS BLVD, WINTER HAVEN 33880

Inspection Date: 10/16/2009

Inspection Number: 1867092

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

Polk County

License Number: 6350552

SUNSHINE VENDING

License Type: Mobile Food Dispensing Vehicle

7000 LUCERNE PARK RD, WINTER HAVEN 33881

Inspection Date: 10/14/2009

Inspection Number: 1137773

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROMANO, JIMMIE

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6305043

CHECKERS #790

License Type: Permanent Food Service

940 HAVENDALE BLVD, WINTER HAVEN 338811353

Inspection Date: 10/12/2009

Inspection Number: 1836193

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROMANO, JIMMIE

Violation CodeObservationViolation Citation

47-13-2

Circuit breaker box blocked and/or inaccessible. For reporting purposes only.

NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

Putnam County

License Number: 6400241 VICK'S SUPPER CLUB
 License Type: Permanent Food Service 207 N 18 ST, PALATKA 321773113

Inspection Date: 10/15/2009 Inspection Number: 1871025 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DOHERTY, BRENDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-40-2	Portable fire extinguisher with expired inspection tag. For reporting purposes only.	61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

License Number: 6400578 LITTLE CAESARS #4060
 License Type: Permanent Food Service 841 S HWY 19, PALATKA 321779396

Inspection Date: 10/09/2009 Inspection Number: 1916420 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: DOHERTY, BRENDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Violation: 47-16-2 Electrical outlet missing cover plate. For reporting purposes only. BROKEN, NEAR MOP SINK	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Santa Rosa County

License Number: 6700164

REGGIE'S SEAFOOD & BBQ

License Type: Permanent Food Service

7040 HWY 90, MILTON 32583

Inspection Date: 10/14/2009

Inspection Number: 1840326

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WIGGINS, GISELE

Violation Code

Observation

Violation Citation

47-16-2 Electrical outlet missing cover plate, walkin freezer. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

Sarasota County

License Number: 6804056		TACO BELL #24556	
License Type: Permanent Food Service		3510 CLARK RD, SARASOTA 34231	
Inspection Date: 10/14/2009	Inspection Number: 1851653	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DILLARD, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exit in back room, empty boxes and cardboard in front of exit door. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

License Number: 6804425		SAM SELTZER'S STEAKHOUSE #4	
License Type: Permanent Food Service		7111 S TAMIAMI TRL, SARASOTA 34231	
Inspection Date: 10/12/2009	Inspection Number: 1882463	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DILLARD, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
39-05-2	Ventilation inadequate as evidenced by smoke in kitchen area. For reporting purposes only. Smoke from grill under hood.	NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY	

License Number: 6803453		CAFE GABBIANO	
License Type: Permanent Food Service		5104 OCEAN BLVD, SARASOTA 34242	
Inspection Date: 10/14/2009	Inspection Number: 1902894	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: POSA, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-07-2	Exit sign missing. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.	

License Number: 6804802		CLAYTON'S SIESTA GRILLE	
License Type: Permanent Food Service		1256 OLD STICKNEY POINT RD, SARASOTA 34242	
Inspection Date: 10/14/2009	Inspection Number: 1892564	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: POSA, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

Sarasota County

License Number: 6804825

SAL & TONY'S PIZZERIA

License Type: Permanent Food Service

545 S TAMIAMI TRL, VENICE 34285

Inspection Date: 10/16/2009

Inspection Number: 1913133

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: STEVENS, DAVID

Violation Code

Observation

Violation Citation

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.rear walkin cooler hallway/ceiling fan

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Seminole County

License Number: 6904671

TJS SEAFOOD SHACK

License Type: Permanent Food Service

197 E MITCHELL HAMMOCK RD, OVIEDO 32765

Inspection Date: 10/14/2009

Inspection Number: 1869945

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PLEICONES, KIM

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6903439

INTERNATIONAL HOUSE OF PANCAKE

License Type: Permanent Food Service

17 ALAFAYA WOODS BLVD, OVIEDO 327656233

Inspection Date: 10/13/2009

Inspection Number: 1880150

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PLEICONES, KIM

Violation CodeObservationViolation Citation

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. hasp locks on storage rooms by ice machine

Repeat Violation.

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 6900807

CHURCHS CHICKEN

License Type: Permanent Food Service

2561 FRENCH AVE S, SANFORD 32773

Inspection Date: 10/14/2009

Inspection Number: 1916873

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

St. Johns County

License Number: 6501017

ATHENA RESTAURANT

License Type: Permanent Food Service

14 CATHEDRAL PL, ST AUGUSTINE 320844417

Inspection Date: 10/09/2009

Inspection Number: 1880972

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Time Extension

Inspector Name: GOSAI, MATT

Violation CodeObservationViolation Citation

47-04-2

Violation: 47-04-2

Observed frayed/spliced electrical wires. For reporting purposes only. UNDER
SHELF AT MAKETABLE

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6501337

CRACKER BARREL

License Type: Permanent Food Service

2441 SR 16, ST AUGUSTINE 32092

Inspection Date: 10/08/2009

Inspection Number: 1901293

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LAMIE, ERNEST

Violation CodeObservationViolation Citation

15-25-2

Hood filters not equipped with a drip tray. For reporting purposes only.

NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

License Number: 6500849

REEF (THE)

License Type: Permanent Food Service

4100 COASTAL HWY, ST AUGUSTINE 320951419

Inspection Date: 10/15/2009

Inspection Number: 1839804

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. SMALL GAP IN HOODFILTERS

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

St. Lucie County

License Number: 6650214		EL TORITO GROCERIES	
License Type: Mobile Food Dispensing Vehicle		3500 OKEECHOBEE RD, FORT PIERCE 34947	
Inspection Date: 10/16/2009	Inspection Number: 1136665	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6602830		BUCKSHOT BAY ON THE HARD	
License Type: Permanent Food Service		109 FISHERMANS WHARF, FORT PIERCE 34950	
Inspection Date: 10/12/2009	Inspection Number: 1919635	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, DIANNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-13-2	Emergency light does not function when tested. For reporting purposes only. Most lights throughout facility.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.	
License Number: 6602856		NEONNOY-S CORP	
License Type: Permanent Food Service		217 ORANGE AVENUE, FORT PIERCE 34950	
Inspection Date: 10/14/2009	Inspection Number: 1837411	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: DAVIS, DIANNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Violation: 46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Door adjacent to sushi bar has 3 locks and all are locked.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Door adjacent to sushi bar has 3 locks and all are locked.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

St. Lucie County

License Number: 6601883 TIKI BAR & RESTAURANT
 License Type: Permanent Food Service 2 AVE A, FT PIERCE 349504410

Inspection Date: 10/13/2009 Inspection Number: 1909184 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 6601898 SUSIE Q'S
 License Type: Permanent Food Service 263 SE PORT ST LUCIE BLVD, PORT SAINT LUCIE 34952

Inspection Date: 10/15/2009 Inspection Number: 1868229 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 6602892 FRATELLI ITALIAN MARKET & DELI INC
 License Type: Permanent Food Service 1156 SE PORT ST LUCIE BLVD, PORT ST LUCIE 34952

Inspection Date: 10/15/2009 Inspection Number: 1847819 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 6602911 TACO BELL 24715
 License Type: Permanent Food Service 1840 SW GATLIN BLVD, PORT ST LUCIE 34953

Inspection Date: 10/08/2009 Inspection Number: 1919755 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress, rear exit blocked by large pile of empty boxes. For reporting purposes only. Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6600746 CAPS
 License Type: Permanent Food Service 10999 S OCEAN DR, JENSEN BEACH 34957

Inspection Date: 10/14/2009 Inspection Number: 1878592 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Both hood's not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

St. Lucie County

License Number: 6602812

CARVEL/CINNABON

License Type: Permanent Food Service

1405 NW ST LUCIE WEST BOULEVARD, PORT ST LUCIE 34986

Inspection Date: 10/15/2009

Inspection Number: 1868224

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PARNASS, LAUREN P

Violation Code

Observation

Violation Citation

47-05-2

Observed a splitter/multi-plug adapter in use, 6 way adapter plug at waffle iron area. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Suwannee County

License Number: 7100070

KENS BAR-B-Q OF LIVE OAK

License Type: Permanent Food Service

1536 S OHIO AVE, LIVE OAK 320604522

Inspection Date: 10/15/2009

Inspection Number: 1890664

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Volusia County

License Number: 7406044

THE COQUINA DAYTONA BEACH INC

License Type: Permanent Food Service

544 S PALMETTO AVE, DAYTONA BCH 32114

Inspection Date: 10/12/2009

Inspection Number: 1848583

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

46-02-2

Observed lock on exit door that requires a key, tool or special knowledge to open/kitchen door. For reporting purposes only.

NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 7404613

CHECKERS #6260

License Type: Permanent Food Service

1174 BEVILLE RD, DAYTONA BEACH 32114

Inspection Date: 10/12/2009

Inspection Number: 1838170

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces over grill. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 7405875

KAHUNA'S BAR AND GRILL

License Type: Permanent Food Service

530 SEABREEZE BLVD, DAYTONA BEACH 32114

Inspection Date: 10/13/2009

Inspection Number: 1899817

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARRETT, KAREN

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher size K not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

Volusia County

License Number: 7406373

RED TAILS BAR & GRILLE

License Type: Permanent Food Service

230 S BEACH ST, DAYTONA BEACH 32114

Inspection Date: 10/12/2009

Inspection Number: 1858676

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor by entrance to bar. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress/stairway from second floor to ground level. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period from upstairs bar to office. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 7406687

MIMI'S CAFE

License Type: Permanent Food Service

800 NORTH ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 10/14/2009

Inspection Number: 1848442

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARRETT, KAREN

Violation CodeObservationViolation Citation

47-08-2	Observed electrical wiring in disrepair.capped wires in conduit under drain pan .For reporting purposes only. Corrected On Site.by electrician.on premisis.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
---------	--	--

Volusia County

License Number: 7406906

FAIRWAY GRILL AT HOLIDAY INN

License Type: Permanent Food Service

137 AUTOMALL CIRCLE, DAYTONA BEACH 32124

Inspection Date: 10/12/2009

Inspection Number: 1899819

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor/office. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 7406903

CHEFS CAFE

License Type: Permanent Food Service

77 N CHARLES RICHARD BEALL BLVD, DEBARY 32713

Inspection Date: 10/13/2009

Inspection Number: 1919816

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRASKA, GEORGIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher in dining room not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

Wakulla County

License Number: 7500290

POSEY'S UP THE CREEK

License Type: Permanent Food Service

1506 COASTAL HWY, PANACEA 32346

Inspection Date: 10/14/2009

Inspection Number: 1902514

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation CodeObservationViolation Citation

47-08-2

Observed electrical wiring in disrepair. Exposed wires at light switch for walk in freezer.
For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 7502855

HOOK WRECK HENRY'S

License Type: Permanent Food Service

99 ROCK LANDING RD, PANACEA 32346

Inspection Date: 10/14/2009

Inspection Number: 1840887

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WRIGHT, ANDREW

Violation CodeObservationViolation Citation

47-08-2

Observed electrical wiring in disrepair. Taped cord on toaster. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

Walton County

License Number: 7601516

CAFE THIRTY A

License Type: Permanent Food Service

3899 E COUNTY HIGHWAY 30A, SEAGROVE 32459

Inspection Date: 10/12/2009

Inspection Number: 1912371

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation Code

Observation

Violation Citation

15-28-1

Hood filters are not tight-fitting and firmly held in place - leaving open spaces...chef stated when establishment closes in December the hood system will be cleaned and new filters ordered

NFPA 96, 6.2.3.3:: Grease filters shall be arranged so that all exhaust air shall pass through the grease filters.