

**Alachua County**

License Number: 1103147

SHARAB LOUNGE

License Type: Permanent Food Service

109 S MAIN ST, GAINESVILLE 32601

Inspection Date: 03/12/2010

Inspection Number: 1891489

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code      ObservationViolation Citation

45-36-2      Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

45-40-2      Portable fire extinguisher with expired inspection tag. For reporting purposes only.

61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

47-06-2      Observed extension cord in use for non-temporary period. For reporting purposes only. THROUGHOUT ESTABLISHMENT

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1102788

EL NORTENO MEXICAN RESTAURANT

License Type: Permanent Food Service

516 NW 75 ST, GAINESVILLE 32607

Inspection Date: 03/15/2010

Inspection Number: 1870208

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRENNE, LILYANN

Violation Code      ObservationViolation Citation

46-12-2      Emergency lighting illumination insufficient exit sign at front door. For reporting purposes only.

NFPA 101, 7.9.2.1 Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 foot-candle and, at any point, not less than 0.1 foot-candles, measured along the path of egress at floor level. FOR REPORTING PURPOSES ONLY.

47-06-2      Observed extension cord in use for non-temporary period for tv by kitchen.For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Alachua County**

License Number: 1102832

LOS AVINA

License Type: Permanent Food Service

201 W SR 24, ARCHER 32618-5431

Inspection Date: 03/18/2010

Inspection Number: 1839196

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

45-39-2

Violation: 45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. class k For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1102230

CAFE RISQUE

License Type: Permanent Food Service

17035 SE CR 234, MICANOPY 32667

Inspection Date: 03/18/2010

Inspection Number: 1870192

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WRENNE, LILYANN

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord with a 3 way multi adapter in use for non-temporary period at slicer. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period for game machine. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1103011

BLUE HIGHWAY A PIZZERIA

License Type: Permanent Food Service

204 N E HWY 441, MICANOPY 32667

Inspection Date: 03/18/2010

Inspection Number: 1890613

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WRENNE, LILYANN

Violation CodeObservationViolation Citation

45-22-2

Portable fire extinguisher(s) obstructed from view behind mixer and trash can. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

**Alachua County**

License Number: 1102431

HARDEE'S #1501533

License Type: Permanent Food Service

125 N MAIN ST, WALDO 32694

Inspection Date: 03/17/2010

Inspection Number: 1881295

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation Code

Observation

Violation Citation

15-26-2

Observed exhaust system operated with filters removed. For reporting purposes only. ABOVE FRYERS

NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.

**Baker County**

License Number: 1250025

DAISY'S BAR-B-Q

License Type: Mobile Food Dispensing Vehicle

336 W MACCLENNY AVE, MACCLENNY 32063

Inspection Date: 03/18/2010

Inspection Number: 1138008

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

48-08-2

LP-gas tanks not protected from vehicle damage. For reporting purposes only.  
Three propane tanks on ground in front of mobile unit.

NFPA 58, 3.2.4.2 LP-gas containers or systems of which they are a part shall be protected from damage from vehicles. FOR REPORTING PURPOSES ONLY.

**Bay County**

License Number: 1305319

Q'S ICE CREAM

License Type: Permanent Food Service

1431 MARTIN LUTHER KING BLVD, PANAMA CITY 32401

Inspection Date: 03/15/2010

Inspection Number: 1871502

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, JANIE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1300012

MCDONALDS

License Type: Permanent Food Service

717 HARRISON AVE, PANAMA CITY 32405

Inspection Date: 03/15/2010

Inspection Number: 1871500

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, JANIE

Violation CodeObservationViolation Citation

46-05-2

Observed hasp lock on walkin cooler doors.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1305424

JAZMINE THAI CUISINE

License Type: Permanent Food Service

2629 THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 03/18/2010

Inspection Number: 1927845

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DESHAZIER, ERNEST

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. observed extension cord in the kitchen by the steamer.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Bay County**

License Number: 1300179

CAPTAIN ANDERSON'S

License Type: Permanent Food Service

5551 N LAGOON DR, PANAMA CITY BCH 324087915

Inspection Date: 03/18/2010

Inspection Number: 1881697

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DESHAZIER, ERNEST

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only in the salad area.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1305336

CASTAWAYS

License Type: Permanent Food Service

102 CARILLON MARKET ST #100, PANAMA CITY BEACH 32413

Inspection Date: 03/18/2010

Inspection Number: 1925609

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DESHAZIER, ERNEST

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only in the kitchen area by the microwave.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1305401

CRAZY ALLIGATOR LLC

License Type: Permanent Food Service

15514 FRONT BEACH ROAD, PANAMA CITY BEACH 32413

Inspection Date: 03/16/2010

Inspection Number: 1917827

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DESHAZIER, ERNEST

Violation CodeObservationViolation Citation

48-11-2

Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only. Observed LP-gas cylinder in the room next door.

NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

**Brevard County**

License Number: 1506011		JIMMY & CORYS II INC	
License Type: Permanent Food Service		3490 GARDEN STREET, TITUSVILLE 32796	
Inspection Date: 03/16/2010	Inspection Number: 1927771	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZALESKI, AMY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-12-2	Observed trouble/alarm light lighted on fire alarm control panel. For reporting purposes only.	NFPA 72, 7.1.1.1, 7.3.1 and 7.4.3 Inspection, testing, and maintenance programs shall satisfy the requirements of this code, conform to the equipment manufacturer's recommendations, and verify proper operation of the fire alarm system. Visual Inspection. Visual Inspection shall be performed in accordance with the schedules in this chapter or more frequently where required by the authority having jurisdiction. The visual inspection shall be made to ensure that there are no changes that can affect equipment performance. All apparatus requiring rewinding or resetting to maintain normal operation shall be restored to normal as promptly as possible after each test and alarm and kept in normal condition for operation. All test signals received shall be recorded to indicate date, time, and type. FOR REPORTING PURPOSES ONLY.	
License Number: 1503751		TAPPS PUB	
License Type: Permanent Food Service		4711 SUITE 30 N E BABCOCK ST, PALM BAY 32905	
Inspection Date: 03/18/2010	Inspection Number: 1838812	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOODS, CRYSTAL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.mens rest room under soap dispenser	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1504826		LOREENS VILLAGE CAFE	
License Type: Permanent Food Service		2280 NE HARRIS AVE UNIT 6 & 7, PALM BAY 32905	
Inspection Date: 03/15/2010	Inspection Number: 1838846	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WEIMER, EDWIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only.the k class at the back door has a coat over it	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 1504984		PORT CANAVERAL YACHT CLUB	
License Type: Permanent Food Service		910 MULLET RD, CAPE CANAVERAL 32920	
Inspection Date: 03/18/2010	Inspection Number: 1868329	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.Filters in wrong way on hood	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Brevard County**

License Number: 1506064 LATIN FOOD  
 License Type: Permanent Food Service 412 HARBOR CITY BLVD, MELBOURNE 32935

Inspection Date: 03/15/2010 Inspection Number: 1898940 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: WOODS, CRYSTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-07-2	Observed char grill not under suppression system nozzles. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.
45-11-2	Observed cooking equipment in use while hood suppression/exhaust system is turned off. Corrected On Site.turned on	NFPA 96, 11.1.6 Cooking equipment shall not be operated while its fire-extinguishing system or exhaust system is nonoperational or otherwise impaired. FOR REPORTING PURPOSES ONLY.

License Number: 1504393 BOSTON MARKET #0349  
 License Type: Permanent Food Service 2450 N WICKHAM RD, MELBOURNE 329358125

Inspection Date: 03/17/2010 Inspection Number: 1837338 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WOODS, CRYSTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.abc on floor in kitchen	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 1506119 OUTRIGGERS BAR & GRILL INC  
 License Type: Permanent Food Service 4015 MAIN ST, MICCO 32976

Inspection Date: 03/17/2010 Inspection Number: 1926964 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate/outside storage area For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1620739 FRESH CATCH SEAFOOD INC  
 License Type: Permanent Food Service 1050 W PEMBROKE RD, HALLANDALE 33009

Inspection Date: 03/18/2010 Inspection Number: 1874623 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 1621464 NORTH APRON FOOD COURT  
 License Type: Permanent Food Service 901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 03/17/2010 Inspection Number: 1874639 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.k class	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1621470 CHRISTINE LEE'S AT GULFSTREAM PARK  
 License Type: Permanent Food Service 901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 03/17/2010 Inspection Number: 1884868 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-40-2	Portable fire extinguisher with no approved inspection tag. For reporting purposes only.k.class	61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1622046		PHILLY SUBS & GRILL	
License Type: Permanent Food Service		901 N BROADWALK, HOLLYWOOD 33019	
Inspection Date: 03/15/2010	Inspection Number: 1926866	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 1616203		MARCELLAS RESTAURANT & PIZZA	
License Type: Permanent Food Service		12305 PEMBROKE RD, PEMBROKE PINES 33025	
Inspection Date: 03/16/2010	Inspection Number: 1905420	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 1621857		LITTLE CAESARS	
License Type: Permanent Food Service		12705 MIRAMAR PKWY, MIRAMAR 33027	
Inspection Date: 03/19/2010	Inspection Number: 1905412	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 1620988		EMPANADA FACTORY	
License Type: Permanent Food Service		17722 PINES BLVD, HOLLYWOOD 33029	
Inspection Date: 03/18/2010	Inspection Number: 1905424	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

**Broward County**

License Number: 1618221		SANTINO'S PIZZA / PASTA	
License Type: Permanent Food Service		18267 PINES BLVD, PEMBROKE PINES 33029	
Inspection Date: 03/17/2010	Inspection Number: 1894901	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated, dinning room. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1619567		POLLO TROPICAL #51	
License Type: Permanent Food Service		17539 PINES BLVD, PEMBROKE PINES 33029	
Inspection Date: 03/18/2010	Inspection Number: 1884742	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-10-2	Pull station for fire suppression system inaccessible, box next to it. For reporting purposes only. Corrected On Site.	NFPA 96, 10.5.1 A readily accessible means for manual activation shall be located between 42 inches and 48 inches above the floor, be accessible in the event of a fire, be located in a path of egress, and clearly identify the hazard protected. FOR REPORTING PURPOSES ONLY.	
45-36-2	1 Hood suppression system tag missing . For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 1619702		PAPA JOHNS PIZZA # 2675	
License Type: Permanent Food Service		17535 PINES BLVD, PEMBROKE PINES 33029	
Inspection Date: 03/17/2010	Inspection Number: 1874489	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged, cook's line. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
49-06-2	Observed flammable material stored on top of water heater. For reporting purposes only. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 1620968		CHICK 'N CHOP ON THE GRILL	
License Type: Permanent Food Service		18255 PINES BLVD, PEMBROKE PINES 33029	
Inspection Date: 03/16/2010	Inspection Number: 1894921	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-10-2	Pull station's pin missing on the fire suppression system. For reporting purposes only.	NFPA 96, 10.5.1 A readily accessible means for manual activation shall be located between 42 inches and 48 inches above the floor, be accessible in the event of a fire, be located in a path of egress, and clearly identify the hazard protected. FOR REPORTING PURPOSES ONLY.	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	

**Broward County**

License Number: 1617436		AMAZING THAI JAPANESE REST	
License Type: Permanent Food Service		18411 PINES BLVD, PEMBROKE PINES 330291415	
Inspection Date: 03/17/2010	Inspection Number: 1843774	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated, back door. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1617457		PIZZA HUT	
License Type: Permanent Food Service		18469 PINES BLVD, PEMBROKE PINES 330291415	
Inspection Date: 03/16/2010	Inspection Number: 1874493	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box, back door. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 1617668		DOMINOS PIZZA #5114	
License Type: Permanent Food Service		17728 PINES BLVD, PEMBROKE PINES 330291501	
Inspection Date: 03/18/2010	Inspection Number: 1833429	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VASQUEZ, JANNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored on top of water heater. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 1618031		CHRISTINA'S CAFE	
License Type: Permanent Food Service		2201 E ATLANTIC BLVD, POMPANO BEACH 33060	
Inspection Date: 03/16/2010	Inspection Number: 1885422	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-35-2	No current hood fire suppression system inspection report available. For reporting purposes only.	NFPA 1, 13.1.5 and 10.2.2 Detailed records documenting all systems and equipment testing and maintenance shall be kept by the property owner and shall be made available upon request for review by the AHJ. The AHJ shall be permitted to require the owner, operator, or occupant to provide tests or test reports, without expense to the AHJ, as proof of compliance with the intent of this Code. FOR REPORTING PURPOSES ONLY.	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.12/07	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.12/07 k class	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.12/07 abc	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

**Broward County**

License Number: 1618589 OCEAN BREEZE MARKET  
 License Type: Permanent Food Service 1110 S OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 03/16/2010 Inspection Number: 1865043 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.expired 4/28/09	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 1619626 DUFFY'S DINER  
 License Type: Permanent Food Service 3305 N FEDERAL HWY, POMPANO BEACH 33064

Inspection Date: 03/11/2010 Inspection Number: 1895641 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: EARP, NICOLETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1601264 ROSIE'S LOUNGE  
 License Type: Permanent Food Service 1711 NE 29 ST, POMPANO BCH 330646833

Inspection Date: 03/12/2010 Inspection Number: 1844460 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: EARP, NICOLETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-13-2	Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1612472

DOMINO'S PIZZA #3828

License Type: Permanent Food Service

900 S POMPANO PKWY, POMPANO BCH 330694307

Inspection Date: 03/15/2010

Inspection Number: 1854699

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIEHL, TERRENCE

Violation CodeObservationViolation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. rear kitchen door.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

47-15-2 Observed an uncovered electrical box. For reporting purposes only. above door in walk in cooler

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1608272

INTERNATIONAL HOUSE OF PANCAKES 36-67

License Type: Permanent Food Service

1395 POMPANO PKWY, POMPANO BEACH 33069-4313

Inspection Date: 03/16/2010

Inspection Number: 1906086

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIEHL, TERRENCE

Violation CodeObservationViolation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 1616218

CHECKERS RESTAURANT #295

License Type: Permanent Food Service

1401 S POWERLINE RD, POMPANO BEACH 33069-4315

Inspection Date: 03/18/2010

Inspection Number: 1895663

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIEHL, TERRENCE

Violation CodeObservationViolation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1621426 BOVA PRIME  
 License Type: Permanent Food Service 401 E LAS OLAS BLVD, FORT LAUDERDALE 33301

Inspection Date: 03/17/2010 Inspection Number: 1885078 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Bar	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1619334 TIMPANO ITALIAN CHOPHOUSE  
 License Type: Permanent Food Service 450 E LAS OLAS BLVD, FT LAUDERDALE 33301

Inspection Date: 03/19/2010 Inspection Number: 1874807 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K Class, Kitchen	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 1613616 GALLERIA GRILL  
 License Type: Permanent Food Service 915 MIDDLE RIVER DR #110, FORT LAUDERDALE 33304

Inspection Date: 03/18/2010 Inspection Number: 1921102 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: TORRES, LARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. k class fire extinguisher on floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1621169	TRINA RESTAURANT & LOUNGE
License Type: Permanent Food Service	601 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304
Inspection Date: 03/12/2010	Inspection Number: 1864883
Inspector Name: TORRES, LARRY	Inspection Type: Routine - Food
	Inspection Disposition: Administrative complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only. By mop sink, three tanks by room service area.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.

License Number: 1601593	TOUCAN DO PATIO BAR
License Type: Permanent Food Service	4116 N OCEAN DR, FORT LAUDERDALE 33308
Inspection Date: 03/15/2010	Inspection Number: 1854589
Inspector Name: MERNO, RAHLIBA	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1622498 CANCUN MEXICAN GRILL  
 License Type: Permanent Food Service 6300 N ANDREWS AVE, FORT LAUDERDALE 33309

Inspection Date: 03/15/2010 Inspection Number: 1926000 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SCHNEIDER, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only walkin door missing exit push button on door.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated. For reporting purposes only. polo room	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
46-13-2	Emergency light does not function when tested. For reporting purposes only.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.ladies room	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 1615143 RANDALL PROPERTY MANAGEMENT LLC  
 License Type: Permanent Food Service 5353 S SR 7, DAVIE 33314

Inspection Date: 03/16/2010 Inspection Number: 1874599 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: QUINONES, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. front counter.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 1618294 MINEO PIZZA WINGS & RAW BAR  
 License Type: Permanent Food Service 4261 GRIFFIN RD, FT LAUDERDALE 33314

Inspection Date: 03/16/2010 Inspection Number: 1905498 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: QUINONES, JOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

**Broward County**

License Number: 1622356		NAVAS TAVERNA N GRILL	
License Type: Permanent Food Service		5416 SOUTH STATE ROAD 7, HOLLYWOOD 33314	
Inspection Date: 03/15/2010	Inspection Number: 1874539	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: QUINONES, JOSE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
License Number: 1616134		MARCIA'S CAFE	
License Type: Permanent Food Service		3750 N SR 7, LAUDERDALE LAKES 33319	
Inspection Date: 03/18/2010	Inspection Number: 1885216	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WILLIAMS, NOVELETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Repeat Violation.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 1621557		APPLEBEE'S NEIGHBORHOOD GRILL & BAR	
License Type: Permanent Food Service		6005 N UNIVERSITY DR, TAMARAC 33321	
Inspection Date: 03/16/2010	Inspection Number: 1875005	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, NOVELETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-13-2	Emergency light does not function when tested in the men's restroom. For reporting purposes only.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.	
License Number: 1606403		INTERNATIONAL HOUSE OF PANCAKES 36-41	
License Type: Permanent Food Service		2454 N UNIVERSITY DR, SUNRISE 33322-3088	
Inspection Date: 03/15/2010	Inspection Number: 1864739	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BECKER, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Broward County**

License Number: 1619267		TGI FRIDAYS 294	
License Type: Permanent Food Service		13550 N SUNRISE BLVD, SUNRISE 33323	
Inspection Date: 03/15/2010	Inspection Number: 1833841	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JOY, TATJANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-42-2	Observed hood filters installed horizontally, rather than vertically. For reporting purposes only at cookline.	NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY	
License Number: 1619849		SCRUBY'S BBQ	
License Type: Permanent Food Service		8990 SR 84, DAVIE 33324	
Inspection Date: 03/15/2010	Inspection Number: 1926665	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, FERNANDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.rear.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1616732		LUKE'S PLACE	
License Type: Permanent Food Service		3558 S UNIVERSITY DR, DAVIE 33328	
Inspection Date: 03/18/2010	Inspection Number: 1886396	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DURDEN, VICKIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 1620999		CHILI'S	
License Type: Permanent Food Service		4515 WESTON RD, WESTON 33331	
Inspection Date: 03/17/2010	Inspection Number: 1927856	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DURDEN, VICKIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 1622053		CHICK FIL A	
License Type: Permanent Food Service		8190 W COMMERCIAL BLVD, LAUDERHILL 33351	
Inspection Date: 03/18/2010	Inspection Number: 1885132	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BECKER, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. ABC next to kitchen door.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	

**Broward County**

License Number: 1621357

BRUS ROOM SPORTS GRILL

License Type: Permanent Food Service

123 NE 20 AVE #21, DEERFIELD BEACH 33441

Inspection Date: 03/15/2010

Inspection Number: 1865059

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: EARP, NICOLETTE

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.  
Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

License Number: 1606671

Q KITCHEN

License Type: Permanent Food Service

206 N FEDERAL HWY, DEERFIELD BCH 334413612

Inspection Date: 03/16/2010

Inspection Number: 1875247

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: EARP, NICOLETTE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

**Charlotte County**

License Number: 1801348

TACO BELL #24555

License Type: Permanent Food Service

1001 KINGS HWY, PORT CHARLOTTE 33980

Inspection Date: 03/19/2010

Inspection Number: 1851807

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TARTAGLIONE, DOMINICK JR

Violation Code

Observation

Violation Citation

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

**Citrus County**

License Number: 1900890

NEON LEON'S ZYDECO STEAKHOUSE

License Type: Permanent Food Service

10350 W YULEE DR, HOMOSASSA 34448

Inspection Date: 03/12/2010

Inspection Number: 1887927

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRAIG, JILL

Violation Code

Observation

Violation Citation

47-08-2 Observed electrical wiring in disrepair- light fixture in walkin cooler hanging from ceiling. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Clay County**

License Number: 2001015		KFC	
License Type: Permanent Food Service		2693 BLANDING BLVD, MIDDLEBURG	32068
Inspection Date: 03/15/2010	Inspection Number: 1881311	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DOHERTY, BRENDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only. Repeat Violation.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY	
License Number: 2000899		EL POTRO OF ORANGE PARK	
License Type: Permanent Food Service		195 BLANDING BLVD #1, ORANGE PARK	32073
Inspection Date: 03/18/2010	Inspection Number: 1890731	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: D'ANTONIO, JANET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor, bar. For reporting purposes only. Repeat Violation.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. Masking taped cord on large stick mixer.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period, runs behind water heater. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate, kitchen wall. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

**Collier County**

License Number: 2100170

NAPLES SAILING &amp; YACHT CLUB

License Type: Permanent Food Service

896 RIVERPOINT DR, NAPLES 341023496

Inspection Date: 03/17/2010

Inspection Number: 1913768

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MORRIS, CHARLES

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.  
Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2101171

LITTLE CAESARS

License Type: Permanent Food Service

5337 AIRPORT RD, NAPLES 34109

Inspection Date: 03/13/2010

Inspection Number: 1927569

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MORRIS, CHARLES

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. Corrected On Site.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2102494

AMIGO'S

License Type: Permanent Food Service

1000 N COLLIER BLVD #15, MARCO ISLAND 34145

Inspection Date: 03/15/2010

Inspection Number: 1852315

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: MORRIS, CHARLES

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. k type  
Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

**Columbia County**

License Number: 2200457

PHISH HEADS INC

License Type: Permanent Food Service

1445 SW MAIN BLVD #170, LAKE CITY 320256901

Inspection Date: 03/12/2010

Inspection Number: 1900686

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: FULTON, DANIEL

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. BAR AREA BLOCKED BY  
COUNTER .For reporting purposes only.NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of  
egress shall be continuously maintained free of all  
obstructions or impediments to full instant use in the  
case of fire or other emergency. Means of access must  
permit unobstructed travel at all times and be  
maintained free of obstructions and fire hazards. Halls,  
entrances and stairways shall be clean, ventilated and  
well-lighted day and night. Hall and stair runners shall  
be kept in good condition. Hand rails shall be installed  
on all stairways and guard rails around all porches and  
steps. Adequate means of exit shall be provided  
pursuant to NFPA 101. FOR REPORTING  
PURPOSES ONLY.

License Number: 2200069

FATHER &amp; SON FOOD FOR LESS

License Type: Permanent Food Service

810 NE WASHINGTON STREET, LAKE CITY 32055

Inspection Date: 03/16/2010

Inspection Number: 1927698

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: FULTON, DANIEL

Violation CodeObservationViolation Citation

45-36-2

Hood suppression system tag out-of-date. MAY 2009.For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the  
fire-extinguishing system and listed exhaust hoods  
containing a constant or fire-actuated water system  
shall be made at least every 6 months by properly  
trained and qualified persons. FOR REPORTING  
PURPOSES ONLY.

45-37-2

Portable fire extinguisher missing from designated location. (K) For reporting  
purposes only. Corrected On Site.NFPA 10, 1.5.2 Portable fire extinguishers shall be  
maintained in a fully charged and operable condition  
and shall be kept in their designated places at all times  
when they are not being used. FOR REPORTING  
PURPOSES ONLY.

License Number: 2200135

BURGER KING #1679

License Type: Permanent Food Service

4560 90 HWY WEST, LAKE CITY 32055

Inspection Date: 03/16/2010

Inspection Number: 1849562

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: FULTON, DANIEL

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For  
reporting purposes only.NFPA 96, 6.2.3.3 Grease filters shall be arranged so  
that all exhaust air shall pass through the grease filters.  
For reporting purposes only.

**Columbia County**

License Number: 2200541 DO MO JAPANESE RESTAURANT  
 License Type: Permanent Food Service HWY 90 & I-75, LAKE CITY 32055

Inspection Date: 03/19/2010 Inspection Number: 1880173 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: FULTON, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
46-12-2	Emergency lighting illumination insufficient. For reporting purposes only.	NFPA 101, 7.9.2.1 Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 foot-candle and, at any point, not less than 0.1 foot-candles, measured along the path of egress at floor level. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. In several places. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2250055 DIANE'S HOUSE OF DOGS  
 License Type: Mobile Food Dispensing Vehicle 215 SW HOME DEPOT DR, LAKE CITY 32055

Inspection Date: 03/15/2010 Inspection Number: 1133564 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: FULTON, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2324652 PAPA JOHNS #377  
 License Type: Permanent Food Service 15428 NW 77 CT, MIAMI LAKES 33014

Inspection Date: 03/16/2010 Inspection Number: 1894021 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PEREZ, TONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.[ missing tag in rear extinguisher ]	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2326643 KEN & MIKES PIZZA & PASTA & AM  
 License Type: Permanent Food Service 16393 NW 67 AVE, MIAMI LAKES 33014

Inspection Date: 03/15/2010 Inspection Number: 1842841 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PEREZ, TONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2330454 LAKES SEAFOOD RESTAURANT  
 License Type: Permanent Food Service 15480 NW 77 CT, MIAMI LAKES 33014

Inspection Date: 03/17/2010 Inspection Number: 1853125 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PEREZ, TONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.
48-13-2	Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only. Corrected On Site.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2331369 CASAVANA CUBAN CUISINE  
 License Type: Permanent Food Service 16435 NW 67 AVE, MIAMI LAKES 33014

Inspection Date: 03/15/2010 Inspection Number: 1863389 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PEREZ, TONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.



**Dade County**

License Number: 2312798		SNACK BAR	
License Type: Permanent Food Service		450 NW 37 AVE, MIAMI 331254041	
Inspection Date: 03/17/2010	Inspection Number: 1853271	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BLAIR, ANTONIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-11-2	Observed LP-gas cylinder with greater than one pound LP-gas capacity inside a building. For reporting purposes only.	NFPA 58, 3.4.8.4 and 5.3.1.2 Cylinders used with commercial food service appliances shall be used inside restaurants and in attended commercial food catering operations in accordance with the following: (a) Cylinders and appliances shall be listed. (b) Commercial food service appliances shall not have more than two 10-oz nonrefillable butane gas cylinders, each having a maximum capacity of 1.08 lb. (c) Cylinders shall comply with UL 147B, Standard for Nonrefillable (Disposal) Type Metal Container Assemblies for Butane. (d) Cylinders shall be connected directly to the appliance and shall not be manifolded. (e) Cylinders shall be an integral part of the listed, approved, commercial food service device and shall be connected without the use of a rubber hose. (f) Storage of cylinders shall be in accordance with 5.3.1. The cylinders shall not exceed a water capacity of 2.7 lb [nominal 1 lb. LP-Gas] Exception: Storage in restaurants and at food service locations of 10-oz butane nonrefillable containers shall be limited to no more than 24 containers, and an additional twenty-four 10-oz butane nonrefillable containers stored in another location within the building, where constructed with at least a 2-hour fire wall protection. FOR REPORTING PURPOSES ONLY.	

License Number: 2318813		LOST AND FOUND SALOON INC RESTAURANT	
License Type: Permanent Food Service		185 NW 36 ST, MIAMI 33127	
Inspection Date: 03/18/2010	Inspection Number: 1853299	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BLAIR, ANTONIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.back door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

License Number: 2356739		HOUND DOGGIES.COM	
License Type: Mobile Food Dispensing Vehicle		292 NW 54TH STREET, MIAMI 33127	
Inspection Date: 03/19/2010	Inspection Number: 1139769	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, LEONARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-40-2	Portable fire extinguisher with no approved inspection tag. For reporting purposes only.	61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.	

**Dade County**

License Number: 2328816		DELICIAS HONDURAS	
License Type: Permanent Food Service		955 WEST FLAGLER STREET, MIAMI 33130	
Inspection Date: 03/16/2010	Inspection Number: 1894213	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: KHAN, MOHAMMAD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2330547		RESTAURANT HABANA FLAGLER	
License Type: Permanent Food Service		1067 W FLAGLER ST, MIAMI 33130	
Inspection Date: 03/15/2010	Inspection Number: 1873851	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: KHAN, MOHAMMAD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2332288		WAXY OCONNORS	
License Type: Permanent Food Service		690 SW 1ST CT, MIAMI 33130	
Inspection Date: 03/15/2010	Inspection Number: 1917526	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: KHAN, MOHAMMAD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2332749		JAMO'N JAMO'N JAMO'N	
License Type: Permanent Food Service		10 SW SOUTH RIVER DR #C-1, MIAMI 33130	
Inspection Date: 03/15/2010	Inspection Number: 1926962	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHAN, MOHAMMAD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Dade County**

License Number: 2313308 MASAYITA  
 License Type: Permanent Food Service 973 W FLAGLER ST, MIAMI 331301139

Inspection Date: 03/15/2010 Inspection Number: 1894231 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: KHAN, MOHAMMAD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
15-25-2	Violation: 15-25-2 Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

License Number: 2332095 FIRST AND SECOND  
 License Type: Permanent Food Service 168 SE 1ST STREET UNIT 1A, MIAMI 33131

Inspection Date: 03/18/2010 Inspection Number: 1832650 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: DIXON, DASSITA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2318252 CAMILA'S RESTAURANT  
 License Type: Permanent Food Service 129 SE 1 AVE, MIAMI 331311001

Inspection Date: 03/15/2010 Inspection Number: 1873701 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: DIXON, DASSITA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

**Dade County**

License Number: 2324852		CONTINENTAL MIAMI BAYSIDE	
License Type: Permanent Food Service		316 NE 2 ST, MIAMI 33132	
Inspection Date: 03/16/2010	Inspection Number: 1904580	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIXON, DASSITA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with one filter removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	

License Number: 2300006		SPS RESTAURANT	
License Type: Permanent Food Service		1757 NE 2 AVE, MIAMI 331321191	
Inspection Date: 03/17/2010	Inspection Number: 1853147	Inspection Type: Routine - Food	Inspection Disposition: Emergency Order Callback Complied
Inspector Name: DIXON, DASSITA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
15-40-2	Violation: 15-40-2 No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY	
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY	
37-20-2	Violation: 37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

License Number: 2319702		THE KNIFE STEAKHOUSE	
License Type: Permanent Food Service		3444 MAIN HWY, MIAMI 33133	
Inspection Date: 03/16/2010	Inspection Number: 1874353	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CONYERS,			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-13-2	Emergency light does not function when tested. For reporting purposes only, grill room.	NFPA 101, 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows: (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds. (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered. (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2). FOR REPORTING PURPOSES ONLY.	

**Dade County**

License Number: 2332362

MR. CHU'S

License Type: Permanent Food Service

2728 PONCE DE LEON BLVD, CORAL GABLES 33134

Inspection Date: 03/15/2010

Inspection Number: 1832825

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BURROWS, LEON

Violation CodeObservationViolation Citation

47-04-2

Observed frayed/spliced electrical wires. For reporting purposes only.in area near dishwasher

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2327697

VILLAGE CAFE RESTAURANT

License Type: Permanent Food Service

9540 NE 2 AVE, MIAMI 33138

Inspection Date: 03/11/2010

Inspection Number: 1832086

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIARTE, DENNIS

Violation CodeObservationViolation Citation

37-20-2

Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only. 04/09 last serviced.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 2328638

MADONNA'S II

License Type: Permanent Food Service

77700 BISCAYNE BLVD, MIAMI 33138

Inspection Date: 03/12/2010

Inspection Number: 1862938

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIARTE, DENNIS

Violation CodeObservationViolation Citation

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2331988

RED LIGHT GREEN LIGHT

License Type: Permanent Food Service

7700 BISCAYNE BLVD, MIAMI 33138

Inspection Date: 03/16/2010

Inspection Number: 1852631

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIARTE, DENNIS

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

45-41-2 Portable fire extinguisher tag out-of-date. For reporting purposes only. 01/09

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2321921

THE PLACE

License Type: Permanent Food Service

720 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 03/15/2010

Inspection Number: 1926610

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RICHARD, DICKSON

Violation CodeObservationViolation Citation

47-05-2 Observed a splitter/multi-plug adapter in use. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2327812

REGAL CINEMAS S BCH 18 2FL CON

License Type: Permanent Food Service

1120 LINCOLN RD, MIAMI BEACH 33139

Inspection Date: 03/17/2010

Inspection Number: 1862914

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BATISTA, JENNY

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2302186

GIA'S KITCHEN

License Type: Permanent Food Service

4525 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 03/17/2010

Inspection Number: 1883442

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: URIARTE, DENNIS

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. service bar.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2301464

JARAGUA RESTAURANT LIQUOR LOUNGE

License Type: Permanent Food Service

1298 NW 29 STREET, MIAMI 33142

Inspection Date: 03/17/2010

Inspection Number: 1904791

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GRACIA, REGINALD

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2312591		CAFETERIA LA ESQUINA DE ORO CORP.	
License Type: Permanent Food Service		2148 NW 17 AVE, MIAMI 33142	
Inspection Date: 03/15/2010	Inspection Number: 1927458	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRACIA, REGINALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 2327086		EL ENCUESTRO RESTAURANT	
License Type: Permanent Food Service		3511 NW 17 AVE, MIAMI 33142	
Inspection Date: 03/15/2010	Inspection Number: 1920443	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GRACIA, REGINALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	

License Number: 2331812		SOCRIS GRILL RESTAURANT	
License Type: Permanent Food Service		3517 NW 17 AVE, MIAMI 33142	
Inspection Date: 03/15/2010	Inspection Number: 1863703	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GRACIA, REGINALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

**Dade County**

License Number: 2332759 PIZZA WINGS N THINGS  
 License Type: Permanent Food Service 1220 NW 54 ST, MIAMI 33142

Inspection Date: 03/15/2010 Inspection Number: 1927444 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued  
 Inspector Name: GRACIA, REGINALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
15-26-2	Observed exhaust system without filters . For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 2317749 SUNSHINE CAFETERIA  
 License Type: Permanent Food Service 3690 NW 54 ST, MIAMI 331423213

Inspection Date: 03/16/2010 Inspection Number: 1873896 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: GRACIA, REGINALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
46-07-2	Exit signs missing. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2320565

BAHAMIAM RESTAURANTS

License Type: Permanent Food Service

1413 NW 54 ST, MIAMI 331423860

Inspection Date: 03/17/2010

Inspection Number: 1843124

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GRACIA, REGINALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY
46-07-2	Exit signs missing. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
48-13-2	Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2315554

ANGEL'S CAFETERIA

License Type: Permanent Food Service

3677 NW 50 ST, MIAMI 331423933

Inspection Date: 03/17/2010

Inspection Number: 1863710

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: GRACIA, REGINALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

License Number: 2329093

FARE TO REMEMBER

License Type: Catering

1557 SUNSET DRIVE, CORAL GABLES 33143

Inspection Date: 03/15/2010

Inspection Number: 1093230

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CONYERS,

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2326322

TWO CHEFS RESTAURANT INC

License Type: Permanent Food Service

8279 S DIXIE HWY, MIAMI 331437717

Inspection Date: 03/15/2010

Inspection Number: 1864251

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: CONYERS,

Violation CodeObservationViolation Citation

47-16-2 Electrical outlet missing cover plate. For reporting purposes only.broken.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

48-10-2 Gas appliance lacking seal (AGA/UL, etc.). For reporting purposes only.

61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

48-21-1 No carbon monoxide sensor device located in a gas boiler room in a building which also contains sleeping rooms.

509.211(5) FS Every enclosed space or room that contains a boiler regulated under chapter 554 which is fired by the direct application of energy from the combustion of fuels and that is located in any portion of a public lodging establishment that also contains sleeping rooms shall be equipped with one or more carbon monoxide sensor devices that bear the label of a nationally recognized testing laboratory and have been tested and listed as complying with the most recent Underwriters Laboratories, Inc., Standard 2034, or its equivalent, unless it is determined that carbon monoxide hazards have otherwise been adequately mitigated as determined by the division.

Boiler Information: boiler/waterheater in backroom.

License Number: 2302695

YUM YUM CHINESE RESTAURANT

License Type: Permanent Food Service

3104 CORAL WAY, MIAMI 33145

Inspection Date: 03/15/2010

Inspection Number: 1833004

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GANDOLFF, JORGE

Violation CodeObservationViolation Citation

37-20-2 Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.

NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

48-07-2 Observed gas venting in disrepair. For reporting purposes only.Water heater

61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2326182		PAPA JOHNS 889	
License Type: Permanent Food Service		2210 SW 22 ST CORAL WAY, MIAMI 33145	
Inspection Date: 03/15/2010	Inspection Number: 1863881	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2330733		SUSHI CHEF	
License Type: Permanent Food Service		3100 SW 22 ST, MIAMI 33145	
Inspection Date: 03/15/2010	Inspection Number: 1884260	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 2302860		MYKONOS RESTAURANT	
License Type: Permanent Food Service		1201 CORAL WAY, MIAMI 331452961	
Inspection Date: 03/18/2010	Inspection Number: 1927934	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, LEONARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2331659		FOGOVIVO CHURRASQUERIA	
License Type: Permanent Food Service		7711 SW 40 ST, MIAMI 33155	
Inspection Date: 03/18/2010	Inspection Number: 1894425	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: HERNANDEZ, LEONARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

**Dade County**

License Number: 2327100 RINCONCITO LATINO III  
 License Type: Permanent Food Service 15956 SW 137 AVE, KENDALL 33156

Inspection Date: 03/16/2010 Inspection Number: 1905082 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VALDERRAMA, ELISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only.by cane juice maker	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

License Number: 2322453 POLLO TROPICAL # 3  
 License Type: Permanent Food Service 8975 S DIXIE HWY, MIAMI 33156

Inspection Date: 03/16/2010 Inspection Number: 1853589 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.backdoor	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2325275 MIYAKO JAPANESE RESTAURANT OF DADELAND  
 License Type: Permanent Food Service 9533 S DIXIE HIGHWAY, MIAMI 33156

Inspection Date: 03/18/2010 Inspection Number: 1874075 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.backdoor	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2331088 SIAM DRAGEN RESTAURANT  
 License Type: Permanent Food Service 7748 N KENDALL DRIVE #E-02, MIAMI 33156-7523

Inspection Date: 03/17/2010 Inspection Number: 1904982 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

**Dade County**

License Number: 2320577 HIGHLY FLAVORED HAITIAN CUISINE  
 License Type: Permanent Food Service 9479 SW 160 ST, MIAMI 33157

Inspection Date: 03/16/2010 Inspection Number: 1863949 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: NUNEZ, ANDRES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryers being used	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2325529 JADE'S GARDEN CHINESE REST  
 License Type: Permanent Food Service 11227 SW 152 ST, MIAMI 331571101

Inspection Date: 03/17/2010 Inspection Number: 1874091 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 2315594 CHINA GATE  
 License Type: Permanent Food Service 19349 S DIXIE HWY, MIAMI 331577603

Inspection Date: 03/16/2010 Inspection Number: 1874083 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 2319530 PAPA JOE'S PIZZA AND PASTA  
 License Type: Permanent Food Service 19361 S DIXIE HWY, MIAMI 331577603

Inspection Date: 03/16/2010 Inspection Number: 1894507 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: DE LA CRUZ, ADONIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. small fryer	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

License Number: 2315390 WENDYS INTL #1703-142  
 License Type: Permanent Food Service 1532 NE 163 ST, NORTH MIAMI BEACH 331624718

Inspection Date: 03/12/2010 Inspection Number: 1842605 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: UNOLD, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

**Dade County**

License Number: 2323632		CHECKER DRIVE IN REST #190	
License Type: Permanent Food Service		1800 NE 163 ST, NORTH MIAMI BEACH 331624806	
Inspection Date: 03/10/2010	Inspection Number: 1832332	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNOLD, RICARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2316398		EL CORTADITO CAFE	
License Type: Permanent Food Service		9873 SW 40TH STREET, MIAMI 33165	
Inspection Date: 03/19/2010	Inspection Number: 1922724	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood system and filters not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2331764		EASTMAN CAFE	
License Type: Permanent Food Service		9636 SW 24 ST, MIAMI 33165	
Inspection Date: 03/19/2010	Inspection Number: 1927838	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
License Number: 2331927		CHINA WOK	
License Type: Permanent Food Service		9340 SW 56TH STREET, MIAMI 33165	
Inspection Date: 03/19/2010	Inspection Number: 1894469	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2325048		SHORTY'S BBQ	
License Type: Permanent Food Service		11575 SW 40 ST, MIAMI 331653313	
Inspection Date: 03/17/2010	Inspection Number: 1843318	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, LEONARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	

**Dade County**

License Number: 2323351		CANTON SUN CHINESE RESTAURANT	
License Type: Permanent Food Service		10162 W FLAGLER ST, MIAMI 33174	
Inspection Date: 03/17/2010	Inspection Number: 1864307	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
License Number: 2328746		PONELOYA NICARAGUAN CUISINE	
License Type: Permanent Food Service		10170 W FLAGLER STREET, MIAMI 33174	
Inspection Date: 03/17/2010	Inspection Number: 1874423	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. PORTABLE FRYER NOT UNDER HOOD	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 2321961		MI PUEBLO RESTAURANT	
License Type: Permanent Food Service		10910 W FLAGLER ST, MIAMI 331741280	
Inspection Date: 03/12/2010	Inspection Number: 1843714	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only. Corrected On Site.	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.	

**Dixie County**

License Number: 2500154

MARY'S COUNTRY DELI SUBS &amp; MORE

License Type: Permanent Food Service

25878 SE US 19, STE B, OLD TOWN 32680

Inspection Date: 03/17/2010

Inspection Number: 1910986

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 2500156

THE BRICK GRILL

License Type: Permanent Food Service

27674 SE 19 HWY, OLD TOWN 32680

Inspection Date: 03/17/2010

Inspection Number: 1880279

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: BROWNING, JULIANNE

Violation CodeObservationViolation Citation

48-08-2

LP-gas tanks not protected from vehicle damage. For reporting purposes only.

NFPA 58, 3.2.4.2 LP-gas containers or systems of which they are a part shall be protected from damage from vehicles. FOR REPORTING PURPOSES ONLY.

**Duval County**

License Number: 2612102		LINDA'S SEAFOOD RESTAURANT	
License Type: Permanent Food Service		704 LANE AVE S, JACKSONVILLE 32205	
Inspection Date: 03/16/2010	Inspection Number: 1890501	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RIVERA, STEVEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 2614139		TIMES GRILL	
License Type: Permanent Food Service		5149 NORMANDY BLVD #1, JACKSONVILLE 32205	
Inspection Date: 03/16/2010	Inspection Number: 1839246	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RIVERA, STEVEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.K CLASS ON FLOOR BACK DOOR.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 2614122		SAKE HOUSE	
License Type: Permanent Food Service		1478 RIVERPLACE BLVD 101, JACKSONVILLE 32207	
Inspection Date: 03/17/2010	Inspection Number: 1870530	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. cardboard boxes on top	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 2614481		SONNY-D CARRY OUT RESTAURANT	
License Type: Permanent Food Service		7303 NORTH PEARL ST., JACKSONVILLE 32208	
Inspection Date: 03/15/2010	Inspection Number: 1927442	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAVIS, MOSES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-30-2	No Class K portable fire extinguisher provided for high hazard cooking area (for suppression system/equipment installed after June 30, 1998). For reporting purposes only.	NFPA 10, 4.3.2. and 4.3.2.1 Class K Fire Extinguishers for Cooking Oil Fires. Fire extinguishers provided for the protection of cooking appliances that use combustible cooking media (vegetable or animal oils and fats) shall be listed and labeled for Class K fires. Class K fire extinguishers manufactured after January 1, 2002, shall not be equipped with extended wand-type discharge devices. Fire extinguishers installed specifically for the protection of cooking appliances that use combustible cooking media (animal, vegetable oils and fats) prior to June 30, 1998, shall not be required to comply with 4.3.2. (Also see 4.3.2.3.). FOR REPORTING PURPOSES ONLY.	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

**Duval County**

License Number: 2608283

LONDON SEAFOOD PLACE

License Type: Permanent Food Service

5032 -5034 BLANDING BLVD, JACKSONVILLE 32210

Inspection Date: 03/15/2010

Inspection Number: 1921334

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

15-25-2

Hood filters not equipped with a drip tray. For reporting purposes only.  
Repeat Violation.

NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.  
Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 2613779

SILVER STAR CHINESE RESTAURANT

License Type: Permanent Food Service

5016 BLANDING BLVD, JACKSONVILLE 32210

Inspection Date: 03/15/2010

Inspection Number: 1870862

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Duval County**

License Number: 2614174 LA RAZA II  
 License Type: Permanent Food Service 6011 103 ST STE# 4, JACKSONVILLE 32210

Inspection Date: 03/16/2010 Inspection Number: 1914346 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SILBERMAN, STEPHANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exit, backdoor. For reporting purposes only. Corrected On Site. Repeat Violation.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Repeat Violation.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2610180 OVERTIME SPORTS BAR  
 License Type: Permanent Food Service 6337 SAN JUAN AVE, JACKSONVILLE 322102853

Inspection Date: 03/17/2010 Inspection Number: 1870884 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: SILBERMAN, STEPHANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Violation: 47-06-2  Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Duval County**

License Number: 2608344		MCDONALDS	
License Type: Permanent Food Service		7359 103 ST, JACKSONVILLE 322106700	
Inspection Date: 03/16/2010	Inspection Number: 1927689	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SILBERMAN, STEPHANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed exit, door blocked by buns. For reporting purposes only. Corrected On Site.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	

License Number: 2612660		PAPA JOHNS PIZZA	
License Type: Permanent Food Service		5921 W UNIVERSITY BLVD #3, JACKSONVILLE 32216	
Inspection Date: 03/18/2010	Inspection Number: 1850204	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RIVERA, STEVEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. PIZZA OVEN missing filters. Repeat Violation.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 2612952		HAPPY WOK	
License Type: Permanent Food Service		8595 BEACH BLVD #348, JACKSONVILLE 32216	
Inspection Date: 03/17/2010	Inspection Number: 1911530	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RIVERA, STEVEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only. K CLASS BLOCKED BY WOODEN STORAGE RACK. Repeat Violation.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	

License Number: 2611365		UNCLE SAM'S SNACK SHOP	
License Type: Permanent Food Service		3733 UNIVERSITY BLVD W, JACKSONVILLE 32217	
Inspection Date: 03/18/2010	Inspection Number: 1839741	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FIELDER, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair	

License Number: 2614248		WOODY'S BAR-B-Q	
License Type: Permanent Food Service		5930 POWER AVE, JACKSONVILLE 32217	
Inspection Date: 03/18/2010	Inspection Number: 1870622	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FIELDER, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46	Out of compliance: Exiting system - adequate, good repair	NFPA 101, 96, 10 Exiting system - adequate, good repair	
49	Out of compliance: Flammable/combustible materials - properly stored	NFPA 101, 96, 10 Flammable/combustible materials - properly stored	

**Duval County**

License Number: 2612428		OSAKA GRILL SUSHI BUFFET	
License Type: Permanent Food Service		11701 SAN JOSE BLVD STE 3, JACKSONVILLE 32223	
Inspection Date: 03/15/2010	Inspection Number: 1927728	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: FIELDER, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Observed splitter plug and extension cords being used on line. Reporting purposes only.	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 2613078		PEKING WOK	
License Type: Permanent Food Service		1650 SAN PABLO RD S #6, JACKSONVILLE 32224	
Inspection Date: 03/18/2010	Inspection Number: 1901849	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-05-2	Observed a splitter/multi-plug adapter in use./ extension cord./ near white refrigerator. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2612035		APPLEBEE'S NEIGHBORHOOD GRILL & BAR #4230	
License Type: Permanent Food Service		13201 ATLANTIC BLVD, JACKSONVILLE 32225	
Inspection Date: 03/12/2010	Inspection Number: 1891247	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only./ kitchen area.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2612356		FONGS RESTAURANT	
License Type: Permanent Food Service		12777 ATLANTIC BLVD #23, JACKSONVILLE 32225	
Inspection Date: 03/15/2010	Inspection Number: 1839965	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. on the food shelf.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

**Duval County**

License Number: 2612748		FAST BOYS WINGS	
License Type: Permanent Food Service		12220 ATLANTIC BLVD #108, JACKSONVILLE 32225	
Inspection Date: 03/18/2010	Inspection Number: 1881143	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only./ req. every 6 mos for service.	NFPA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	
45-41-2	Portable fire extinguisher tag out-of-date./ For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	

License Number: 2613397		CHILI'S GRILL & BAR	
License Type: Permanent Food Service		12987 ATLANTIC BLVD, JACKSONVILLE 32225	
Inspection Date: 03/15/2010	Inspection Number: 1911824	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 2614089		MY PIZZA	
License Type: Permanent Food Service		14025 MT PLEASANT RD, JACKSONVILLE 32225	
Inspection Date: 03/16/2010	Inspection Number: 1927320	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STOREY, MARIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-08-2	LP-gas tanks not protected from vehicle damage. For reporting purposes only. back of restaurant	NFPA 58, 3.2.4.2 LP-gas containers or systems of which they are a part shall be protected from damage from vehicles. FOR REPORTING PURPOSES ONLY.	

License Number: 2607880		CHUCKE CHEESE	
License Type: Permanent Food Service		9820 ATLANTIC BLVD, JACKSONVILLE 322256536	
Inspection Date: 03/12/2010	Inspection Number: 1850412	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, DERRICK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-02-2	Observed circuit breaker taped open. For reporting purposes only. Repeat Violation.	NFPA 70, 240.80 Circuit breakers shall be tripfree and capable of being closed and opened by manual operation. FOR REPORTING PURPOSES ONLY.	

**Duval County**

License Number: 2613592		TASTE AT 645 ATLANTIC	
License Type: Permanent Food Service		645 ATLANTIC BOULEVARD, ATLANTIC BEACH 32233	
Inspection Date: 03/17/2010	Inspection Number: 1922883	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only./ kitchen area.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2614031		BEETHOVEN'S BAGEL BISTRO	
License Type: Permanent Food Service		5917 ROOSEVELT BLVD, STE 1, JACKSONVILLE 32244	
Inspection Date: 03/11/2010	Inspection Number: 1901635	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SILBERMAN, STEPHANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 2614348		CRAZY FISH JACKSONVILLE BEACH	
License Type: Permanent Food Service		2510 2ND AVE N, JACKSONVILLE BEACH 32250	
Inspection Date: 01/15/2010	Inspection Number: 1881098	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CARANGIAN, REYNALDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Out of compliance: Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 2611960		TOP CHINA	
License Type: Permanent Food Service		1020 EDGEWOOD AVE N #16, JACKSONVILLE 32254	
Inspection Date: 03/11/2010	Inspection Number: 1901637	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: SILBERMAN, STEPHANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

**Duval County**

License Number: 2609767

SUBWAY SANDWICHES &amp; SALADS

License Type: Permanent Food Service

1020 N EDGEWOOD AVE #21, JACKSONVILLE 322542381

Inspection Date: 03/17/2010

Inspection Number: 1860571

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: SILBERMAN, STEPHANIE

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exit, backdoor blocked by trash. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2612798

HOP SHING CHINESE FOOD

License Type: Permanent Food Service

11101 ST AUGUSTINE RD #7, JACKSONVILLE 32257

Inspection Date: 03/18/2010

Inspection Number: 1901406

Inspection Type: Routine - Food

Inspection Disposition: Emergency  
order recommended

Inspector Name: FIELDER, ANDREW

Violation CodeObservationViolation Citation

46

Out of compliance: Exiting system - adequate, good repair

NFPA 101, 96, 10 Exiting system - adequate, good repair

License Number: 2611242

HUNGRY HOWIE'S PIZZA &amp; SUBS #244

License Type: Permanent Food Service

8011 MERRILL RD STE# 20, JACKSONVILLE 32277

Inspection Date: 03/18/2010

Inspection Number: 1860439

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: YOUNG, DERRICK

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. Repeat Violation.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

47-15-2

Observed an uncovered electrical box. For reporting purposes only.  
Between walk-in cooler and pizza oven

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

**Duval County**

License Number: 2610563

BONO'S

License Type: Permanent Food Service

8011 MERRILL RD #23, JACKSONVILLE 322773799

Inspection Date: 03/18/2010

Inspection Number: 1839915

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, DERRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only. Behind reach -in units	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. powering kitchen reach -in	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Escambia County**

License Number: 2705422

BAGELHEADS

License Type: Permanent Food Service

916 E GREGORY ST, PENSACOLA 32501

Inspection Date: 03/15/2010

Inspection Number: 1927823

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

45-39-2

Portable fire ABC extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

46-09-2

Exit sign in dining room not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 2701564

LANDRY'S SEAFOOD HOUSE

License Type: Permanent Food Service

905 E GREGORY ST, PENSACOLA 325014330

Inspection Date: 03/15/2010

Inspection Number: 1927821

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: RILEY, DAVID

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed exit in rear of dining room. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 2701090

TIFFANY'S ON THE BEACH

License Type: Permanent Food Service

3 CASINO BEACH BOARDWALK, PENSACOLA BEACH 32561

Inspection Date: 03/12/2010

Inspection Number: 1871160

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WINN, RONALD

Violation CodeObservationViolation Citation

49-07-2

Observed flammable material (cardboard) placed in contact with electric grill. For reporting purposes only.

61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.



**Franklin County**

License Number: 2900207

BLUE PARROT OCEANFRONT CAFE

License Type: Permanent Food Service

68 W GORRIE, ST GEORGE ISLAND 32328

Inspection Date: 03/12/2010

Inspection Number: 1902491

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation Code

Observation

Violation Citation

47-03-2

Observed unused openings in panel box unprotected. For reporting purposes only.

NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

**Gadsden County**

License Number: 3000027

ROYAL SAVOY PATIO

License Type: Permanent Food Service

1834 SW FLAGLER AVE, QUINCY 323514116

Inspection Date: 03/16/2010

Inspection Number: 1892002

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARGROVE, DAVID

Violation Code

Observation

Violation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. SHORT IN THE WIRING - COMES ON WHEN MOVE PLUG.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Gilchrist County**

License Number: 3100102

BROOKE'S PLACE

License Type: Permanent Food Service

321 N MAIN STREET, TRENTON 32693

Inspection Date: 03/12/2010

Inspection Number: 1926954

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only. Side dining area

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Hamilton County**

License Number: 3400166	TELFORD HOTEL RESTAURANT		
License Type: Permanent Food Service	16521 RIVER S, WHITE SPRINGS 32096		
Inspection Date: 03/16/2010	Inspection Number: 1901012	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: HENTGES, JUDY			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
45-39-2	Violation: 45-39-2  Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. Oven wires directly spliced into power source.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3400184	FAT BELLY'S		
License Type: Permanent Food Service	16750 SPRING STREET, WHITE SPRINGS 32096		
Inspection Date: 03/17/2010	Inspection Number: 1890677	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENTGES, JUDY			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. toaster	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Hernando County**

License Number: 3701082	GRILL 301		
License Type: Permanent Food Service	4131 TREIMAN BLVD, RIDGE MANOR 33523		
Inspection Date: 03/17/2010	Inspection Number: 1925650	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DANCHO, JOHN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
47-02-2	Observed circuit breaker taped open....electric box in kitchen. For reporting purposes only.		NFPA 70, 240.80 Circuit breakers shall be tripfree and capable of being closed and opened by manual operation. FOR REPORTING PURPOSES ONLY.
License Number: 3701080	WINGS N PIZZA BARN		
License Type: Permanent Food Service	308 NORTH BROAD ST, BROOKSVILLE 34601		
Inspection Date: 03/19/2010	Inspection Number: 1908523	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DANCHO, JOHN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress....bar on exit in dining room...For reporting purposes only. Corrected On Site.		NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
License Number: 3700748	HARMONY HOUSE FAMILY REST		
License Type: Permanent Food Service	440 BROAD ST, MASARYKTOWN 346047401		
Inspection Date: 03/19/2010	Inspection Number: 1857251	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DANCHO, JOHN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.		NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.
License Number: 3700873	CHINA ONE		
License Type: Permanent Food Service	1446 PINEHURST DR, SPRING HILL 34606		
Inspection Date: 03/15/2010	Inspection Number: 1877867	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GLENN, DAVID			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.		61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Hernando County**

License Number: 3700601 VILLAGE PIZZA  
 License Type: Permanent Food Service 4060 DELTONA BLVD STE 4, SPRING HILL 346062299

Inspection Date: 03/18/2010 Inspection Number: 1877823 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 3700314 BRIAN'S PLACE  
 License Type: Permanent Food Service 3306 SHOAL LINE BLVD, SPRING HILL 34607

Inspection Date: 03/16/2010 Inspection Number: 1927765 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GLENN, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small flat top grill not under hood system.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Powering outside light.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Highlands County**

License Number: 3801054

SO GOOD CAFE AND BEER GARDEN

License Type: Permanent Food Service

1458 CUMMINGS AVE, AVON PARK 33825

Inspection Date: 03/12/2010

Inspection Number: 1927926

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARNHART, RICHARD

Violation Code

Observation

Violation Citation

47 ELECTRIC WIRE HANGING AT LEAK IN KITCHEN

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

**Hillsborough County**

License Number: 3906828	MCDONALDS RESTAURANT #4514		
License Type: Permanent Food Service	4650 MCINTOSH RD, DOVER 335274132		
Inspection Date: 03/15/2010	Inspection Number: 1927639	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment. For reporting purposes only. Corrected On Site.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.	

License Number: 3902959	SHOWTOWN USA		
License Type: Permanent Food Service	7001 MOTTIE, GIBSONTON 335344803		
Inspection Date: 03/18/2010	Inspection Number: 1927966	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OGDEN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.rear door outside	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.outside rear door	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

License Number: 3904695	HOUSE OF CHINA		
License Type: Permanent Food Service	18463 US 41, LUTZ 33549		
Inspection Date: 03/16/2010	Inspection Number: 1836782	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	

License Number: 3915618	WESTSHORE PIZZA		
License Type: Permanent Food Service	18431 US HIGHWAY 41 N, LUTZ 33549		
Inspection Date: 03/16/2010	Inspection Number: 1898372	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.	

**Hillsborough County**

License Number: 3910748 MCDONALDS  
 License Type: Permanent Food Service 106 CRYSTAL GROVE BLVD, LUTZ 335496446

Inspection Date: 03/16/2010 Inspection Number: 1898392 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CHEW, TEOW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 3916000 DQ GRILL & CHILL  
 License Type: Permanent Food Service 10503 GIBSONTON DR, RIVERVIEW 33569

Inspection Date: 03/16/2010 Inspection Number: 1856869 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BOWEN, JEFFREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only. Hood-fire-suppression systems are past due to be serviced and retagged.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 3916161 FRANKS AND SUBS  
 License Type: Permanent Food Service 10451 GIBSONTON DRIVE, RIVERVIEW 33569

Inspection Date: 03/16/2010 Inspection Number: 1917616 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BOWEN, JEFFREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only. Unable to read tag. The AutoFry-fire-suppression system must be serviced, and retagged, at least every-six months.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. Portable-fire extinguisher must be mounted on a wall.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only. Portable fire extinguisher is past due to be serviced and retagged.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3915868

ACROPOLIS GREEK TAVERNA

License Type: Permanent Food Service

6108 WINTHROP TOWN CENTER AVE, RIVERVIEW 33578

Inspection Date: 03/17/2010

Inspection Number: 1927232

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BOWEN, JEFFREY

Violation CodeObservationViolation Citation

45-10-2

Pull station for fire suppression system inaccessible. For reporting purposes only. Relocate the drink box, so that the hood-fire-suppression trigger is readily accessible.

NFPA 96, 10.5.1 A readily accessible means for manual activation shall be located between 42 inches and 48 inches above the floor, be accessible in the event of a fire, be located in a path of egress, and clearly identify the hazard protected. FOR REPORTING PURPOSES ONLY.

License Number: 3916699

BUM BUM

License Type: Permanent Food Service

1700 W WATERS AVE, TAMPA 33604

Inspection Date: 03/17/2010

Inspection Number: 1923194

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PETERSON, DOUGLAS

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912334

D'ITALIA

License Type: Permanent Food Service

1811 NORTH 15TH STREET, TAMPA 33605

Inspection Date: 03/19/2010

Inspection Number: 1887755

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OGDEN, RICHARD

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-08-2

Observed electrical wiring in disrepair. For reporting purposes only, by emergency light rear area.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3904191		FAST & BEST SANDWICH SHOP	
License Type: Permanent Food Service		4935 E 7 AVE, TAMPA 336054705	
Inspection Date: 03/15/2010	Inspection Number: 1927614	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OGDEN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.rear storage area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 3910751		RESTAURANT LA MEXICANA	
License Type: Permanent Food Service		902 S 22 ST, TAMPA 336056302	
Inspection Date: 03/19/2010	Inspection Number: 1928096	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OGDEN, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 3906947		YEOMAN'S ROAD PUB	
License Type: Permanent Food Service		236 E DAVIS BLVD, TAMPA 33606	
Inspection Date: 03/18/2010	Inspection Number: 1927986	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KLUSENDORF, JEANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. fan in kitchen	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 3910933		ZIA'S	
License Type: Permanent Food Service		TAMPA INTERNATIONAL AIRPORT, AIRSIDE A 2ND FLOOR, TAMPA 33607	
Inspection Date: 03/18/2010	Inspection Number: 1897344	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIRABELLA, FRANK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. prep area	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

**Hillsborough County**

License Number: 3915692

PIPO'S CAFE

License Type: Permanent Food Service

3501 N AREMENIA AVE, TAMPA 33607

Inspection Date: 03/08/2010

Inspection Number: 1928056

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WAGNER, MARGARET

Violation CodeObservationViolation Citation

45 Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and  
sufficient

48 Out of compliance: Gas appliances - properly installed, maintained

NFPA 101, 96, 10 Gas appliances - properly installed,  
maintained

License Number: 3915867

CHILI'S TOO

License Type: Permanent Food Service

TAMPA INTERNATIONAL AIRPORT, AIRSIDE C 3RD LEVEL, TAMPA 33607

Inspection Date: 03/17/2010

Inspection Number: 1907647

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MIRABELLA, FRANK

Violation CodeObservationViolation Citation47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes  
only. dish room61C-1.004(11) FAC Electrical wiring. To prevent fire or  
injury, defective electrical wiring shall be replaced and  
wiring shall be kept in good repair. No extension cords  
shall be used except during cleaning, maintenance and  
other temporary activities. Only a wall switch or  
approved pull cord shall be permitted in bathrooms. In  
accordance with the provisions of NFPA 70, the  
National Electrical Code, as adopted by the Division of  
State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire  
Safety Rules and Standards, sufficient electrical outlets  
shall be provided. FOR REPORTING PURPOSES  
ONLY.

License Number: 3916492

AQUAKNOX

License Type: Permanent Food Service

7627 COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Inspection Date: 03/12/2010

Inspection Number: 1907589

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MIRABELLA, FRANK

Violation CodeObservationViolation Citation47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes  
only. wine cooler.61C-1.004(11) FAC Electrical wiring. To prevent fire or  
injury, defective electrical wiring shall be replaced and  
wiring shall be kept in good repair. No extension cords  
shall be used except during cleaning, maintenance and  
other temporary activities. Only a wall switch or  
approved pull cord shall be permitted in bathrooms. In  
accordance with the provisions of NFPA 70, the  
National Electrical Code, as adopted by the Division of  
State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire  
Safety Rules and Standards, sufficient electrical outlets  
shall be provided. FOR REPORTING PURPOSES  
ONLY.

**Hillsborough County**

License Number: 3906297 HANA DELI  
 License Type: Permanent Food Service 5201 KENNEDY BLVD STE 130, TAMPA 33609

Inspection Date: 03/19/2010 Inspection Number: 1928095 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3916435 WESTSHORE PIZZA HARDROCK  
 License Type: Permanent Food Service 5310 ORIENT ROAD, TAMPA 33610

Inspection Date: 03/18/2010 Inspection Number: 1836884 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-36-2	Hood suppression system tag out-of-date. For reporting purposes only.	NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3911130 NORTH 22ND STREET GYROS  
 License Type: Permanent Food Service 4014 N 22 ST, TAMPA 336107549

Inspection Date: 03/16/2010 Inspection Number: 1878031 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3906565 CROWN PLAZA TAMPA  
 License Type: Permanent Food Service 10221 E PRINCESS PALM AVE, TAMPA 336109271

Inspection Date: 03/17/2010 Inspection Number: 1836918 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PETERSON, DOUGLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

License Number: 3915426 VINO E PASTA  
 License Type: Permanent Food Service 3603 GANDY BLVD, TAMPA 33611

Inspection Date: 03/19/2010 Inspection Number: 1928092 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3915718 RAMON'S CUBANS  
 License Type: Permanent Food Service 4053 S DALE MABRY HWY, TAMPA 33611

Inspection Date: 03/15/2010 Inspection Number: 1927607 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. on floor.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 3900220 MAD DOGS & ENGLISHMEN INC  
 License Type: Permanent Food Service 4115 S MAC DILL AVE, TAMPA 336111936

Inspection Date: 03/16/2010 Inspection Number: 1927738 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3912868		WING KING OF FLETCHER	
License Type: Permanent Food Service		1132 E FLETCHER AVE, TAMPA 33612	
Inspection Date: 03/18/2010	Inspection Number: 1846192	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHEW, TEOW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	
License Number: 3911116		OUTBACK	
License Type: Permanent Food Service		3802 W MARTIN LUTHER KING BLVD, TAMPA 33614	
Inspection Date: 03/18/2010	Inspection Number: 1907847	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-27-2	Portable fire extinguisher blocked/not easily accessible. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 3911117		CARVEL	
License Type: Permanent Food Service		3802 W MARTIN LUTHER KING BLVD, TAMPA 33614	
Inspection Date: 03/18/2010	Inspection Number: 1877149	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DORSEY, KATHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-27-2	Portable fire extinguisher blocked/not easily accessible. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 3912219		MAMMA MIA PIZZA	
License Type: Permanent Food Service		8130 W WATERS AVE, TAMPA 33615	
Inspection Date: 03/15/2010	Inspection Number: 1927309	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DECKER, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

**Hillsborough County**

License Number: 3916111

PEI WEI ASIAN DINER

License Type: Permanent Food Service

12927 N DALE MABRY HWY, TAMPA 33618

Inspection Date: 03/11/2010

Inspection Number: 1897594

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: DORSEY, KATHY

Violation Code

Observation

Violation Citation

45-38-2

Violation: 45-38-2

Portable fire extinguisher not fully charged. For reporting purposes only. by back door

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3910771

VALLARTAS MEXICAN RESTAURANT

License Type: Permanent Food Service

13731 N DALE MABRY, TAMPA 336182417

Inspection Date: 03/17/2010

Inspection Number: 1897615

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: DORSEY, KATHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Violation: 15-28-2  Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
45-39-2	Violation: 45-39-2  Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K class extinguisher on floor in kitchen	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. K class extinguisher on floor in kitchen	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
46-05-2	Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. by chairs outside	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.
46-05-2	Violation: 46-05-2  Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. by chairs outside	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3911749 SEA FOOD PALACE  
 License Type: Permanent Food Service 6207 CAUSEWAY BOULEVARD, TAMPA 33619

Inspection Date: 03/15/2010 Inspection Number: 1927613 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: OGDEN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-05-2	Observed a splitter/multi-plug adapter in use. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 3912002 MASTER WOK  
 License Type: Permanent Food Service 8005 CITRUS PARK TOWN CENTER, TAMPA 33625

Inspection Date: 03/15/2010 Inspection Number: 1876937 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: DECKER, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
37-20-2	Violation: 37-20-2  Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 3912920 CHILI'S BAR & GRILL  
 License Type: Permanent Food Service 8402 CITRUS PARK DR, TAMPA 33625

Inspection Date: 03/17/2010 Inspection Number: 1856387 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DECKER, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. hasp lock on freezer	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 3915408 SUBWAY  
 License Type: Permanent Food Service 8625 CITRUS PARK DR, TAMPA 33625

Inspection Date: 03/17/2010 Inspection Number: 1856395 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DECKER, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only. Repeat Violation.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 3910896 HONEYBAKED HAM CO  
 License Type: Permanent Food Service 12040 ANDERSON RD, TAMPA 336255682

Inspection Date: 03/17/2010 Inspection Number: 1866667 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DECKER, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Hillsborough County**

License Number: 3912037 THE MARRAKECH RESTAURANT  
 License Type: Permanent Food Service 2402 SOUTH MACDILL, TAMPA 33629

Inspection Date: 03/16/2010 Inspection Number: 1916813 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. over employee handwash sink.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 3912436 VALLARTA'S MEXICAN RESTAURANT  
 License Type: Permanent Food Service 9212 ANDERSON RD, TAMPA 33634

Inspection Date: 03/05/2010 Inspection Number: 1856401 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: WAGNER, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

Inspection Date: 03/15/2010 Inspection Number: 1856401 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: DECKER, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 3912126 LENOCES NEIGHBORHOOD REST  
 License Type: Permanent Food Service 13949 W HILLSBOROUGH AVE, TAMPA 33635

Inspection Date: 03/09/2010 Inspection Number: 1856397 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: WAGNER, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

**Indian River County**

License Number: 4101079

OAK HARBOR CLUB

License Type: Permanent Food Service

4755 S HARBOR DR, VERO BEACH 32967

Inspection Date: 03/19/2010

Inspection Number: 1868051

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. EXPIRED For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 4101074

FELIXS PLACE

License Type: Permanent Food Service

40 43RD AVE, VERO BEACH 32968

Inspection Date: 03/11/2010

Inspection Number: 1909181

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

45-22-2

Portable fire extinguisher(s) obstructed from view-K class extinguisher and pull station not accessible. For reporting purposes only.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

47-08-2

Observed electrical wiring in disrepair. Looks to have added several new outlets on prep area of kitchen. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Lake County**

License Number: 4508195		APPLEBEES NEIGHBORHOOD GRILL & BAR	
License Type: Permanent Food Service		15351 US HWY 441, EUSTIS 32726	
Inspection Date: 03/11/2010	Inspection Number: 1900216	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTIN, ROBERT KEVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.flat grill	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 4501509		CHECKERS #6324	
License Type: Permanent Food Service		480 E BURLEIGH BLVD, TAVARES 32778	
Inspection Date: 03/16/2010	Inspection Number: 1859095	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only. Observed in kitchen door near ice machine.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 4508349		DOUBLE TAKE PIZZA	
License Type: Permanent Food Service		2601 STATE ROAD 19 UNIT K, TAVARES 32778	
Inspection Date: 03/18/2010	Inspection Number: 1879735	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 4500866		HARDEE'S #1500724	
License Type: Permanent Food Service		301 E BURLEIGH BLVD, TAVARES 327782201	
Inspection Date: 03/16/2010	Inspection Number: 1889919	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only. No punch for fire extinguishers location in kitchen.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 4508298		THAI & FRIENDS RESTAURANT	
License Type: Permanent Food Service		20349 US HWY 27 N, CLERMONT 34711	
Inspection Date: 03/17/2010	Inspection Number: 1890197	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, ALEX			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. SMALL FRYER AT EXHAUST HOOD NOT UNDER FIRE SUPPRESION SYSTEM NOZZLES. Notified Fire AHJ. For reporting purposes only. Corrected On Site	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	

**Lake County**

License Number: 4508313

GEKKO JAPANESE RESTAURANT

License Type: Permanent Food Service

13900 COUNTY ROAD 455 SUITE 109A, CLERMONT 34711

Inspection Date: 03/17/2010

Inspection Number: 1927731

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHIU, ALEX

Violation Code

Observation

Violation Citation

46-05-2

Observed obstructed exits, stairs, hallways or egress. For reporting purposes only.  
[Back exit/egress blocked by a refrigerator and food items ]

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

**Lee County**

License Number: 4602798		LA CASONA RESTAURANT	
License Type: Permanent Food Service		3758 CLEVELAND AVE, FORT MYERS 33901	
Inspection Date: 03/18/2010	Inspection Number: 1903225	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AHMED, SYED			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 4603780		CAPONE'S PIZZERIA & RESTAURANT	
License Type: Permanent Food Service		4529 BAYSHORE RD, NORTH FORT MYERS 33903	
Inspection Date: 03/15/2010	Inspection Number: 1927692	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANDMANN, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 4603555		TWISTEE TREAT	
License Type: Permanent Food Service		10 PINE ISLAND RD, N FT MYERS 339033762	
Inspection Date: 03/17/2010	Inspection Number: 1927908	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANDMANN, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.main bx uncovered	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 4604858		MCDONALDS	
License Type: Permanent Food Service		1222 CAPE CORAL PKWY, CAPE CORAL 33904	
Inspection Date: 03/17/2010	Inspection Number: 1882736	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SOMMERS, KARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-03-2	Observed clearance between sprinkler head and top of storage less than 18 inches--back dry storage. For reporting purposes only.	NFPA 13, 5.5.6 The clearance between the deflector and the top of storage shall be 18 inches or greater. FOR REPORTING PURPOSES ONLY.	
License Number: 4603981		CANTINA LAREDO	
License Type: Permanent Food Service		5200 BIG PINE WAY, FORT MYERS 33907	
Inspection Date: 03/16/2010	Inspection Number: 1841843	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CERQUERA, LINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Leon County**

License Number: 4703374 A & D BUFFALOS  
 License Type: Permanent Food Service 1500 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 03/15/2010 Inspection Number: 1922833 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: ROSS, CYNTHIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 4700764 LINDYS CHICKEN #3  
 License Type: Permanent Food Service 1231 E LAFAYETTE, TALLAHASSEE 323014518

Inspection Date: 03/15/2010 Inspection Number: 1840786 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, walkin cooler door will only open from outside . For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 4702119 CHILI'S SOUTHWEST GRILL & BAR  
 License Type: Permanent Food Service 719 APALACHEE PKWY, TALLAHASSEE 323014534

Inspection Date: 03/15/2010 Inspection Number: 1871646 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WRIGHT, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.
45-39-2	Portable Class K fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

**Leon County**

License Number: 4702464		GOLDEN CORRAL OF TALLAHASSEE 734	
License Type: Permanent Food Service		1630 N MONROE ST, TALLAHASSEE 32303	
Inspection Date: 03/15/2010	Inspection Number: 1927653	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WRIGHT, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-15-2	No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.	NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.	
47-03-2	Observed unused openings in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 4703181		HEAVENLY CATERING INC	
License Type: Permanent Food Service		622 EUGENIA STREET, TALLAHASSEE 32310	
Inspection Date: 03/15/2010	Inspection Number: 1912612	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SMITH, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 4750126		SEINEYARD SEAFOOD CATERING	
License Type: Mobile Food Dispensing Vehicle		8056 WOODVILLE HWY, WOODVILLE 32362	
Inspection Date: 03/16/2010	Inspection Number: 1134352	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WRIGHT, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-38-2	Portable ABC fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 4703103		RODNEY'S DELI & CAFE	
License Type: Permanent Food Service		2600 BLAIRSTONE RD ROOM#185, TALLAHASSEE 32399	
Inspection Date: 03/19/2010	Inspection Number: 1920204	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: ROSS, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

**Levy County**

License Number: 4800567

KONA JOES ISLAND CAFE

License Type: Permanent Food Service

490 DOCK ST SUITE A, CEDAR KEY 32625

Inspection Date: 03/18/2010

Inspection Number: 1900786

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWNING, JULIANNE

Violation Code

Observation

Violation Citation

45-31-2

Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. . For reporting purposes only.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

**Manatee County**

License Number: 5103109

BURGER KING #6392

License Type: Permanent Food Service

6502 E SR 64, BRADENTON 34208

Inspection Date: 03/15/2010

Inspection Number: 1927681

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CHRISTENSON, MELISSA

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged next to back exit. Repair on order. For reporting purposes only. Corrected On Site.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5102991

RIVER WILDERNESS CLUB INC

License Type: Permanent Food Service

1 WILDERNESS BLVD, PARRISH 34219-9329

Inspection Date: 03/12/2010

Inspection Number: 1927563

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CHRISTENSON, MELISSA

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.



**Marion County**

License Number: 5202081		MARKET OF MARION ICE CREAM CON	
License Type: Permanent Food Service		12888 SE US HWY 441, BELLEVIEW 344204566	
Inspection Date: 03/19/2010	Inspection Number: 1901204	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ANAZIA, ROLAND			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only. Beverage cooler .	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5202387		THE LEVEE	
License Type: Permanent Food Service		20583 W PENNSYLVANIA AVE, DUNNELLON 34432	
Inspection Date: 03/16/2010	Inspection Number: 1849775	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WRENNE, LILYANN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period outside light. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5202678		MCKINNEY'S PLACE	
License Type: Permanent Food Service		11943 N WILLIAMS STREET STE D, DUNNELLON 34432	
Inspection Date: 03/16/2010	Inspection Number: 1927774	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WRENNE, LILYANN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period to George Forman gril.For reporting purposes only. Repeat Violation.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5201197		JADE LOUNGE	
License Type: Permanent Food Service		2423 NE JACKSONVILLE RD, OCALA 34470	
Inspection Date: 03/12/2010	Inspection Number: 1839469	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRYANT, BENJAMIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-25-2	Hood filters not equipped with a drip tray. For reporting purposes only.	NFPA 96, 6.2.4.1 Grease filters shall be equipped with a grease drip tray beneath their lower edges. FOR REPORTING PURPOSES ONLY	



**Marion County**

License Number: 5202662

KING GARDEN

License Type: Permanent Food Service

17860 SE 109TH AVE #603, SUMMERFIELD 34491

Inspection Date: 03/15/2010

Inspection Number: 1839515

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANAZIA, ROLAND

Violation Code

Observation

Violation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only. FRont/back door .

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Martin County**

License Number: 5301204

ROY'S BARBQ GRILL &amp; CAFE INC

License Type: Permanent Food Service

3310 INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 03/12/2010

Inspection Number: 1926902

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

45-22-2

Portable fire extinguisher(s) obstructed from view. For reporting purposes only...  
kitchen.

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

License Number: 5300047

YACHT &amp; COUNTRY CLUB INC (THE)

License Type: Permanent Food Service

3883 SE FAIRWAY EAST, STUART 349976119

Inspection Date: 03/16/2010

Inspection Number: 1876113

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DERVIN, RICHARD

Violation CodeObservationViolation Citation

47-04-2

Observed frayed/spliced electrical wires. For reporting purposes only. electric cord  
on 2/door cooler in store room.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Monroe County**

License Number: 5402417		KEV'S CAFE	
License Type: Permanent Food Service		79851 OVERSEAS HWY, ISLAMORADA 33036	
Inspection Date: 03/17/2010	Inspection Number: 1894747	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLIVERO, ANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 5402616		OUTBACK STEAKHOUSE	
License Type: Permanent Food Service		79999 OVERSEAS HWY, ISLAMORADA 33036	
Inspection Date: 03/15/2010	Inspection Number: 1843542	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLIVERO, ANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.Kitchen	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
License Number: 5401465		HUNGRY TARPON	
License Type: Permanent Food Service		77522 OVERSEAS HWY, ISLAMORADA 330363813	
Inspection Date: 03/17/2010	Inspection Number: 1874270	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OLIVERO, ANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only.Wires running in handsink	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
48-06-2	Observed a gas appliance without proper venting. For reporting purposes only.	61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.	

**Monroe County**

License Number: 5400062

BIG PINE COFFEE SHOP

License Type: Permanent Food Service

29943 OVERSEAS HWY, BIG PINE KEY 33043

Inspection Date: 03/18/2010

Inspection Number: 1853860

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OLIVERO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.Front door	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-08-2	Observed electrical wiring in disrepair. For reporting purposes only.Floor by main box	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
47-15-2	Observed an uncovered electrical box. For reporting purposes only.Outside	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

**Nassau County**

License Number: 5501051 YB SLIM POOL HALL & GRILL  
 License Type: Permanent Food Service 542113 US HWY 1, CALLAHAN 32011

Inspection Date: 01/14/2010 Inspection Number: 1928075 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued  
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair

License Number: 5500832 PASTRY KITCHEN  
 License Type: Permanent Food Service 4750 AMELIA ISLAND PKWY, AMELIA ISLAND 32034

Inspection Date: 03/15/2010 Inspection Number: 1870720 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. expired	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

**Nassau County**

License Number: 5500691

EMPLOYEE DINING

License Type: Permanent Food Service

4750 AMELIA ISLAND PKY, AMELIA ISLAND 320345501

Inspection Date: 03/15/2010

Inspection Number: 1839865

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. expired on 1/10 and 3/10	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

**Nassau County**

License Number: 5500693

BANQUET KITCHEN

License Type: Permanent Food Service

4750 AMELIA ISLAND PKY, AMELIA ISLAND 320345501

Inspection Date: 03/15/2010

Inspection Number: 1839867

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only. expired	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

**Nassau County**

License Number: 5500694

MAIN KITCHEN

License Type: Permanent Food Service

4750 AMELIA ISLAND PKY, AMELIA ISLAND 320345501

Inspection Date: 03/15/2010

Inspection Number: 1911704

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

48-12-2 No current boiler certification provided/available. For reporting purposes only. expired

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 5550032

DUANE'S SMOKING

License Type: Mobile Food Dispensing Vehicle

463852 SR 200, YULEE 32097

Inspection Date: 03/15/2010

Inspection Number: 1139680

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-30-2 No Class K portable fire extinguisher provided for high hazard cooking area (for suppression system/equipment installed after June 30, 1998). For reporting purposes only.

NFPA 10, 4.3.2. and 4.3.2.1 Class K Fire Extinguishers for Cooking Oil Fires. Fire extinguishers provided for the protection of cooking appliances that use combustible cooking media (vegetable or animal oils and fats) shall be listed and labeled for Class K fires. Class K fire extinguishers manufactured after January 1, 2002, shall not be equipped with extended wand-type discharge devices. Fire extinguishers installed specifically for the protection of cooking appliances that use combustible cooking media (animal, vegetable oils and fats) prior to June 30, 1998, shall not be required to comply with 4.3.2. (Also see 4.3.2.3.). FOR REPORTING PURPOSES ONLY.

**Okaloosa County**

License Number: 5603528

DAYBREAK CATERING

License Type: Catering

14091 EMERALD COAST PKWY UNIT C, DESTIN 32541

Inspection Date: 03/12/2010

Inspection Number: 1093606

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEREZ, FELIPE

Violation Code

Observation

Violation Citation

15-42-2 Observed one hood filter installed horizontally, rather than vertically. For reporting purposes only.

NFPA 96, 6.2.5 and 6.2.1.4 Grease Filter Orientation. Grease filters that require a specific orientation to drain grease shall be clearly so designated, or the hood shall be constructed so that filters cannot be installed in the wrong orientation; NFPA 96, 6.2.1.4: Grease removal devices supplied as part of listed hood assemblies shall be installed in accordance with the terms of the listing and the manufacturer's instructions. FOR REPORTING PURPOSES ONLY

License Number: 5600018

LOS RANCHEROS

License Type: Permanent Food Service

300 EGLIN PKWY, FT WALTON BCH 325472826

Inspection Date: 03/18/2010

Inspection Number: 1902091

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEREZ, FELIPE

Violation Code

Observation

Violation Citation

15-26-2 Observed exhaust system operated with one filter removed/missing.

NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.

**Okeechobee County**

License Number: 5700531

LIGHTSEY RESTAURANT

License Type: Permanent Food Service

10430 W HWY 78, OKEECHOBEE 349749719

Inspection Date: 03/18/2010

Inspection Number: 1842246

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

15-28-2

Violation: 15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.



**Orange County**

License Number: 5810666 BUCA DI BEPPO  
 License Type: Permanent Food Service 8001 S ORANGE BLOSSOM TRL, ORLANDO 32809

Inspection Date: 03/15/2010 Inspection Number: 1837601 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: LAMBERT, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
45-38-2	Portable fire extinguisher not fully charged, by handwashing sink in kitchen by prep area and also in waitress side station. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5853300 THE SNACK SHACK  
 License Type: Mobile Food Dispensing Vehicle 6422 MILNER BLVD, ORLANDO 32809

Inspection Date: 03/17/2010 Inspection Number: 1135406 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LAMBERT, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5810624 DUNKIN DONUTS / BASKIN ROBBINS  
 License Type: Permanent Food Service 2900 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 03/16/2010 Inspection Number: 1899170 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LAMBERT, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged, by back door storage room. For reporting purposes only. Repeat Violation.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 5809601 FISH ON FIRE  
 License Type: Permanent Food Service 7937 DAETWYLER DR, ORLANDO 32812

Inspection Date: 03/16/2010 Inspection Number: 1927747 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GORIS, WILBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-04-2	Observed frayed/spliced electrical wires. For reporting purposes only. EXPOSED WIRES THROUGHOUT FACILITY AS A RESULT OF FIRE.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Orange County**

License Number: 5809181 PANERA BREAD #3312  
 License Type: Permanent Food Service 11472 UNIVERSITY BLVD, ORLANDO 32817  
 Inspection Date: 03/17/2010 Inspection Number: 1899360 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.2 ON BOTTOM SHELF UNDER GRIL BY THE DOOR	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5811565 RUBY TUESDAY #7182  
 License Type: Permanent Food Service 11401 UNIVERSITY BLVD, ORLANDO 32817  
 Inspection Date: 03/15/2010 Inspection Number: 1878869 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.BY OFFICE	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5808185 PONDEROSA STEAKHOUSE #1046  
 License Type: Permanent Food Service 6362 INTERNATIONAL DR, ORLANDO 32819  
 Inspection Date: 03/15/2010 Inspection Number: 1847984 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.Cooks' line.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Orange County**

License Number: 5812425		GELATORIA	
License Type: Permanent Food Service		5601 UNIVERSAL BLVD, ORLANDO 32819	
Inspection Date: 03/17/2010	Inspection Number: 1920518	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: O'BRYAN, DARLENE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 5805749		RAMADA LAKEFRONT	
License Type: Permanent Food Service		6500 INTERNATIONAL DR, ORLANDO 328198218	
Inspection Date: 03/17/2010	Inspection Number: 1888927	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. Entrance of kitchen .	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 5810261		GOLDEN CORRAL STEAK BUFFET BAK	
License Type: Permanent Food Service		8707 VINELAND AVE, ORLANDO 32821	
Inspection Date: 03/17/2010	Inspection Number: 1879626	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MATHIS, LANCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. Above flat top grill. For reporting purposes only. Corrected On Site.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 5810502		THAI THANI RESTAURANT	
License Type: Permanent Food Service		11025 INTERNATIONAL DR, ORLANDO 32821	
Inspection Date: 03/17/2010	Inspection Number: 1927735	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: MATHIS, LANCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

**Orange County**

License Number: 5809317 HAWTHORN SUITES ORLANDO AIRPORT  
 License Type: Permanent Food Service 7450 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 03/17/2010 Inspection Number: 1858415 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Violation: 45-39-2  Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor, class k. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 5807352 RACHEL'S  
 License Type: Permanent Food Service 8701 SOUTH ORANGE AVE, ORLANDO 32824

Inspection Date: 03/17/2010 Inspection Number: 1857763 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-40-2	No metal container installed for catching grease from hood drip tray. For reporting purposes only.	NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY

License Number: 5811672 EASTSIDE BISTRO  
 License Type: Permanent Food Service 12001 AVALON LAKE DRIVE STE F, ORLANDO 32828

Inspection Date: 03/19/2010 Inspection Number: 1917892 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-06-2	Ventilation hood not designed to prevent grease or condensation from causing cross-contamination.For reporting purposes only.NO HOOD SYSTEM .OPERATOR USING CONVECTION OVEN,STEAMER AND FRYING FOOD IN FRYING PANS RESULTING IN GREASE LADEN VAPORS. FIRE MAR	NFPA 96, 5.2 Hood Size. Hoods shall be sized and configured to provide for the capture and removal of grease-laden vapors (See 8.2.2.); 8.2.2 Air Volume. 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. 8.2.2.2 Test data, performance acceptable to the authority having jurisdiction, or both, shall be provided, displayed, or both, upon request. 8.2.2.3 Lower exhaust air volumes shall be permitted during no-load cooking conditions provided they are sufficient to capture and remove flue gases and residual vapors from cooking equipment. FOR REPORTING PURPOSES ONLY
39-05-2	Ventilation inadequate as evidenced by smoke in kitchen area. For reporting purposes only.NO HOOD SYSTEM	NFPA 96, 4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard; and NFPA 96, 8.2.2 Air Volume. NFPA 96, 8.2.2.1: Exhaust air volumes for hoods shall be of a sufficient level to provide for capture and removal of grease-laden cooking vapors. FOR REPORTING PURPOSES ONLY
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.NO HOOD SYSTEM . OPERATOR USING STEAMER ,CONVECTION OVEN AND FRYING FOOD IN FRY PANS AND	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.

**Orange County**

License Number: 5811733		URBAN FLATS - WATERFORD LAKES	
License Type: Permanent Food Service		504 N ALAFAYA TR SUITE 101, ORLANDO 32828	
Inspection Date: 03/12/2010	Inspection Number: 1927220	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: SINGH, GAJENDRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
37-20-2	Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	
47-07-2	Observed scorch marks around electrical outlet. For reporting purposes only. ONE AT EXPO STATION ICORNER	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 5811790		FIFTY BREWS BAR AND GRILL	
License Type: Permanent Food Service		875 WOODBURY ROAD #108, ORLANDO 32828	
Inspection Date: 03/15/2010	Inspection Number: 1926400	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: SINGH, GAJENDRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. SEVERAL UNDER FRONT COUNTER	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

License Number: 5812381		KOTO OF JAPAN	
License Type: Permanent Food Service		8255 LEE VISTA BLVD, ORLANDO 32829	
Inspection Date: 03/18/2010	Inspection Number: 1918216	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Violation: 15-28-2  Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Orange County**

License Number: 5800816

GIRAFFE CAFE

License Type: Permanent Food Service

1905 HOTEL PLAZA BLVD, ORLANDO 32830

Inspection Date: 03/17/2010

Inspection Number: 1837836

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: RIVERA, JESICA M

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. Corrected On Site.Removed.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5811853

PIZZA HUT

License Type: Permanent Food Service

10395 NARCOOSSEE RD #200, ORLANDO 32832

Inspection Date: 03/18/2010

Inspection Number: 1924002

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed emergency exits, stairs, hallways or egress, blocked with cart, step ladder, trashcan and empty boxes . For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 5811933

TACO BELL

License Type: Permanent Food Service

10211 NARCOOSSEE RD, ORLANDO 32832

Inspection Date: 03/18/2010

Inspection Number: 1909675

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-05-2

Observed obstructed emergency exits, stairs, hallways or egress, blocked with trash and boxes. For reporting purposes only.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.



**Orange County**

License Number: 5805064

POOLSIDE CAFE

License Type: Permanent Food Service

8686 PALM PKWY, ORLANDO 32836

Inspection Date: 03/18/2010

Inspection Number: 1899452

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RIVERA, JESICA M

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

**Orange County**

License Number: 5812320

SWEET TOMATOES

License Type: Permanent Food Service

12561 S APOPKA VINELAND RD, ORLANDO 32836

Inspection Date: 03/18/2010

Inspection Number: 1899424

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RIVERA, JESICA M

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 5811834

MOJITOS ULTRA LOUNGE

License Type: Permanent Food Service

13526 VILLAGE PARK DR STE# 226, ORLANDO 32837

Inspection Date: 03/16/2010

Inspection Number: 1910307

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: NEGRON, LARA

Violation CodeObservationViolation Citation

45

Out of compliance: Fire extinguishers - proper and sufficient

NFPA 101, 96, 10 Fire extinguishers - proper and sufficient

License Number: 5811929

QUIZNOS SUB

License Type: Permanent Food Service

3119 DANIELS RD 102, WINTER GARDEN 34787

Inspection Date: 03/11/2010

Inspection Number: 1879723

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

49-08-2

Observed flammables and debris stored underneath three compartment sink. For reporting purposes only.

61C-1.004(7) FAC (7) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. FOR REPORTING PURPOSES ONLY.

**Orange County**

License Number: 5812034

CHIPOTLE MEXICAN GRILL

License Type: Permanent Food Service

3317 DANIELS RD #102, WINTER GARDEN 34787

Inspection Date: 03/11/2010

Inspection Number: 1889943

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

45-40-2

Portable fire extinguisher with no approved inspection tag. For reporting purposes only.

61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

License Number: 5812272

HOBOS BBQ HOUSE

License Type: Permanent Food Service

15502 STONEYBROOK WEST PKWY #118, WINTER GARDEN 34787

Inspection Date: 03/11/2010

Inspection Number: 1926710

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

45-41-2

Portable fire extinguisher tag out-of-date. For reporting purposes only.

NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.

**Osceola County**

License Number: 5910787

DOMINO'S PIZZA

License Type: Permanent Food Service

8687 IRLO BRONSON PARKWAY, KISSIMMEE 34747

Inspection Date: 03/15/2010

Inspection Number: 1927629

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For Coca Cola Cooler located at front area. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 5910959

EDY'S ENTERTAINMENT LLC

License Type: Permanent Food Service

7551 W IRLO BRONSON HWY, KISSIMMEE 34747

Inspection Date: 03/19/2010

Inspection Number: 1898730

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. At back preparation area. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

**Palm Beach County**

License Number: 6051516		TOMMY DOG	
License Type: Mobile Food Dispensing Vehicle		8110 MONETARY DRIVE, WEST PALM BEACH 33404	
Inspection Date: 03/16/2010	Inspection Number: 1135852	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-22-2	Portable fire extinguisher(s) obstructed from view. For reporting purposes only.	NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.	
License Number: 6010187		WENDY'S/INTERGALACTIC BURGER	
License Type: Permanent Food Service		2975 45 ST, WEST PALM BEACH 334071901	
Inspection Date: 03/11/2010	Inspection Number: 1834942	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6007698		45 STREET CAFE	
License Type: Permanent Food Service		6001 VILLAGE BLVD, WEST PALM BEACH 334071944	
Inspection Date: 03/16/2010	Inspection Number: 1834940	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-24-2	Hood filters need cleaning. For reporting purposes only.	NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY	
License Number: 6011111		HONG KONG CAFE	
License Type: Permanent Food Service		2100 45 ST, WEST PALM BEACH 334072016	
Inspection Date: 03/11/2010	Inspection Number: 1834948	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-24-2	Hood filters need cleaning. For reporting purposes only.	NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY	
45-38-2	Portable fire extinguisher not fully charged. For reporting purposes only. k-class extinguisher	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.	
License Number: 6012904		HOOTERS OF WEST PALM BEACH LAKES	
License Type: Permanent Food Service		2020 PALM BEACH LAKES BLVD, WEST PALM BEACH 33409	
Inspection Date: 03/17/2010	Inspection Number: 1896334	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-24-2	Hood filters need cleaning. For reporting purposes only.	NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Palm Beach County**

License Number: 6007338	BEAR LAKES COUNTRY CLUB		
License Type: Permanent Food Service	1901 VILLAGE BLVD, WEST PALM BEACH 334097399		
Inspection Date: 03/17/2010	Inspection Number: 1875971	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JONES, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-24-2	Hood filters need cleaning. For reporting purposes only.	NFPA 96, 6.2.3.4 Grease filters shall be easily accessible and removable for cleaning. FOR REPORTING PURPOSES ONLY	
15-27-2	Observed the presence of mesh filters in a hood where grease laden vapors are produced. For reporting purposes only.	NFPA 96, 6.1.3 Mesh filters shall not be used. FOR REPORTING PURPOSES ONLY	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 6007757	BAY CITY BISTRO		
License Type: Permanent Food Service	4240 NORTHLAKE BLVD, PALM BCH GDNS 334106222		
Inspection Date: 03/16/2010	Inspection Number: 1896436	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Violation: 46-09-2 Exit signs not properly illuminated. For reporting purposes only.backdoor	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

License Number: 6019734	OUTBACK STEAKHOUSE		
License Type: Permanent Food Service	11101 SOUTHERN BLVD, ROYAL PALM BEACH 33411		
Inspection Date: 03/16/2010	Inspection Number: 1896288	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MIDDLETON, ELWYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 6020138	KONTIKI RESTAURANT		
License Type: Permanent Food Service	13860 WELLINGTON TRACE, VILLAGE OF WELLINGTO 33414		
Inspection Date: 03/17/2010	Inspection Number: 1896172	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MENOR, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only. 20 pound propalN tanks (2) IN KITCHEN	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	

License Number: 6019135	SMOKEY BONES BAR & FIRE GRILL #7539		
License Type: Permanent Food Service	10260 FOREST HILL BLVD, WELLINGTON 33414		
Inspection Date: 03/15/2010	Inspection Number: 1865521	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MENOR, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Palm Beach County**

License Number: 6020435

BURGER KING # 17461

License Type: Permanent Food Service

1760 S MILITARY TRAIL, WEST PALM BEACH 33415

Inspection Date: 03/16/2010

Inspection Number: 1927802

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

46-05-2 Observed obstructed exits, stairs, hallways or egress. For reporting purposes only. Corrected On Site.

NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

License Number: 6051549

TAQUERIA LA ESTRELLA

License Type: Mobile Food Dispensing Vehicle

2690 SOUTH MILITARY TRAIL, WEST PALM BEACH 33415

Inspection Date: 03/12/2010

Inspection Number: 1137651

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6013014

BOVA CUCINA

License Type: Permanent Food Service

1901 N MILITARY TRL, BOCA RATON 33431

Inspection Date: 02/24/2010

Inspection Number: 1928059

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

15-28-2 Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.  
--- cook line, just to the right of char broiler.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

45-15-2 No placard placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only.

NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.

License Number: 6020272

PALATE PLEASERS

License Type: Permanent Food Service

777 YAMATO RD, BOCA RATON 33431

Inspection Date: 06/26/2009

Inspection Number: 1831962

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

47 Out of compliance: Electrical wiring - adequate, good repair

NFPA 101, 96, 10 Electrical wiring - adequate, good repair

**Palm Beach County**

License Number: 6010841		ARGENTANGO GRILL	
License Type: Permanent Food Service		508 VIA DE PALMAS, BOCA RATON 33432	
Inspection Date: 12/30/2009	Inspection Number: 1927942	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45	Out of compliance: Fire extinguishers - proper and sufficient	NFPA 101, 96, 10 Fire extinguishers - proper and sufficient	
48	Out of compliance: Gas appliances - properly installed, maintained	NFPA 101, 96, 10 Gas appliances - properly installed, maintained	
License Number: 6019029		BOCA PITA EXPRESS	
License Type: Permanent Food Service		7185 N BERACASA WAY, BOCA RATON 33433	
Inspection Date: 03/15/2010	Inspection Number: 1844658	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: PIERI, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.6 BURNERS STOVE NO VENT	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 6009826		BAGEL WORKS	
License Type: Permanent Food Service		8177 GLADES RD, BOCA RATON 33434	
Inspection Date: 03/18/2010	Inspection Number: 1927884	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: PIERI, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.BACK ,FRONT	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.WRAPPED AROUND HANDWASH FAUCETS DISHMACHINE AREA AND WAIT STATION HANDWASH	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	
License Number: 6013847		WENDY'S OLD FASHIONED HAMBURGERS	
License Type: Permanent Food Service		600 E WOOLBRIGHT RD, BOYNTON BEACH 33435	
Inspection Date: 03/19/2010	Inspection Number: 1906532	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURGGRAVE, BROCK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only. mens restroom	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

**Palm Beach County**

License Number: 6020342

BUTTERFLY ASIAN BISTRO

License Type: Permanent Food Service

305 EAST WOOLBRIGHT ROAD, BOYNTON BEACH 33435

Inspection Date: 03/19/2010

Inspection Number: 1921855

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BURGGRABE, BROCK

Violation CodeObservationViolation Citation

47-06-2 Observed extension cord in use for non-temporary period. For reporting purposes only. taped to floor

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6013349

CASA CUBA RESTAURANT

License Type: Permanent Food Service

6230 INDIANTOWN RD #10, JUPITER 33458

Inspection Date: 03/16/2010

Inspection Number: 1876025

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

46-09-2 Exit signs not properly illuminated. For reporting purposes only.backdoor

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

License Number: 6019969

ELAYNE'S

License Type: Permanent Food Service

2425 10 AVE NORTH, LAKE WORTH 33461

Inspection Date: 03/12/2010

Inspection Number: 1844948

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONCEPCION, MARIA

Violation CodeObservationViolation Citation

45-39-2 Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6019712

2 CHEFS SOUPAREE

License Type: Permanent Food Service

6338 LANTANA RD STE 60, LANTANA 33462

Inspection Date: 03/15/2010

Inspection Number: 1865481

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PONCE, NUARETTE

Violation CodeObservationViolation Citation

45-31-2 Observed the use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. OPERATOR COOKING BACON ON A GRIDDLE\_PLACED IN THE FRONT COUNTER OF THE ESTABLISHMENT.

NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.



**Palm Beach County**

License Number: 6020396 CATHY'S COURTSIDE CAFE  
 License Type: Permanent Food Service 1605 US HWY 1, JUPITER 33477

Inspection Date: 03/18/2010 Inspection Number: 1920449 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: DERVIN, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.
49-12-2	Observed container of flammable material over 5 gallons stored in establishment. For reporting purposes only. propane tank. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.

License Number: 6007727 2ND STREET CORNER BAR RESTAURANT INC  
 License Type: Permanent Food Service 214 SE 2 ST, DELRAY BEACH 33483

Inspection Date: 03/16/2010 Inspection Number: 1923876 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MULLINGS, SEANTELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.
45-07-2	Observed misalignment of hood suppression system nozzles. For reporting purposes only. no nozzles over tabletop fryer	NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only - in kitchen.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6012865 CUISINE CREOLE  
 License Type: Permanent Food Service 229 SE 2 AVE, DELRAY BEACH 33483

Inspection Date: 03/11/2010 Inspection Number: 1865320 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: MULLINGS, SEANTELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-13-2	Violation: 48-13-2  Deep fat fryer installed without 16-inch separation from open flame. For reporting purposes only.	NFPA 96, 12.1.2.4 All deep fat fryers shall be installed with at least a 16-inch space between the fryer and surface flames from adjacent cooking equipment. FOR REPORTING PURPOSES ONLY.



**Pasco County**

License Number: 6102616

TAMPA BAY GOLF &amp; COUNTRY CLUB

License Type: Permanent Food Service

10641 OLD TAMPA BAY RD, SAN ANTONIO 33576

Inspection Date: 03/19/2010

Inspection Number: 1857121

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

45-22-2

Portable fire extinguisher(s) obstructed from view. For reporting purposes only.  
bar area

NFPA 10, 1.5.6 Fire extinguishers shall not be obstructed or obscured from view. In large rooms, and in certain locations where visual obstructions cannot be completely avoided, means shall be provided to indicate the extinguisher location. FOR REPORTING PURPOSES ONLY.

License Number: 6112918

BEST OF PHILLY CHEESESTEAK HOUSE

License Type: Permanent Food Service

2321 SEVEN SPRINGS BLVD, NEW PORT RICHEY 34655

Inspection Date: 03/19/2010

Inspection Number: 1857153

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. For reporting purposes only. by back  
door

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 6101199

PIT BOSS BAR B QUE &amp; PUB

License Type: Permanent Food Service

4221 LITTLE RD, NEW PORT RICHEY 346551606

Inspection Date: 03/16/2010

Inspection Number: 1867355

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROTHAG, SANDRA

Violation CodeObservationViolation Citation

45-38-2

Portable fire extinguisher not fully charged. For reporting purposes only.

NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6101792

MUGOOS DINER

License Type: Permanent Food Service

16103 US HWY 19, HUDSON 34667

Inspection Date: 03/17/2010

Inspection Number: 1927904

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GLENN, DAVID

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes  
only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Pinellas County**

License Number: 6216153		BIG STEIN'S DELI	
License Type: Permanent Food Service		9001 4 ST N, ST. PETERSBURG 33702	
Inspection Date: 03/18/2010	Inspection Number: 1927991	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 6212688		THAI KITCHEN RESTAURANT	
License Type: Permanent Food Service		1126 N 62 AVE, ST PETERSBURG 337027422	
Inspection Date: 03/16/2010	Inspection Number: 1856069	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-09-2	Exit signs not properly illuminated. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

License Number: 6216059		BONEFISH GRILL	
License Type: Permanent Food Service		5061 4 ST N, ST. PETERSBURG 33703	
Inspection Date: 03/15/2010	Inspection Number: 1886764	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WAGNER, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Pinellas County**

License Number: 6205584

BERMUDA'S

License Type: Permanent Food Service

5700 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 09/23/2009

Inspection Number: 1908247

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIROCCO, JOSEPH

Violation Code      ObservationViolation Citation

15-26-2      Observed exhaust system operated with filters removed. For reporting purposes only.

NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.

48-12-2      No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6211769

CHECKERS #160

License Type: Permanent Food Service

6730 CENTRAL AVE, ST PETERSBURG 337071332

Inspection Date: 03/18/2010

Inspection Number: 1927601

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, TRINETTE

Violation Code      ObservationViolation Citation

47-16-2      Electrical outlet cover plate in disrepair. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6216585

EL MAGUEY MEXICAN RESTAURANT

License Type: Permanent Food Service

4327 66 ST N, KENNETH CITY 33709

Inspection Date: 03/15/2010

Inspection Number: 1927191

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURKE, LAWRENCE

Violation Code      ObservationViolation Citation

15-40-2      No metal container installed for catching grease from hood drip tray. For reporting purposes only.

NFPA 96, 6.2.4.3 Grease drip trays shall be pitched to drain into an enclosed metal container having a capacity not exceeding 1 gallon. FOR REPORTING PURPOSES ONLY

47-15-2      Observed an uncovered electrical box. For reporting purposes only.{BEHIND TRUE UPRIGHT COOLER}

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

**Pinellas County**

License Number: 6214941		SAM SELTZER'S STEAKHOUSE	
License Type: Permanent Food Service		3500 TYRONE BLVD, ST PETERSBURG 33710	
Inspection Date: 03/16/2010	Inspection Number: 1855771	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate. For reporting purposes only.[switch cover missing in storage room]	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6215133		KRISTINA'S CAFE	
License Type: Permanent Food Service		3590 N 34 ST, ST PETERSBURG 33713	
Inspection Date: 03/08/2010	Inspection Number: 1927770	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47	Out of compliance: Electrical wiring - adequate, good repair	NFPA 101, 96, 10 Electrical wiring - adequate, good repair	
License Number: 6251258		FRANKS FRANKS #3	
License Type: Mobile Food Dispensing Vehicle		2619 23 AVE NORTH, ST. PETERSBURG 33713	
Inspection Date: 03/17/2010	Inspection Number: 1137716	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-41-2	Portable fire extinguisher tag out-of-date. For reporting purposes only.	NFPA 10, 6.3.1 Frequency. Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. FOR REPORTING PURPOSES ONLY.	
License Number: 6211522		CHECKERS #139	
License Type: Permanent Food Service		3501 N 34 ST, ST PETERSBURG 337131516	
Inspection Date: 03/15/2010	Inspection Number: 1927661	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: JACKSON, BEATRICE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet missing cover plate behind grill line freezer. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6216449		LA QUINTA INN #684	
License Type: Permanent Food Service		4999 34TH ST N, ST. PETERSBURG 33714	
Inspection Date: 03/12/2010	Inspection Number: 1835306	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BURKE, LAWRENCE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-15-2	Observed an uncovered electrical box. For reporting purposes only.[storage room]	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	

**Pinellas County**

License Number: 6209598

MEKONG ORIENTAL RESTAURANT

License Type: Permanent Food Service

5944 N 34 STREET, ST PETERSBURG 337141211

Inspection Date: 03/18/2010

Inspection Number: 1876355

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BURKE, LAWRENCE

Violation CodeObservationViolation Citation

47-04-2

Observed frayed/spliced electrical wires. For reporting purposes only.[reachin cooler]

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6212927

WOK DELI

License Type: Permanent Food Service

1846 N 61 AVE, ST PETERSBURG 337141526

Inspection Date: 03/19/2010

Inspection Number: 1896748

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: BURKE, LAWRENCE

Violation CodeObservationViolation Citation

45-36-2

Violation: 45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

45-36-2

Hood suppression system tag out-of-date. For reporting purposes only.

NPFA 96, 11.2.1 An inspection and servicing of the fire-extinguishing system and listed exhaust hoods containing a constant or fire-actuated water system shall be made at least every 6 months by properly trained and qualified persons. FOR REPORTING PURPOSES ONLY.

License Number: 6213166

THAI WOK RESTAURANT

License Type: Permanent Food Service

11270 N 4 ST UNIT 214, ST PETERSBURG 337162937

Inspection Date: 03/17/2010

Inspection Number: 1927878

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JACKSON, BEATRICE

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Pinellas County**

License Number: 6215338

GOOD FELLAS PIZZERIA &amp; WINGS

License Type: Permanent Food Service

11002 4TH ST N, ST. PETERSBURG 33716-6883

Inspection Date: 03/18/2010

Inspection Number: 1927992

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, BEATRICE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6216299

ANGIES GRILL

License Type: Permanent Food Service

1732 DREW ST, CLEARWATER 33755

Inspection Date: 03/19/2010

Inspection Number: 1876671

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WINSOR, KIMBERLY

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only...right side of hotline.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6208525

BELLEAIR GRILL

License Type: Permanent Food Service

1575 S FORT HARRISON AVE, CLEARWATER 33756

Inspection Date: 03/17/2010

Inspection Number: 1920074

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, CAROL S

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6213208

PETE &amp; SHORTY'S

License Type: Permanent Food Service

2820 GULF TO BAY BLVD, CLEARWATER 33759

Inspection Date: 03/12/2010

Inspection Number: 1886824

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WINSOR, KIMBERLY

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

**Pinellas County**

License Number: 6216437

R&amp;S MARKET, DELI &amp; PIZZERIA

License Type: Permanent Food Service

2645 STATE ROAD 590, CLEARWATER 33759

Inspection Date: 03/19/2010

Inspection Number: 1886804

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WINSOR, KIMBERLY

Violation CodeObservationViolation Citation

45-07-2

Observed misalignment of hood suppression system nozzles. For reporting purposes only....fryer has no nozzle coverage.

NFPA 96, 10.2 Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's instructions, and the following standards where applicable. (1) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems (2) NFPA 13, Standard for the Installation of Sprinkler Systems (3) NFPA 17, Standard for Dry Chemical Extinguishing Systems (4) NFPA 17A, Standard for Wet Chemical Extinguishing Systems. FOR REPORTING PURPOSES ONLY.

48-06-2

Observed a gas appliance without proper venting. For reporting purposes only....fryer not completely under ventilation hood.

61C-1.004(13)(a) FAC Gas appliances. All appliances, including water heaters using gas, shall be kept in good repair and properly vented when manufacturers' instructions require venting of the appliance and shall meet the following requirements: (a) All appliances shall have a nationally recognized testing laboratory seal such as AGA or UL seal. FOR REPORTING PURPOSES ONLY.

License Number: 6206242

MIXED GRILLE

License Type: Permanent Food Service

3001 COUNTRYSIDE BLVD, CLEARWATER 33761

Inspection Date: 03/16/2010

Inspection Number: 1845960

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRAIG, CHRISTINE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.[under long table to left]

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6214028

BAN THAI SUSHI

License Type: Permanent Food Service

2519 MCMULLEN BOOTH RD # 506, CLEARWATER 33761

Inspection Date: 03/16/2010

Inspection Number: 1866461

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CRAIG, CHRISTINE

Violation CodeObservationViolation Citation

46-08-2

Exit signs not visible from any direction. For reporting purposes only[.in back sushi side]

NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.

**Pinellas County**

License Number: 6210024

MUGS N JUGS RESTAURANT

License Type: Permanent Food Service

14100 US HIGHWAY 19 N, CLEARWATER 33764

Inspection Date: 03/15/2010

Inspection Number: 1866125

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, CAROL S

Violation CodeObservationViolation Citation

45-39-2

Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

License Number: 6215162

PIZZERIA BELLA NAPOLI

License Type: Permanent Food Service

4900 E. BAY DR. UNIT C, LARGO 33764

Inspection Date: 03/12/2010

Inspection Number: 1896812

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, CAROL S

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6214429

SUZIE Q'S DINER

License Type: Permanent Food Service

9124 SEMINOLE BLVD, SEMINOLE 33772

Inspection Date: 03/17/2010

Inspection Number: 1866305

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: OLSEN, JAMES

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. broken plate on switch near toaster

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6214362

COUNTRY LEGENDS CAFE

License Type: Permanent Food Service

1568 MAIN ST, DUNEDIN 34698

Inspection Date: 03/18/2010

Inspection Number: 1856295

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

**Pinellas County**

License Number: 6211503

GRANT STADIUM

License Type: Permanent Food Service

373 DOUGLAS AVE, DUNEDIN 346987913

Inspection Date: 03/16/2010

Inspection Number: 1856265

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

15-28-2

Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only. Corrected On Site.

NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

**Polk County**

License Number: 6307259	LOS BROTHERS		
License Type: Permanent Food Service	1037 E MAIN ST, LAKE LAND 33801		
Inspection Date: 03/15/2010	Inspection Number: 1856727	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.	

License Number: 6307388	CHOP SHOP (THE)		
License Type: Permanent Food Service	126 KENTUCKY AVE, LAKE LAND 33801		
Inspection Date: 03/16/2010	Inspection Number: 1887445	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
37-20-2	Violation: 37-20-2  Hood not cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. For reporting purposes only.	NFPA 96, 11.4.2 Hoods, grease removal devices, fans, ducts, and other appurtenances shall be cleaned to bare metal prior to surfaces becoming heavily contaminated with grease or oily sludge. FOR REPORTING PURPOSES ONLY	

License Number: 6307261	THE GARDEN DELI		
License Type: Permanent Food Service	3342 WINTER LAKE ROAD, LAKE LAND 33803		
Inspection Date: 03/18/2010	Inspection Number: 1927983	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WHITE, RICKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-31-2	Observed the use of cooking equipment producing grease laden vapors with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	NFPA 96, 10.1.2 Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment. FOR REPORTING PURPOSES ONLY.	

License Number: 6304002	CHILI'S GRILL & BAR #216		
License Type: Permanent Food Service	3980 N US HWY 98, LAKE LAND 338093813		
Inspection Date: 03/17/2010	Inspection Number: 1927889	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, SHARON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only./ above grills.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

License Number: 6305126	ASIAN CHAO LAKE LAND		
License Type: Permanent Food Service	3800 US HWY 98 N #672, LAKE LAND 338093828		
Inspection Date: 03/12/2010	Inspection Number: 1927552	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JACKSON, SHARON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	

**Polk County**

License Number: 6304569 TOUCHDOWN EDDIE'S  
 License Type: Permanent Food Service 6617 N SOCRUM LOOP ROAD, LAKE LAND 33809-4182

Inspection Date: 03/16/2010 Inspection Number: 1927790 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only./ back stockroom.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only./ back stockroom.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6307894 PANCHO'S GRILL & CANTINA  
 License Type: Permanent Food Service 117 E LAKE AVE STE B, AUBURNDALE 33823

Inspection Date: 03/18/2010 Inspection Number: 1928019 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-06-2	Observed extension cord in use for non-temporary period. For reporting purposes only./ kitchen /reachin cooler	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6307819 ZEN - ASIAN GRILL  
 License Type: Permanent Food Service 4812 GRANDVIEW PARKWAY, DAVENPORT 33837

Inspection Date: 03/15/2010 Inspection Number: 1927635 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROMANO, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.

**Polk County**

License Number: 6301856

ARBY'S RESTAURANT

License Type: Permanent Food Service

612 HWY 60 W, LAKE WALES 33853

Inspection Date: 03/18/2010

Inspection Number: 1927978

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation CodeObservationViolation Citation

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. Front counter

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6307642

BIG DADDY'S BBQ

License Type: Permanent Food Service

3400 AVENUE G NW, WINTER HAVEN 33880

Inspection Date: 03/17/2010

Inspection Number: 1927851

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: WHITE, CHERYL

Violation CodeObservationViolation Citation

47-08-2

Observed electrical wiring in disrepair. Light over grills. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Putnam County**

License Number: 6400812

KING BUFFET

License Type: Permanent Food Service

321 HWY 19 N, PALATKA 32177

Inspection Date: 03/18/2010

Inspection Number: 1901793

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. NEAR KITCHEN DOOR

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only. NEAR KITCHEN DOOR

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. AT SUSHI STATION

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2

Violation: 47-16-2

Electrical outlet missing cover plate. For reporting purposes only. AT SUSHI STATION

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6400669

KRYSTAL

License Type: Permanent Food Service

505 N HWY 19, PALATKA 321773033

Inspection Date: 03/18/2010

Inspection Number: 1850672

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DOHERTY, BRENDEN

Violation CodeObservationViolation Citation

45-40-2

Portable fire extinguisher with no approved inspection tag. For reporting purposes only. CLASS K

61C-1.004(9)(b) FAC and NFPA 10, 6.3.4 A standard state approved service tag shall be attached to each extinguisher and a person holding a valid state permit issued by the State Fire Marshal shall recharge or inspect the extinguisher and shall prepare the tag to include the information required by rule 4A-21.241, FAC, herein adopted by reference. Maintenance Recordkeeping. Each fire extinguisher shall have a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service. FOR REPORTING PURPOSES ONLY.

**Santa Rosa County**

License Number: 6701353		SUBWAY #27086	
License Type: Permanent Food Service		5644 WOODBINE ROAD, PACE 32571	
Inspection Date: 03/15/2010	Inspection Number: 1927719	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WINN, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-07-2	Exit sign missing over front egress. For reporting purposes only.	NFPA 101, 7.10.1.2 Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign readily visible from any direction of exit access. FOR REPORTING PURPOSES ONLY.	
License Number: 6701405		SONIC DRIVE IN	
License Type: Permanent Food Service		4001 HWY 90, PACE 32571	
Inspection Date: 03/16/2010	Inspection Number: 1927814	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WINN, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 6701058		MCDONALDS RESTAURANT #15316	
License Type: Permanent Food Service		3540 HWY 90, PACE 325711060	
Inspection Date: 03/15/2010	Inspection Number: 1850796	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WINN, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-2	Observed unused opening in panel box unprotected. For reporting purposes only.	NFPA 70, 110.12(a) Unused Openings - Unused openings in boxes or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. FOR REPORTING PURPOSES ONLY.	
License Number: 6701063		PIZZA HUT #2073	
License Type: Permanent Food Service		4241 HWY 90, PACE 325712011	
Inspection Date: 03/16/2010	Inspection Number: 1927813	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WINN, RONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-05-2	Observed obstructed rear exit or egress. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.	
46-09-2	Exit signs not properly illuminated at front egress. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.	

**Sarasota County**

License Number: 6803736

KOBERNICK HOUSE DAIRY KITCHEN

License Type: Permanent Food Service

1951 N HONORE AVE, SARASOTA 342359117

Inspection Date: 03/17/2010

Inspection Number: 1852409

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VON CANNON, DEBORAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	No current boiler certification provided/available. For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

**Sarasota County**

License Number: 6803737

KOBERNICK HOUSE MEAT KITCHEN

License Type: Permanent Food Service

1951 N HONORE AVE, SARASOTA 342359117

Inspection Date: 03/17/2010

Inspection Number: 1842143

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VON CANNON, DEBORAH

Violation CodeObservationViolation Citation

48-12-2

No current boiler certification provided/available. For reporting purposes only.

69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 6803453

CAFE GABBIANO

License Type: Permanent Food Service

5104 OCEAN BLVD, SARASOTA 34242

Inspection Date: 03/18/2010

Inspection Number: 1902893

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: POSA, ANTHONY

Violation CodeObservationViolation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.

**Seminole County**

License Number: 6903518		ITALIAN VILLAGE PIZZA	
License Type: Permanent Food Service		1014 E SEMORAN BLVD, CASSELBERRY 32707	
Inspection Date: 03/17/2010	Inspection Number: 1900094	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WATSON, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-06-2	Observed flammable material stored around water heater. For reporting purposes only. Paper bag and cotton mops. Corrected On Site.	61C-1.004(8) FAC (8) Flammable materials inside an establishment shall be stored in approved-type containers (maximum size 5 gallons) and in such a manner as to prevent a fire hazard. FOR REPORTING PURPOSES ONLY.	
License Number: 6900991		BURGER KING #3331	
License Type: Permanent Food Service		1190 SPRINGS CENTER SOUTH, ALTAMONTE SPGS 327141941	
Inspection Date: 03/18/2010	Inspection Number: 1848752	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CHIU, CECILIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-26-2	Observed exhaust system operated with filters removed. For reporting purposes only.	NFPA 96, 11.1.2 Filter-equipped exhaust systems shall not be operated with filters removed. For reporting purposes only.	
License Number: 6903233		ALI BABA	
License Type: Permanent Food Service		1155 W SR 434 #105, LONGWOOD 32750	
Inspection Date: 03/15/2010	Inspection Number: 1838298	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: ZALESKI, AMY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-16-2	Electrical outlet by sandwich press missing cover plate. For reporting purposes only.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.	
License Number: 6904571		BERNIE'S GOURMET TO GO	
License Type: Permanent Food Service		1875 W CR 419 STE 400, OVIEDO 32765	
Inspection Date: 03/18/2010	Inspection Number: 1890295	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PLEICONES, KIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.	
License Number: 6904825		HABANEROS MEXICAN GRILL #5	
License Type: Permanent Food Service		829 EYRIE DR, OVIEDO 32765	
Inspection Date: 03/11/2010	Inspection Number: 1922656	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PLEICONES, KIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only. fire extinguisher on floor in office	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.	

**Seminole County**

License Number: 6903057 VIVONA'S NORTH RESTAURANT AND PIZZERIA  
 License Type: Permanent Food Service 2477 S. PARK AVE, SANFORD 32771

Inspection Date: 03/19/2010 Inspection Number: 1910748 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. Storeroom.	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6903689 BURGER KING #12368  
 License Type: Permanent Food Service 201 S FRENCH AVE, SANFORD 32771

Inspection Date: 03/16/2010 Inspection Number: 1849434 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-13-2	Circuit breaker box blocked and/or inaccessible. For reporting purposes only. Corrected On Site. Repeat Violation.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

License Number: 6904457 DUNKIN DONUTS/BASKIN ROBBINS  
 License Type: Permanent Food Service 4510 W SR 46, SANFORD 32771

Inspection Date: 03/19/2010 Inspection Number: 1917070 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-37-2	Portable fire extinguisher missing from designated location. For reporting purposes only. Kitchen.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

License Number: 6902160 MCDONALD'S  
 License Type: Permanent Food Service 4260 SR 426, WINTER PARK 327929364

Inspection Date: 03/17/2010 Inspection Number: 1910522 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MOORE, CAROLYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-39-2	Portable fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.	NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.

**St. Johns County**

License Number: 6501935

AMERICAN GRAFFITI RESTAURANT AND BAR

License Type: Permanent Food Service

410 ANASTASIA BLVD, SAINT AUGUSTINE 32080

Inspection Date: 03/17/2010

Inspection Number: 1859583

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GOSAI, MATT

Violation CodeObservationViolation Citation

47-05-2

Observed a splitter/multi-plug adapter in use. For reporting purposes only. BY  
MIXER

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6500062

OSTEENS RESTAURANT

License Type: Permanent Food Service

205 ANASTASIA BLVD, ST AUGUSTINE 32080

Inspection Date: 03/17/2010

Inspection Number: 1901444

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation CodeObservationViolation Citation

47-15-2

Observed an uncovered electrical box. For reporting purposes only. TIMER BOX  
OUTSIDE NEAR WALKINCOOLER

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

47-16-2

Electrical outlet missing cover plate. For reporting purposes only. SECOND  
STOREROOM

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6500816

CAFE ON THE GREEN / AUGUSTINE GRILL

License Type: Permanent Food Service

1000 PGA TOUR BLVD, PONTE VEDRA BCH 32082-3036

Inspection Date: 03/15/2010

Inspection Number: 1850188

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TUCKER, CATHY

Violation CodeObservationViolation Citation

48-21-1

No carbon monoxide sensor device located in a gas boiler room in a building  
which also contains sleeping rooms.Boiler Information: Boiler Jurisdiction Number: FL007605, Boiler Expiration Date:  
6/17/10 Boiler Jurisdiction Number: FL097200, Boiler Ex

509.211(5) FS Every enclosed space or room that contains a boiler regulated under chapter 554 which is fired by the direct application of energy from the combustion of fuels and that is located in any portion of a public lodging establishment that also contains sleeping rooms shall be equipped with one or more carbon monoxide sensor devices that bear the label of a nationally recognized testing laboratory and have been tested and listed as complying with the most recent Underwriters Laboratories, Inc., Standard 2034, or its equivalent, unless it is determined that carbon monoxide hazards have otherwise been adequately mitigated as determined by the division.

**St. Johns County**

License Number: 6500396 MI CASA CAFE  
 License Type: Permanent Food Service 69 ST GEORGE STREET, SAINT AUGUSTINE 32084

Inspection Date: 03/16/2010 Inspection Number: 1901476 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-16-2	Violation: 47-16-2  Electrical outlet missing cover plate. For reporting purposes only. NEXT TO MAKETABLE	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.
47-16-2	Electrical outlet missing cover plate. For reporting purposes only. NEXT TO MAKETABLE	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 6500145 MONKS VINEYARD (THE)  
 License Type: Permanent Food Service 56 ST GEORGE ST, ST AUGUSTINE 320843608

Inspection Date: 03/16/2010 Inspection Number: 1880955 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Observed lock on exit door that requires a key, tool or special knowledge to open. For reporting purposes only. UPSTAIRS EXIT LOCKED WITH PADLOCK	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 6501213 FAMILY DINER  
 License Type: Permanent Food Service 2443 SR 16, ST AUGUSTINE 32092

Inspection Date: 03/18/2010 Inspection Number: 1927709 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended  
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
15-28-2	Hood filters are not tight-fitting and firmly held in place - leaving open spaces. For reporting purposes only.	NFPA 96, 6.2.3.3 Grease filters shall be arranged so that all exhaust air shall pass through the grease filters. For reporting purposes only.



**St. Lucie County**

License Number: 6600473 SNACK BAR  
 License Type: Permanent Food Service 6759 S US HWY #1, PORT SAINT LUCIE 34952

Inspection Date: 03/10/2010 Inspection Number: 1909263 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-07-2	Observed scorch marks around electrical outlet above reach in freezer. For reporting purposes only.	61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

License Number: 6602452 GOODFELLAS PIZZA PASTA & SUBS  
 License Type: Permanent Food Service 2993 S. 25TH. ST., FORT PIERCE 34981

Inspection Date: 03/18/2010 Inspection Number: 1928017 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-14-2	Emergency light by walk-in cooler, hanging from wires. Notified Fire AHJ. For reporting purposes only.	NFPA 101, 7.9.1.1 Emergency lighting facilities for means of egress shall be provided in accordance with Section 7.9 for the following: (1) Buildings or structures where required in Chapter 11 through Chapter 42 (2) Underground and limited access structures as addressed in Section 11.7 (3) High-rise buildings as required by other sections of this Code (4) Doors equipped with delayed-egress locks (5) Stair shaft and vestibule of smokeproof enclosures, for which the following also apply: (a) The stair shaft and vestibule shall be permitted to include a standby generator that is installed for the smokeproof enclosure mechanical ventilation equipment. (b) The standby generator shall be permitted to be used for the stair shaft and vestibule emergency lighting power supply. FOR REPORTING PURPOSES ONLY.

License Number: 6602891 MCDONALDS #4331  
 License Type: Permanent Food Service 5435 NW ST JAMES DR, PORT ST LUCIE 34983

Inspection Date: 03/10/2010 Inspection Number: 1927669 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PARNASS, LAUREN P

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-05-2	Observed obstructed exits, stairs, hallways or egress, exit door near walk in cooler has 2 bread racks in front of it. For reporting purposes only.	NFPA 101, 7.1.10.1 and 61C-1.004(10) FAC Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. Means of access must permit unobstructed travel at all times and be maintained free of obstructions and fire hazards. Halls, entrances and stairways shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Hand rails shall be installed on all stairways and guard rails around all porches and steps. Adequate means of exit shall be provided pursuant to NFPA 101. FOR REPORTING PURPOSES ONLY.

**St. Lucie County**

License Number: 6602091

DOMINO'S PIZZA #3866

License Type: Permanent Food Service

300 PORT ST LUCIE BLVD, PORT ST LUCIE 34984

Inspection Date: 03/18/2010

Inspection Number: 1857983

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PARNASS, LAUREN P

Violation Code

Observation

Violation Citation

47-16-2

Electrical outlet missing cover plate, behind dry food storage shelf. For reporting purposes only. Repeat Violation. Corrected On Site.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

**Sumter County**

License Number: 7000498

DUNKIN DONUTS/BASKIN ROBBINS

License Type: Permanent Food Service

3460 WEDGEWOOD LN, THE VILLAGES 32162

Inspection Date: 03/18/2010

Inspection Number: 1887999

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DANCHO, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated....south exit in dining room. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
46-09-2	Exit signs not properly illuminated....east exit in dining room. For reporting purposes only.	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-14-2	Insufficient space around electrical equipment to permit ready and safe operation of such equipment....electric cord to ice cream freezer running through standing water near floor drain qt front counter..For reporting purposes only.	NFPA 70, 110.32 Work Space about Equipment. Sufficient space shall be provided and maintained about electrical equipment to permit ready and safe operation and maintenance of such equipment. In all cases, the work space shall be adequate to permit at least a 90-degree opening of doors or hinged panels. FOR REPORTING PURPOSES ONLY.

**Taylor County**

License Number: 7200317

STEINHATCHEE LANDING REST

License Type: Permanent Food Service

228 NE HWY 51, STEINHATCHEE 32359

Inspection Date: 03/18/2010

Inspection Number: 1861430

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DODSON, FRED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-09-2	Exit signs not properly illuminated. For reporting purposes only.dining room front	61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.
47-15-2	Observed an uncovered electrical box. For reporting purposes only.breaker box ,storage area	NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

**Volusia County**

License Number: 7402638 INDIGO LAKES GOLF CLUB  
 License Type: Permanent Food Service 312 INDIGO DRIVE, DAYTONA BEACH 32114

Inspection Date: 03/16/2010 Inspection Number: 1923319 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-02-2	Violation: 46-02-2  Observed a lock and hasp on storage room door at bar and at liquor room.. For reporting purposes only.	NFPA 101, 7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side. FOR REPORTING PURPOSES ONLY.

License Number: 7404876 OUTBACK STEAKHOUSE  
 License Type: Permanent Food Service 1490 INTERNATIONAL SPEEDWAY, DAYTONA BEACH 32114

Inspection Date: 03/18/2010 Inspection Number: 1848533 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-12-2	Expired boiler certification provided/available./Viewed inspection report dated 3/05/10 For reporting purposes only.	69A-51.050(2) FAC (2) Inspection Requirements. Each boiler used or proposed to be used in a place of public assembly within this state except boilers exempt under subsection 69A-51.045(6), F.A.C., shall be thoroughly inspected as to its construction, installation and condition as follows: (a) Power boilers and high pressure, high temperature water boilers shall receive a certificate inspection annually. They shall be inspected annually both internally, where construction permits, and externally while not under pressure. They shall also be inspected annually externally while under pressure, if possible, within six (6) months of the internal inspection. (b) Heating boilers, except those constructed of cast iron, shall receive a certificate inspection biennially. This inspection may be an external inspection unless an internal inspection is required by the Authorized Inspector. The Authorized Inspector, due to operating conditions, may require additional inspections. (c) Hot water boilers and hot water supply boilers, except those constructed of cast iron, shall receive a certificate inspection biennially with an internal inspection every four (4) years if the construction of the boiler so permits. (d) Heating boilers and hot water supply boilers constructed of cast iron shall receive a certificate inspection biennially. (e) A grace period of one (1) month beyond the periods specified in paragraphs (a)-(d), above, may elapse between certificate inspections; however, the inspection certificate due date shall not be affected. (f) The Boiler Safety Program may, in its discretion, permit longer periods between certificate inspections. FOR REPORTING PURPOSES ONLY.

License Number: 7406250 CHURCH'S CHICKEN  
 License Type: Permanent Food Service 988 ORANGE AVE, DAYTONA BEACH 32114

Inspection Date: 03/17/2010 Inspection Number: 1927893 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-38-2	Portable fire extinguisher not fully charged by handsink/cookline..For reporting purposes only.	NFPA 10, 1.5.2 Portable fire extinguishers shall be maintained in a fully charged and operable condition and shall be kept in their designated places at all times when they are not being used. FOR REPORTING PURPOSES ONLY.

**Volusia County**

License Number: 7406767

LITTLE CAESARS PIZZA

License Type: Permanent Food Service

918 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 03/17/2010

Inspection Number: 1868964

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period by soda coolers. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

47-15-2

Observed a hose bibb next to the electrical panel at rear door/no splash guard in place to prevent water spray on to electrical. For reporting purposes only.

NFPA 70, 300.31 Covers Required. Suitable covers shall be installed on all boxes to prevent accidental contact with energized parts or physical damage to parts or insulation. FOR REPORTING PURPOSES ONLY.

License Number: 7406875

PAPA JOHNS PIZZA

License Type: Permanent Food Service

2625 ENTERPRISE RD 400, ORANGE CITY 32763

Inspection Date: 03/17/2010

Inspection Number: 1910032

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: BRASKA, GEORGIA

Violation CodeObservationViolation Citation

47-06-2

Violation: 47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only, by soda cooler.  
Repeat Violation.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Wakulla County**

License Number: 7500240

PIZZA HUT #2995

License Type: Permanent Food Service

2650 CRAWFORDVILLE HWY, CRAWFORDVILLE 323272160

Inspection Date: 03/16/2010

Inspection Number: 1892125

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WRIGHT, ANDREW

Violation Code

Observation

Violation Citation

45-39-2

Portable ABC fire extinguisher not properly mounted at least 4 inches off the floor and the top no higher than 5 feet off the floor. For reporting purposes only.  
Corrected On Site.

NFPA 10, 1.5.10 Fire extinguishers having a gross weight not exceeding 40 lb shall be installed so that the top of the fire extinguisher is not more than 5 ft above the floor. Fire extinguishers having a gross weight greater than 40 lb (except wheeled types) shall be so installed that the top of the fire extinguisher is not more than 3½ ft above the floor. In no case shall the clearance between the bottom of the fire extinguisher and the floor be less than 4 in. FOR REPORTING PURPOSES ONLY.



**Walton County**

License Number: 7601745

BURNT PINE COUNTRY CLUB

License Type: Permanent Food Service

9300 W HWY 98, DESTIN 32550

Inspection Date: 03/17/2010

Inspection Number: 1927356

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation CodeObservationViolation Citation

45-15-2

Placard is not placed near Class K portable fire extinguisher stating the fire suppression system must be activated prior to use of the portable extinguisher. For reporting purposes only

NFPA 10, 4.3.2.2 A placard shall be conspicuously placed near the extinguisher that states that the fire protection system shall be activated prior to using the fire extinguisher. FOR REPORTING PURPOSES ONLY.

License Number: 7601898

BAYTOWNE WHARF CONFERENCE CENTER

License Type: Permanent Food Service

9300 EMERALD COAST PKWY, DESTIN 32550

Inspection Date: 03/17/2010

Inspection Number: 1927354

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VINCENT, STACEY

Violation CodeObservationViolation Citation

47-06-2

Observed extension cord in use for non-temporary period. For reporting purposes only.

61C-1.004(11) FAC Electrical wiring. To prevent fire or injury, defective electrical wiring shall be replaced and wiring shall be kept in good repair. No extension cords shall be used except during cleaning, maintenance and other temporary activities. Only a wall switch or approved pull cord shall be permitted in bathrooms. In accordance with the provisions of NFPA 70, the National Electrical Code, as adopted by the Division of State Fire Marshal in Chapter 69A-3, FAC, Uniform Fire Safety Rules and Standards, sufficient electrical outlets shall be provided. FOR REPORTING PURPOSES ONLY.

**Washington County**

License Number: 7700101

PIZZA HUT #2054

License Type: Permanent Food Service

1319 MAIN ST, CHIPLEY 32428

Inspection Date: 03/15/2010

Inspection Number: 1927642

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARDING, LINDA

Violation Code

Observation

Violation Citation

46-09-2

Exit signs not properly illuminated. For reporting purposes only.

61C-1.004(10) FAC Exits shall be clearly marked with approved illuminated exit signs. FOR REPORTING PURPOSES ONLY.