

Alachua County

License Number: 1103186

CHUYS

License Type: Permanent Food Service

3410 SW ARCHER RD, GAINESVILLE 32608

Inspection Date: 07/20/2020

Inspection Number: 2990498

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed 1 red and 1 silver fire extinguisher in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506110

OFF THE TRAXX

License Type: Permanent Food Service

918 E NEW HAVEN AVE, MELBOURNE 32901

Inspection Date: 07/24/2020

Inspection Number: 3008152

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MITTEN, JAMES

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By all in cooler

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620019		GRANO DE MOSTAZA RESTAURANT	
License Type: Permanent Food Service		5550 NW 31 AVE STE 101, FORT LAUDERDALE 33309	
Inspection Date: 07/23/2020	Inspection Number: 3003691	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. -Observed a propane tank exceeds 2.7 pounds stored in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1623290		CHIPOTLE MEXICAN GRILL	
License Type: Permanent Food Service		6320 N ANDREWS AVE, FORT LAUDERDALE 33334	
Inspection Date: 07/23/2020	Inspection Number: 3015136	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door blocked with garbage container. **Corrected On-Site** **Repeat Violation**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 1620361		HACIENDA EL SOL INTERNACIONAL FOODS INC	
License Type: Permanent Food Service		5052 N DIXIE HWY, OAKLAND PARK 33334	
Inspection Date: 07/22/2020	Inspection Number: 3006313	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. -Observed a propane tank exceeds 2.7 pounds stored in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2331931	LA PARRILLA LATINA		
License Type: Permanent Food Service	28864 S DIXIE HWY, HOMESTEAD 33033		
Inspection Date: 07/24/2020	Inspection Number: 3012321	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, RICARDO			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2334027	PLATE		
License Type: Permanent Food Service	2105 CORAL WAY, MIAMI 33145		
Inspection Date: 07/21/2020	Inspection Number: 2972819	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-05-19: **Time Extended** - From follow-up inspection 2020-07-21: **Time Extended**		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2315390	WENDY'S #1703		
License Type: Permanent Food Service	1532 NE 163 ST, NORTH MIAMI BEACH 33162		
Inspection Date: 07/21/2020	Inspection Number: 2987431	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: STUBBS, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed 2 trays of bread and a trolley blocking the marked exit door. **Repeat Violation**		61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
License Number: 2334104	EMPANADA HARRYS BAKERY AND CAFE		
License Type: Permanent Food Service	4009 SW 152ND AVE, MIAMI 33185		
Inspection Date: 07/23/2020	Inspection Number: 3012036	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: URIBE, GUISELLA			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only, located in front of restroom.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330648

KILLER MELTS

License Type: Permanent Food Service

12310 SW 127 AVE, MIAMI 33186

Inspection Date: 07/20/2020

Inspection Number: 3000120

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614144 MCDONALDS 12357
 License Type: Permanent Food Service 8590 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 07/20/2020 Inspection Number: 2990075 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by three rolling bread rack cart. Moved by manager. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2609243 POPEYES LOUISIANA KITCHEN #155
 License Type: Permanent Food Service 10132 SAN JOSE BLVD, JACKSONVILLE 322575838

Inspection Date: 07/20/2020 Inspection Number: 3035630 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Boxes/ broken down boxes blocking pathway to emergency exit at back door. Operator removed boxes from pathway **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hendry County

License Number: 3600166

POPEYE'S FAMOUS FRIED CHICKEN

License Type: Permanent Food Service

504 E SUGARLAND HWY, CLEWISTON 33440-3211

Inspection Date: 07/21/2020

Inspection Number: 2996774

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3801035

DUNKIN DONUTS

License Type: Permanent Food Service

3525 US HWY 27 N, SEBRING 33870

Inspection Date: 07/23/2020

Inspection Number: 3011652

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

46-04-4

Electric panel blocked with racks and equipment.For reporting purposes only.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hillsborough County

License Number: 3912734

TROPICAL RHYTHM

License Type: Permanent Food Service

871 W BLOOMINGDALE AVE, BRANDON 33511

Inspection Date: 07/20/2020

Inspection Number: 3012305

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918284

EL RICO FRAPPE LATINO

License Type: Permanent Food Service

122 PIERCE CHRISTIE DR, VALRICO 33594

Inspection Date: 07/22/2020

Inspection Number: 3038849

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105157

SUBWAY #36886

License Type: Permanent Food Service

2190 45 ST, VERO BEACH 32960

Inspection Date: 07/20/2020

Inspection Number: 2994564

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
By boxes for renovations

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 4100883

PIZZA HUT #12580

License Type: Permanent Food Service

840 S US HWY 1, VERO BCH 329624703

Inspection Date: 07/21/2020

Inspection Number: 2990894

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
By trash **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Lee County

License Number: 4606313

HILTON GARDEN INN FORT MYERS AIRPORT

License Type: Permanent Food Service

16410 CORPORATE COMMERCE WAY, FORT MYERS 33913

Inspection Date: 07/24/2020

Inspection Number: 2997850

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PAGAN, VIRMAR

Violation Code

Observation

Violation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired on 4/3/2020.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Levy County

License Number: 4800486

STEAMERS CLAM BAR & GRILL

License Type: Permanent Food Service

420 DOCK ST, CEDAR KEY 32625

Inspection Date: 07/22/2020

Inspection Number: 3038443

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Silver extinguisher in kitchen area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5104576

BONEFISH GRILL

License Type: Permanent Food Service

8101 COOPER CREEK BLVD, UNIVERSITY PARK 34201

Inspection Date: 07/22/2020

Inspection Number: 3004575

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at rear kitchen door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5250750

SALSA BORICUA FOOD TRUCK

License Type: Mobile Food Dispensing Vehicle

119 MARION OAKS BOULEVARD, OCALA 34473

Inspection Date: 07/24/2020

Inspection Number: 1230448

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. During inspection, operator cooking raw chicken (Pinchos) on a flat top Grill, also two small fryers Used to cooked plantains.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301823

CUBAN CAFE

License Type: Permanent Food Service

9407 SE FEDERAL HWY, HOBE SOUND 33455

Inspection Date: 07/21/2020

Inspection Number: 2994018

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HORTON, TIMOTHY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top fliers in back prep area. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500614

HARDEE'S

License Type: Permanent Food Service

542309 US 1, CALLAHAN 32011

Inspection Date: 07/21/2020

Inspection Number: 3005278

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to handsink by office and another one by handsink at front counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5812820		BUFFALO WILD WINGS 546	
License Type: Permanent Food Service		11400 UNIVERSITY BLVD, ORLANDO 32817	
Inspection Date: 07/24/2020	Inspection Number: 3033313	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.- boxes **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5809344		GOLDEN LOTUS CHINESE RESTAURANT	
License Type: Permanent Food Service		8365 S JOHN YOUNG PKWY, ORLANDO 32819	
Inspection Date: 07/20/2020	Inspection Number: 3013077	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by containers of soy sauce	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810246		SONIC DRIVE-IN	
License Type: Permanent Food Service		5399 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 07/20/2020	Inspection Number: 3007857	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher in floor between the front doors **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810719		CICI'S PIZZA	
License Type: Permanent Food Service		4538 S SEMORAN BLVD, ORLANDO 32822	
Inspection Date: 07/20/2020	Inspection Number: 3027768	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. Plastic cart and heavy plastic carpet, emergency exit by back emergency door.For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Orange County

License Number: 5811916		TACO BELL	
License Type: Permanent Food Service		6065 S GOLDROD RD, ORLANDO 32822	
Inspection Date: 07/23/2020	Inspection Number: 3010524	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked, blocked with boxes. For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5814098		THE BRASS TAP	
License Type: Permanent Food Service		781 N ALAFAYA TRL, ORLANDO 32828	
Inspection Date: 07/20/2020	Inspection Number: 3024156	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.- has BTU of 250,000, if above 200,000, qualifies as a boiler, needs boiler certification.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5811536		CHAAT HOUSE	
License Type: Permanent Food Service		9472 S ORANGE BLOSSOM TR, ORLANDO 32837	
Inspection Date: 07/21/2020	Inspection Number: 2991513	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked, with Trashcan by bakery side. For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5814490		THAI EXPRESS	
License Type: Permanent Food Service		4693 GARDENS PARK BLVD STE 113, ORLANDO 32839	
Inspection Date: 07/24/2020	Inspection Number: 3027106	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door is impeded By multiple mopping buckets. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Osceola County

License Number: 5909767

BURGER KING 12136

License Type: Permanent Food Service

910 CYPRESS PKWY, KISSIMMEE 34759

Inspection Date: 07/20/2020

Inspection Number: 3037664

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216762

HUARACHE AZTECA 3

License Type: Permanent Food Service

22097 US 19 N, CLEARWATER 33765

Inspection Date: 07/21/2020

Inspection Number: 3038045

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Next to exit door in kitchen reading recharge **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217550

BURGERFI SEMINOLE

License Type: Permanent Food Service

11165 PARK BLVD SUITE C, SEMINOLE 33772

Inspection Date: 07/20/2020

Inspection Number: 3000107

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

47-03-4

Observed electrical cover missing for ice cream shake machine and one outlet on line missing cover. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214270

THE GREEN TABLE

License Type: Permanent Food Service

3390 TAMPA RD, PALM HARBOR 34684

Inspection Date: 07/23/2020

Inspection Number: 3007139

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Double counter top fryers newly added - located in back storage area - operator states fryers are brought to cook line and used in the morning then placed in storage area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6307955

GOLDEN DRAGON CHINESE RESTAURANT

License Type: Permanent Food Service

39871 US HIGHWAY 27, HAINES CITY 33844

Inspection Date: 07/21/2020

Inspection Number: 3016526

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Single basket fryer next to the rice cooker. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904582

HINODE SUSHI

License Type: Permanent Food Service

1016 LOCKWOOD BLVD, STE 160, OVIEDO 32765

Inspection Date: 07/20/2020

Inspection Number: 3030974

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the cooks line the the large extinguisher

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407207		TACO BELL	
License Type: Permanent Food Service		1748 DUNLAWTON AVE, PORT ORANGE 32127	
Inspection Date: 07/24/2020	Inspection Number: 3020947	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LARSON, SARAH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door to kitchen. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 7406228		J C'S RIPTIDES	
License Type: Permanent Food Service		2576 S RIDGEWOOD AVENUE, EDGEWATER 32141	
Inspection Date: 07/24/2020	Inspection Number: 2985213	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: PICHARDO, RENEE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. In prep area - From follow-up inspection 2020-07-24: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In prep area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7407145		DOMINO'S PIZZA	
License Type: Permanent Food Service		1675 PROVIDENCE BLVD, DELTONA 32725	
Inspection Date: 07/22/2020	Inspection Number: 3022995	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. By blocked by boxes.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	