

Alachua County

License Number: 1103462

EL PATIO JALISCO

License Type: Permanent Food Service

16135 NW US HWY 441 UNIT 10, ALACHUA 32615

Inspection Date: 08/21/2020

Inspection Number: 2999941

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small table top fry vat located on prep table outside of the hood system. (Use to cook fish)

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1503424		HOA RESTAURANT HOLDER LLC	
License Type: Permanent Food Service		877 S BABCOCK ST, MELBOURNE 32901	
Inspection Date: 08/19/2020	Inspection Number: 3008292	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MITTEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By office door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1502220		JADE PALACE	
License Type: Permanent Food Service		280 E EAU GALLIE BLVD, INDIAN HARBOUR BEACH 32937	
Inspection Date: 08/21/2020	Inspection Number: 3025725	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Entry into kitchen from rear door, red clip missing fire extinguisher. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1506275		THAI THAI BISTRO	
License Type: Permanent Food Service		971 E EAU GALLIE BLVD UNIT F, MELBOURNE 32937	
Inspection Date: 08/19/2020	Inspection Number: 3002630	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Miniature 2 pot fryer not located under hood system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1624708

FLIPPO'S

License Type: Permanent Food Service

801 N FEDERAL HWY #201, HALLANDALE 33009

Inspection Date: 08/19/2020

Inspection Number: 3019662

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Electric fryer by sushi station.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623851

GYM SPORTSBAR

License Type: Permanent Food Service

2287 WILTON DR, WILTON MANORS 33305

Inspection Date: 08/19/2020

Inspection Number: 2992934

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At FE in lobby. Operator replaced with a new one. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801656

HAMPTON INN

License Type: Permanent Food Service

24480 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 08/17/2020

Inspection Number: 2999577

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expiration date of 06/11/2020. **Repeat Violation**

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2326951		DOMINO'S PIZZA #3128	
License Type: Permanent Food Service		27335 S DIXIE HWY, NARANJA 33032	
Inspection Date: 08/17/2020	Inspection Number: 3015086	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, RICARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit blocked by accumulation of boxes.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2335151		VICTORIA BAKERY RESTAURANT	
License Type: Permanent Food Service		1130 WEST FLAGLER ST, MIAMI 33130	
Inspection Date: 08/17/2020	Inspection Number: 3013151	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Located in back bakery area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336233		TASCA PAELLA	
License Type: Permanent Food Service		401 BISCAYNE BLVD #200S, MIAMI 33132	
Inspection Date: 08/19/2020	Inspection Number: 3033387	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 lbs gas tank inside the food preparation area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326995		CARVEL #2509	
License Type: Permanent Food Service		3781 W FLAGLER ST, MIAMI 33134	
Inspection Date: 08/21/2020	Inspection Number: 3009156	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: URIBE, GUISELLA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2336549

EL VENTORRILLO BISTRO

License Type: Permanent Food Service

13920 SW 47 ST #103, MIAMI 33175

Inspection Date: 08/17/2020

Inspection Number: 3026765

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only, located in back preparation area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332013

1000 DEGREES NEAPOLITAN PIZZERIA

License Type: Permanent Food Service

14821 BISCAYNE BLVD, NORTH MIAMI BEACH 33181

Inspection Date: 08/20/2020

Inspection Number: 2999884

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. One extinguisher in the red zone that needs charge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615293	9 BALL HEAVEN		
License Type: Permanent Food Service	2777 UNIVERSITY BLVD W UNIT 12, JACKSONVILLE	32217	
Inspection Date: 08/19/2020	Inspection Number: 3025180	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door on left side of bar blocked with equipment and boxes **Repeat Violation**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2615897	DIAMOND LOUNGE		
License Type: Permanent Food Service	10749 MAIN ST, JACKSONVILLE	32218	
Inspection Date: 08/18/2020	Inspection Number: 3046129	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Black Bar blocking back door of kitchen	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2613663	ROSY'S MEXICAN RESTAURANT		
License Type: Permanent Food Service	4268 OLDFIELD CROSSING DR #107, JACKSONVILLE	32223	
Inspection Date: 08/21/2020	Inspection Number: 3027979	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Marked exit blocked by prep table in kitchen next to dish washing machine **Repeat Violation**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2615696	MI VERACRUZ MEXICAN RESTAURANT 2		
License Type: Permanent Food Service	7001 MERRILL RD STE 45, JACKSONVILLE	32277	
Inspection Date: 08/18/2020	Inspection Number: 3019883	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-02-4	Flammables stored/debris present in dry storage area. For reporting purposes only. Gallon container half full of gasoline stored in dry storage near rear door. Operator removed gas can from building. **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	

Franklin County

License Number: 2900467

HARRY A'S BAR & GRILL

License Type: Permanent Food Service

28 W BAYSHORE DR, ST. GEORGE ISLAND 32328

Inspection Date: 08/18/2020

Inspection Number: 2995526

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DESHAZIER, ERNEST

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 20 lb tanks in the back storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3918192

CHINA 1

License Type: Permanent Food Service

4350 W WATER AVE STE 103, TAMPA 33614

Inspection Date: 08/20/2020

Inspection Number: 2994631

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

49-05-4 Increase in seating from 0 to 8. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4101289

SONNY'S REAL PIT BAR-B-Q OF VERO BEACH

License Type: Permanent Food Service

5001 20 ST, VERO BCH 32966

Inspection Date: 08/21/2020

Inspection Number: 2993873

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher by walk in

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105503

NANCYS BBQ

License Type: Permanent Food Service

14475 SR 70 E, BRADENTON 34202

Inspection Date: 08/18/2020

Inspection Number: 3015122

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on fire extinguisher near exit door near bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800474

QUALITY INN & SUITES

License Type: Permanent Food Service

626 LEE RD, ORLANDO 32810

Inspection Date: 08/21/2020

Inspection Number: 3017539

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LUI, SUK HAN

Violation CodeObservationViolation Citation

45-05-4 - From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only./missing K-class extinguisher/next to cook line hand sink. - From follow-up inspection 2020-08-21: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only./missing K-class extinguisher/next to cook line hand sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810624

DUNKIN' DONUTS/BASKIN ROBBINS

License Type: Permanent Food Service

2900 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 08/19/2020

Inspection Number: 3000503

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only located by back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only located by back door - From follow-up inspection 2020-08-20: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811796

PIE FECTION

License Type: Permanent Food Service

3120 S KIRKMAN RD STE F, ORLANDO 32811

Inspection Date: 08/19/2020

Inspection Number: 3018841

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Propane gas tank stored by hand sink in dish area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5812962

IZZ CAFE CORP

License Type: Permanent Food Service

3575 VINELAND RD, ORLANDO 32811

Inspection Date: 08/20/2020

Inspection Number: 3008440

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only located near exit door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only located near exit door - From follow-up inspection 2020-08-21: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813822

SHERATON LAKE BUENA VISTA SPRINGBOARD MARKET PLACE

License Type: Permanent Food Service

12205 S APOPKA VINELAND RD, ORLANDO 32836

Inspection Date: 08/17/2020

Inspection Number: 3014478

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certification 3/27/2020

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5814128

POPEYES LOUISIANA KITCHEN #179

License Type: Permanent Food Service

10923 W COLONIAL DR, OCOEE 34761

Inspection Date: 08/20/2020

Inspection Number: 2988485

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. K extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5902155

TACO BELL 4347

License Type: Permanent Food Service

3601 13 ST, ST. CLOUD 34769

Inspection Date: 08/21/2020

Inspection Number: 2998349

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Grill cleaner on top of water heater. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6022044

THE COFFEE AND ALE EXCHANGE RESTAURANT

License Type: Permanent Food Service

1626 SOUTH FEDERAL HWY, BOYNTON BEACH 33435

Inspection Date: 08/20/2020

Inspection Number: 3032217

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PITRE, ASTRID

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217177		RUTH'S CHRIS STEAK HOUSE	
License Type: Permanent Food Service		131 2 AVE N, ST. PETERSBURG 33701	
Inspection Date: 08/19/2020	Inspection Number: 2992801	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VALENCIA, ASHLEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top grill used to seared tuna with canola oil	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216371		MANA MANA FALAFEL	
License Type: Permanent Food Service		530 PARK ST, CLEARWATER 33755	
Inspection Date: 08/18/2020	Inspection Number: 3028909	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2020-08-18: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6217623		TROPICAL SMOOTHIE CAFE	
License Type: Permanent Food Service		1840 GULF TO BAY BLVD., CLEARWATER 33765	
Inspection Date: 08/20/2020	Inspection Number: 3024728	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to ice machine in back	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6252361		MEL'S DAWGS	
License Type: Mobile Food Dispensing Vehicle		923 BROADWAY, DUNEDIN 34698	
Inspection Date: 08/21/2020	Inspection Number: 1231041	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Seminole County

License Number: 6903959

MEDITERRANEAN GOURMET

License Type: Permanent Food Service

1525 OVIEDO MARKETPLACE BLVD, OVIEDO 32765

Inspection Date: 08/21/2020

Inspection Number: 2997318

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Mixer is jury ridged with Saran Wrap holding the great in place. This should be repair for employee safety

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501504

BARBARA JEANS ON THE WATER

License Type: Permanent Food Service

15 S ROSCOE BLVD, PONTE VEDRA BEACH 32082

Inspection Date: 08/18/2020

Inspection Number: 2995268

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

20 pound LP tank by cookline. Suppling hot hold line.
Per person in charge Work in progress.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602961

THE BAGEL AND BEAN CO

License Type: Permanent Food Service

1156 SE PORT SAINT LUCIE BLVD, PORT ST LUCIE 34952

Inspection Date: 08/18/2020

Inspection Number: 3011980

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Located at front counter area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7402552 JBS FISH CAMP
 License Type: Permanent Food Service 859 POMPANO AVE, NEW SMYRNA BEACH 32169

Inspection Date: 08/20/2020 Inspection Number: 3029841 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. New boilers	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 7407046 BRUNO'S PIZZA
 License Type: Permanent Food Service 1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 08/19/2020 Inspection Number: 2986894 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405846 NEW CHINA WOK
 License Type: Permanent Food Service 2160 HOWLAND BLVD STE 100, DELTONA 32738

Inspection Date: 08/20/2020 Inspection Number: 3032443 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Front door blocked by takeout window. **Warning**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Front door blocked by takeout window. **Warning** - From follow-up inspection 2020-08-21:	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Volusia County

License Number: 7406340

NEW CHINA CITY ZHANG INC

License Type: Permanent Food Service

1382 HOWLAND BLVD #118, DELTONA 32738

Inspection Date: 08/20/2020

Inspection Number: 3000680

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Front door blocked by takeout window.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Front door blocked by takeout window. - From follow-up inspection 2020-08-21:	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.