

**Alachua County**

License Number: 1100159

GAINESVILLE GOLF &amp; COUNTRY CLUB INC

License Type: Permanent Food Service

7300 SW 35 WAY, GAINESVILLE 32608

Inspection Date: 09/11/2020

Inspection Number: 3019033

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.  
Observed lack of boiler certificates for 2 boilers.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1101747

WAFFLE HOUSE #541

License Type: Permanent Food Service

3919 SW 40 BLVD, GAINESVILLE 32608

Inspection Date: 09/11/2020

Inspection Number: 3003780

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed the kitchen fire extinguisher indicator, is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102593

GAINESVILLE GOLF &amp; COUNTRY CLUB INC

License Type: Permanent Food Service

7300 SW 35 WAY, GAINESVILLE 32608

Inspection Date: 09/11/2020

Inspection Number: 3000406

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.  
Observed lack of certificates for 2 boilers.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Bay County**

License Number: 1305625		MAJOR'S SMOKEHOUSE LLC	
License Type: Permanent Food Service		2701 LISENBY AVE, PANAMA CITY 32405	
Inspection Date: 09/11/2020	Inspection Number: 3023781	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in kitchen near hand wash sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1305235		BRUSTER'S ICE CREAM	
License Type: Permanent Food Service		7101 COASTAL PALMS BLVD, PANAMA CITY 32408	
Inspection Date: 09/09/2020	Inspection Number: 3015941	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near back door in recharge zoom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1305546		WILLY'S LIVE	
License Type: Permanent Food Service		9875 S THOMAS DR, PANAMA CITY BEACH 32408	
Inspection Date: 09/10/2020	Inspection Number: 2998602	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Class K extinguisher in kitchen in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Brevard County**

License Number: 1505986

PALERMO'S PIZZA

License Type: Permanent Food Service

2040 PALM BAY RD NE #1, PALM BAY 32905

Inspection Date: 09/09/2020

Inspection Number: 3017489

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
By cases of pizza boxes

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1506708

FLAVORS OF INDIA

License Type: Permanent Food Service

5675 N ATLANTIC AVE # 117, COCOA BEACH 32931

Inspection Date: 09/08/2020

Inspection Number: 2987574

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Hallway  
by electrical panels.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1618377

MARRIOTT'S BEACHPLACE TOWERS

License Type: Permanent Food Service

21 S ATLANTIC BLVD, FORT LAUDERDALE 33316

Inspection Date: 09/09/2020

Inspection Number: 3004194

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: EVANS, EUGENE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only. Exp 9/7/202061C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in  
good repair or be installed to maintain a minimum of 68  
degrees Fahrenheit throughout the building. The  
insurance inspector's boiler report is required annually  
for power boilers and high pressure/high temperature  
boilers and biannually for low pressure steam or vapor  
heating boilers and shall be posted in the boiler room.  
For reporting purposes only.

License Number: 1614108

SUBWAY 5283

License Type: Permanent Food Service

13606 SR 84, DAVIE 33325

Inspection Date: 09/10/2020

Inspection Number: 3025216

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: SEWELL, SANGAY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Observed back door blocked with cart. Operator removed \*\*Corrected On-Site\*\*61C-1.004(9) FAC: (9 Reporting: Means of access,  
including entrances, halls, and stairways, must permit  
unobstructed travel at all times and shall be clean,  
ventilated and well-lighted day and night. Hall and stair  
runners shall be kept in good condition. Railways, as  
defined in 61C-1.001(23), F.A.C., shall be installed on  
all stairways and around all porches and steps. For  
reporting purposes only.

**Charlotte County**

License Number: 1801910

FAT POINT BREWING

License Type: Permanent Food Service

611 CHARLOTTE ST, PUNTA GORDA 33950

Inspection Date: 09/10/2020

Inspection Number: 2987524

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. According to the operator, the establishment has a appointment for boiler inspection on 10/03/2020.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Collier County**

License Number: 2101567

BAMBU TROPICAL BAR AND GRILLE

License Type: Permanent Food Service

1221 5 AVE S, NAPLES 34102

Inspection Date: 09/10/2020

Inspection Number: 2991262

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DILLON, TIMOTHY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a propane tank used for the heating lamps in the bar storage room. Operator removed the propane tanks.  
\*\*Corrected

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2317295		HOLIDAY INN	
License Type: Permanent Food Service		7707 NW 103 ST, HIALEAH GARDENS 33016	
Inspection Date: 09/10/2020	Inspection Number: 3031650	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334130		CAMBRIA SUITES MIAMI AIRPORT- BLUE LAGOON	
License Type: Permanent Food Service		6750 NW 7 ST, MIAMI 33126	
Inspection Date: 09/10/2020	Inspection Number: 2998763	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTINEZ, YANET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired on 9/5/20.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2333891		SUBWAY 55712 INC	
License Type: Permanent Food Service		6792 SW 40 ST, MIAMI 33155	
Inspection Date: 09/09/2020	Inspection Number: 3029224	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ALEJANDRO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2334673		PUPUSERIA SALVADORENA	
License Type: Permanent Food Service		10929 SW 186 STREET, CUTLER RIDGE 33157	
Inspection Date: 09/10/2020	Inspection Number: 3011416	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed approximately 6 heavy boxes stored blocking exit door.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

**Dade County**

License Number: 2326833

CARIBE CAFETERIA RESTAURANT

License Type: Permanent Food Service

2660 SW 137 AVE, MIAMI 33175

Inspection Date: 09/09/2020

Inspection Number: 3016666

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed fire extinguisher gauge in red zone next to pizza oven - From follow-up inspection 2020-09-09: Portable fire extinguisher gauge in red zon

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328532

PEKING ONE

License Type: Permanent Food Service

16229 SW 88 ST, MIAMI 33196

Inspection Date: 09/11/2020

Inspection Number: 3023282

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only, located by exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Duval County**

License Number: 2613945

LA NOPALERA MEXICAN RESTAURANT

License Type: Permanent Food Service

8206 PHILIPS HWY STE 29, JACKSONVILLE 32256

Inspection Date: 09/10/2020

Inspection Number: 3052942

Inspection Type: Complaint Full

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Hallway to back exit door blocked with cases of drinks delivery

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2615015

EMPANADA'S FACTORY

License Type: Permanent Food Service

8060 PHILIPS HWY STE 101, JACKSONVILLE 32256-7476

Inspection Date: 09/10/2020

Inspection Number: 3006597

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
At back kitchen door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hardee County**

License Number: 3500260

PALETERIA MIS TESOROS

License Type: Permanent Food Service

401 N 6TH AVENUE, WAUCHULA 33873

Inspection Date: 09/04/2020

Inspection Number: 3005661

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet u covered and in use at ice cream storage area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 20 lb propane tank in building stored in hall at bathrooms.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803835		SHERATON ORLANDO NORTH GRANFE CAFE & LOUNGE& LINK	
License Type: Permanent Food Service		600 NORTH LAKE DESTINY DR, MAITLAND 32751	
Inspection Date: 09/11/2020	Inspection Number: 3012290	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5803839		SHERATON ORLANDO EMPLOYEE CAFETERIA	
License Type: Permanent Food Service		600 N LAKE DESTINY DR, MAITLAND 32751	
Inspection Date: 09/11/2020	Inspection Number: 3006127	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5808456		GRAFFITI JUNKTION II LLC	
License Type: Permanent Food Service		2401 EDGEWATER DR, ORLANDO 32804	
Inspection Date: 09/11/2020	Inspection Number: 3053720	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash can impeding access to exit door. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5810143		PANERA BREAD 3318	
License Type: Permanent Food Service		7826 W SANDLAKE RD, ORLANDO 32819	
Inspection Date: 09/10/2020	Inspection Number: 3001739	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Orange County**

License Number: 5814361		COCO THAI	
License Type: Permanent Food Service		6304 INTERNATIONAL DR, SUITE D, ORLANDO 32819	
Inspection Date: 09/09/2020	Inspection Number: 3006733	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by cart	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5813523		POLLO TROPICAL	
License Type: Permanent Food Service		6674 S SEMORAN BLVD, ORLANDO 32822	
Inspection Date: 09/08/2020	Inspection Number: 3007575	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked, cart with Trashcan by back door. For reporting purposes only. - From follow-up inspection 2020-09-08: Blocked with trash can **Time Extended**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5815068		ALBASHA HOOKAH CAFE INC	
License Type: Permanent Food Service		11955 S APOPKA VINELAND RD, ORLANDO 32836	
Inspection Date: 09/11/2020	Inspection Number: 3052911	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Observed paint cans stored located near the women's restroom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Palm Beach County**

License Number: 6012406

DELI ON RYE

License Type: Permanent Food Service

4311 N FEDERAL HWY, BOCA RATON 33431

Inspection Date: 09/11/2020

Inspection Number: 3003238

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood is present with ansul system installed. Counter top fryer not underneath hood. Employee moved to

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6216299

ANGIES GRILL

License Type: Permanent Food Service

1732 DREW ST, CLEARWATER 33755

Inspection Date: 09/08/2020

Inspection Number: 3034862

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
By back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903964

THAI CORNER RESTAURANT

License Type: Permanent Food Service

3589 LAKE EMMA RD, LAKE MARY 32746

Inspection Date: 09/10/2020

Inspection Number: 2993618

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit by bathrooms partial blocked by buckets of soap.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**St. Lucie County**

License Number: 6650382

TROPICAL LATIN FOODS LLC

License Type: Mobile Food Dispensing Vehicle

1690 SE VILLAGE GREEN DR, PORT ST LUCIE 34952

Inspection Date: 09/10/2020

Inspection Number: 1229674

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One hooked to a rice cooker cooking one beside counter. **\*\*Warning\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Volusia County**

License Number: 7400571

BELLO VALENTINOS RESTAURANT INC

License Type: Permanent Food Service

2516 N DIXIE FWY, NEW SMYRNA BEACH 32168

Inspection Date: 09/09/2020

Inspection Number: 3025609

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Outside customer restroom

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 7407540

TIPSY TACO CANTINA

License Type: Permanent Food Service

746 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 09/10/2020

Inspection Number: 3026250

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Using fryer and flat grill.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.