

**Brevard County**

License Number: 1506304

LONGHORN STEAKHOUSE #5410

License Type: Permanent Food Service

255 PALM BAY ROAD, MELBOURNE 32904

Inspection Date: 09/23/2020

Inspection Number: 3023731

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506768

SALSAS MEXICAN RESTAURANT

License Type: Permanent Food Service

5675 N ATLANTIC AVE STE 119-121, COCOA BEACH 32931

Inspection Date: 09/24/2020

Inspection Number: 2994139

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Fire alarm strobe coming away from wall by rear door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1612654 RED LOBSTER #0424  
 License Type: Permanent Food Service 296 N UNIVERSITY DR, PEMBROKE PINES 33024

Inspection Date: 09/22/2020 Inspection Number: 2998939 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Gasoline tanks in electrical / boiler room	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1623823 GOLD MARQUESS FINE CHINESE CUISINE  
 License Type: Permanent Food Service 8525 PINES BLVD, PEMBROKE PINES 33024

Inspection Date: 09/24/2020 Inspection Number: 3029828 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Gas canister filled with gas in electrical room	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1615256 WORLD FAMOUS INC  
 License Type: Permanent Food Service 3684 W OAKLAND PARK BLVD, LAUDERDALE LAKES 33311

Inspection Date: 09/24/2020 Inspection Number: 2995937 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By Bathroom	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624199 DOMINOS PIZZA #8646  
 License Type: Permanent Food Service 3851 W OAKLAND PARK BLVD, LAUDERDALE LAKES 33311

Inspection Date: 09/24/2020 Inspection Number: 3032111 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed empty boxes blocking the exit door. Operator removed boxes and cleared the path to the exit door in the kitchen. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Broward County**

License Number: 1624576

TACOS EL PAPI AND BLANKA'S BAKERY

License Type: Permanent Food Service

3591 N ANDREWS AVE STE D, OAKLAND PARK 33334

Inspection Date: 09/22/2020

Inspection Number: 3019053

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2326231

SUBWAY 1360

License Type: Permanent Food Service

775 W 49 ST, HIALEAH 33012

Inspection Date: 09/24/2020

Inspection Number: 2995311

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CUDEMOS, VIRNA

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes and garbage bags blocked exit door.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2324338

PIZZA HUT DELIVERY #710716

License Type: Permanent Food Service

3901 E 4 AVE, HIALEAH 330132705

Inspection Date: 09/24/2020

Inspection Number: 2996876

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JOSEPH, VANRIE

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed blocked with cardboard boxes

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2359379

SCATTA'S SEAFOOD

License Type: Mobile Food Dispensing Vehicle

545 WEST LUCY STREET, FLORIDA CITY 33034

Inspection Date: 09/21/2020

Inspection Number: 1231487

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2300248		MCDONALD OF FLA CORP	
License Type: Permanent Food Service		18250 NW 27 AVE, OPA LOCKA 330563545	
Inspection Date: 09/23/2020	Inspection Number: 3027199	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: STUBBS, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed crates of buns blocking door marked exit. Employee removed crates. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2316700		GRAND CHINA RESTAURANT	
License Type: Permanent Food Service		18643 S DIXIE HWY, CUTLER BAY 33157	
Inspection Date: 09/23/2020	Inspection Number: 3030266	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 20 lbs propane tank connected to burner inside restaurant located at the front of the house.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2315594		ACKEES JAMAICAN CUISINE	
License Type: Permanent Food Service		19349 SOUTH DIXIE HIGHWAY, MIAMI 33157	
Inspection Date: 09/21/2020	Inspection Number: 3055442	Inspection Type: Complaint Full	Inspection Disposition: Emergency order recommended
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 20lbs propane tank attached to a burner inside kitchen area. In use at the time of the inspection.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2335234

PIZZA NAPOLITANO

License Type: Permanent Food Service

8481 NW S RIVER DR, MEDLEY 33166

Inspection Date: 09/23/2020

Inspection Number: 2994894

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small fryer and electric stove being used in the establishment with no hood suppression syste

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Observed table in front of fire extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328210

LITTLE CAESARS #2259

License Type: Permanent Food Service

19975 NW 2 AVE, NORTH MIAMI 33169

Inspection Date: 09/25/2020

Inspection Number: 2984635

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked with garbage bin. For reporting purposes only.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2321767

PIZZA HUT #710706

License Type: Permanent Food Service

19960 NW 2 AVE, MIAMI 331692904

Inspection Date: 09/21/2020

Inspection Number: 2996860

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked by four (4) garbage bins. For reporting purposes only. Manager removed bins. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2331813

CMX CINEBISTRO DOLPHIN

License Type: Permanent Food Service

11471 NW 12 ST UNIT E615, SWEETWATER 33172

Inspection Date: 09/25/2020

Inspection Number: 3027368

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher overcharged located by walk in freezer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316721

OASIS GRILL

License Type: Permanent Food Service

12400 SW 152 ST, MIAMI 33177

Inspection Date: 09/25/2020

Inspection Number: 3026935

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Observed a gas tank of 20 pounds stored at preparation area behind of the oven at preparation area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330521

QUIZNOS SUB

License Type: Permanent Food Service

9700 NW 115 WAY, MEDLEY 33178

Inspection Date: 09/25/2020

Inspection Number: 3021849

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JA DE DIOS, YANLEE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By empty boxes.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2331528

GREEN APPLE KENDALL

License Type: Permanent Food Service

15160 SW 136 ST STE 1, MIAMI 33196

Inspection Date: 09/25/2020

Inspection Number: 2987350

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only, located by reach in freezer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613195

SUBWAY #29656

License Type: Permanent Food Service

3200 ARMSDALE RD STE 8, JACKSONVILLE 32218

Inspection Date: 09/25/2020

Inspection Number: 3011000

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Wooden bar blocking back exit door

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Hillsborough County**

License Number: 3911778	CHICK FIL A AT BRANDON VILLAGE
License Type: Permanent Food Service	11325 CAUSEWAY BLVD, BRANDON 33511
Inspection Date: 09/22/2020	Inspection Number: 2990828
Inspector Name: MOULDER, BRITTANY	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher located next to walkin door
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912144	CHIPOTLE MEXICAN GRILL #1626
License Type: Permanent Food Service	829 EAST BLOOMINGDALE AVE, BRANDON 33511
Inspection Date: 09/22/2020	Inspection Number: 3004247
Inspector Name: MOULDER, BRITTANY	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observe people near back exit door on floor,COS, observed manager remove and place in proper area **Corrected On-Site**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917092	BAHAMA BREEZE #3054
License Type: Permanent Food Service	805 BRANDON TOWN CENTER DR, BRANDON 33511
Inspection Date: 09/25/2020	Inspection Number: 2987183
Inspector Name: MOULDER, BRITTANY	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observe on floor near emergency exit door ,COS, observed employee place extinguisher in proper area **Corrected On-Site** ***Repeat Violation**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3916585	BRIO
License Type: Permanent Food Service	2223 N WESTSHORE DR SPACE B-309, TAMPA 33607
Inspection Date: 09/25/2020	Inspection Number: 3056584
Inspector Name: CANNELLA, MARK	Inspection Type: Food-Licensing Inspection
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
	<u>Violation Citation</u>
	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Indian River County**

License Number: 4101056

SKYDIVE SEBASTIAN

License Type: Permanent Food Service

400 W AIRPORT ROAD, SEBASTIAN 329583926

Inspection Date: 09/25/2020

Inspection Number: 2984739

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to trip sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4100952

ARBY'S #6124

License Type: Permanent Food Service

1605 S US 1, VERO BEACH 32960

Inspection Date: 09/21/2020

Inspection Number: 2987845

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Electrical plug missing face plate-adjacent to outdoor walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4101257

DOMINO'S PIZZA #4925

License Type: Permanent Food Service

5445 20 ST #103, VERO BEACH 32966

Inspection Date: 09/25/2020

Inspection Number: 2999511

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

47-03-4

Outlet cover behind water heater missing.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lake County**

License Number: 4500136

HACIENDA

License Type: Permanent Food Service

10400 CR 48, HOWEY IN THE HILLS 347373000

Inspection Date: 09/24/2020

Inspection Number: 2997001

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREY, RANDY

Violation Code

Observation

Violation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Manatee County**

License Number: 5101782

SHAKE STATION

License Type: Permanent Food Service

4219 US HWY 301 N, ELLENTON 34222

Inspection Date: 09/21/2020

Inspection Number: 3011244

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on extinguisher near kitchen/dining room door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5428415

CHEF ROLFS TUNAS

License Type: Permanent Food Service

80939 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 09/23/2020

Inspection Number: 2977173

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exterior front of building , exposed wiring from conduit and junction box.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Nassau County**

License Number: 5501067

PIZZA HUT #4252

License Type: Permanent Food Service

542168 US HWY 1, CALLAHAN 32011

Inspection Date: 09/21/2020

Inspection Number: 3028919

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500062

THE SURF RESTAURANT BAR GRILL &amp; MOTEL

License Type: Permanent Food Service

3199 S FLETCHER AVE, AMELIA ISLAND 32034

Inspection Date: 09/24/2020

Inspection Number: 3013373

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In server station room by bar

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500812

AREA 51 BBQ &amp; GRILL

License Type: Permanent Food Service

510 S 8 ST, FERNANDINA BEACH 32034

Inspection Date: 09/22/2020

Inspection Number: 3026747

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By entrance to kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803866		DOMINO'S PIZZA #5013	
License Type: Permanent Food Service		2 E MAIN ST, AOPKA 327035256	
Inspection Date: 09/22/2020	Inspection Number: 3021503	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GREENE, MARVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5811180		THE ALFOND INN CATERING	
License Type: Catering		300 EAST NEW ENGLAND AVE, WINTER PARK 32789	
Inspection Date: 09/23/2020	Inspection Number: 1116444	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5813252		HAMILTON'S KITCHEN	
License Type: Permanent Food Service		300 E NEW ENGLAND AVE, WINTER PARK 32789	
Inspection Date: 09/23/2020	Inspection Number: 3014785	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5813268		THE ALFOND INN NOST	
License Type: Permanent Food Service		300 NEW ENGLAND AVE, WINTER PARK 32789	
Inspection Date: 09/23/2020	Inspection Number: 3020576	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

**Orange County**

License Number: 5812347

BONEFISH GRILL

License Type: Permanent Food Service

5463 ORLANDO GATEWAY CIR #101, ORLANDO 32812

Inspection Date: 09/23/2020

Inspection Number: 2998373

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANZ, LISA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.- trash cans and cardboard boxes blocking back door

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Pinellas County**

License Number: 6215667

CHICK-FIL-A OF CLEARWATER

License Type: Permanent Food Service

2516 GULF-TO-BAY BLVD, CLEARWATER 33765

Inspection Date: 09/21/2020

Inspection Number: 3003750

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
In recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212615

CARAMBOLA

License Type: Permanent Food Service

400 MANDALAY AVE, CLEARWATER 33767

Inspection Date: 09/24/2020

Inspection Number: 3023495

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

48-01-5

All boiler certificates expired 1/25/20For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.