

Alachua County

License Number: 1103595

TUNIS SEAFOOD WINGS & SUBS

License Type: Permanent Food Service

1818 NE WALDO RD, GAINESVILLE 32609

Inspection Date: 01/12/2021

Inspection Number: 3060867

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed silver fire extinguisher in the recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed the wires for the pillar sign are exposed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505080 KO9 CHINA BAR
 License Type: Permanent Food Service 2099 PALM BAY RD NE, PALM BAY 32905

Inspection Date: 01/11/2021 Inspection Number: 3052006 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with hood suppression system turned off educated Notified Fire AHJ. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502164 HILTON COCOA BEACH OCEANFRONT RESORT
 License Type: Permanent Food Service 1550 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 01/15/2021 Inspection Number: 3075509 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Tiki bar	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506708 FLAVORS OF INDIA
 License Type: Permanent Food Service 5675 N ATLANTIC AVE # 117, COCOA BEACH 32931

Inspection Date: 01/12/2021 Inspection Number: 3052594 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher by soup well. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Ansul plug not seated in position. Operator states company is due out to reset.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505386 ASIAN GOURMET
 License Type: Permanent Food Service 459 N HARBOR CITY BLVD, MELBOURNE 32935

Inspection Date: 01/12/2021 Inspection Number: 3050170 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher in dishwasher area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506374 SUMO JAPANESE RESTAURANT LLC
 License Type: Permanent Food Service 258 EAST EAU GALLIE BLVD, INDIAN HARBOUR BEACH 32937

Inspection Date: 01/11/2021 Inspection Number: 3023071 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Middle light under hood hanging by wires.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618965 TACO BELL 20192
 License Type: Permanent Food Service 6835 TAFT ST, HOLLYWOOD 33024

Inspection Date: 01/14/2021 Inspection Number: 3047869 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FEIGELES, MITCHELL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher is by office door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623195 SUVICHE FT LAUDERDALE
 License Type: Permanent Food Service 401 E LAS OLAS BLVD #150, FORT LAUDERDALE 33301

Inspection Date: 01/15/2021 Inspection Number: 3047241 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By office. - From follow-up inspection 2021-01-15: Portable fire extinguisher gauge in red zone. For reporting purposes only. By office. **Time Ext	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625198 MZ FATTY'S
 License Type: Permanent Food Service 806 NW 14 AVENUE, FORT LAUDERDALE 33311

Inspection Date: 01/14/2021 Inspection Number: 3075083 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. -Observed a electrical box with exposed wiring.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621143

UNDERGROUND KITCHEN LLC

License Type: Catering

4072 NE 5 TERR, OAKLAND PARK 33334

Inspection Date: 01/13/2021

Inspection Number: 1118076

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801964

HOLIDAY INN EXPRESS & SUITES PUNTA GORDA

License Type: Permanent Food Service

9075 MAC DR, PUNTA GORDA 33950

Inspection Date: 01/11/2021

Inspection Number: 3025092

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certificate. Jurisdiction No. 134468. Expiration: 08/17/2020

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Clay County

License Number: 2001144 SONIC DRIVE IN #5411
 License Type: Permanent Food Service 1801 TOWN CENTER BLVD, FLEMING ISLAND 32003

Inspection Date: 01/11/2021 Inspection Number: 3052696 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher across from walk in cooler, gauge in red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2000840 EL PEGAO
 License Type: Permanent Food Service 2177 KINGSLEY AVE STE 13, ORANGE PARK 32073

Inspection Date: 01/13/2021 Inspection Number: 3058282 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Fire extinguisher gauge in red zone. For reporting purposes only. Per employee when the hood system was being cleaned the previous day the maintenance staff set off the fire suppression system, thus the tank for the hood system is now in the red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke. For reporting purposes only. Per employee the fire suppression system for the hood system was set off by the maintenance staff during routine cleaning. Establishment using a small fryer for coo	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317304 LA LECHONERA CUBANA
 License Type: Permanent Food Service 701 W 27 ST, HIALEAH 33010

Inspection Date: 01/14/2021 Inspection Number: 3052735 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PRIETO, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 4 LP tanks next to the steam table at the front counter counter area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330560 EL RIO LINDO CAFE CORP
 License Type: Permanent Food Service 641 SW 12TH AVENUE, MIAMI 33130

Inspection Date: 01/15/2021 Inspection Number: 3053043 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed fryers not under the hood. Observed 2 Portable fryer is	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334647 LAVASCA DELICATESSEN INC
 License Type: Permanent Food Service 3407 SW 8TH STREET, MIAMI 33135

Inspection Date: 01/12/2021 Inspection Number: 3054871 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332535 VIA EMILIA
 License Type: Permanent Food Service 1120 15 ST, MIAMI BEACH 33139

Inspection Date: 01/15/2021 Inspection Number: 3006866 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Located at back storage area.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Dade County

License Number: 2318247 POPEYES CHICKEN & BISCUITS #9
 License Type: Permanent Food Service 20690 NW 2 AVE, NORTH MIAMI 33169-2509

Inspection Date: 01/11/2021 Inspection Number: 3001645 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage can and boxes blocking marked exit. Employee removed items. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2334621 HURRICANE GRILL & WINGS OF KENDALL
 License Type: Permanent Food Service 15500 SW 88 STREET, MIAMI 33196

Inspection Date: 01/11/2021 Inspection Number: 3062689 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near kitchen entrance near dish machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2607565

DESERT RIDER SANDWICH SHOP

License Type: Permanent Food Service

217 HOGAN ST, JACKSONVILLE 322024201

Inspection Date: 01/13/2021

Inspection Number: 3037117

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Fried eggs in pan on cooks line no hood suppression system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Gilchrist County

License Number: 3100107

BURGER SPOT

License Type: Permanent Food Service

204 W WADE STREET, TRENTON 32693

Inspection Date: 01/15/2021

Inspection Number: 3037364

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Big extinguisher on wall in kitchen. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3916033

RICKY'S SPORTS BAR AND GRILL

License Type: Permanent Food Service

6520 N US HWY, APOLLO BEACH 33572

Inspection Date: 01/15/2021

Inspection Number: 3070961

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOWAL, KYLE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. All portable fire extinguishers empty. Operator has contacted Cintas and they are being refilled later today. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Levy County

License Number: 4850072

FAT G'S BBQ & CATERING

License Type: Mobile Food Dispensing Vehicle

907 E NOBLE AVE, WILLISTON 32696

Inspection Date: 01/12/2021

Inspection Number: 1233965

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.
Observed lack of a fire extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301739 MR GYRO'S GREEK AND MEDITERRANEAN GRILL
 License Type: Permanent Food Service 2383 SE FEDERAL HWY, STUART 34994

Inspection Date: 01/13/2021 Inspection Number: 3056663 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5350334 JAKE'S ATOMIC CAFE
 License Type: Mobile Food Dispensing Vehicle 3620 SE DIXIE HWY, STUART 34997-5247

Inspection Date: 01/13/2021 Inspection Number: 1233717 Inspection Type: Food-Licensing Inspection Inspection Disposition: Call Back - Complied
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2021-01-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6020164

THE CAPITAL GRILLE #8035

License Type: Permanent Food Service

11365 LEGACY AVE BLDG B, PALM BEACH GARDENS 33410

Inspection Date: 01/11/2021

Inspection Number: 3063696

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.outlet broken/front of walk in cooler#2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6113219

THE HUNGRY GREEK OF WESLEY CHAPEL

License Type: Permanent Food Service

2653 BRUCE B DOWNS #118, WESLEY CHAPEL 33544

Inspection Date: 01/13/2021

Inspection Number: 3043063

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216626 DOWNTOWN PIZZA SPORTS BAR AND GRILL
 License Type: Permanent Food Service 428 CLEVELAND ST, CLEARWATER 33755

Inspection Date: 01/13/2021 Inspection Number: 3045278 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. On pizza line next to hand sink in recharge	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6210391 RED LOBSTER #0454
 License Type: Permanent Food Service 10500 E ULMERTON RD #490, LARGO 33771

Inspection Date: 01/14/2021 Inspection Number: 3038691 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BEACHAM, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-01-15: **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6216724 WILD IRIS CAFE
 License Type: Permanent Food Service 434 VIRGINIA LN, DUNEDIN 34698

Inspection Date: 01/14/2021 Inspection Number: 3056648 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two LP tanks moved from the back dry storage area **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903716 SUPER 8 CHINESE RESTAURANT
 License Type: Permanent Food Service 1455 SEMORAN BLVD STE 127, CASSELBERRY 32707

Inspection Date: 01/12/2021 Inspection Number: 3044786 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. At the 3 compartment sink a lp tank is fueling a gas burner on the table next to the ice machine , also 1 can at the back do	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905080 CAPACHOS BAR & GRILL
 License Type: Permanent Food Service 1410 FL ST RD 436, CASSELBERRY 32707

Inspection Date: 01/12/2021 Inspection Number: 3034995 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Light resting on oven no panel covering transformer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Light resting on oven no panel covering transformer - From follow-up inspection 2021-01-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501685

DOMINO'S #3140

License Type: Permanent Food Service

2220 CR 210 W #103, SAINT JOHNS 32259

Inspection Date: 01/13/2021

Inspection Number: 3001202

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Boxes by rear exit. Moved by manager. **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Volusia County

License Number: 7406575

THE BULLDOG PUB

License Type: Permanent Food Service

577 DELTONA BLVD STE1, DELTONA 32725

Inspection Date: 01/12/2021

Inspection Number: 3057157

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking bacon on a flat top grill. Notified Lisa Nadeau, Deltona Fire Inspector, 386-878-8656. Left vo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.