



**Broward County**

License Number: 1625123 MBS CARIBBEAN RESTAURANT AND BAKERY INC  
 License Type: Permanent Food Service 1825 E SAMPLE RD, POMPANO BEACH 33064

Inspection Date: 01/20/2021 Inspection Number: 3062582 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619983 DUNKIN DONUTS  
 License Type: Permanent Food Service 399 S SR 7, MARGATE 33068

Inspection Date: 01/21/2021 Inspection Number: 3067961 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door blocked by trash can and empty boxes.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1621797 POLLO TROPICAL RESTAURANT #90  
 License Type: Permanent Food Service 5780 S UNIVERSITY DR BAY 1-101, DAVIE 33328

Inspection Date: 01/20/2021 Inspection Number: 3036192 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SEWELL, SANGAY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.  Observed exit path blocked with black rolling garbage bin and rolling cart with empty oil bottles.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Clay County**

License Number: 2001376

WINGSTOP

License Type: Permanent Food Service

410 BLANDING BLVD UNIT 15, ORANGE PARK 32073

Inspection Date: 01/21/2021

Inspection Number: 3059198

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher by back door to kitchen in red zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2332002

CAFE CHUNG KING

License Type: Permanent Food Service

1250 NW 54 STREET, MIAMI 33142

Inspection Date: 01/22/2021

Inspection Number: 3050227

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: APONTE RIVERA, MELISA

Violation CodeObservationViolation Citation

47-01-4	- From initial inspection : Observed exposed electrical wires. For reporting purposes only. Located in wall and ceiling fixtures in kitchen area. - From follow-up inspection 2021-01-22: Observed exposed electrical wires. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-01-4	Observed exposed electrical wires. For reporting purposes only. Located in wall and ceiling fixtures in kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334186

POLLO TROPICAL

License Type: Permanent Food Service

7090 CORAL WAY, MIAMI 33155

Inspection Date: 01/21/2021

Inspection Number: 3051447

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: APONTE RIVERA, MELISA

Violation CodeObservationViolation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 2325048

SHORTY'S BBQ

License Type: Permanent Food Service

11575 SW 40 ST, MIAMI 331653313

Inspection Date: 01/19/2021

Inspection Number: 3021388

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only, located in front of walk-in cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---



**Duval County**

License Number: 2614830 SUSHI CAFE  
 License Type: Permanent Food Service 2025 RIVERSIDE AVE #201, JACKSONVILLE 32204

Inspection Date: 01/21/2021 Inspection Number: 3053999 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 5 by sushi area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614466 CHURCH'S CHICKEN #2091  
 License Type: Permanent Food Service 1060 E 21 ST, JACKSONVILLE 32206

Inspection Date: 01/19/2021 Inspection Number: 3016792 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614119 HOMEWOOD SUITES BY HILTON JACKSONVILLE DOWNTOWN SOUTHBANK  
 License Type: Permanent Food Service 1201 KINGS AVE, JACKSONVILLE 32207

Inspection Date: 01/20/2021 Inspection Number: 3054346 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired 10/18/19	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2612424 BLU DINER  
 License Type: Permanent Food Service 5868 NORWOOD AVE, JACKSONVILLE 32208

Inspection Date: 01/21/2021 Inspection Number: 3061239 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Red fire extinguisher near back door on ground is undercharged.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2607041 JACK'S SANDWICH SHOP  
 License Type: Permanent Food Service 9303 LEM TURNER, JACKSONVILLE 322082274

Inspection Date: 01/21/2021 Inspection Number: 3061697 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher near back exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612784 ADAMS SANDWICH SHOPPE  
 License Type: Permanent Food Service 6071 ST AUGUSTINE RD, JACKSONVILLE 32217

Inspection Date: 01/19/2021 Inspection Number: 3061595 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Pathway to back door blocked by cardboard boxes. Operator waiting for dumpster to be emptied to remove boxes from establishment	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2609830 FUJI 3  
 License Type: Permanent Food Service 11362 SAN JOSE BLVD STE 8, JACKSONVILLE 32223

Inspection Date: 01/22/2021 Inspection Number: 3060393 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Pathway to exit door in dining area blocked by a table and chairs	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2615394 ARBY'S 8100  
 License Type: Permanent Food Service 7612 MERRILL RD, JACKSONVILLE 32277

Inspection Date: 01/21/2021 Inspection Number: 3036111 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to rear door has gauge in red.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Flagler County**

License Number: 2800798

EL POLLO COLORAO

License Type: Permanent Food Service

227 ST JOES PLAZA DR STE A, PALM COAST 32164

Inspection Date: 01/22/2021

Inspection Number: 3062374

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two small fryers placed outside hood site. (next to existing fryer which has adequate hood protection

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3701142

KARMA SPIRITS & CAFE

License Type: Permanent Food Service

10511 SPRING HILL DR, SPRING HILL 34608

Inspection Date: 01/20/2021

Inspection Number: 3022901

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

49-04-4

Establishment is licensed for 40 seats and has 75 seats present including bar stools. The paper license at the restaurant shows 140 seats. Reviewed with District Manager Jon Truex

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Highlands County**

License Number: 3801197

LA ISLA FLAVOR CAFE

License Type: Permanent Food Service

308 W INTERLAKE BLVD, LAKE PLACID 33852

Inspection Date: 01/20/2021

Inspection Number: 3053291

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed exit door at back locked and unable to easily open from inside. Must be left unlocked while building is occupied, until corrected. Fire department has inspected and is aware and has made recommendat

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Marion County**

License Number: 5202918

THE CRAZY CUCUMBER MARKET STREET

License Type: Permanent Food Service

4414 SW COLLEGE RD UNIT 1910, OCALA 34474

Inspection Date: 01/19/2021

Inspection Number: 3060603

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near kitchen entrance. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Nassau County**

License Number: 5501150

STATE LINE BARBECUE COMPANY

License Type: Permanent Food Service

2020 SADLER RD, FERNANDINA BEACH 32034

Inspection Date: 01/20/2021

Inspection Number: 3041042

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEVILLE, DAVID

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Propane tank used to light smoker is stored in back kitchen area. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6013720 I HOP  
 License Type: Permanent Food Service 4745 W ATLANTIC AVE, DELRAY BEACH 33445

Inspection Date: 01/21/2021 Inspection Number: 3033905 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located in kitchen next to hand wash sink and ice cream freezer.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021514 THE PARISIAN  
 License Type: Permanent Food Service 201 N US HWY 1 STE D9, JUPITER 33477

Inspection Date: 01/19/2021 Inspection Number: 3057037 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6013505 CAFE ARGENTO  
 License Type: Permanent Food Service 5301 N FEDERAL HWY, BOCA RATON 33487

Inspection Date: 01/19/2021 Inspection Number: 3067484 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located in kitchen next to door to front counter	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019284 RENZOS CAFE PIZZERIA  
 License Type: Permanent Food Service 6900 N FEDERAL HWY, BOCA RATON 33487

Inspection Date: 01/19/2021 Inspection Number: 3057715 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6102534

COURTHOUSE KITCHEN

License Type: Permanent Food Service

7530 LITTLE RD #107, NEW PORT RICHEY 34654

Inspection Date: 01/21/2021

Inspection Number: 3005807

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

49-04-4	Employee states that she cooks raw burger and raw chicken in stove burner in a pan. There is no hood over stove top or grill. There is grease debris in these units.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	--	--

License Number: 6102499

BEST OF PHILLY

License Type: Permanent Food Service

13510 US 19, HUDSON 34667

Inspection Date: 01/21/2021

Inspection Number: 3018128

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher at front counter	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

**Pinellas County**

License Number: 6217553 CITY'S BISTRO  
 License Type: Permanent Food Service 695 CENTRAL AVE, ST. PETERSBURG 33701

Inspection Date: 01/21/2021 Inspection Number: 3046051 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VILLEGAS, TATTYANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Panini press to cook chicken and other proteins and flat top. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217238 PREP KITCHEN  
 License Type: Permanent Food Service 100 CORONADO DRIVE, CLEARWATER 33767

Inspection Date: 01/21/2021 Inspection Number: 3056533 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	boiler certificate available for boiler. For reporting purposes only. FI124576-fl124575-fl124574 all exp 12/4/2020	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6217239 OCEAN HAI  
 License Type: Permanent Food Service 100 CORONADO DR, CLEARWATER 33767

Inspection Date: 01/21/2021 Inspection Number: 3045109 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	boiler certificate expired available for boiler. For reporting purposes only. FI124576-fl124575-fl124574 all exp 12/4/2020	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6214805 ESPOSITO PIZZA VINO AND MORE  
 License Type: Permanent Food Service 191 ORANGE ST UNIT 403, PALM HARBOR 34683

Inspection Date: 01/19/2021 Inspection Number: 3033086 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Unlocked <b>**Corrected On-Site**</b>	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Polk County**

License Number: 6305665

RED LOBSTER #6207

License Type: Permanent Food Service

230 CYPRESS GARDENS BLVD, WINTER HAVEN 33880

Inspection Date: 01/19/2021

Inspection Number: 3042645

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired 3/14/20	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	---

**Sarasota County**

License Number: 6805737

CASSARIANO UTC

License Type: Permanent Food Service

243 N CATTLEMEN RD UNIT 80, SARASOTA 34243

Inspection Date: 01/20/2021

Inspection Number: 3039329

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at top of stairs to office. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6902808

TUSCAWILLA COUNTRY CLUB- CLUB HOUSE

License Type: Permanent Food Service

1500 WINTER SPRINGS BLVD, WINTER SPRINGS 32708

Inspection Date: 01/20/2021

Inspection Number: 3061391

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

49-03-4	Flammables stored/debris present in hot water tank room. For reporting purposes only. Charcoal lighter fluid present in the room of a gas water heater	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	--	--

**St. Lucie County**

License Number: 6650466

PICANTE COCINA

License Type: Mobile Food Dispensing Vehicle

1661 SW TAURUS LN, PORT ST LUCIE 34984

Inspection Date: 01/16/2021

Inspection Number: 1232291

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

