

Alachua County

License Number: 1103503

MIDICI THE NEAPOLITAN PIZZA COMPANY OF GAINESVILLE

License Type: Permanent Food Service

4949 CELEBRATION POINTE AVE #100, GAINESVILLE 32608

Inspection Date: 01/29/2021

Inspection Number: 3006706

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Tanks stored in shared hallway leading to dumpster area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bradford County

License Number: 1400166

SUBWAY 45333

License Type: Permanent Food Service

22804 US HWY 301 N, LAWTEY 32058

Inspection Date: 02/04/2021

Inspection Number: 3009936

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

47-01-4

Observed frayed/spliced electrical wires. For reporting purposes only.
Missing outlet cover next to prep table across from office

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505423

CHINA PARK

License Type: Permanent Food Service

2301 SR 524 #115, COCOA 32926

Inspection Date: 02/03/2021

Inspection Number: 3051660

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Front door blocked closed with table to take orders so customers do not enter due to covid ****Repeat Violation****

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Broward County

License Number: 1618887 NAMI SUSHI & GRILL
 License Type: Permanent Food Service 17007 PINES BLVD, HOLLYWOOD 33027

Inspection Date: 02/02/2021 Inspection Number: 3065698 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher next to cook in over charged zone. - From follow-up inspection 2021-02-02: Observed same. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher next to cook in over charged zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622634 CROCANTE
 License Type: Permanent Food Service 2708 N UNIVERSITY DR, CORAL SPRINGS 33065

Inspection Date: 02/04/2021 Inspection Number: 3065094 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRADY, OSSIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed multiple electric induction cook top used to cook bacon, chicken and eggs with no hood installed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623074 AMERICAN SOCIAL
 License Type: Permanent Food Service 721 E LAS OLAS BLVD, FORT LAUDERDALE 33301

Inspection Date: 02/02/2021 Inspection Number: 3053771 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed approximately 3 propane tanks by upstairs ice machine. Inspector will email inspection report to Fire Marshall for review.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801657

HOLIDAY INN EXPRESS

License Type: Permanent Food Service

24440 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 02/01/2021

Inspection Number: 3046332

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired balcony certificate.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Clay County

License Number: 2001324

MR CHUBBY'S WINGS

License Type: Permanent Food Service

2349 VILLAGE SQUARE PKWY STE 101, FLEMING ISLAND 32003

Inspection Date: 02/02/2021

Inspection Number: 3062139

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher at rear exit to kitchen is in the red zone	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Door marked emergency exit by bathrooms blocked with a bar across door, manager corrected during inspection. **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Collier County

License Number: 2103416

SAKURA BUFFET

License Type: Permanent Food Service

8855 IMMOKALEE RD, NAPLES 34120

Inspection Date: 02/02/2021

Inspection Number: 3058781

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERRY, WILLIAM

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Fire exit by restrooms blocked. Corrected on site. **Corrected on site**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Dade County

License Number: 2330934		FLEMING'S PRIME STEAKHOUSE #2005	
License Type: Permanent Food Service		2525 PONCE DE LEON BLVD, CORAL GABLES 33134	
Inspection Date: 02/05/2021	Inspection Number: 2986158	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ALEJANDRO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2331007		SOCIAL CAFE	
License Type: Permanent Food Service		1024 OCEAN DRIVE, MIAMI BEACH 33139	
Inspection Date: 02/05/2021	Inspection Number: 3040187	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Near office/storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2332140		MONDRIAN CAFFE	
License Type: Permanent Food Service		1100 WEST AVE, MIAMI BEACH 33139	
Inspection Date: 02/02/2021	Inspection Number: 3005604	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 1 boiler certificate missing. Observed heating device with 499,000 btu. - From follow-up inspection 2021-02-02: Observed a boiler inspection completed, operator waiting for boiler certificates. Operator provided invoice and boiler inspection. **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2332535		VIA EMILIA	
License Type: Permanent Food Service		1120 15 ST, MIAMI BEACH 33139	
Inspection Date: 02/03/2021	Inspection Number: 3006866	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: ELDER, AUDREY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Located at back storage area. - From follow-up inspection 2021-02-03: Marked exit/path to marked exit blocked. For reporting purposes only. Located at back storage area. **Time Extended**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Dade County

License Number: 2322325	QUAIL ROOST TAVERN
License Type: Permanent Food Service	10442 SW 186 ST, MIAMI 33157
Inspection Date: 02/01/2021	Inspection Number: 3056538
Inspector Name: AZPURUA, JULIO	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed at kitchen connected to a burner.
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336106	POPEYES #12455
License Type: Permanent Food Service	5875 NW 36TH ST, VIRGINIA GARDENS 33166
Inspection Date: 02/02/2021	Inspection Number: 2988193
Inspector Name: GONZALEZ, ERIK	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by back door in recharge zone.
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313005	MIAMI SUBS
License Type: Permanent Food Service	19000 NW 2 AVE, MIAMI 33169
Inspection Date: 02/03/2021	Inspection Number: 3057501
Inspector Name: STUBBS, CHRISTINE	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Warning**
	<u>Violation Citation</u>
	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2315167	JAE MIAMI DADE
License Type: Permanent Food Service	19650 NW 2 AVE, MIAMI 33169
Inspection Date: 02/03/2021	Inspection Number: 3063344
Inspector Name: STUBBS, CHRISTINE	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed multiple boxes are blocking marked exit.
	<u>Violation Citation</u>
	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Duval County

License Number: 2615260		AKELS DELI	
License Type: Permanent Food Service		50 N LAURA ST STE #125, JACKSONVILLE 32202	
Inspection Date: 02/03/2021	Inspection Number: 3049692	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking eggs and reheating meat on flat top portable grill with no hood suppression system	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2611597		BALLAS CARIBBEAN RESTAURANT	
License Type: Permanent Food Service		1410 PALMDALE ST, JACKSONVILLE 32208	
Inspection Date: 02/01/2021	Inspection Number: 3065072	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-03-4	Fuel-burning, wick-type, unvented space heater in use inside an enclosed building or patio area. For reporting purposes only. In bar area.	509.211(2)(a) FS Reporting: (2)(a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tank in mop closet near hot water heater.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613353		BLUE CRAB CRABHOUSE	
License Type: Permanent Food Service		3057 JULINGTON CREEK RD, JACKSONVILLE 32223	
Inspection Date: 02/05/2021	Inspection Number: 3061701	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two propane tanks stored in storage room. Operator removed tanks and placed outside for outdoor heaters **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2615282		CATULLO'S ITALIAN	
License Type: Permanent Food Service		1650 SAN PABLO RD S, #2, JACKSONVILLE 32224	
Inspection Date: 02/02/2021	Inspection Number: 3025875	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank located next to back door in kitchen. Operator removed propane tank to properly store outside **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2613067	BAR-B-Q STICKS		
License Type: Permanent Food Service	120 1/2 LEMON ST, NEPTUNE BEACH	32266	
Inspection Date: 02/03/2021	Inspection Number: 2997463	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer on prep table in middle of the kitchens door flat grill next to service window. There is no hood suppression system installed over fryer and grill. Smoke and grease build up throughout kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614615	WENDY'S #78		
License Type: Permanent Food Service	7663 MERRILL RD, JACKSONVILLE	32277	
Inspection Date: 02/04/2021	Inspection Number: 3051788	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back kitchen door blocked with multiple garbage containers and trash. Employee removed and unblock path. **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2615696	MI VERACRUZ MEXICAN RESTAURANT 2		
License Type: Permanent Food Service	7001 MERRILL RD STE 45, JACKSONVILLE	32277	
Inspection Date: 02/02/2021	Inspection Number: 3076619	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-02-4	Flammables stored/debris present in attic/basement. For reporting purposes only. Half gallon of gasoline stored near rear door in small gasoline container.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	

Flagler County

License Number: 2800801

NAPOLI PIZZA

License Type: Permanent Food Service

4845 BELLE TERRE PKWY, SUITE B, PALM COAST 32164

Inspection Date: 02/01/2021

Inspection Number: 3062458

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Rear exit blocked by boxes. Moved by manager **Corrected On-Site**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hernando County

License Number: 3701261

INDRANI'S ROTI SHOP

License Type: Permanent Food Service

3073 ANDERSON SNOW RD, SPRING HILL 34609

Inspection Date: 02/03/2021

Inspection Number: 3002760

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system not turned on . Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-12-04: Operator has called for service. There is no cooking being done at this visit. **Time Extended** - From follow-up inspection 2021-02-03: No cooking being done at this time. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3953033

DUNAS LATIN FOOD

License Type: Mobile Food Dispensing Vehicle

5224 S DALE MABRY HWY, RIVERVIEW 33579

Inspection Date: 02/02/2021

Inspection Number: 1234271

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3910482

CHIL'S SOUTHWEST GRILL/BAR

License Type: Permanent Food Service

8510 W HILLSBOROUGH AVE, TAMPA 336153817

Inspection Date: 02/01/2021

Inspection Number: 3037410

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Across from office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105149

HEATONS REEF BAR AND GRILL

License Type: Permanent Food Service

3500 OCEAN DRIVE, VERO BEACH 32963

Inspection Date: 02/03/2021

Inspection Number: 3072495

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. 135445, 135444, 135443 all expired 10/30/2020

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 4105151

COBALT

License Type: Permanent Food Service

3500 OCEAN DRIVE, VERO BEACH 32963

Inspection Date: 02/03/2021

Inspection Number: 3062127

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher by walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. 5 Certifications out of date. Expired 10/30/2020.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Marion County

License Number: 5203124

DINA'S ON THE GREEN

License Type: Permanent Food Service

1415 W GLENEAGLES RD, OCALA 34472

Inspection Date: 02/04/2021

Inspection Number: 3065318

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. At the cook line, female employee cooking raw chicken, no hood installed.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400817

ISLANDER RESTAURANT

License Type: Permanent Food Service

35 OCEAN REEF DR STE 200, KEY LARGO 33037

Inspection Date: 02/01/2021

Inspection Number: 3051127

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5401412

GIANNI RISTORANTE

License Type: Permanent Food Service

35 OCEAN REEF DRIVE SUITE 200, KEY LARGO 33037

Inspection Date: 02/02/2021

Inspection Number: 3050986

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tanks were removed.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402397

HARD ROCK CAFE

License Type: Permanent Food Service

313 DUVAL ST, KEY WEST 330406565

Inspection Date: 02/03/2021

Inspection Number: 3021737

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 1/23/21

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5805662

GARDEN GROVE RESTAURANT

License Type: Permanent Food Service

1200 EPCOT RESORT BLVD, LAKE BUENA VISTA 32830

Inspection Date: 02/04/2021

Inspection Number: 3052336

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed no boiler certificates for temporary boilers, per engineering.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5811853

PIZZA HUT

License Type: Permanent Food Service

10395 NARCOOSSEE RD UNIT 200, ORLANDO 32832

Inspection Date: 02/05/2021

Inspection Number: 3034647

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FRANZ, LISA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.- back door
blocked by 2 trash cans, moved cans, **Corrected On-Site**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5811110

TAKUMI

License Type: Permanent Food Service

8933 W COLONIAL DR, OCOEE 34761

Inspection Date: 02/02/2021

Inspection Number: 3042346

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K
extinguisher next to kitchen exit door. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019404	FAIRFIELD INN & SUITES JUPITER		
License Type: Permanent Food Service	6748 INDIANTOWN RD, JUPITER 33458		
Inspection Date: 02/02/2021	Inspection Number: 3076714	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 121021,121022,095111 all exp 03/15/2019 **Repeat Violation**		61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
License Number: 6022179	COURTYARD BY MARRIOTT DELRAY BEACH		
License Type: Permanent Food Service	135 SE 6 AVE, DELRAY BEACH 33483-5224		
Inspection Date: 02/05/2021	Inspection Number: 3060101	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**		61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
License Number: 6021070	PZZA GROUP LLC		
License Type: Permanent Food Service	5848 W ATLANTIC AVE STE 142, DELRAY BEACH 33484		
Inspection Date: 02/01/2021	Inspection Number: 3067384	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHATOON, BEGUM			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by big garbage can , boxes . For reporting purposes only.		61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
License Number: 6022118	BELLA AMICI PIZZERIA & RESTAURANTE		
License Type: Permanent Food Service	7491 N FEDERAL HWY SITE C-13, BOCA RATON 33487		
Inspection Date: 02/02/2021	Inspection Number: 3041211	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located in back of house in between cook line and door across from hood		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6113117

SLICE OF LIFE PIZZERIA

License Type: Permanent Food Service

9123 LITTLE RD, NEW PORT RICHEY 34654

Inspection Date: 02/03/2021

Inspection Number: 2987336

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: TORRACO, MARIANNE

Violation CodeObservationViolation Citation

49-04-4

- From initial inspection : Operator increased restaurant size by obtaining the unit next store to original unit. 2 bathrooms were added, additional seating, coffee bar area and increase in walk in cooler . Seating increased to 86. - From follow-up inspection 2021-01-04: Plans have been submitted and approved but operator has not completed all requirements for the Fire Marshall.
Reviewed with Senior Inspector Michele Dahl , 30 days extension given. **Time Extended** - From follow-up inspection 2021-02-03:
Seating increase evaluations form partially completed (max number of seats is not reported) and not submitted.
Reviewed with Supervisor Christine Craig
Operator must remove extra seats as License is for 36.
Extension given for 30 days to complete walls and ceilings and submit comp,teed increase in seating evaluation.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Time Extended

License Number: 6102516

NIKO'S GRILL

License Type: Permanent Food Service

14100 HICKS RD, HUDSON 34669

Inspection Date: 02/01/2021

Inspection Number: 3069544

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: TORRACO, MARIANNE

Violation CodeObservationViolation Citation

49-04-4

- From initial inspection : Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements.

49 seats, 28 in booths, 5 at counter
Seating increase form given - From follow-up inspection 2021-02-01: **Time Extended**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Pinellas County

License Number: 6218087	TE NONA DELICATUS
License Type: Permanent Food Service	5526 66 ST N, ST. PETERSBURG 33709
Inspection Date: 02/04/2021	Inspection Number: 3043142
Inspector Name: VILLEGAS, TATTYANA	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Ext to back foot inside kitchen.
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215840	ANTOJITOS DONA CHIRRISS
License Type: Permanent Food Service	2095 N HIGHLAND ST, CLEARWATER 33755-1300
Inspection Date: 02/01/2021	Inspection Number: 3052339
Inspector Name: BENEDICT, TRACY	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank in kitchen next to hand sink, operator removed tank and put outside **Corrected On-Site**
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213699	METRO DELI
License Type: Permanent Food Service	28100 US 19 N STE 103, CLEARWATER 33761
Inspection Date: 02/02/2021	Inspection Number: 3058435
Inspector Name: PEARCE, LAURA	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Electric Grill used to cook bacon and make grilled cheese on prep table
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215647	PACHANGA AREPA
License Type: Permanent Food Service	1991 DREW ST STE A, CLEARWATER 33765
Inspection Date: 02/05/2021	Inspection Number: 3049215
Inspector Name: BENEDICT, TRACY	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank next to oven in kitchen, operator took tank outside **Corrected On-Site**
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215105

WENDY'S PROPERTIES LLC

License Type: Permanent Food Service

11760 OAKHURST RD, LARGO 33774

Inspection Date: 02/05/2021

Inspection Number: 3053766

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked by trash/boxes. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6218032

JOJOS ITALIAN DINER

License Type: Permanent Food Service

217 S PINELLAS AVENUE, TARPON SPRINGS 34689

Inspection Date: 02/02/2021

Inspection Number: 3060102

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HIRST, DAN

Violation CodeObservationViolation Citation

49-03-4

Flammables stored/debris present in hot water heater room. For reporting purposes only.
Can of gasoline in back room by water heater. Operator removed and stored properly outside. **Corrected On-Site**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Polk County

License Number: 6350490

EL CABRITO TAQUERIA

License Type: Mobile Food Dispensing Vehicle

119 N HWY 17-92, HAINES CITY 33844

Inspection Date: 02/05/2021

Inspection Number: 1226438

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400213

MCDONALDS #3134

License Type: Permanent Food Service

2627 REID ST, PALATKA 321772807

Inspection Date: 02/05/2021

Inspection Number: 3077026

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Silver extinguisher across from mop sink

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6803879

BLASE CAFE

License Type: Permanent Food Service

5263 OCEAN BLVD UNIT 9, SARASOTA 34242

Inspection Date: 02/05/2021

Inspection Number: 3033527

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Person in charge placed the tank outside.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805328

PANERA BREAD #1600

License Type: Permanent Food Service

17899 TAMIAMI TRL, NORTH PORT 34287

Inspection Date: 02/03/2021

Inspection Number: 3035047

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MOREHEAD, PHILIP

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only. **Corrected On-Site**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6805210

BK 17535

License Type: Permanent Food Service

1071 S TOLEDO BLADE BLVD, NORTH PORT 34288

Inspection Date: 02/03/2021

Inspection Number: 3076704

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: MOREHEAD, PHILIP

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only. **Corrected On-Site**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

St. Johns County

License Number: 6501026

SCHMAGEL'S BAGELS

License Type: Permanent Food Service

69 HYPOLITA ST, SAINT AUGUSTINE 32084

Inspection Date: 02/01/2021

Inspection Number: 3064164

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment uses griddle to cook eggs on and does not have a hood suppression system. Need letter from fire Marshall approving griddle without fire suppression system. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403436

1888

License Type: Permanent Food Service

600 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 02/03/2021

Inspection Number: 3059268

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Type k on wall near dish machine

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.