

Alachua County

License Number: 1103217

NEWBERRY PIZZA

License Type: Permanent Food Service

120 SW 250 ST, NEWBERRY 32669

Inspection Date: 03/10/2021

Inspection Number: 3061904

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
One propane tank hooked to a single burner stored near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305821

SSPCB HOSPITALITY LLC

License Type: Permanent Food Service

12513 FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 03/09/2021

Inspection Number: 3054174

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONROE, JANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506790

MEXICO'S GRILL

License Type: Permanent Food Service

5240 N ATLANTIC AVE, UNIT 170, COCOA BEACH 32931

Inspection Date: 03/08/2021

Inspection Number: 3059292

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506150

SQUID LIPS WATERFRONT

License Type: Permanent Food Service

1477 PINEAPPLE AVE, MELBOURNE 32935

Inspection Date: 03/10/2021

Inspection Number: 3025600

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MITTEN, JAMES

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only
At shark bar

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619092	PIEZANOS POMPANO
License Type: Permanent Food Service	40 SW 15 ST, POMPANO BEACH 33060
Inspection Date: 03/08/2021	Inspection Number: 3070182
Inspector Name: GOODWIN, NICHOLAS	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located next hand sink and pizza oven
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620698	SNAPPERS FISH AND CHICKEN
License Type: Permanent Food Service	600 NW 3 ST, POMPANO BEACH 33060
Inspection Date: 03/09/2021	Inspection Number: 3063132
Inspector Name: GOODWIN, NICHOLAS	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
49-01-4	Flammables stored in storage room. For reporting purposes only. Gasoline can and gas pressure washer stored in dry storage room.
	<u>Violation Citation</u>
	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1617543	EL MARIACHI
License Type: Permanent Food Service	4625 UNIVERSITY DR, CORAL SPRINGS 33067
Inspection Date: 03/08/2021	Inspection Number: 3070808
Inspector Name: STEUBER, RYAN	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At triple sink
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621088	BROWARD CATERING
License Type: Catering	1437 S POWERLINE RD, POMPANO BEACH 33069
Inspection Date: 03/09/2021	Inspection Number: 1118052
Inspector Name: GOODWIN, NICHOLAS	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2250089

MAMA DUKES HOME COOKING

License Type: Mobile Food Dispensing Vehicle

133 NW WILTON WAY, LAKE CITY 32055

Inspection Date: 03/09/2021

Inspection Number: 1232018

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327558		PRESTONS MAIN KITCHEN	
License Type: Permanent Food Service		1601 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 03/10/2021	Inspection Number: 3073868	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 086663, 133030, 133393, 131418, 131417, 130721, 086664, 086665, 095285, 095284 All expire	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2335836		ROSETTA BAKERY	
License Type: Permanent Food Service		929 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 03/08/2021	Inspection Number: 3063254	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: URIBE, GUISELLA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only, located on second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2319252		SOCIAL CLUB	
License Type: Permanent Food Service		1725 COLLINS AVE, MIAMI BEACH 331392006	
Inspection Date: 03/11/2021	Inspection Number: 3064309	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: URIBE, GUISELLA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2318950		TOP OF THE FALLS	
License Type: Permanent Food Service		5225 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 03/09/2021	Inspection Number: 3037430	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. As per Chief Engineer, the inspection is scheduled for the next week.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2330429	DONNA MARE		
License Type: Permanent Food Service	3925 COLLINS AVE KITCHEN/LOBBY BAR, MIAMI BEACH	33140	
Inspection Date: 03/10/2021	Inspection Number: 3070826	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. By the entrance door.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2332744	FLORIDA GRILL		
License Type: Permanent Food Service	4299 COLLINS AVE, MIAMI BEACH	33140	
Inspection Date: 03/08/2021	Inspection Number: 3073819	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks on premises.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2334027	PLATE		
License Type: Permanent Food Service	2105 CORAL WAY, MIAMI	33145	
Inspection Date: 03/09/2021	Inspection Number: 3050629	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Warning** - From follow-up inspection 2021-03-09: no hood **Time E		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2326916	SUNSHINE CAFE		
License Type: Permanent Food Service	8180 NW 36 ST, MIAMI	33166	
Inspection Date: 03/11/2021	Inspection Number: 3063990	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located inside kitchen.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Gadsden County

License Number: 3000340

WAFFLE HOUSE #1561

License Type: Permanent Food Service

2380 BRICKYARD RD, MIDWAY 32343

Inspection Date: 03/08/2021

Inspection Number: 3046560

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher near ice machine in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3918362

PAL CAMPO RESTAURANT - TAMPA

License Type: Permanent Food Service

9218 ANDERSON ROAD, TAMPA 33634

Inspection Date: 03/12/2021

Inspection Number: 3058720

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602336 FOUNTAIN GRILLE
 License Type: Permanent Food Service 18621 N TAMIAMI TRAIL, NORTH FORT MYERS 33903

Inspection Date: 03/11/2021 Inspection Number: 3046077 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed tank by office area. Operator removed to an outside storage area. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4602638 BUON APPETITO CAFE INC
 License Type: Permanent Food Service 6314 CORPORATE CT D, FORT MYERS 33919

Inspection Date: 03/08/2021 Inspection Number: 3079214 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ORDONEZ, ADADBELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At three compartment sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105092

SOMBREROS

License Type: Permanent Food Service

1330 US HWY 301, PALMETTO 34221

Inspection Date: 03/10/2021

Inspection Number: 3010165

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Person in charge placed the tanks outside. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202339

SONIC DRIVE IN

License Type: Permanent Food Service

2401 SW 19 AVE RD, OCALA 34471

Inspection Date: 03/08/2021

Inspection Number: 3067589

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.
Extinguisher near hand sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811112		DUBSDREAD CATERING	
License Type: Catering		604 E MAIN ST, APOPKA 32703	
Inspection Date: 03/11/2021	Inspection Number: 1117334	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-01-4	Observed frayed/spliced electrical wires. For reporting purposes only, plate missing from a electrical box in the the stock room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811231		BUBBALOU'S BODACIOUS BBQ	
License Type: Permanent Food Service		1701 N. ROCK SPRINGS, APOPKA 32712	
Inspection Date: 03/12/2021	Inspection Number: 3047961	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the 3 compartment sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5804218		BUBBALOU'S BODACIOUS BBQ	
License Type: Permanent Food Service		1471 LEE RD, WINTER PARK 32789	
Inspection Date: 03/09/2021	Inspection Number: 3052859	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only, 3 propane tanks in storage building across street	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811108		EURO POL POLISH DELI	
License Type: Permanent Food Service		3090 ALOMO AVE STE 125, WINTER PARK 32792	
Inspection Date: 03/09/2021	Inspection Number: 3060359	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator is frying food at back kitchen preparation area without a hood suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5807092	NEW YORK DELI		
License Type: Permanent Food Service	255 S ORANGE AVE #103, ORLANDO	32801	
Inspection Date: 03/11/2021	Inspection Number: 3041283	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTESANO, MISTI			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - small one burners used to sear chicken and fry eggs.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 5814122	FARM & HAUS		
License Type: Permanent Food Service	3201 CORRINE DRIVE SUITE 1, ORLANDO	32803	
Inspection Date: 03/09/2021	Inspection Number: 3066263	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENRY, KRISTINA			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 5813354	CAFE PINAR INC		
License Type: Permanent Food Service	730 W SAND LAKE RD #30, ORLANDO	32809	
Inspection Date: 03/08/2021	Inspection Number: 3061729	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. Deep fryer on top of prep table outside hood, kitchen. For reporting purposes only.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 5803445	CHRISTNER'S PRIME STEAK & LOBSTER		
License Type: Permanent Food Service	729 LEE RD, ORLANDO	328105621	
Inspection Date: 03/11/2021	Inspection Number: 3073156	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tank located in the stock room at the 2nd kitchen. Removed the propane tank		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810253		ZAXBY'S RESTAURANT	
License Type: Permanent Food Service		11554 UNIVERSITY BLVD, ORLANDO 32817	
Inspection Date: 03/09/2021	Inspection Number: 3045324	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash impeding access to rear exit door. **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5804085		SHERATON ORLANDO LAKE BUENA VISTA RESORT	
License Type: Permanent Food Service		12205 S APOPKA VINELAND RD, ORLANDO 32836	
Inspection Date: 03/09/2021	Inspection Number: 3078998	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certifications expired 4/21/2018 General Manager will notify Boiler Inspection office.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5814289		PDQ	
License Type: Permanent Food Service		14000 S JOHN YOUNG PKWY, ORLANDO 32837	
Inspection Date: 03/08/2021	Inspection Number: 3063110	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVIS, DAVID			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - trash blocking exit door **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5805732		BELLA NAPOLI	
License Type: Permanent Food Service		750 S BLUFORD AVE., OCOEE 34761	
Inspection Date: 03/11/2021	Inspection Number: 3039052	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GREENE, MARVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small next to hand sink area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Palm Beach County

License Number: 6021001

BRIO

License Type: Permanent Food Service

550 S ROSEMARY AVE SPACE C3, WEST PALM BEACH 33401

Inspection Date: 03/10/2021

Inspection Number: 3079570

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed tank from building.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6005485

TIDELINE OCEAN RESORT AND SPA - PALM BEACH, A KIMPTON HOTEL

License Type: Permanent Food Service

2842 S OCEAN BLVD, PALM BEACH 33480

Inspection Date: 03/10/2021

Inspection Number: 3064021

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pasco County

License Number: 6113562

MERMAIDS LOUNGE & EATERY

License Type: Permanent Food Service

11024 STATE RD 52, HUDSON 34669

Inspection Date: 03/12/2021

Inspection Number: 3013297

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

49-04-4

Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Outside: 1 picnic tables that seats 8; 4 picnic tables that seat 4 each: total 24 seats outside

In

Polk County

License Number: 6305719

RED LOBSTER #6208

License Type: Permanent Food Service

3706 US 98 N, LAKELAND 33809

Inspection Date: 03/10/2021

Inspection Number: 3071336

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, GUADALUPE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. Expired 02/16/2019

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6306376

HAVANA CAFE DELIGHTS INC

License Type: Permanent Food Service

155 E MAIN ST, BARTOW 33830

Inspection Date: 03/10/2021

Inspection Number: 3064731

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
K class extinguisher in recharge zone in kitchen across from three compartment sink

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6308134

GFS CATERINGLLC

License Type: Permanent Food Service

7710 SR 544 E, WINTERHAVEN 33881

Inspection Date: 03/12/2021

Inspection Number: 3058193

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Observed a Presto Profry in use and a flat grill used to cook hamburgers and hotdogs in use.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.