

**Alachua County**

License Number: 1103595

TUNIS SEAFOOD WINGS & SUBS

License Type: Permanent Food Service

1818 NE WALDO RD, GAINESVILLE 32609

Inspection Date: 03/16/2021

Inspection Number: 3060867

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed silver fire extinguisher in the recharge zone. - From follow-up inspection 2021-03-16: The Silver K class is indicated in the recharge zone \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-03-4 - From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.  
Observed the wires for the pillar sign are exposed. - From follow-up inspection 2021-03-16: No change \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1502391	RUSTIC		
License Type: Permanent Food Service	200 RIALTO PL, MELBOURNE	32901	
Inspection Date: 03/15/2021	Inspection Number: 3064977	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: QUINONES, ANTONIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

License Number: 1504639	MAMBOS		
License Type: Permanent Food Service	1300 N ATLANTIC AVE, COCOA BEACH	32931	
Inspection Date: 03/18/2021	Inspection Number: 3074373	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. End of cookline by fryers. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 11/6/2020 - From follow-up inspection 2021-03-19: **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 11/6/2020	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

License Number: 1506317	COCOA BEACH SPORTS PUB		
License Type: Permanent Food Service	142 N ORLANDO AVE STE 600, COCOA BEACH	32931	
Inspection Date: 03/15/2021	Inspection Number: 3070375	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MITTEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Broward County**

License Number: 1611217

AFFAIRS D'ELEGANCE

License Type: Catering

121 SW 5 ST, POMPANO BEACH 33060

Inspection Date: 03/18/2021

Inspection Number: 1117754

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. LP tanks located in storage area building where dish washer is located

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625235

AC KITCHEN &amp; LOUNGE

License Type: Permanent Food Service

1870 SAWGRASS MILLS CIRCLE, SUNRISE 33323

Inspection Date: 03/19/2021

Inspection Number: 3077367

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRADY, OSSIAN

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Observed 2 boilers on 8th floor with Max BTU/hr of 800,000 and per tank storage of 500 gallons. No boiler certification available for either boiler.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1611984

FRA DIAVOLO

License Type: Permanent Food Service

5444 N UNIVERSITY DR, LAUDERHILL 33351

Inspection Date: 03/15/2021

Inspection Number: 3072537

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning  
Issued

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.  
-Observed Electric fuse box in disrepair. In kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2001212

AMC THEATRES ORANGE PARK 24

License Type: Permanent Food Service

1910 WELLS RD, ORANGE PARK 32073

Inspection Date: 03/17/2021

Inspection Number: 3028717

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-01-4

Fire alarm panel in trouble/sounding alarm. For reporting purposes only.  
 Fire panel near main office is sounding alarm, per manager they are aware and have a technician scheduled to replace a faulty part.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2336751

OKAMI

License Type: Permanent Food Service

156 NE 41 ST, MIAMI 33137

Inspection Date: 03/16/2021

Inspection Number: 3072173

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SEYBA, JAMES

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Employee removed. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334217

GRILL HOUSE

License Type: Permanent Food Service

976 ARTHUR GODFREY RD, MIAMI BEACH 33140

Inspection Date: 03/16/2021

Inspection Number: 3037087

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank by the ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Flagler County**

License Number: 2800484

BURGER KING

License Type: Permanent Food Service

6115 E HWY 100, FLAGLER BEACH 32136

Inspection Date: 03/15/2021

Inspection Number: 3079507

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Rear. Exit blocked by boxes. Moved by manager. **\*\*Corrected On-Site\*\***

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Hillsborough County**

License Number: 3906626

PLANT CITY HOMESTYLE BUFFET

License Type: Permanent Food Service

1914 JAMES L REDMAN PKWY, PLANT CITY 33563

Inspection Date: 03/18/2021

Inspection Number: 3079952

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEWIS, RICKY

Violation CodeObservationViolation Citation

49-02-4

Flammables stored/debris present in dry food storage area For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 3953079

LATINO SPOT

License Type: Mobile Food Dispensing Vehicle

7209 E HILLSBOROUGH AVE, TAMPA 33610

Inspection Date: 03/18/2021

Inspection Number: 1234779

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOWAL, KYLE

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4702758

MASA

License Type: Permanent Food Service

1650 N MONROE ST, TALLAHASSEE 32303

Inspection Date: 03/18/2021

Inspection Number: 3080045

Inspection Type: Complaint Partial

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed electrical wiring from ceiling hanging down in ware washing area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703157

RELISH - BIG TASTY BURGERS #1

License Type: Permanent Food Service

1935 W TENNESSEE ST, TALLAHASSEE 32304

Inspection Date: 03/15/2021

Inspection Number: 3067621

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in overcharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703387

PANDA EXPRESS #1873

License Type: Permanent Food Service

1410 W TENNESSEE ST, TALLAHASSEE 32304

Inspection Date: 03/15/2021

Inspection Number: 3066319

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5800323		REEL FISH COASTAL KITCHEN & BAR	
License Type: Permanent Food Service		1234 N ORANGE AVE, WINTER PARK 32789	
Inspection Date: 03/17/2021	Inspection Number: 3063056	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only, 3 propane tanks in back dry storage building, operator removed tanks from building **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814057		COCO	
License Type: Permanent Food Service		100 S EOLA DR UNIT 104, ORLANDO 32801	
Inspection Date: 03/16/2021	Inspection Number: 2994902	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MONTESANO, MISTI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - stored next to back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5808867		LA LECHONERA EL BARRIO	
License Type: Permanent Food Service		435 N SEMORAN BLVD, ORLANDO 32807	
Inspection Date: 03/15/2021	Inspection Number: 3035001	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HENRY, KRISTINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking eggs on a grill to order in front counter area behind steam well.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5813147		ICE & BITES CAFE	
License Type: Permanent Food Service		3402 TECHNOLOGICAL AVE #220, ORLANDO 32817	
Inspection Date: 03/17/2021	Inspection Number: 3041031	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rolling cart impeding access to rear exit door. **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

**Orange County**

License Number: 5813014

ANTILLE'S CUISINE

License Type: Permanent Food Service

2798 N HIAWASSEE RD, ORLANDO 32818

Inspection Date: 03/18/2021

Inspection Number: 3047703

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Door in restroom hallway.

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5807118

BOI BRAZIL CHURRASCARIA

License Type: Permanent Food Service

5668 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 03/17/2021

Inspection Number: 3070397

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5911218

ROSIE CARIBBEAN RESTAURANT LLC

License Type: Permanent Food Service

704 N MAIN ST, KISSIMMEE 34744

Inspection Date: 03/17/2021

Inspection Number: 3079681

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: BORRERO, AUDREY

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with hood not working, suppression system installed. Notified Fire AHJ. For reporting purposes only.

Not working. - From follow-up inspection 2021-03-17: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with hood not working, suppression system installed. Notified Fire AHJ. For reporting purposes only.

Not working.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911668

GRAND HOTEL KISSIMMEE - BREAKFAST

License Type: Permanent Food Service

3104 PARKWAY BOULEVARD, KISSIMMEE 34747

Inspection Date: 03/15/2021

Inspection Number: 3077552

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Polk County**

License Number: 6308340

CLEO'S BREAKFAST & BRUNCH BAR

License Type: Permanent Food Service

400 SOUTH CHARLESTON AVE, FORT MEADE 33841

Inspection Date: 03/19/2021

Inspection Number: 3062931

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, GUADALUPE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed counter top fryer on food production table no hood, operator moved to a space under hood. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406886

OLIVE GARDEN #1814

License Type: Permanent Food Service

5447 SOUTH WILLIAMSON BOULEVARD, PORT ORANGE 32128

Inspection Date: 03/15/2021

Inspection Number: 3064078

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

49-05-4

Small amount of wood for signs stored in water heater room. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407077

THE DOGHOUSE BAR &amp; GRILL

License Type: Permanent Food Service

3400 S NOVA RD, PORT ORANGE 32129

Inspection Date: 03/16/2021

Inspection Number: 3031240

Inspection Type: Routine - Food

Inspection Disposition: Emergency  
order recommended

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

4 propane tanks stored inside, manager removed.

-manager stated temporarily moved inside after recent theft. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.