

Brevard County

License Number: 1505908 TROPICAL SMOOTHIE CAFE FL-101
 License Type: Permanent Food Service 4700 BABCOCK ST NE SUITE 9, PALM BAY 32905

Inspection Date: 04/16/2021 Inspection Number: 3082661 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506108 GATORS DOCKSIDE
 License Type: Permanent Food Service 683 DAVE NISBET DR, CAPE CANAVERAL 32920

Inspection Date: 04/14/2021 Inspection Number: 3082502 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only. Hook By electrical panels. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1507011 COCOA BEACH FISH CAMP GRILL
 License Type: Permanent Food Service 5602 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 04/14/2021 Inspection Number: 3081759 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By beer storage behind mousetrap bar. - From follow-up inspection 2021-04-14: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By beer storage behind mousetrap bar.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1503786

POMPANO GRILL

License Type: Permanent Food Service

110 N BREVARD AVE, COCOA BCH 329312948

Inspection Date: 04/16/2021

Inspection Number: 3075147

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Tabletop fryer used to flash fry tuna. - From follow-up inspection 2021-04-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Tabletop fryer used to flash fry tuna.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600734	JACK'S DINER		
License Type: Permanent Food Service	1031 N FEDERAL HWY, HOLLYWOOD	33020-3539	
Inspection Date: 04/16/2021	Inspection Number: 3074775	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEWIS, LYNDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1608794	SUBWAY		
License Type: Permanent Food Service	201 E SUNRISE BLVD, FORT LAUDERDALE	33304	
Inspection Date: 04/14/2021	Inspection Number: 3010918	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Board across rear exit door.	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
46-04-4	- From initial inspection : Exit door locked. For reporting purposes only. Board across rear exit door. - From follow-up inspection 2021-04-15: Exit door locked. For reporting purposes only. Board across rear exit door. **Time Extended**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

License Number: 1616060	GREEK PASTRIES & DELI		
License Type: Permanent Food Service	4701 N FEDERAL HWY A15, FORT LAUDERDALE	33308	
Inspection Date: 04/13/2021	Inspection Number: 3064328	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: DEJONG, STEVEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. Manager stated currently not using table top fryer. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1618782

GOLDEN CORRAL

License Type: Permanent Food Service

7401 W COMMERCIAL BLVD, TAMARAC 33319

Inspection Date: 04/12/2021

Inspection Number: 3082233

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: ROGERS, VERNEL

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed Main kitchen rear exit door blocked by empty boxes. Operator moved boxes from exit door.

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Clay County

License Number: 2001245

PASTA MARKET ITALIAN RESTAURANT AND CLAM BAR

License Type: Permanent Food Service

1930 KINGSLEY AVE, ORANGE PARK 32073

Inspection Date: 04/12/2021

Inspection Number: 3077436

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher next to triple sink in back of kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336085		CREMA GOURMET ESPRESSO BAR	
License Type: Permanent Food Service		1010 BRICKELL AVE CU1, MIAMI 33131	
Inspection Date: 04/14/2021	Inspection Number: 3074657	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed induction cooktop at the back area with no hood. Advised operator to check with the local fire department agency having jurisdiction over the induction cooktops with no hood. As per operator, she cooks eggs in the frying pans on the induction cooktops.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2322804		GOURMET KOSHER LLC	
License Type: Permanent Food Service		330 NE 59 ST, MIAMI 33137	
Inspection Date: 04/13/2021	Inspection Number: 3072361	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler inspection not current: jurisdiction #: 02379, expired: 11/13/2020	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2330674		PINOLANDIA 3 CORPORATION	
License Type: Permanent Food Service		10948 SW 184 ST, MIAMI 33157	
Inspection Date: 04/12/2021	Inspection Number: 3051365	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Observed portable fire extinguisher behind preparation table and microwave, not accessible.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2611566

SUBWAY SANDWICHES & SALADS

License Type: Permanent Food Service

5351 NORMANDY BLVD, JACKSONVILLE 322054829

Inspection Date: 04/12/2021

Inspection Number: 3081643

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Boxes in the way, rear door

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2600332

ONE OCEAN RESORT HOTEL & SPA

License Type: Permanent Food Service

1 OCEAN BLVD, ATLANTIC BEACH 32233

Inspection Date: 04/09/2021

Inspection Number: 3074343

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2611257

HABIBI HOOKAH BAR

License Type: Permanent Food Service

314 1 ST N, JACKSONVILLE 32250

Inspection Date: 04/13/2021

Inspection Number: 3075822

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, MAYRA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
15lbs Propane tank stored in kitchen in between walk in cooler and the water heater. Manager removed propane tank from kitchen. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917506

DAILY DOSE COFFEE HOUSE AND EATERY

License Type: Permanent Food Service

302 KNIGHTS RUN # 130, TAMPA 33602

Inspection Date: 04/16/2021

Inspection Number: 3065709

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: COLEMAN, TONYA

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2021-04-16: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606040

THE GOLF CLUB AT MAGNOLIA LANDING

License Type: Permanent Food Service

3501 AVENIDA DEL VERA BLVD, NORTH FORT MYERS 33917

Inspection Date: 04/12/2021

Inspection Number: 3047272

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank inside utility closet. Operator removed tank and placed outside. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5103511

CHECKERS DRIVE IN REST # 161

License Type: Permanent Food Service

5140 W CORTEZ RD UNIT 161, BRADENTON 342102809

Inspection Date: 04/13/2021

Inspection Number: 3041261

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed at fire extinguisher near ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301385

DUNKIN DONUTS/BASKIN ROBBINS

License Type: Permanent Food Service

2101 SE OCEAN BLVD, STUART 34996

Inspection Date: 04/12/2021

Inspection Number: 3009645

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door. - From follow-up inspection 2021-04-12: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5428253

FARO BLANCO RESORT & MARINA

License Type: Permanent Food Service

1996 OVERSEAS HWY, MARATHON 33050

Inspection Date: 04/09/2021

Inspection Number: 3064305

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

49-03-4

Flammables stored/debris present in boiler room. For reporting purposes only.
Container of Denatured alcohol in boiler room **Corrected On-Site**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Okaloosa County

License Number: 5604198

MAIN BREW COFFEE CORP

License Type: Permanent Food Service

450 C RACETRACK RD NW, FORT WALTON BEACH 32547

Inspection Date: 04/12/2021

Inspection Number: 3079706

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Two electrical cook top / ovens observed in kitchen.
No hood system in place.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5807781		SAZON'S RESTAURANT BUFFET & GRILL	
License Type: Permanent Food Service		701 W LANCASTER RD, ORLANDO 32809	
Inspection Date: 04/13/2021	Inspection Number: 3066273	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PLEICONES, KIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks at cook line. One tank connected to propane griddle. Owner disconnected and removed tanks from building **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5808122		PIRATES DINNER ADVENTURE	
License Type: Permanent Food Service		6400 CARRIER DR, ORLANDO 32819	
Inspection Date: 04/14/2021	Inspection Number: 3065364	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. K class extinguisher blocked by warming box	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5813402		CABANA BAY BEACH RESORT-GALAXY BOWL	
License Type: Permanent Food Service		6550 ADVENTURE WAY, ORLANDO 32819	
Inspection Date: 04/07/2021	Inspection Number: 3071410	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by glass trays **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5812945		THE OCOEE TACO COMPANY	
License Type: Permanent Food Service		40 TAYLOR ST, OCOEE 34761	
Inspection Date: 04/14/2021	Inspection Number: 2986397	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GREENE, MARVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer being used on table next to ice machine. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5911427

VILLA BAKERY CON SABOR VENEZOLANO

License Type: Permanent Food Service

5407 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 04/13/2021

Inspection Number: 3076719

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5907004

STADIUM CONCESSIONS - HOME PLATE INNER

License Type: Permanent Food Service

800 S VICTORY WAY, KISSIMMEE 34747

Inspection Date: 04/14/2021

Inspection Number: 3009267

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./ 088977 , 088997 , ,088998, exp 2/22/20 expired

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6021751

LOUIE BOSSI'S RISTORANTE BAR PIZZERIA

License Type: Permanent Food Service

100 E PALMETTO PARK RD., BOCA RATON 33432

Inspection Date: 04/14/2021

Inspection Number: 3082487

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEUBER, RYAN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At kitchen next to hand sink

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6005485

TIDELINE OCEAN RESORT AND SPA - PALM BEACH, A KIMPTON HOTEL

License Type: Permanent Food Service

2842 S OCEAN BLVD, PALM BEACH 33480

Inspection Date: 04/15/2021

Inspection Number: 3082406

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small deep fryer at sushi bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-04-16: **Time Extended**

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pasco County

License Number: 6113562

MERMAIDS LOUNGE & EATERY

License Type: Permanent Food Service

11024 STATE RD 52, HUDSON 34669

Inspection Date: 04/12/2021

Inspection Number: 3013297

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

49-04-4

- From initial inspection : Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Outside: 1 picnic tables that seats 8; 4 picnic tables that seat 4 each: total 24 seats outside

Inside: 9 seats at Tables , 22 bar stools: 31 inside total seats

Total 55 seats

- From follow-up inspection 2021-04-12: Not complied.

Outside: 2 picnic tables that seat 4 each: total 8.

1 picnic table that seats 8.

Outside total is 16.

Inside: 6 seats at tables on left side of bar.

2 seats at tables at right side of bar.

23 seats at the bar.

Total inside seats is 31.

Total seats inside and outside is 47. ****Admin Complaint****

Pinellas County

License Number: 6217803

DR. BBQ

License Type: Permanent Food Service

1101 1ST AVE SOUTH, ST PETERSBURG 33705

Inspection Date: 04/15/2021

Inspection Number: 3074055

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
-fire extinguisher in bar area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211181

WATER COLOUR STEAK HOUSE AND GRILL

License Type: Permanent Food Service

1201 GULF BLVD, CLEARWATER BEACH 33767

Inspection Date: 04/12/2021

Inspection Number: 3041626

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
All certificates expired: FI 134097, FI 134098, FI 134099, FI 134100 all exp.
9/12/2020

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6217482

DANSTE HOSPITALITY GROUP LLC

License Type: Permanent Food Service

635 S GULFVIEW BOULEVARD, CLEARWATER BEACH 33767

Inspection Date: 04/16/2021

Inspection Number: 3059125

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

49-01-4

Flammables stored/debris present in walk in cooler storage are. 3 tanks of propane. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Seminole County

License Number: 6902129

U RESTAURANT/ COOL BEANS CAFE

License Type: Permanent Food Service

350 S NORTHLAKE BLVD, ALTAMONTE SPRINGS 32701

Inspection Date: 04/12/2021

Inspection Number: 3071465

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
-boiler certificates expired.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Volusia County

License Number: 7403180

FIVE STAR PIZZA

License Type: Permanent Food Service

3755 S NOVA RD STE B, PORT ORANGE 32129

Inspection Date: 04/16/2021

Inspection Number: 3080063

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Unit on wall at exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -large supply of pizza boxes causing obstruction in pathway to exit door. **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.