

Brevard County

License Number: 1506363

COUNTRY COOKIN' DINER

License Type: Permanent Food Service

616 BARNES BLVD, ROCKLEDGE 32955

Inspection Date: 04/27/2021

Inspection Number: 3083643

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Back exit near restrooms blocked by ladders and table

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Broward County

License Number: 1619262

THE ROYAL PIG PUB

License Type: Permanent Food Service

350 E LAS OLAS BLVD STE 150, FORT LAUDERDALE 33301

Inspection Date: 04/29/2021

Inspection Number: 3070960

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By mop sink near office. - From follow-up inspection 2021-04-29: Portable fire extinguisher gauge in red zone. For reporting purposes only. By mop sink near office. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By mop sink near office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2359671	PURA VIDA 97		
License Type: Mobile Food Dispensing Vehicle	24420 SOUTH DIXIE HIGHWAY, HOMESTEAD	33032	
Inspection Date: 04/30/2021	Inspection Number: 1235487	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335786	PORTOFINO DELI CAFE		
License Type: Permanent Food Service	500 S POINTE DR SUITE 130, MIAMI BEACH	33139	
Inspection Date: 04/27/2021	Inspection Number: 3058281	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located next to front counter Steamtable unit. **Repeat Violation** - From follow-up inspection 2021-04-27: Portable fire extinguisher gauge in red zone. For reporting purposes only. Located next to front counter Steamtable unit. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2300027	MCDONALDS REST OF FLORIDA INC		
License Type: Permanent Food Service	6150 S DIXIE HWY, MIAMI	331435003	
Inspection Date: 04/28/2021	Inspection Number: 3083697	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the pallets blocking the exit door. Advised, the operator removed the items. **Corrected On-Site**	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2326329	TACO BELL- 26473		
License Type: Permanent Food Service	640 NE 125 ST, NORTH MIAMI	33161	
Inspection Date: 04/26/2021	Inspection Number: 3083201	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located in front of office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2336495

PATE CREOL

License Type: Permanent Food Service

12997 W DIXIE HWY, NORTH MIAMI 33161

Inspection Date: 04/26/2021

Inspection Number: 3059797

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

48-04-4 - From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. ****Repeat Violation**** - From follow-up inspection 2021-04-26: On 4/26/21 at the time of callback inspection Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. ****Repeat Violation** **Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800719

CHINA CAFE CHEN INC

License Type: Permanent Food Service

426 BEACH VILLAGE DR, FLAGLER BEACH 32136

Inspection Date: 04/27/2021

Inspection Number: 3083673

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher by front hand wash sink is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800774

BROOKLYN MIKE'S PIZZA AND RESTAURANT

License Type: Permanent Food Service

4982 PALM COAST PKWY NW, PALM COAST 32137

Inspection Date: 04/29/2021

Inspection Number: 3082100

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
In back storage area, exit path blocked by wire shelving unit.

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2800798

EL POLLO COLORAO

License Type: Permanent Food Service

227 ST JOE PLAZA DR STE A, PALM COAST 32164

Inspection Date: 04/28/2021

Inspection Number: 3062374

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Two small fryers placed outside hood site. (next to existing fryer which has adequate hood protection.) - From follow-up inspection 2021-01-26:
At callback : time needed to review. **Time Extended** - From follow-up inspection 2021-03-26: At callback time needed to submit Plan review. Fryers to be relocated.
Establishment has just signed lease to purchase adjacent building space. (2/12/21) still needs time to consider new layout. **Time Extended** - From follow-up inspection 2021-04-28: Operator is expanding restaurant into unit to the right. Is waiting on installing hood filter as fryers will be relocated in new layout pending renovations. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917816

PITA KEBOB

License Type: Permanent Food Service

3028 E COLLEGE AVE, RUSKIN 33570

Inspection Date: 04/27/2021

Inspection Number: 3046294

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SANDERS, CLEVELAND

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.
Observed fire extinguisher stored on the floor next to mop sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3915657

SPICE KITCHEN

License Type: Permanent Food Service

11653 COUNTRYWAY BLVD, TAMPA 33626

Inspection Date: 04/28/2021

Inspection Number: 3012791

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

46-04-4

- From initial inspection : Exit door locked. Marked side exit door blocked by stacks of chairs. For reporting purposes only. - From follow-up inspection 2021-02-24: Still blocked. **Time Extended** - From follow-up inspection 2021-03-05: **Time Extended** - From follow-up inspection 2021-04-28: **Time Extended**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Indian River County

License Number: 4105220

MARCO'S PIZZA

License Type: Permanent Food Service

1820 SW 58 AVE UNIT 112, VERO BEACH 32966

Inspection Date: 04/28/2021

Inspection Number: 3083876

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. Silver K class extinguisher on high shelving over north side prep table.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4651119

TAQUERIA LEON DE MICHOACAN 1

License Type: Mobile Food Dispensing Vehicle

2737 LAFAYETTE ST, FORT MYERS 33916

Inspection Date: 04/29/2021

Inspection Number: 1235414

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703676

MISSION BBQ TALLAHASSEE

License Type: Permanent Food Service

216 SOUTH MAGNOLIA DR STE 101, TALLAHASSEE 32301

Inspection Date: 04/28/2021

Inspection Number: 3060759

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, PAUL

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Properly stored during inspection. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5501200 SPRINGHILL SUITES AMELIA ISLAND
 License Type: Permanent Food Service 2700 ATLANTIC AVE, FERNANDINA BEACH 32034

Inspection Date: 04/27/2021 Inspection Number: 3077909 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEVILLE, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler data plate states boiler is 500,000 BTU output, 160 gal, and 210°F	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5501201 COURTYARD AMELIA ISLAND
 License Type: Permanent Food Service 2700 ATLANTIC AVE, FERNANDINA BEACH 32034

Inspection Date: 04/27/2021 Inspection Number: 3077910 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEVILLE, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler data plate states boiler is 500,000 BTU output, 160 gal, and 210°F	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5813239

CITY PHO AND GRILL

License Type: Permanent Food Service

156 LAKE AVE, MAITLAND 32751

Inspection Date: 04/28/2021

Inspection Number: 3082429

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning
Issued

Inspector Name: LEEMIS, REBECCA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
- blocked by potted plant

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5814057

COCO

License Type: Permanent Food Service

100 S EOLA DR UNIT 104, ORLANDO 32801

Inspection Date: 04/26/2021

Inspection Number: 3079963

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MONTESANO, MISTI

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
- in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217803 DR. BBQ
 License Type: Permanent Food Service 1101 1ST AVE SOUTH, ST PETERSBURG 33705

Inspection Date: 04/30/2021 Inspection Number: 3074055 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: WILMOT, TASHARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. -fire extinguisher in bar area - From follow-up inspection 2021-04-21: **Time Extended** - From follow-up inspection 2021-04-30: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216971 DUFF'S BUFFET
 License Type: Permanent Food Service 26111 US HWY 19 N, CLEARWATER 33763

Inspection Date: 04/30/2021 Inspection Number: 3070710 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAHL, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class on cook line	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217202 NORTH ISLAND BAR AND GRILLE
 License Type: Permanent Food Service 600 MANDALAY AVE., CLEARWATER 33767

Inspection Date: 04/30/2021 Inspection Number: 3045078 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in kitchen. For reporting purposes only. 2-20lbs propane tanks stored under prep table.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Sumter County

License Number: 7000603

BIG BASS GRILL AND LAKEFRONT RESORT

License Type: Permanent Food Service

965 COUNTY RD 439, LAKE PANASOFFKEE 33538

Inspection Date: 04/26/2021

Inspection Number: 3078293

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By front door and indoor bar. - From follow-up inspection 2021-04-26: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407046

BRUNO'S PIZZA

License Type: Permanent Food Service

1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 04/29/2021

Inspection Number: 3081847

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.