

Broward County

License Number: 1621146

LA CARRETA RESTAURANT

License Type: Permanent Food Service

14791 MIRAMAR PKWY, MIRAMAR 33027

Inspection Date: 05/21/2021

Inspection Number: 3085191

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, RHEANNE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certification on 3/17/2021.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2330470

LIME FRESH MEXICAN GRILL

License Type: Permanent Food Service

1439 ALTON RD, MIAMI BEACH 33139

Inspection Date: 05/20/2021

Inspection Number: 3085020

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone located next to kitchen three
compartment sink. For reporting purposes only.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 2358793

PORCHETTONI

License Type: Mobile Food Dispensing Vehicle

8489 NW 64 STREET, MIAMI 33166

Inspection Date: 05/21/2021

Inspection Number: 1235264

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed extinguisher in recharge zone located by MFDV entrance.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Duval County

License Number: 2652228

EL PLATO LATINO

License Type: Mobile Food Dispensing Vehicle

1850 EMERSON ST, JACKSONVILLE 32207

Inspection Date: 05/20/2021

Inspection Number: 1235839

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.
Operator has one at In route to home and will put on truck later

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2600525

RAY & ANN SINGLETON'S SEAFOOD SHACK

License Type: Permanent Food Service

4728 OCEAN ST, ATLANTIC BEACH 32233

Inspection Date: 05/17/2021

Inspection Number: 3084584

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: GONZALEZ, MAYRA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Two 15lbs propane tanks stored near bathrooms in front area near kitchens entrance.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800666

GRILL AT THE CONSERVATORY

License Type: Permanent Food Service

300 CONSERVATORY WAY, PALM COAST 32137

Inspection Date: 05/21/2021

Inspection Number: 3080465

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
No boiler report available at the time of inspection, person in charge states they do have one, just not able to provide at time of inspection. ****Repeat Violation****

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hillsborough County

License Number: 3918338

WILD N SMOKEY BBQ

License Type: Permanent Food Service

6032 N US HWY 41, APOLLO BEACH 33572

Inspection Date: 05/20/2021

Inspection Number: 3073939

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: SANDERS, CLEVELAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from x to y. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	- From initial inspection : Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from x to y. For reporting purposes only. - From follow-up inspection 2021-05-21: Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. Time Extended** **Time Extended** - From follow-up inspection 2021-05-21: - From initial inspection : Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. - From follow-up inspection 2021-05-21: Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. Time Extended** **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	- From initial inspection : Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from x to y. For reporting purposes only. - From follow-up inspection 2021-05-21: Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. Time Extended** **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604207

TACO BELL #24552

License Type: Permanent Food Service

4860 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 05/17/2021

Inspection Number: 3048411

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by rear exit in the red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5102178 RIVER PALM
 License Type: Permanent Food Service 100 RIVERFRONT DR, BRADENTON 34205

Inspection Date: 05/17/2021 Inspection Number: 3031600 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired for FL096039, expired 04/18/21 and for FL09638, expired 04/18/21.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5105342 RIVER STRAND GOLF AND COUNTRY CLUB TIKI BAR
 License Type: Permanent Food Service 7155 GRAND ESTUARY TRAIL, BRADENTON 34212

Inspection Date: 05/19/2021 Inspection Number: 3022173 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed two fryers in use without hood suppression system in back kitchen preparation area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5453159

G AND GS PIZZA

License Type: Mobile Food Dispensing Vehicle

14620 SW 50 ST, MIAMI 33175

Inspection Date: 04/28/2021

Inspection Number: 1227127

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near service window.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811527

OVATIONS FOOD SERVICES DR PHILLIPS CENTER KITCHEN

License Type: Catering

155 EAST ANDERSON ST, ORLANDO 32801

Inspection Date: 05/21/2021

Inspection Number: 1118264

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTESANO, MISTI

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5805732

BELLA NAPOLI

License Type: Permanent Food Service

750 S BLUFORD AVE., OCOEE 34761

Inspection Date: 05/17/2021

Inspection Number: 3039052

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Small next to hand sink area. **Repeat Violation** - From follow-up inspection 2021-05-17: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5905638

EASTERN PEARL RESTAURANT

License Type: Permanent Food Service

2959 VINELAND RD, KISSIMMEE 34746

Inspection Date: 04/21/2021

Inspection Number: 3077323

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

49-05-4

Observed: Flammables stored near a source of ignition. Various items stored near or at bottom of water heater, located in dry storage room.
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900789

INTERNATIONAL HOUSE OF PANCAKES -36#101

License Type: Permanent Food Service

6065 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34747

Inspection Date: 05/21/2021

Inspection Number: 3085199

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher located dumpster area behind grease container

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6213659

PAN FILOS

License Type: Permanent Food Service

656 S GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 05/19/2021

Inspection Number: 3069310

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

49-01-4

Flammables stored/debris present in kitchen area- pizza.For reporting purposes only. LP tank in pizza make area. Item removed. **Corrected On-Site**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Seminole County

License Number: 6903920

NEW PEKING BUFFET INC

License Type: Permanent Food Service

100 LIVE OAKS BLVD, CASSELBERRY 32707

Inspection Date: 05/21/2021

Inspection Number: 3084878

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

47-03-4

Breaker room used for storage of old racks and a large bin

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7404885

TACO BELL #24

License Type: Permanent Food Service

1408 BEVILLE RD, DAYTONA BCH 32114

Inspection Date: 05/17/2021

Inspection Number: 3084665

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

47-01-4

Cover to electrical panel not attached to panel. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401981

STROUDS BARBEQUE AND GRILL LLC

License Type: Permanent Food Service

2516 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 05/17/2021

Inspection Number: 3084886

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

-full/standard size propane, employee removed **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406465

LITTLE CAESARS

License Type: Permanent Food Service

328 E NEW YORK AVE, DELAND 32724

Inspection Date: 05/18/2021

Inspection Number: 3084939

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only. Pad lock n exterior door by bathrooms. **Corrected On-Site**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.