

**Collier County**

License Number: 2103107

TRATTORIA ABRUZZO

License Type: Permanent Food Service

2359 VANDERBILT BEACH RD #416, NAPLES 34109

Inspection Date: 05/25/2021

Inspection Number: 3065992

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PENN, BRIAN

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed six - 15 pound propane tanks inside kitchen to the left of the walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2332405 LITTLE CAESARS PIZZA  
 License Type: Permanent Food Service 827 SW 8 AVE, MIAMI 33130

Inspection Date: 05/28/2021 Inspection Number: 3085627 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to hand sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336495 PATE CREOL  
 License Type: Permanent Food Service 12997 W DIXIE HWY, NORTH MIAMI 33161

Inspection Date: 05/28/2021 Inspection Number: 3059797 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. <b>**Repeat Violation**</b> - From follow-up inspection 2021-04-26: On 4/26/21 at the time of callback inspection Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. <b>**Repeat Violation**</b> <b>**Time Extended**</b> - From follow-up inspection 2021-05-28: On 5/28/21 at the time of callback inspection observed propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. <b>**Repeat Violation**</b> - From follow-up inspection 2021-04-26: On 4/26/21 at the time of callback inspection Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. <b>**Repeat Violation**</b> <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hamilton County**

License Number: 3450017

REGIA TAQUERIA

License Type: Mobile Food Dispensing Vehicle

2959 NW CR 141, JENNINGS 32053

Inspection Date: 05/24/2021

Inspection Number: 1235898

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code    Observation

Violation Citation

48-04-4    Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Next to driver seat.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3700093

BECKYJACKS FOOD SHACK

License Type: Permanent Food Service

8070 CORTEZ BLVD, WEEKI WACHEE 34607

Inspection Date: 05/25/2021

Inspection Number: 3080294

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: TORRACO, MARIANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-04-4	- From initial inspection : Establishment operating with changed menu and/or increased seating without septic system approval for such change.  7 picnic table of 4 near fence: 27; Outside seats 20, Inside seats 27 Total 74 seats - From follow-up inspection 2021-05-25: Reviewed with Supervisor Christine Craig , Request AC **Admin Complaint**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
49-04-4	- From initial inspection : Establishment operating with changed menu and/or increased seating without septic system approval for such change. 32 seats in outside deck, 7 picnic tables with 42 seats on grass near fence, 4 chairs and a table in the grass With a total of 78 outside seats.  26 seats inside with 2 bar stools totaling 28 inside.  106 total seats **Repeat Violation** **Admin Complaint** - From follow-up inspection 2021-05-26: AC submitted on inspection of 5-26-2021. Reviewed with Supervisor Christine Craig . **Admin Complaint**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
49-04-4	Establishment operating with changed menu and/or increased seating without septic system approval for such change. 32 seats in outside deck, 7 picnic tables with 42 seats on grass near fence, 4 chairs and a table in the grass With a total of 78 outside seats.  26 seats inside with 2 bar stools totaling 28 inside.  106 total seats **Repeat Violation** **Admin Complaint**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Hillsborough County**

License Number: 3952632 CARNITAS DON ANDRES  
 License Type: Mobile Food Dispensing Vehicle 12120 US 41N, GIBSONTON 33534

Inspection Date: 05/28/2021 Inspection Number: 1230224 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HALILOVIC, ALEKSANDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Extinguisher stored on the floor in mobile unit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918729 LAZY GATOR  
 License Type: Permanent Food Service 102 SHELL POINT RD, RUSKIN 33570

Inspection Date: 05/27/2021 Inspection Number: 3085433 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SANDERS, CLEVELAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. Observed fire extinguisher stored on the floor on cook line. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3916593 THE VINEYARD TRATTORIA AND PIZZERIA  
 License Type: Permanent Food Service 250 APOLLO BEACH BLVD, APOLLO BEACH 33572

Inspection Date: 05/26/2021 Inspection Number: 3001705 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: SANDERS, CLEVELAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Operator hung fire extinguisher at designated location at time of inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912992 JIMMY'S TACOS  
 License Type: Permanent Food Service 1604 N 17 ST, TAMPA 33605

Inspection Date: 05/28/2021 Inspection Number: 3071508 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: HALILOVIC, ALEKSANDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher used door stop .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4100961

LARRY'S ROADSIDE RESTAURANT NORTH

License Type: Permanent Food Service

2555 27 AVE, VERO BEACH 32960

Inspection Date: 05/27/2021

Inspection Number: 3080018

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small table top Flat top present without hood. Grease on walls and ceiling tile above.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5150455

TAQUERIA MI REINA

License Type: Mobile Food Dispensing Vehicle

1880 63RD AVE E, BRADENTON 34203

Inspection Date: 05/24/2021

Inspection Number: 1233766

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
\*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6113557

OLLIES ON THE BEACH

License Type: Permanent Food Service

6438 CLARK STREET, HUDSON 34667

Inspection Date: 05/24/2021

Inspection Number: 3080385

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

49-04-4

- From initial inspection : Establishment increased seating without municipal sewer approval.  
60 seats outside and 26 seats inside. Total of 86 seats.  
Seating increase form emailed. - From follow-up inspection 2021-03-25: \*\*Time Extended\*\* - From follow-up inspection 2021-05-24: \*\*Time Extended\*\*

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.



**Pinellas County**

License Number: 6217567

JOEYS NEW YORK PIZZA III LLC

License Type: Permanent Food Service

30681 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 05/26/2021

Inspection Number: 3068220

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: COLE, GABRIELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by hand sink at entrance of kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by hand sink at entrance of kitchen. From follow-up inspection 2021-05-28: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Santa Rosa County**

License Number: 6701313

RUBY TUESDAY #4554

License Type: Permanent Food Service

4917 HWY 90, PACE 32571

Inspection Date: 05/28/2021

Inspection Number: 3085650

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HATLER, MATTHEW

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Outlet on right corner of expo line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6804572 THE WHISKEY BARREL  
 License Type: Permanent Food Service 15 S BLVD OF THE PRESIDENTS, SARASOTA 34236

Inspection Date: 05/26/2021 Inspection Number: 3074124 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: MCKEON, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One Lp tank storage in the stairwell. Manager placed the tank outside. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805221 THE ROSEMARY  
 License Type: Permanent Food Service 411 N. ORANGE AVE, SARASOTA 34236

Inspection Date: 05/27/2021 Inspection Number: 3082872 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MCKEON, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 5:Propane tanks stored in the dining room. Manager placed the tanks outside. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sumter County**

License Number: 7000603

BIG BASS GRILL AND LAKEFRONT RESORT

License Type: Permanent Food Service

965 COUNTY RD 439, LAKE PANASOFFKEE 33538

Inspection Date: 05/27/2021

Inspection Number: 3078293

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: COLE, GABRIELLE

Violation Code    Observation

Violation Citation

45-02-4    - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By front door and indoor bar.    - From follow-up inspection 2021-04-26: \*\*Time Extended\*\*    - From follow-up inspection 2021-05-27: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.