

Bay County

License Number: 1305147

ZAXBY'S

License Type: Permanent Food Service

9960 HUTCHISON BLVD, PANAMA CITY BEACH 32407

Inspection Date: 06/01/2021

Inspection Number: 3085722

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329123

RICKY AREPAS AND HOT DOGS

License Type: Catering

414 SW 22 AVE, MIAMI 33135

Inspection Date: 06/04/2021

Inspection Number: 1118478

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2318211

KENTUCKY FRIED CHICKEN

License Type: Permanent Food Service

20285 NW 2 AVE, MIAMI 33169

Inspection Date: 06/02/2021

Inspection Number: 3085798

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: STUBBS, CHRISTINE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed multiple boxes are in front of back kitchen door marked exit. **Repeat Violation**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hillsborough County

License Number: 3917390

MIDFLORIDA CREDIT UNION AMPHITHEATER AT THE FL STATE FAIR-EAST

License Type: Permanent Food Service

4802 US 301 N, TAMPA 33610

Inspection Date: 06/01/2021

Inspection Number: 3005024

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOWAL, KYLE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Stand C12.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605543

IN GOD HANDS CATERING

License Type: Catering

13026 PALM BEACH BLVD UNIT D, FORT MYERS 33905

Inspection Date: 06/02/2021

Inspection Number: 1116691

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JOHNSON, JONATHAN

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810266

CHINA BUFFET

License Type: Permanent Food Service

8255 INTERNATIONAL DR STE 124, ORLANDO 32819

Inspection Date: 06/03/2021

Inspection Number: 3085719

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked Exit door blocked with empty boxes For reporting purposes only. **Corrected On-Site** **Repeat Violation**

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pinellas County

License Number: 6215670

MOES SOUTHWEST GRILL #204

License Type: Permanent Food Service

2679 GULF TO BAY BLVD STE 590, CLEARWATER 33759

Inspection Date: 06/04/2021

Inspection Number: 3085723

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.