

Brevard County

License Number: 1506386

POLLO TROPICAL

License Type: Permanent Food Service

4335 W NORFOLK PKWY, WEST MELBOURNE 32904

Inspection Date: 06/08/2021

Inspection Number: 3086115

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: QUINONES, ANTONIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator call to request inspection due to Fire Suppression System Discharged. Unable to verified that Fire Suppression System Is Recharged. Operator indicates that Fire Department is schedule to inspect system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Cookline hood lights dangling down due to water and grease damage inside the lights due to Fire Suppression System Discharged. Ceiling light with water inside - rear of building back area Cookline right side. - From follow-up inspection 2021-06-09: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Cookline hood lights dangling down due to water and grease damage inside the lights due to Fire Suppression System Discharged. Ceiling light with water inside - rear of building back area Cookline right side.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506431

SHORE LANES/ MARIACHI LOCO MEXICAN BAR&GRILL

License Type: Permanent Food Service

600 N. COURTENAY PARKWAY, MERRITT ISLAND 32953

Inspection Date: 06/09/2021

Inspection Number: 3086103

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back stair leading to kitchen exit blocked,	61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Broward County

License Number: 1611948

THAI THAI & SUSHI BAR LLC

License Type: Permanent Food Service

1861 N PINE ISLAND RD, PLANTATION 33322

Inspection Date: 06/10/2021

Inspection Number: 3086004

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRADY, OSSIAN

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Observed rear exit door in customer throughfare blocked by rolling cart.

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Clay County

License Number: 2001197

TEE MARIE'S

License Type: Permanent Food Service

1100 MARTIN LUTHER KING JR BLVD, GREEN COVE SPRINGS 32043

Inspection Date: 06/08/2021

Inspection Number: 3015111

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
 One Propane tank located in storage room. Owner moved to vehicle to take home.
 Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3952969

LA CASA DEL TRIPLETON

License Type: Mobile Food Dispensing Vehicle

3224 W TAMPA BAY AVE, TAMPA 33611

Inspection Date: 06/11/2021

Inspection Number: 1232500

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored on floor in unit .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606976

SABOR DE MICHOACAN

License Type: Permanent Food Service

1501 ORTIZ AVE, FORT MYERS 33905

Inspection Date: 06/05/2021

Inspection Number: 3085576

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5428353

SONIC DRIVE-IN

License Type: Permanent Food Service

2312 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 06/07/2021

Inspection Number: 3085960

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DEMARTINI, JOSEPH

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes blocking back door exit.

61C-1.004(9) FAC Reporting: (9) Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Orange County

License Number: 5803158

GREENHOUSE CAFE

License Type: Permanent Food Service

2300 MAITLAND CENTER PKWY STE 120, MAITLAND 32751

Inspection Date: 06/07/2021

Inspection Number: 3066503

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LEEMIS, REBECCA

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
- stove, griddle, and press added and producing grease laden vapors as evidenced by stained ceiling tiles and vents. Observed operator frying bacon on press. No hood system. - From follow-up inspection 2021-06-07: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602384

HARBOR COVE

License Type: Permanent Food Service

1930 HARBORTOWN DR, FORT PIERCE 34946

Inspection Date: 06/11/2021

Inspection Number: 3086112

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Sushi bar has two small countertop fryers

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.