

Alachua County

License Number: 1102497

THE ATRIUM AT GAINESVILLE

License Type: Permanent Food Service

2431 NW 41ST ST, GAINESVILLE 32606

Inspection Date: 06/21/2021

Inspection Number: 3085912

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the silver K-class, the yellow indicator is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200688

GATOR'S DOCKSIDE LAKE CITY

License Type: Permanent Food Service

313 NW COMMONS LOOP, LAKE CITY 32055

Inspection Date: 06/24/2021

Inspection Number: 3087071

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the back door in kitchen. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2359766 ANGEL'S TIKI BAR
 License Type: Mobile Food Dispensing Vehicle 860 NE 79TH ST, MIAMI 33138

Inspection Date: 06/17/2021 Inspection Number: 1235394 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312223 SUSHI RUNNER
 License Type: Permanent Food Service 17331 S DIXIE HWY, PALMETTO BAY 33157

Inspection Date: 06/22/2021 Inspection Number: 3087085 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: AZPURUA, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 20 lbs. propane tank stored at office next to kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700973

CHINA KITCHEN

License Type: Permanent Food Service

11198 SPRING HILL DR, SPRING HILL 34609

Inspection Date: 06/25/2021

Inspection Number: 3087194

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.
Surge protector by reach in cooler, scorched outlets

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3918338

WILD N SMOKEY BBQ

License Type: Permanent Food Service

6032 N US HWY 41, APOLLO BEACH 33572

Inspection Date: 06/23/2021

Inspection Number: 3085657

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANDERS, CLEVELAND

Violation Code ObservationViolation Citation

49-05-4 Increased seating from 0 to 13. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917203

BAY GARDENS RETIREMENT VILLAGE

License Type: Permanent Food Service

1415 E 124TH AVE, TAMPA 33612

Inspection Date: 06/22/2021

Inspection Number: 3063966

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: JAIME, ANTONY

Violation Code ObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver Extinguisher by back door. - From follow-up inspection 2021-06-22: Observed k class fire extinguisher still in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216189

EL CARRIEL

License Type: Permanent Food Service

1215 N MARTIN LUTHER KING, CLEARWATER 33755

Inspection Date: 06/21/2021

Inspection Number: 3065050

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.