

Alachua County

License Number: 1103368 FORMAGGIO'S BISTRO & WINE BAR
 License Type: Permanent Food Service 2441 NW 43 ST #12, GAINESVILLE 32606

Inspection Date: 07/14/2021 Inspection Number: 3114314 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the K-class Siver fire extinguisher is in the lower red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103422 CHIPOTLE MEXICAN GRILL #2735
 License Type: Permanent Food Service 2231 NW 13 ST #100, GAINESVILLE 32609

Inspection Date: 07/16/2021 Inspection Number: 3129447 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the fire extinguisher by the back door is in the red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103428 ADAMS RIB CO
 License Type: Permanent Food Service 2109 NW 13TH ST, GAINESVILLE 32609

Inspection Date: 07/16/2021 Inspection Number: 3102335 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the red fire extinguisher on the way to the smoker, is in the red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305665

DENNYS

License Type: Permanent Food Service

2438 MARTIN LUTHER KING JR BLVD, PANAMA CITY 32405

Inspection Date: 07/15/2021

Inspection Number: 3127329

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class by kitchen door in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bradford County

License Number: 1400157

SONIC DRIVE IN #5185

License Type: Permanent Food Service

825 N TEMPLE AVE, STARKE 32091

Inspection Date: 07/16/2021

Inspection Number: 3106566

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DOTY, JOSEPH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher near back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502535

CHICK-FIL-A AT MELBOURNE SQUARE

License Type: Permanent Food Service

1700 W NEW HAVEN AVE STE 407, MELBOURNE 32904

Inspection Date: 07/12/2021

Inspection Number: 3126256

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: QUINONES, ANTONIO

Violation Code Observation

Violation Citation

47-03-4 Exposure of electrical wiring. For reporting purposes only.
 - ceiling light missing cover and exposed electrical wiring.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619626 LAS CARNITAS LATIN CUISINE
 License Type: Permanent Food Service 3305 N FEDERAL HWY, POMPANO BEACH 33064

Inspection Date: 07/15/2021 Inspection Number: 3087438 Inspection Type: Complaint Full Inspection Disposition: Emergency order recommended
 Inspector Name: STEUBER, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. In dry storage room, boxes and water stacked directly in front of the exit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623792 TACO BELL # 181
 License Type: Permanent Food Service 11431 W SAMPLE RD, CORAL SPRINGS 33065

Inspection Date: 07/12/2021 Inspection Number: 3097294 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door blocked with boxes and garbage container.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1611115 LITTLE CAESARS #207
 License Type: Permanent Food Service 277 S SR 7, MARGATE 33068

Inspection Date: 07/13/2021 Inspection Number: 3131004 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed Main kitchen rear exit door blocked by trash can and speed rack. Operator moved trash can and speed rack. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623408 BOKAMPER'S
 License Type: Permanent Food Service 3115 NE 32 AVE, FORT LAUDERDALE 33308

Inspection Date: 07/13/2021 Inspection Number: 3139658 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: DEJONG, STEVEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Small fryer on prep cooler by ice cream / dessert station. Fryer turned off and Chef moved unit next to grill under hood. Notified AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1613633 ALL SPICE
 License Type: Permanent Food Service 908 W SUNRISE BLVD, FORT LAUDERDALE 33311

Inspection Date: 07/15/2021 Inspection Number: 3110779 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. For extinguisher in kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620142 PEYTON'S PLACE BAR & GRILL
 License Type: Permanent Food Service 13400 W SUNRISE BLVD, SUNRISE 33323

Inspection Date: 07/16/2021 Inspection Number: 3132821 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRADY, OSSIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed certificates 098676 expired 02/19/21 and 098655 expired 02/19/21. Per previous inspections operator stated inspector was to come out Wednesday July 21, 2021. **Corrective Action Taken**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Collier County

License Number: 2102134 RITZ CARLTON-GUMBO LIMBO / SAND BAR
 License Type: Permanent Food Service 280 VANDERBILT BEACH RD, NAPLES 34108

Inspection Date: 07/14/2021 Inspection Number: 3122021 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PFENNING, BRUNO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Operator moved extinguishers to proper storage. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102825 KOMOON THAI SUSHI & CEVICHE
 License Type: Permanent Food Service 1575 PINE RIDGE RD UNIT 9, NAPLES 34109

Inspection Date: 07/14/2021 Inspection Number: 3139668 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DILLON, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a tank in the restaurant by the back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101030 THE DECK AT 560
 License Type: Permanent Food Service 560 S. COLLIER BLVD, MARCO ISLAND 34145

Inspection Date: 07/14/2021 Inspection Number: 3114939 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAVES, PETER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certification has expired.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Columbia County

License Number: 2200734

DUNKIN DONUTS

License Type: Permanent Food Service

14143 S US HWY 441, LAKE CITY 32024

Inspection Date: 07/12/2021

Inspection Number: 3091089

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302701	FRITANGA CANA BRAVA 3		
License Type: Permanent Food Service	2795 NW 7 ST, MIAMI 33125		
Inspection Date: 07/13/2021	Inspection Number: 3140100	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located inside ware washing area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2330336	BOTERO EMPLOYEE CAFETERIA		
License Type: Permanent Food Service	1435 BRICKELL AVE, MIAMI 33131		
Inspection Date: 07/16/2021	Inspection Number: 3140528	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FI 134042, expired 02/04/21; FI 134041, expired 02/04/21; on the 10th floor. FL 57334 expiration date 02/04/21, FL 13404 expiration date 02/04/21, expiration date 02/04/21, FL96424 02/04/21, FL 96425 expiration date 02/04/21, 7th floor. FI 017975, expires 07/24/20; FL 017974, expires 05/23/20, 18th floor. FI 057332, expired 2/4/21. FI 134041 2/4 21. FI 134042 2nd floor	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

License Number: 2330344	PFOUR SEASON HOTEL MIAMI BANQUET KITCHEN		
License Type: Permanent Food Service	1435 BRICKELL AVE, MIAMI 33131		
Inspection Date: 07/16/2021	Inspection Number: 3140531	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FI 134042, expired 02/04/21; FI 134041, expired 02/04/21; on the 10th floor. FL 57334 expiration date 02/04/21, FL 13404 expiration date 02/04/21, expiration date 02/04/21, FL96424 02/04/21, FL 96425 expiration date 02/04/21, 7th floor. FI 017975, expires 07/24/20; FL 017974, expires 05/23/20, 18th floor. FI 057332, expired 2/4/21. FI 134041 2/4 21. FI 134042 2nd floor	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2330346 EDGE
 License Type: Permanent Food Service 1435 BRICKELL AVE, MIAMI 33131

Inspection Date: 07/16/2021 Inspection Number: 3140529 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed establishment has a small grease fryer on a prep table with no hood suppression system above. Operator unplugged the grease fryer and moved it to the office during the inspection. As per operator, establishment will no longer use the grease fryer. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FI 134042, expired 02/04/21; FI 134041, expired 02/04/21; on the 10th floor. FL 57334 expiration date 02/04/21, FL 13404 expiration date 02/04/21, expiration date 02/04/21, FL96424 02/04/21,FL 96425 expiration date 02/04/21,7th floor. FI 017975, expires 07/24/20; FL 017974, expires 05/23/20, 18th floor. FI 057332, expired 2/4/21. FI 134041 2/4 21. FI 134042 2nd floor	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2316987 HOLIDAY INN DOWNTOWN PORT OF MIAMI
 License Type: Permanent Food Service 340 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 07/08/2021 Inspection Number: 3121359 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334071 SRIRACHA HOUSE
 License Type: Permanent Food Service 1502-1504 WASHINGTON AVENUE, MIAMI BEACH 33139

Inspection Date: 07/14/2021 Inspection Number: 3107792 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. At the time of inspection observed a pile of cardboard boxes blocking exit path leading to back kitchen exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334035

HILTON CABANA MIAMI BEACH - ALLISON RESTAURANT

License Type: Permanent Food Service

6261 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 07/12/2021

Inspection Number: 3120344

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expire boiler certificates since 4/24/2021.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2329414

MUNCHKIN CATERERS

License Type: Catering

5301 NW 23 AVE, MIAMI 33142

Inspection Date: 07/14/2021

Inspection Number: 1118695

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONCEPCION, ADRIEL

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Water temperature exceeds 210°f.
Observed water temperature at 250°f.
Also gallons of water is over 120 gallons of water.
Observed 200 gallons of water.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332914

HOOTERS RESTAURANT

License Type: Permanent Food Service

3301 CORAL WAY, MIAMI 33145

Inspection Date: 07/12/2021

Inspection Number: 3113272

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334768

CHIPOTLE MEXICAN GRILL #2707

License Type: Permanent Food Service

2200 SW 87 AVE, MIAMI 33165

Inspection Date: 07/13/2021

Inspection Number: 3108607

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ELDER, AUDREY

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Located across from walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.
Located across from walk in cooler. - From follow-up inspection 2021-07-14:
Portable fire extinguisher gauge in red zone. For reporting purposes only.
Located across from walk in cooler. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325445

ME LATTE CAFE

License Type: Permanent Food Service

4095 SW 137 AVE STE 1, MIAMI 33175

Inspection Date: 07/14/2021

Inspection Number: 3105655

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIBE, GUISELLA

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Observed exit blocked by oven.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330338

MC DONALDS

License Type: Permanent Food Service

12185 SW 26 STREET, MIAMI 33175

Inspection Date: 07/12/2021

Inspection Number: 3112626

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIBE, GUISELLA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only, located next to the ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615783 SWEET MAMA'S
 License Type: Permanent Food Service 1527 CESERY BLVD, JACKSONVILLE 32211

Inspection Date: 07/14/2021 Inspection Number: 3105130 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in storage room. For reporting purposes only. LP gas tank stored in rear storage area next to rear door.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 2613263 THE PERFECT PEAR
 License Type: Catering 3724 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 07/16/2021 Inspection Number: 1119492 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ARMSTRONG, RICO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tanks at front door entrance. Person in charge removed tanks from building. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613388 ZAXBY'S
 License Type: Permanent Food Service 1372 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 07/16/2021 Inspection Number: 3118876 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher by office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615037 CHURCH'S CHICKEN
 License Type: Permanent Food Service 1855 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 07/13/2021 Inspection Number: 3114166 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher by office area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher by office area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615029 FIREHOUSE SUBS
 License Type: Permanent Food Service 6337 ROOSEVELT BLVD STE 2, JACKSONVILLE 32244

Inspection Date: 07/09/2021 Inspection Number: 3089373 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELLEMARE, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. 110 outlet-hanging out of wall, located inside a cabinet in the dining area under the ice tea/beverage counter.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614563 LITTLE CAESARS
 License Type: Permanent Food Service 8614 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 07/12/2021 Inspection Number: 3128619 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Exit door block with trash can. Employee removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800632 OUTBACK STEAKHOUSE #1040
License Type: Permanent Food Service 45 PLAZA DR, PALM COAST 32137

Inspection Date: 07/14/2021 Inspection Number: 3113137 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At dishwashing area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800802 CHICK-FIL-A
License Type: Permanent Food Service 1000 PALM COAST PKWY NW, PALM COAST 32137

Inspection Date: 07/14/2021 Inspection Number: 3114151 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the fire extinguisher by the back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900863

CHILES MEXICAN RESTAURANT

License Type: Permanent Food Service

3247 W COLUMBUS DR, TAMPA 33607

Inspection Date: 07/14/2021

Inspection Number: 3127236

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exposed wiring over three compartment sink in kitchen at fuse box.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4101319

WILD THYME CATERING

License Type: Catering

1785 OLD DIXIE HWY, VERO BEACH 32960

Inspection Date: 07/16/2021

Inspection Number: 1119332

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3-4 small tanks stored in dry storage area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604213

BELLA MIA PIZZERIA

License Type: Permanent Food Service

5171 ORANGE GROVE BLVD, NORTH FORT MYERS 33903

Inspection Date: 07/14/2021

Inspection Number: 3107177

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed full mop bucket and full trash can blocking exit out of back of restaurant through prep kitchen. Operator moved bucket and trash can. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202642

OFF DUTY TAVERN

License Type: Permanent Food Service

1011 NE 14 ST, OCALA 34470

Inspection Date: 07/14/2021

Inspection Number: 3093245

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Behind bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300923 WENDY'S 4826
 License Type: Permanent Food Service 1409 NE JENSEN BEACH BLVD, JENSEN BEACH 34957

Inspection Date: 07/12/2021 Inspection Number: 3128252 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301515 BIG APPLE PIZZA
 License Type: Permanent Food Service 1858 JENSEN BEACH BLVD, JENSEN BEACH 34957

Inspection Date: 07/12/2021 Inspection Number: 3106462 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811180

THE ALFOND INN CATERING

License Type: Catering

300 EAST NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 07/13/2021

Inspection Number: 1119048

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. Certificate for one boiler on roof expired 2/2/20
Repeat Violation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5813268

THE ALFOND INN NOST

License Type: Permanent Food Service

300 NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 07/13/2021

Inspection Number: 3122936

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only, certificate for one boiler on roof expired 2/20/20
Repeat Violation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815133

ROLL THE WORLD

License Type: Permanent Food Service

18 N DOLLINS AVE K41, ORLANDO 32805

Inspection Date: 07/12/2021

Inspection Number: 3112264

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PLEICONES, KIM

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815134

YOUKRAVE

License Type: Permanent Food Service

18 N DOLLINS AVE K5, ORLANDO 32805

Inspection Date: 07/12/2021

Inspection Number: 3105868

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PLEICONES, KIM

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5815172 MARCO'S PIZZA
 License Type: Permanent Food Service 18 N DOLLINS AVE K20, ORLANDO 32805

Inspection Date: 07/12/2021 Inspection Number: 3099713 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815174 18 N DOLLINS AVE ORL
 License Type: Permanent Food Service 18 N DOLLINS AVE K11, ORLANDO 32805

Inspection Date: 07/12/2021 Inspection Number: 3124489 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. For 2 boilers for the entire facility Input rating 1,500,000	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815184 WING KINGZ, HAUTE BURGERS, BUENOS DIAS
 License Type: Permanent Food Service 18 N DOLLINS AVE K7, ORLANDO 32805

Inspection Date: 07/12/2021 Inspection Number: 3112091 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815216 ROLLING LOUD
 License Type: Permanent Food Service 18 N DOLLINS AVE K28, ORLANDO 32805

Inspection Date: 07/12/2021 Inspection Number: 3093582 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5804053 WENDY'S #4450
 License Type: Permanent Food Service 11734 E COLONIAL DR, ORLANDO 32817

Inspection Date: 07/14/2021 Inspection Number: 3114727 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JENKINS, JOSHUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by rolling cart filled with cardboard and by 4-wheel moving dolly. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807506 CAFE TU TU TANGO
 License Type: Permanent Food Service 8625 S INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/14/2021 Inspection Number: 3140115 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer being used in the pizza station.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer being used in the pizza station. - From follow-up inspection 2021-07-15: Fryer is still at location. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5855437 MR FROD PIZZA
 License Type: Mobile Food Dispensing Vehicle 5001 W SANDLAKE ROAD, VIN 1454, ORLANDO 32819

Inspection Date: 07/13/2021 Inspection Number: 1236404 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. By reach in cooler. Operator placed outside. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811591 MCDONALDS RESTAURANTS OF FLORIDA INC
 License Type: Permanent Food Service 10701 NARCOOSSEE RD, ORLANDO 32827

Inspection Date: 07/12/2021 Inspection Number: 3092203 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - trash can filled with boxes **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807780 CHEVYS FRESH MEX
 License Type: Permanent Food Service 12547 SR 535, LAKE BUENA VISTA 32830

Inspection Date: 07/13/2021 Inspection Number: 3092355 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Checked boiler certification has expired 3/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5808500 EL MERCADO DE CORONADO
 License Type: Permanent Food Service 1000 W BUENA VISTA DR, LAKE BUENA VISTA 328301000

Inspection Date: 07/14/2021 Inspection Number: 3134309 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical extension cord used for two waffle irons in the front service area(gluten free) For reporting purposes only. Engineering notify concerning electrical cord. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812945 THE OCOEE TACO COMPANY
 License Type: Permanent Food Service 40 TAYLOR ST, OCOEE 34761

Inspection Date: 07/15/2021 Inspection Number: 2986397 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: GREENE, MARVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer being used on table next to ice machine. **Repeat Violation** - From follow-up inspection 2021-06-14: **Time Extended** - From follow-up inspection 2021-07-15: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217553

CITY'S BISTRO

License Type: Permanent Food Service

695 CENTRAL AVE, ST. PETERSBURG 33701

Inspection Date: 07/16/2021

Inspection Number: 3127547

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILLEGAS, TATTYANA

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.
Panini press for cooking proteins. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211849

MARRIOTT KOKOMOS GRILL

License Type: Permanent Food Service

1201 GULF BLVD, CLEARWATER BEACH 33767

Inspection Date: 07/12/2021

Inspection Number: 3102843

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 3 out of 4 certificates expired.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Sarasota County

License Number: 6804413

HAMPTON INN SARASOTA

License Type: Permanent Food Service

5995 CATTLERIDGE BLVD, SARASOTA 34232

Inspection Date: 07/16/2021

Inspection Number: 3095790

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certificate expired 07/15/21.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

St. Lucie County

License Number: 6600768

TROPICAL SMOOTHIE CAFE

License Type: Permanent Food Service

6632 S FEDERAL HIGHWAY, PORT ST LUCIE 34952

Inspection Date: 07/13/2021

Inspection Number: 3102667

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407479

TIANO'S CUCINA ITALIANO

License Type: Permanent Food Service

1860 VICTORY CIRCLE, DAYTONA BEACH 32114

Inspection Date: 07/13/2021

Inspection Number: 3136559

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LARSON, SARAH

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Numerous boxes blocking back door to kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7404376

HEALTH TREE CAFE

License Type: Permanent Food Service

715 EARL ST, DAYTONA BEACH 32118

Inspection Date: 07/12/2021

Inspection Number: 3098409

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
-rear door unit on wall

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.