

Broward County

License Number: 1601468 MCDONALD'S #924
 License Type: Permanent Food Service 5835 HOLLYWOOD BLVD, HOLLYWOOD 33023

Inspection Date: 07/19/2021 Inspection Number: 3141629 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked with card board bin. Operator removed.For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621857 LITTLE CAESARS
 License Type: Permanent Food Service 12705 MIRAMAR PKWY, MIRAMAR 33027

Inspection Date: 07/21/2021 Inspection Number: 3112954 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher on wall by front door entrance in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625019 WENDY'S RESTAURANT 11670
 License Type: Permanent Food Service 6630 N SR 7, COCONUT CREEK 33073

Inspection Date: 07/20/2021 Inspection Number: 3112238 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - Observed rear exit door block with containers with sandwich buns **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618537 JULIAN BAGEL PLACE
 License Type: Permanent Food Service 11570 WILES RD # 6, CORAL SPRINGS 33076

Inspection Date: 07/19/2021 Inspection Number: 3120864 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621481 SPOONS GRILL
 License Type: Permanent Food Service 3987 NW 19 ST, LAUDERDALE LAKES 33311

Inspection Date: 07/19/2021 Inspection Number: 3101183 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At fire extinguisher at register	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625235 AC KITCHEN & LOUNGE
 License Type: Permanent Food Service 1870 SAWGRASS MILLS CIRCLE, SUNRISE 33323

Inspection Date: 07/16/2021 Inspection Number: 3124369 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BRADY, OSSIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boilers at 8th floor at Max 800,000 BTU/hr input rating and tanks supporting 500 Gallons. No boiler certifications available at time of inspection. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2331725 SUBPREME GRILL
 License Type: Permanent Food Service 15260 SW 280 ST, HOMESTEAD 33032

Inspection Date: 07/20/2021 Inspection Number: 3094353 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed crates blocking back exit door. Crates were moved. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333852 SHIRAZ BISTRO & MARKET
 License Type: Permanent Food Service 9630 SW 77 AVE, MIAMI 33156

Inspection Date: 07/22/2021 Inspection Number: 3114611 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the back door exit blocked by a garbage can **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325375 POPEYE'S FRIED CHICKEN #18
 License Type: Permanent Food Service 1000 N MIAMI BCH BLVD, NORTH MIAMI BEACH 331623828

Inspection Date: 07/21/2021 Inspection Number: 3124884 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage can blocking marked exit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333367 QUALITY INN MIAMI AIRPORT
 License Type: Permanent Food Service 3959 NW 79 AVE, MIAMI 33166

Inspection Date: 07/19/2021 Inspection Number: 3128850 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 080920, 123866. Expiration 11/27/2020.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2335934 CHILI'S
 License Type: Permanent Food Service 15200 SW 127 AVE, MIAMI 33177

Inspection Date: 07/21/2021 Inspection Number: 3135233 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed a gas water heating device on site with a water capacity of 130 gallons. Phone number 850-413-3723. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334104 EMPANADA HARRYS BAKERY AND CAFE
 License Type: Permanent Food Service 4009 SW 152ND AVE, MIAMI 33185

Inspection Date: 07/19/2021 Inspection Number: 3114872 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: URIBE, GUISELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only, located next to reach in freezer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615444 ONYX SPORTS BAR & LOUNGE
 License Type: Permanent Food Service 5611 NORWOOD AVE, JACKSONVILLE 32208

Inspection Date: 07/23/2021 Inspection Number: 3134283 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two large propane tanks in ice machine room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608119 BONO'S PIT BAR B Q
 License Type: Permanent Food Service 5903 NORWOOD AVE, JACKSONVILLE 322084345

Inspection Date: 07/23/2021 Inspection Number: 3106214 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large tank by Bbq pit near front counter. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614791 JIMMY JOHN'S GOURMET SANDWICHES STORE #2023
 License Type: Permanent Food Service 510 AIRPORT CIRCLE DRIVE SUITE 106, JACKSONVILLE 32218

Inspection Date: 07/20/2021 Inspection Number: 3142156 Inspection Type: Complaint Full Inspection Disposition: Emergency order recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by exit door near restrooms.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615487 STONER'S PIZZA JOINT NORTH JACKSONVILLE
 License Type: Permanent Food Service 11565 N MAIN ST STE 200, JACKSONVILLE 32218

Inspection Date: 07/20/2021 Inspection Number: 3142171 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Gas can next to hot water heater in closet.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615201

JERSEY MIKES SUBS

License Type: Permanent Food Service

8050 PHILIPS HWY, JACKSONVILLE 32256

Inspection Date: 07/21/2021

Inspection Number: 3115336

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.
Exit back door in kitchen block with trash

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3801129

SWEET FROG

License Type: Permanent Food Service

2932 US HWY 27 N, SEBRING 33870

Inspection Date: 07/19/2021

Inspection Number: 3126449

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At back exit by family bathroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917990 PHOLICIOUS
 License Type: Permanent Food Service 456 BRANDON TOWN CENTER DR STE9055, STE 9055, BRANDON 33511

Inspection Date: 07/22/2021 Inspection Number: 3103080 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed mini fryer in kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918338 WILD N SMOKEY BBQ
 License Type: Permanent Food Service 6032 N US HWY 41, APOLLO BEACH 33572

Inspection Date: 07/22/2021 Inspection Number: 3073939 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: COLEMAN, TONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	- From initial inspection : Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from x to y. For reporting purposes only. - From follow-up inspection 2021-05-21: Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. Time Extended** **Time Extended** - From follow-up inspection 2021-05-21: - From initial inspection : Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. - From follow-up inspection 2021-05-21: Flammables stored near a source of ignition. Increase in seating cite 49-05-4 (flammable stored near a source of ignition) modify to say 'increase in seating from 0 to 15. For reporting purposes only. Time Extended** **Time Extended** - From follow-up inspection 2021-07-22: **Admin Complaint**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3916998 CRY BABY CAFE
 License Type: Permanent Food Service 710 HARBOUR POST DR, TAMPA 33602

Inspection Date: 07/21/2021 Inspection Number: 3101647 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: COLEMAN, TONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed operator cooking bacon on flattop stove in front kitchen area without a hood system	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917863 HARVEST STATION
 License Type: Permanent Food Service 2712 W WATERS AVE, TAMPA 33614

Inspection Date: 07/20/2021 Inspection Number: 3108565 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ZHANG, JACKY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator reheat commercially packaged cooked meatball and cooked chicken on the electric griddle in kitchen. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3916664

HAAGEN DAZS NESTLE TOLL HOUSE

License Type: Permanent Food Service

8035 CITRUS PARK TOWN CENTER, TAMPA 33625

Inspection Date: 07/23/2021

Inspection Number: 3125815

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4508793 THE AMSTERDAMMER
 License Type: Permanent Food Service 110 S 5TH ST, LEESBURG 34748

Inspection Date: 07/21/2021 Inspection Number: 3142113 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHIPPER, DENIKA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Found on the floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606616

EUROPEAN AMERICAN BAKERY CAFE

License Type: Permanent Food Service

12450 METRO PKWY UNIT 1, FORT MYERS 33966

Inspection Date: 07/22/2021

Inspection Number: 3119949

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code

Observation

Violation Citation

45-02-4

Observed: Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in overcharged zone, located next to 6 burner stove and grill in kitchen.
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703850

CRAFTY CRAB OF TALLAHASSEE

License Type: Permanent Food Service

2226 NORTH MONROE ST, TALLAHASSEE 32303

Inspection Date: 07/23/2021

Inspection Number: 3087210

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation Code

Observation

Violation Citation

46-01-4 Marked exit towards the front of building to marked exit blocked. Observed manager unblock door. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5250753

FOOD WIZARDS

License Type: Mobile Food Dispensing Vehicle

7299 SE MARICAMP RD, OCALA 34472

Inspection Date: 07/23/2021

Inspection Number: 1237935

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near door needle at "recharge"

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5854837 CHEF JEAN CUISINE
 License Type: Mobile Food Dispensing Vehicle 1206 W ROBINSON ST, ORLANDO 32805

Inspection Date: 07/21/2021 Inspection Number: 1239365 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tank inside mobile unit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814599 POKE STOP
 License Type: Permanent Food Service 11565 UNIVERSITY BLVD SUITE #5, ORLANDO 32817

Inspection Date: 07/23/2021 Inspection Number: 3128425 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JENKINS, JOSHUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Bulk food cart in front of rear door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806164 BURGER KING 6962
 License Type: Permanent Food Service 12371 S ORANGE BLOSSOM TRL, ORLANDO 32837

Inspection Date: 07/23/2021 Inspection Number: 3101480 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5910787

DOMINO'S PIZZA #3232

License Type: Permanent Food Service

8687 W IRLO BRONSON HWY STE# 106, KISSIMMEE 34747

Inspection Date: 07/20/2021

Inspection Number: 3094739

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.

Kitchen exit door blocked by blue trays on cart. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013775 DUFFYS SPORTS GRILL
 License Type: Permanent Food Service 11588 US HWY 1, PALM BEACH GARDENS 33410

Inspection Date: 07/21/2021 Inspection Number: 3119670 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOLDMAN, BARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only. Operator posted during inspection. **Corrected On-Site**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6019984 LITTLE CAESARS
 License Type: Permanent Food Service 1449 S CONGRESS AVE #26, DELRAY BEACH 33445

Inspection Date: 07/20/2021 Inspection Number: 3089002 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit path blocked by boxes and bagged trash	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019404 FAIRFIELD INN & SUITES JUPITER
 License Type: Permanent Food Service 6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 07/16/2021 Inspection Number: 3090000 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 121021, 121022, 095111 all exp 3/5/2019 **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6003849 SINCLAIR'S
 License Type: Permanent Food Service 5 N A1A, JUPITER 33477

Inspection Date: 07/22/2021 Inspection Number: 3121747 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 099577, 099578, 098381 all exp 5/20/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6007350

SANDBAR

License Type: Permanent Food Service

5 N A1A, JUPITER 33477

Inspection Date: 07/22/2021

Inspection Number: 3127962

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.099577, 099578, 098381 exp 05/20/2021

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6007461

EMPLOYEE DINING AREA

License Type: Permanent Food Service

5 N A1A, JUPITER 33477

Inspection Date: 07/22/2021

Inspection Number: 3134288

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.099577, 099578, 098381 all exp 05/20/2021

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pasco County

License Number: 6113242

BAGELICIOUS AND MORE

License Type: Permanent Food Service

30032 SR 54 E, WESLEY CHAPEL 33543

Inspection Date: 07/19/2021

Inspection Number: 3119325

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLE, GABRIELLE

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. By back
exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6102819

HAROLD SELTZER'S STEAKHOUSE

License Type: Permanent Food Service

9409 US HWY 19 N # 493, PORT RICHEY 34668

Inspection Date: 07/19/2021

Inspection Number: 3140101

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: TORRACO, MARIANNE

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.3 speed
racks moved **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6252479	BIG MA'S BACKYARD BBQ & SOUL FOOD
License Type: Mobile Food Dispensing Vehicle	601 34 ST S, ST. PETERSBURG 33712

Inspection Date: 07/23/2021	Inspection Number: 1236347	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
-----------------------	--------------------	---------------------------

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Menu submitted indicates possible grease laden vapors. There is no hood or fire suppression system only exhaust fans.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 6216060	RONNIE PASTRAMIS DELI & CATERING INC
License Type: Permanent Food Service	10361 66 ST N, PINELLAS PARK 33782

Inspection Date: 07/23/2021	Inspection Number: 3088766	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILMOT, TASHARA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
-----------------------	--------------------	---------------------------

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. -next to prep sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	-----------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Polk County

License Number: 6307803

BROADWAY DINER

License Type: Permanent Food Service

1380 N BROADWAY AVE, BARTOW 33830

Inspection Date: 07/22/2021

Inspection Number: 3126682

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By cook line

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7404376 HEALTH TREE CAFE
 License Type: Permanent Food Service 715 EARL ST, DAYTONA BEACH 32118

Inspection Date: 07/20/2021 Inspection Number: 3098409 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. -rear door unit on wall - From follow-up inspection 2021-07-20:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406514 AAVTAR INDIAN CUISINE
 License Type: Permanent Food Service 318 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 07/21/2021 Inspection Number: 3097757 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. -unit on wall near exit door, type K. Manager states calling service provider.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Cleaning supplies next to water heater vent stack **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406999

HIDDEN TREASURES

License Type: Permanent Food Service

5993 RIDGEWOOD AVENUE, PORT ORANGE 32127

Inspection Date: 07/21/2021

Inspection Number: 3111752

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WOOD, JUSTIN

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Unit on wall in south dock server station

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.

Unit on wall in south dock server station - From follow-up inspection
2021-07-22: Operator called service provider

Complied** **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

2 propane tanks stored outside of office on bottom shelf. Manager had employee move tanks outside

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407232

RED BOWL

License Type: Permanent Food Service

1820 DUNLAWTON AVE #105, PORT ORANGE 32127

Inspection Date: 07/19/2021

Inspection Number: 3116939

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Bicycle partially blocked exit by bathrooms

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.