
Bay County

License Number: 1304051

WENDY'S OLD FASHIONED HAMBURGERS

License Type: Permanent Food Service

8720 THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 07/28/2021

Inspection Number: 3109217

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Red extinguisher by office door in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506081

BEACH EATZ

License Type: Permanent Food Service

24 NORTH ORLANDO AVE, SUITE G, COCOA BEACH 32931

Inspection Date: 07/27/2021

Inspection Number: 3098279

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top grill used to reheat precooked pita meat, reheat chicken from crock pot. Met Fire Marshall at location, he advised operator not to use for anything that produces vapors.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505528

GOLDEN DRAGON

License Type: Permanent Food Service

291 E EAU GALLIE BLVD, INDIAN HARBOUR BEACH 32937

Inspection Date: 07/28/2021

Inspection Number: 3098851

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation Code ObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1622985 HOT CHICKS - HOUSE OF CHICKEN
 License Type: Permanent Food Service 14816 PINES BLVD, PEMBROKE PINES 33027

Inspection Date: 07/29/2021 Inspection Number: 3098834 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by rear kitchen door in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624281 WINGSTOP RESTAURANT
 License Type: Permanent Food Service 15999 PINES BLVD SUITE 101, PEMBROKE PINES 33027

Inspection Date: 07/28/2021 Inspection Number: 3127004 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher on wall next to ice bucket in overcharged zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618815 CRACKER BARREL #268
 License Type: Permanent Food Service 1960 NW 150 AVE, PEMBROKE PINES 33028

Inspection Date: 07/29/2021 Inspection Number: 3107809 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEALY, VALENCIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed kitchen exit door blocked by discarded cardboard boxes in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625271 KONOS GELATO
 License Type: Permanent Food Service 3444 MAIN HWY #20, COCONUT GROVE 33133

Inspection Date: 07/27/2021 Inspection Number: 3118039 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked by trash can. Advised, the operator removed the trash can. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200721

JERSEY MIKE'S SUBS

License Type: Permanent Food Service

2888 W US 90 #105, LAKE CITY 32055

Inspection Date: 07/27/2021

Inspection Number: 3110055

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the front door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329607

ONE STOP ONLY CORNER CATERING

License Type: Catering

2795 W 78 ST, HIALEAH 33016

Inspection Date: 07/29/2021

Inspection Number: 1119301

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331400

TAQUERIA MORELIA

License Type: Permanent Food Service

1871 NE 8 ST, HOMESTEAD 33033

Inspection Date: 07/28/2021

Inspection Number: 3119392

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332360

MAIN KITCHEN & BAY CAFE

License Type: Permanent Food Service

485 BRICKELL AVE, MIAMI 33131

Inspection Date: 07/30/2021

Inspection Number: 3114598

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL 123105, Expired on 07/06/2018; FI 123107, Expired on 07/06/2018

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2331043

LITTLE CESARS PIZZA STORE #2288

License Type: Permanent Food Service

3715 WEST FLAGLER, MIAMI 33134

Inspection Date: 07/30/2021

Inspection Number: 3131426

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ALEJANDRO

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Empty boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2332152

SANTORINI

License Type: Permanent Food Service

101 OCEAN DRIVE, MIAMI BEACH 33139

Inspection Date: 07/29/2021

Inspection Number: 3119217

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336949

ZARI CAFE

License Type: Permanent Food Service

1200 WASHINGTON AVENUE, MIAMI BEACH 33139

Inspection Date: 07/27/2021

Inspection Number: 3085944

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Propane tanks were removed. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336495

PATE CREOL

License Type: Permanent Food Service

12997 W DIXIE HWY, NORTH MIAMI 33161

Inspection Date: 07/27/2021

Inspection Number: 3059797

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: SUAREZ, LEOPOLDO

Violation Code ObservationViolation Citation

48-04-4 - From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. **Repeat Violation** - From follow-up inspection 2021-04-26: On 4/26/21 at the time of callback inspection Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. **Repeat Violation** **Time Extended** - From follow-up inspection 2021-05-28: On 5/28/21 at the time of callback inspection observed propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. **Repeat Violation** - From follow-up inspection 2021-04-26: On 4/26/21 at the time of callback inspection Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks inside kitchen. **Repeat Violation** **Time Extended** - From follow-up inspection 2021-07-27: On 7/27/21 at the time of callback inspection observed 2 propane tanks inside kitchen. **Admin Complaint**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2357999

NATY BISTRO

License Type: Mobile Food Dispensing Vehicle

12248 SW 130 ST, MIAMI 33186

Inspection Date: 07/29/2021

Inspection Number: 1236949

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by hood overcharged. Also, observed extinguisher in recharge zone located by soda reach in cooler inside MFDV.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612424 BLU DINER
 License Type: Permanent Food Service 5868 NORWOOD AVE, JACKSONVILLE 32208

Inspection Date: 07/27/2021 Inspection Number: 3094495 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large tank in back storage area. Tank removed. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615293 9 BALL HEAVEN
 License Type: Permanent Food Service 2777 UNIVERSITY BLVD W UNIT 12, JACKSONVILLE 32217

Inspection Date: 07/27/2021 Inspection Number: 3128001 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Pathway in Hall leading from bar to along exterior of kitchen partially blocked with cabinet and cases of alcohol	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612964 RP MCMURPHYS
 License Type: Permanent Food Service 1183 BEACH BLVD, JACKSONVILLE BEACH 32250

Inspection Date: 07/28/2021 Inspection Number: 3143195 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Electrical wires running through ceiling on cook line. - From follow-up inspection 2021-07-28: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Electrical wires running through ceiling on cook line.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702626

WHATABURGER #25

License Type: Permanent Food Service

1313 N NEW WARRINGTON RD, PENSACOLA 32506

Inspection Date: 07/27/2021

Inspection Number: 3143979

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GARDNER, GREGORY

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
The back door was blocked by a stack of box's. The manager removed box's by throwing them out **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800748

FANCY SUSHI & GRILL

License Type: Permanent Food Service

5290 E STATE HWY 100 105, PALM COAST 32164

Inspection Date: 07/26/2021

Inspection Number: 3124426

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
By mop sink by the back door, extinguisher in red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3701226

TIJUANA FLATS

License Type: Permanent Food Service

12320 CORTEZ BLVD, BROOKSVILLE 34613

Inspection Date: 07/27/2021

Inspection Number: 3144008

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
By back door, undercharge

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3910272 BARBARA'S FAMILY RESTAURANT
 License Type: Permanent Food Service 514 S HWY 41, RUSKIN 33570

Inspection Date: 07/27/2021 Inspection Number: 3144017 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANDERS, CLEVELAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher stored on floor in dry storage area with gauge in the red.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher stored on the floor next to reach in freezer away from its designated area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912992 JIMMY'S TACOS
 License Type: Permanent Food Service 1604 N 17 ST, TAMPA 33605

Inspection Date: 07/28/2021 Inspection Number: 3071508 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HALILOVIC, ALEKSANDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher used door stop . From follow-up inspection 2021-07-28: Fire extinguisher still improperly stored. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606109

FIVE GUYS (CORAL WALK)

License Type: Permanent Food Service

1860 NE PINE ISLAND RD STE 210, CAPE CORAL 33909

Inspection Date: 07/28/2021

Inspection Number: 3090963

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOREHEAD, PHILIP

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only by trash cans. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5150455

TAQUERIA MI REINA

License Type: Mobile Food Dispensing Vehicle

1880 63RD AVE E, BRADENTON 34203

Inspection Date: 07/26/2021

Inspection Number: 1233766

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2021-07-26: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814684 WINGSTOP 1507
 License Type: Permanent Food Service 7628 UNIVERSITY BLVD, WINTER PARK 32792

Inspection Date: 07/27/2021 Inspection Number: 3128627 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only, Large propane tank by desk in kitchen 2 large propane tanks in hallway Operator moved 3 tanks to outside **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811332 CHIPOTLE MEXICAN GRILL #675
 License Type: Permanent Food Service 1700 W SANDLAKE RD, BELLE ISLE 32809

Inspection Date: 07/29/2021 Inspection Number: 3106532 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash can and boxes blocking back exit. Operator moved **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807506 CAFE TU TU TANGO
 License Type: Permanent Food Service 8625 S INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/29/2021 Inspection Number: 3144437 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer at the pizza station. - From follow-up inspection 2021-07-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer at the pizza station.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5812406 MAMA ROMANO'S
 License Type: Permanent Food Service 13802 LANDSTAR BLVD #101, ORLANDO 32824

Inspection Date: 07/26/2021 Inspection Number: 3119706 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800816 AMERICAN KITCHEN
 License Type: Permanent Food Service 1905 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830

Inspection Date: 07/30/2021 Inspection Number: 3114034 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed electrical wires exposed on the wall face plate cover missing, engineering notify. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808495 CORONADO SPGS CONVENTION CENTER
 License Type: Permanent Food Service 1001 W BUENA VISTA DR, LAKE BUENA VISTA 32830

Inspection Date: 07/28/2021 Inspection Number: 3092954 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certifications expired 7/18/2021 spoke to engineering Manager will notify Reddy Creek on the status. **Corrective Action Taken**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5808498 COMMISSARY KITCHEN CORONADO
 License Type: Catering 1000 W BUENA VISTA DR, LAKE BUENA VISTA 32830

Inspection Date: 07/28/2021 Inspection Number: 1118761 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certifications expired 7/18/2021 spoke to engineering Manager will notify Reddy Creek on the status. **Corrective Action Taken**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5808499

MAYA GRILL CORONADO SPRINGS

License Type: Permanent Food Service

1000 W BUENA VISTA DR, LAKE BUENA VISTA 328301000

Inspection Date: 07/28/2021

Inspection Number: 3089391

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed boiler certifications expired 7/18/2021 spoke to engineering Manager will
notify Reddy Creek on the status **Corrective Action Taken**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5808513

SIESTA'S POOL BAR

License Type: Permanent Food Service

1000 W BUENA VISTA DR, LAKE BUENA VISTA 328301000

Inspection Date: 07/28/2021

Inspection Number: 3089376

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed boiler certifications expired 7/18/2021 spoke to engineering Manager will
notify Reddy Creek on the status.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6004547 PICANHA BRAZIL STEAKHOUSE
 License Type: Permanent Food Service 22797 SR 7, BOCA RATON 33428

Inspection Date: 07/27/2021 Inspection Number: 3113030 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Class K on ground under HWS next to rear exit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020527 LA PERRADA DEL GORDO BOCA
 License Type: Permanent Food Service 23039 SR 7, BOCA RATON 33428

Inspection Date: 07/29/2021 Inspection Number: 3107490 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020095 LAQUINTA INN
 License Type: Permanent Food Service 34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 07/30/2021 Inspection Number: 3101214 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.086671 exp 4/15/2017	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6022414 DADS FAVORITE BURGERS & PIES
 License Type: Permanent Food Service 33 SE 3 AVENUE #6, DELRAY BEACH 33483

Inspection Date: 07/26/2021 Inspection Number: 3136678 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6022416

BONA BONA ICE CREAM

License Type: Permanent Food Service

33 SE 3 AVE #5, DELRAY BEACH 33483

Inspection Date: 07/27/2021

Inspection Number: 3136610

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6214994

EASTERN CHINA PEARL LLC

License Type: Permanent Food Service

3313 CENTRAL AVENUE, ST. PETERSBURG 33713

Inspection Date: 07/29/2021

Inspection Number: 3144864

Inspection Type: Complaint Full

Inspection Disposition: Emergency Order Callback Not Complied

Inspector Name: VILLEGAS, TATTYANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Under wok station - From follow-up inspection 2021-07-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Under wok station - From follow-up inspection 2021-07-29: **Time Extended** - From follow-up inspection 2021-07-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Under wok station	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905120	BUFFALO WILD WINGS 556
License Type: Permanent Food Service	1670 RINEHART RD, SANFORD 32771
Inspection Date: 07/26/2021	Inspection Number: 3118314
Inspector Name: ANGEL, TERRY	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by boxes and bagged garbage.
	<u>Violation Citation</u> 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905161	THE ALLEY AND FUEL
License Type: Permanent Food Service	114 S PARK AVE, SANFORD 32771
Inspection Date: 07/28/2021	Inspection Number: 3120788
Inspector Name: ANGEL, TERRY	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. By bar.
	<u>Violation Citation</u> 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6902174	WENDY'S #4473
License Type: Permanent Food Service	3717 S ORLANDO BLVD, SANFORD 32773
Inspection Date: 07/30/2021	Inspection Number: 3114827
Inspector Name: THORNCROFT, ROBERT	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher at the end of the line is in the red
	<u>Violation Citation</u> 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905190	WINGSTOP
License Type: Permanent Food Service	120 W LAKE MARY BLVD, SANFORD 32773
Inspection Date: 07/26/2021	Inspection Number: 3109837
Inspector Name: THORNCROFT, ROBERT	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
47-03-4	The ice machine is plugged into a extension cord that leads across the walk way on the floor. A unused receptical is located behind the machine.
	<u>Violation Citation</u> 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6605152 A TOUCH OF BROOKLYN
 License Type: Permanent Food Service 2331 S US HWY 1, FORT PIERCE 34982

Inspection Date: 07/28/2021 Inspection Number: 3140089 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. On back caged area. Door is blocked by miscellaneous thing now and door is boarded due to door being broken.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602062 PUEBLO VIEJO
 License Type: Permanent Food Service 291 SW PORT ST LUCIE BLVD, PORT ST LUCIE 34984

Inspection Date: 07/26/2021 Inspection Number: 3125003 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HYNES, MONICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407540

TIPSY TACO CANTINA

License Type: Permanent Food Service

746 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 07/27/2021

Inspection Number: 3128833

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke not under hood with suppression system.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.