

Alachua County

License Number: 1102750

HILTON UNVIERISTY OF FLORIDA CONFERENCE CENTER GAINESVILLE

License Type: Permanent Food Service

1714 SW 34 ST, GAINESVILLE 32607

Inspection Date: 08/17/2021

Inspection Number: 3128224

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed the silver fire extinguisher, indicator in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1507053

OCEANSIDE DISTILLERY

License Type: Permanent Food Service

240 W CENTRAL BLVD, CAPE CANAVERAL 32920

Inspection Date: 08/18/2021

Inspection Number: 3149254

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621678	END ZONE RESTAURANT & GRILL		
License Type: Permanent Food Service	5601 PEMBROKE RD, HOLLYWOOD 33023		
Inspection Date: 08/16/2021	Inspection Number: 3093549	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Breaker box, when operator turn on hot water breaker , sparks inside breaker box appears. Operator turned off hot water breaker. Notified Fire Marshall Megan.*Corrective Action Taken** **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1615997	SHALAMAS ROTISHOP		
License Type: Permanent Food Service	1432 N SR 7, MARGATE 33063		
Inspection Date: 08/18/2021	Inspection Number: 3112298	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-01-4	Flammables stored/debris present in kitchen and prep room. For reporting purposes only. Manager put out side **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	
License Number: 1619902	SYLVAIN'S CAFE LLC		
License Type: Permanent Food Service	1634 SE 3 CT, DEERFIELD BEACH 33441		
Inspection Date: 08/20/2021	Inspection Number: 3093157	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located on cook line	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1619152	COCHIC		
License Type: Permanent Food Service	1631 SE 3 CT, DEERFIELD BEACH 33441-4418		
Inspection Date: 08/20/2021	Inspection Number: 3124501	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Charlotte County

License Number: 1801657

HOLIDAY INN EXPRESS

License Type: Permanent Food Service

24440 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 08/18/2021

Inspection Number: 3120750

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Columbia County

License Number: 2200676

BW BLACKSMITH

License Type: Permanent Food Service

419 SW FL 247 STE 101, LAKE CITY 32025

Inspection Date: 08/16/2021

Inspection Number: 3117220

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. On pillar near back door across from dry storage shelf.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2332853

SUAREZ BBQ INC

License Type: Permanent Food Service

12963 W OKEECHOBEE RD STE 5-6, HIALEAH GARDENS 33018

Inspection Date: 08/19/2021

Inspection Number: 3102540

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335060

ZUUK MEDITERRANEAN KITCHEN

License Type: Permanent Food Service

1250 SOUTH MIAMI AVENUE, #105, MIAMI 33130

Inspection Date: 08/16/2021

Inspection Number: 3148903

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near back door. - From follow-up inspection 2021-08-18: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312394

LIZ CAFE

License Type: Permanent Food Service

2600 W FLAGLER ST, MIAMI 33135

Inspection Date: 08/19/2021

Inspection Number: 3118916

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Stove not underneath the hood cooking in progress.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335289

MINA BISTRO

License Type: Permanent Food Service

63 NW 9 ST, MIAMI 33136

Inspection Date: 08/19/2021

Inspection Number: 3096546

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed in the kitchen: the establishment has a small double portable fryer underneath a hood with no hood suppression system installed. Observed employee frying empanadas in the small double portable fryer during the inspection.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332212

LEMONI CAFE INC

License Type: Permanent Food Service

4600 NE 2 AVE SUITE 8, MIAMI 33137

Inspection Date: 08/20/2021

Inspection Number: 3113040

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEYBA, JAMES

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322453

POLLO TROPICAL # 3

License Type: Permanent Food Service

8975 S DIXIE HWY, MIAMI 33156

Inspection Date: 08/19/2021

Inspection Number: 3094106

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICO, JORGE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed emergency exit door blocked by garbage can **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917767

TACO BELL #6146

License Type: Permanent Food Service

13032 US 301 S, RIVERVIEW 33578

Inspection Date: 08/19/2021

Inspection Number: 3134618

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANDERS, CLEVELAND

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
 -Observed fire extinguisher gauge in red, located near management's office.
 - Observed fire extinguisher gauge in the red located at rear exterior door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912268

THINH AN KITCHEN & TOFU

License Type: Permanent Food Service

8104 W WATERS AVE, TAMPA 33615

Inspection Date: 08/18/2021

Inspection Number: 3127094

Inspection Type: Routine - Food

Inspection Disposition: Emergency Order Callback Not Complied

Inspector Name: EHLERS, MICHAEL

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**
 - From follow-up inspection 2021-08-18: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**
 - From follow-up inspection 2021-08-18: **Time Extended** - From follow-up inspection 2021-08-19: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**
 - From follow-up inspection 2021-08-18: **Time Extended** - From follow-up inspection 2021-08-19: **Time Extended** - From follow-up inspection 2021-08-19: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hillsborough County

License Number: 3916003

MET LIFE CAFE

License Type: Permanent Food Service

18205 CRANE NEST DR, TAMPA 33647

Inspection Date: 08/16/2021

Inspection Number: 3111678

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 400 gallon electric water heater for the cafeteria. The operating BTUs 126,000/ hr

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4603564

HARDEES

License Type: Permanent Food Service

4900 PALM BEACH BLVD, FORT MYERS 33905-3230

Inspection Date: 08/17/2021

Inspection Number: 3128464

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by mop sink room in the red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300932

TACO BELL #24537

License Type: Permanent Food Service

2958 NW FEDERAL HWY, JENSEN BEACH 34957

Inspection Date: 08/17/2021

Inspection Number: 3094458

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By Walk-in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5815119 LA BOULANGERIE
 License Type: Permanent Food Service 50 S ROSALIND AVE STE C, ORLANDO 32801

Inspection Date: 08/18/2021 Inspection Number: 3130327 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JENKINS, JOSHUA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by food carts. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815013 LECHONERA SAJOMA
 License Type: Permanent Food Service 1919 MCCOY RD, ORLANDO 32809

Inspection Date: 08/17/2021 Inspection Number: 3110898 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Mop bucket in front of back door near bathrooms. Operator moved **Corrected On-Site** - From follow-up inspection 2021-08-17: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Mop bucket in front of back door near bathrooms. Operator moved **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808436 SUBWAY #632
 License Type: Permanent Food Service 10924 E COLONIAL DR, ORLANDO 32817

Inspection Date: 08/16/2021 Inspection Number: 3100499 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Metal bar on at kitchen exit door during hours of operation.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5813924

MCDONALD'S #3896

License Type: Permanent Food Service

6875 SANDLAKE RD, ORLANDO 32819

Inspection Date: 08/19/2021

Inspection Number: 3096569

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by gray trash bin by the back done ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911441

PEI WEI FRESH KITCHEN #0258

License Type: Permanent Food Service

6250 W IRLO BRONSON MEMORIAL HWY, CELEBRATION 34747

Inspection Date: 08/16/2021

Inspection Number: 3120593

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911501

TIJUANA FLATS

License Type: Permanent Food Service

4100 13TH ST, ST. CLOUD 34769

Inspection Date: 08/19/2021

Inspection Number: 3089927

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: NIEVES, RAFAEL

Violation Code ObservationViolation Citation46-01-4 - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**
- From follow-up inspection 2021-08-19: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6011675

LAZY LOGGERHEAD CAFE

License Type: Permanent Food Service

601 S A1A, JUPITER 33477

Inspection Date: 08/18/2021

Inspection Number: 3120085

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.electrical cover plate missing/kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805141

PATRICK'S 1481

License Type: Permanent Food Service

1481 MAIN STREET, SARASOTA 34236

Inspection Date: 08/19/2021

Inspection Number: 3100927

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MCKEON, MICHAEL

Violation Code Observation

Violation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Exposed electrical wires above door inside walk-in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-03-4 - From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Exposed electrical wires above door inside walk-in cooler. -
From follow-up inspection 2021-08-20: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6605090

CRISPY FISH AND CHICKEN INC

License Type: Permanent Food Service

3205 SOUTH US HIGHWAY 1, FORT PIERCE 34982

Inspection Date: 08/17/2021

Inspection Number: 3122888

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	<p>Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two burners on back prep table</p> <p>Manger says he is going to dispose of them. Spoke with AHJ they will send someone today or tomorrow to make sure they have been removed.</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
45-04-4	<p>- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two burners on back prep table</p> <p>Manger says he is going to dispose of them. Spoke with AHJ they will send someone today or tomorrow to make sure they have been removed. - From follow-up inspection 2021-08-18: Managers states fire marshal came and said it was ok to keep burners on premises. **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Suwannee County

License Number: 7100282

ITALIAN PIZZERIA AND RESTAURANT JO INC

License Type: Permanent Food Service

602 HOWARD ST W, LIVE OAK 32064

Inspection Date: 08/18/2021

Inspection Number: 3123251

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by back door next to dish machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406575

THE BULLDOG PUB

License Type: Permanent Food Service

577 DELTONA BLVD STE1, DELTONA 32725

Inspection Date: 08/19/2021

Inspection Number: 3117821

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Establishment uses flat top grill to cook burgers. Notified Lisa Nadeau, Deltona Fire Inspector, 386-878-8656. Left Voice Message. - From follow-up inspection 2021-08-19: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Establishment uses flat top grill to cook burgers. Notified Lisa Nadeau, Deltona Fire Inspector, 386-878-8656. Left Voice Message.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.