

Alachua County

License Number: 1102998

COLD STONE CREAMERY #559

License Type: Permanent Food Service

3433 ARCHER RD #A3, GAINESVILLE 32608

Inspection Date: 08/24/2021

Inspection Number: 3131904

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near entrance to kitchen area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1617069		EL TAMARINDO COAL FIRED PIZZA LLC	
License Type: Permanent Food Service		712 ATLANTIC SHORES BLVD, HALLANDALE 33009	
Inspection Date: 08/27/2021	Inspection Number: 3091120	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building in storage room.For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1607264		BURGER KING 75	
License Type: Permanent Food Service		1030 W HALLANDALE BEACH BLVD, HALLANDALE BEACH 33009	
Inspection Date: 08/27/2021	Inspection Number: 3152633	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Operator moved bin and card board boxes. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1653125		PANADICTO	
License Type: Mobile Food Dispensing Vehicle		5817 SW 21 STREET, WEST PARK 33023	
Inspection Date: 08/24/2021	Inspection Number: 1239208	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621962		SAL'S ITALIAN RISTORANTE	
License Type: Permanent Food Service		14535 SW 5 ST, PEMBROKE PINES 33027	
Inspection Date: 08/23/2021	Inspection Number: 3106724	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MARTINEZ, RHEANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only. Observed fire extinguisher in overcharged zone across from pizza counter next to portable Ac unit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1601072

LIGHTHOUSE POINT YACHT CLUB

License Type: Permanent Food Service

2701 NE 42ND ST, LIGHTHOUSE POINT 33064

Inspection Date: 08/25/2021

Inspection Number: 3102753

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Located outside of dry storage bar room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001197

TEE MARIE'S

License Type: Permanent Food Service

1100 MARTIN LUTHER KING JR BLVD, GREEN COVE SPRINGS 32043

Inspection Date: 08/24/2021

Inspection Number: 3117950

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
One propane tank located on back storage closet. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200600

SONIC DRIVE IN OF LAKE CITY

License Type: Permanent Food Service

1333 SW MAIN BLVD, LAKE CITY 32025

Inspection Date: 08/24/2021

Inspection Number: 3096382

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on end of wall of cooks line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326374		CAFETERIA LA SAGUERA	
License Type: Permanent Food Service		3001 W 12 AVE #6, HIALEAH 33012	
Inspection Date: 08/24/2021	Inspection Number: 3108160	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed emergency exit door blocked by un-used reach in cooler. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336365		LANA'S PERRY WINGS	
License Type: Permanent Food Service		18553 NW 27 AVE, MIAMI GARDENS 33056	
Inspection Date: 08/25/2021	Inspection Number: 3104172	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: STUBBS, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by mop bucket.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326517		PREMOS DELI	
License Type: Permanent Food Service		1 SE 3 AVE STE 160, MIAMI 33131	
Inspection Date: 08/27/2021	Inspection Number: 3100031	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has a portable double grease fryer in the kitchen by the walk in cooler. Observed a flat	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327916		STAND 117	
License Type: Permanent Food Service		601 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 08/27/2021	Inspection Number: 3124898	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. exp 01/10/2020	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2333007	STAND 116		
License Type: Permanent Food Service	601 BISCAYNE BLVD, MIAMI	33132	
Inspection Date: 08/27/2021	Inspection Number: 3094751	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. exp 01/10/2020.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334249	CART 120		
License Type: Permanent Food Service	601 BISCAYNE BLVD, MIAMI	33132	
Inspection Date: 08/27/2021	Inspection Number: 3126406	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Exp 01/10/2020.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334836	CART 120		
License Type: Permanent Food Service	601 BISCAYNE BLVD, MIAMI	33132	
Inspection Date: 08/27/2021	Inspection Number: 3108217	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334870	CART 116		
License Type: Permanent Food Service	601 BISCAYNE BLVD, MIAMI	33132	
Inspection Date: 08/27/2021	Inspection Number: 3089661	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Exp 01/10/2020.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2334871		CART 116	
License Type: Permanent Food Service		601 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 08/27/2021	Inspection Number: 3133256	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Exp. 01-10-2020.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334956		CART 115	
License Type: Permanent Food Service		601 BISCAYNE BOULEVARD, MIAMI 33132	
Inspection Date: 08/27/2021	Inspection Number: 3089686	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Exp 01/10/2020.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2330151		COLD STONE CREAMERY	
License Type: Permanent Food Service		9059 S DIXIE HWY, MIAMI 33156	
Inspection Date: 08/24/2021	Inspection Number: 3147279	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed s garbage can in front of the exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2331271		HI-POT	
License Type: Permanent Food Service		1665 SW 107TH AVE, MIAMI 33165	
Inspection Date: 08/24/2021	Inspection Number: 3151746	Inspection Type: Complaint Full	Inspection Disposition: Emergency order recommended
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes of supplies and ladder stored blocking exit door near customers bathroom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2614199

HOT WOK

License Type: Permanent Food Service

7200 NORMANDY BLVD #8, JACKSONVILLE 32205

Inspection Date: 08/26/2021

Inspection Number: 3127079

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door ****Repeat Violation**** - From follow-up inspection 2021-08-26: Same

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611323

CROSS CREEK BBQ & STEAK

License Type: Permanent Food Service

850 S LANE AVE, JACKSONVILLE 322054705

Inspection Date: 08/23/2021

Inspection Number: 3131081

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Entrance to kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2652158

CHABELITAS MEXICAN CUISINE

License Type: Mobile Food Dispensing Vehicle

5960 RICHARD ST, JACKSONVILLE 32216

Inspection Date: 08/27/2021

Inspection Number: 1237732

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Mobile unit has a small fryer that is not under the hood system when in use.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615567		MEDITERRANEAN GRILL	
License Type: Permanent Food Service		5230 BAYMEADOWS RD STE 10, JACKSONVILLE 32217	
Inspection Date: 08/25/2021	Inspection Number: 3128086	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: JEFFERS, MARY-BETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank,stored in hallway area near restrooms. Operator removed propane tank and placed outside **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614540		BUFFALO WILD WINGS #293	
License Type: Permanent Food Service		13230 CITY STATION DRIVE, JACKSONVILLE 32218	
Inspection Date: 08/24/2021	Inspection Number: 3132098	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit through liquor storage area is blocked by empty beer kegs. Kegs moved. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2609764		THAI BLOSSOM BISTRO	
License Type: Permanent Food Service		10916 ATLANTIC BLVD #24, JACKSONVILLE 32225	
Inspection Date: 08/25/2021	Inspection Number: 3108770	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door in hallway next to unisex bathroom is blocked with mop buckets and crates in a manner that a person would have to move the items to exit the building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3910962		KENTUCKY FRIED CHICKEN	
License Type: Permanent Food Service		3102 E COLLEGE AVE, RUSKIN 335705225	
Inspection Date: 08/27/2021	Inspection Number: 3118669	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANDERS, CLEVELAND			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Red fire extinguisher located at entrance of dry storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3912480		CHINA CHEN	
License Type: Permanent Food Service		4880 SUN CITY CENTER BLVD, SUN CITY CENTER 33573	
Inspection Date: 08/24/2021	Inspection Number: 3115178	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANDERS, CLEVELAND			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed portable fire extinguisher behind front counter with gauge in the red.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3917454		POPEYES	
License Type: Permanent Food Service		10551 BIG BEND RD, RIVERVIEW 33578	
Inspection Date: 08/26/2021	Inspection Number: 3105433	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANDERS, CLEVELAND			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Operator placed item at designated location at time of inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3911007 NEBRASKA CAFETERIA
 License Type: Permanent Food Service 905 E 20 AVE, TAMPA 33605

Inspection Date: 08/27/2021 Inspection Number: 3100408 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: SMITH, MATTHEW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Y back door. - From follow-up inspection 2021-08-27: By back door. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Y back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3904651 SALEM'S FRESH EATS
 License Type: Permanent Food Service 2015 N 50TH STREET, TAMPA 33619

Inspection Date: 08/24/2021 Inspection Number: 3107019 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, MATTHEW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By walk in cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600111 SHORES BAR & GRILL
 License Type: Permanent Food Service 12156 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 08/23/2021 Inspection Number: 3095319 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by swinging doors entering the kitchen is in the red. Notified operator.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603808 KENTUCKY FRIED CHICKEN
 License Type: Permanent Food Service 4336 PALM BEACH BLVD, FORT MYERS 339053415

Inspection Date: 08/27/2021 Inspection Number: 3134882 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by back exit door in the red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603582 ADAMS FOOD INC
 License Type: Permanent Food Service 8 NE PINE ISLAND RD, CAPE CORAL 33909

Inspection Date: 08/25/2021 Inspection Number: 3092067 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MOREHEAD, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703835

MIRANDA'S

License Type: Permanent Food Service

5323 W TENNESSEE ST, TALLAHASSEE 32304

Inspection Date: 08/26/2021

Inspection Number: 3130724

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CHARLES, BRENDA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105676

CULVERS

License Type: Permanent Food Service

3515 CORTEZ RD, BRADENTON 34210

Inspection Date: 08/26/2021

Inspection Number: 3152636

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AUBIN, GARY

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Observed cardboard blocking the back door by dry storage.
Operator removed cardboard. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202959

LOCOS GRILL AND PUB

License Type: Permanent Food Service

3105 EAST SILVER SPRINGS BLVD, OCALA 34470

Inspection Date: 08/23/2021

Inspection Number: 3092033

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher located near back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5815358		GATLIN HALL BREWING	
License Type: Permanent Food Service		4721 S. ORANGE AVE, ORLANDO 32806	
Inspection Date: 08/27/2021	Inspection Number: 3084715	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VAZQUEZ, JULITZA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5812518		CAPTAIN DS UNION PARK	
License Type: Permanent Food Service		10414 EAST COLONIAL DRIVE, UNION PARK 32817	
Inspection Date: 08/24/2021	Inspection Number: 3097359	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VAZQUEZ, JULITZA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Garbage cans blocking the back exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811105		LA QUINTA INN	
License Type: Permanent Food Service		5825 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 08/26/2021	Inspection Number: 3136324	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate has expired F1130055 5/16/2020	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Orange County

License Number: 5810902

HOFFNER CATERING & SUPPLY

License Type: Catering

4880 B DISTRIBUTION CT UNIT 1-2, ORLANDO 32822

Inspection Date: 08/24/2021

Inspection Number: 1119106

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Grill on top prep table across cook line . **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Grill on top prep table across cook line . **Repeat Violation** - From	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911130 ABUELOS MEXICAN FOOD EMBASSY
 License Type: Permanent Food Service 2431 W OSCEOLA PARKWAY, KISSIMMEE 34741

Inspection Date: 08/23/2021 Inspection Number: 3109683 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only.- above 3 bin sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.- above 3 bin sink - From follow-up inspection 2021-08-24: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911120 ANTOJOS BORICUAS II
 License Type: Permanent Food Service 2914 PLEASANT HILL RD, KISSIMMEE 34746

Inspection Date: 08/24/2021 Inspection Number: 3105029 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: FERTIL, SYLVERST

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019350		MACARTHUR'S	
License Type: Permanent Food Service		4000 RCA BLVD, PALM BEACH GARDENS 33410	
Inspection Date: 08/26/2021	Inspection Number: 3097036	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOLDMAN, BARRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. J# 135773, 135774 - 05/2021 expired. Inspection conducted waiting on Certificates. **Corrective Action Taken**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6013529		JERSEY MIKE'S	
License Type: Permanent Food Service		6390 W INDIANTOWN RD STE 34, JUPITER 33458-7980	
Inspection Date: 08/26/2021	Inspection Number: 3132053	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Speed rack/back door/corrective action taken/operator removed speed rack. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6022417		TIP TO TAIL	
License Type: Permanent Food Service		33 SE 3 AVENUE #7 & #8, DELRAY BEACH 33483	
Inspection Date: 08/23/2021	Inspection Number: 3105773	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6022423		TIFFIN BOX	
License Type: Permanent Food Service		33 SE 3 AVENUE #16, DELRAY BEACH 33483	
Inspection Date: 08/23/2021	Inspection Number: 3099357	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Palm Beach County

License Number: 6022428

INCREDIBOWL

License Type: Permanent Food Service

33 SE 3 AVENUE #31, DELRAY BEACH 33483

Inspection Date: 08/23/2021

Inspection Number: 3136811

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6216176		SUBWAY #33258	
License Type: Permanent Food Service		18415 US HWY 19 N, CLEARWATER 33764	
Inspection Date: 08/27/2021	Inspection Number: 3100819	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WILMOT, TASHARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. -by ladder and a box	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215667		CHICK-FIL-A OF CLEARWATER	
License Type: Permanent Food Service		2516 GULF-TO-BAY BLVD, CLEARWATER 33765	
Inspection Date: 08/27/2021	Inspection Number: 3106882	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HUNT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Back door extinguisher in the red.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6217275		WAREHOUSE DELI	
License Type: Permanent Food Service		141 STEVENS AVE STE 8, OLDSMAR 34677	
Inspection Date: 08/24/2021	Inspection Number: 3120361	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAHL, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Deadbolt on back door locked, discussed with owner, unlocked door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

St. Johns County

License Number: 6501473 TACO BELL- 26464
 License Type: Permanent Food Service 2453 SR 16, SAINT AUGUSTINE 32092

Inspection Date: 08/27/2021 Inspection Number: 3120200 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by equipment. Moved by manager. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6502361 BONCHON
 License Type: Permanent Food Service 475 DURBIN PAVILION DR UNIT K101, SAINT JOHNS 32259

Inspection Date: 08/26/2021 Inspection Number: 3117530 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by equipment.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405261 DELICIAS CENTROAMERICANAS LLC
 License Type: Permanent Food Service 722 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 08/27/2021 Inspection Number: 3103184 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7404966 PEGGYS COUNTRY KITCHEN
 License Type: Permanent Food Service 2100 S RIDGEWOOD AVE, EDGEWATER 32141

Inspection Date: 08/27/2021 Inspection Number: 3153094 Inspection Type: Complaint Full Inspection Disposition: Emergency order recommended
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. -inside kitchen next to wall ventilation system next to fryers/hood system. Light switch, and exposed wires around affected area where visible fire damage exists.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.