

Alachua County

License Number: 1100907

BEVS BETTER BURGERS

License Type: Permanent Food Service

15010 N MAIN ST, ALACHUA 32615

Inspection Date: 09/14/2021

Inspection Number: 3116514

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the red fire extinguisher by the door is in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506207		OZZIE'S CRABHOUSE	
License Type: Permanent Food Service		4391 DIXIE HWY NE, PALM BAY 32905	
Inspection Date: 09/14/2021	Inspection Number: 3157030	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. BOILER CERTIFICATION EXPIRED	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1505484		CHINA WOK	
License Type: Permanent Food Service		1150 MALABAR RD #119, PALM BAY 32907	
Inspection Date: 09/14/2021	Inspection Number: 3102489	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SCHOENLY, BARBARA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Only 1/2 of the hood suppression is working at this time- one of the motors is out-the operator has an appointment to have replaced this afternoon Talked with city of Palm Bay fire inspector Graham they will be out to check establishment tomorrow to ensure second motor replaced and hood system is properly working	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1506708		FLAVORS OF INDIA	
License Type: Permanent Food Service		5675 N ATLANTIC AVE # 117, COCOA BEACH 32931	
Inspection Date: 09/13/2021	Inspection Number: 3092917	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1621146		LA CARRETA RESTAURANT	
License Type: Permanent Food Service		14791 MIRAMAR PKWY, MIRAMAR 33027	
Inspection Date: 09/16/2021	Inspection Number: 3125263	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTINEZ, RHEANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired certification from 3/17/2021. Operator stated had inspector email new current boiler certification. Observed new expiration as 6/2/2022. Advised operator to post new certification. **Corrective Action Taken** **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1623582		JIMMY JOHNS	
License Type: Permanent Food Service		2531 SAMPLE RD, MARGATE 33073	
Inspection Date: 09/16/2021	Inspection Number: 3136976	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door block with cardboard boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1609524		WENDYS OLD FASHIONED HAMBURGERS	
License Type: Permanent Food Service		5900 W OAKLAND PARK BLVD STE 100, FORT LAUDERDALE 33313	
Inspection Date: 09/16/2021	Inspection Number: 3114660	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROGERS, VERNEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen exit door- observed exit door being blocked by empty boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1624007		DONNAS CARIBBEAN RESTAURANT	
License Type: Permanent Food Service		4200 NW 12 ST, LAUDERHILL 33313	
Inspection Date: 09/13/2021	Inspection Number: 3115044	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: ROGERS, VERNEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen exit door at cook line- observed exit door being blocked by trash can. Operator removed trash can. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1617510

DOMINO'S PIZZA INC #5067

License Type: Permanent Food Service

705 S SR 7, PLANTATION 33317-4055

Inspection Date: 09/15/2021

Inspection Number: 3156354

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: NEALY, VALENCIA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
-Observed exit door blocked by discarded card board boxes in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001324 MR CHUBBY'S WINGS
 License Type: Permanent Food Service 2349 VILLAGE SQUARE PKWY STE 101, FLEMING ISLAND 32003

Inspection Date: 09/14/2021 Inspection Number: 3089626 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Bar on marked exit door by bathrooms, employee corrected during inspection. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001091 LA CASITA MEXICAN RESTAURANT
 License Type: Permanent Food Service 20 N ORANGE AVE, GREEN COVE SPRINGS 32043

Inspection Date: 09/13/2021 Inspection Number: 3107383 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two propane tanks in back storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325441	MESA'S BBQ
License Type: Permanent Food Service	1125 W 29 ST, HIALEAH 33012
Inspection Date: 09/14/2021	Inspection Number: 3096533
Inspector Name: PAGAN, VICTOR	Inspection Type: Routine - Food
	Inspection Disposition: Call Back - Complied
<u>Violation Code</u>	<u>Observation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on extinguisher located just inside the kitchen entrance from the dining room area. - From follow-up inspection 2021-09-14: **Time Extended**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2330395	MIAMI GRILL CATERING
License Type: Permanent Food Service	2350 W 84 ST #8, HIALEAH 33016
Inspection Date: 09/17/2021	Inspection Number: 3126926
Inspector Name: CRUZ, EDGAR	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2359885	FARINAS FOOD TRUCK
License Type: Mobile Food Dispensing Vehicle	26000 S DIXIE HWY, PRINCETON 33032
Inspection Date: 09/17/2021	Inspection Number: 1244703
Inspector Name: GONZALEZ, RICARDO	Inspection Type: Food-Licensing Inspection
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 2331966	LA CARRETA MIA C-26-A
License Type: Permanent Food Service	4200 NW 21 ST, CONC D-37, MIAMI 33122
Inspection Date: 09/16/2021	Inspection Number: 3090702
Inspector Name: SANCHEZ, JAVIER	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL 003481 Expired on 05/22/21
	<u>Violation Citation</u>
	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2320101		MI RINCONCITO MEXICANO	
License Type: Permanent Food Service		1961 SW 8 ST, MIAMI 33135	
Inspection Date: 09/14/2021	Inspection Number: 3112863	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336286		SIPS	
License Type: Permanent Food Service		1951 NW 7 AVE, 190, MIAMI 33136	
Inspection Date: 09/17/2021	Inspection Number: 3122514	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed in the back cook area: establishment has a hood installed without the fire suppression system. Observed a flat top grill, a charbroil grill, and grease fryer. Observed employee frying fish in the back kitchen area during the inspection.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2333666		THE LOCAL HOUSE	
License Type: Permanent Food Service		400 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 09/10/2021	Inspection Number: 3095509	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located inside dry storage room. - From follow-up inspection 2021-09-10: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2334642		HABITAT	
License Type: Permanent Food Service		2301 2377 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/15/2021	Inspection Number: 3122334	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CONCEPCION, ADRIEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boilers in room next to bar located in upstairs area. Observed a BTU count 800,000, 132 gallons, 210°F Temperature to indicate as boilers. As well as no Carbon Monoxide detector in room where boilers are located.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2328463		AQUA RESTAURANT	
License Type: Permanent Food Service		4101 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 09/14/2021	Inspection Number: 3099524	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired (FL 095074, 095074 exp 3/14/2020)	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334381		VERMONIC'S CAFE	
License Type: Permanent Food Service		3191 CORAL WAY STE 111, CORAL GABLES 33145	
Inspection Date: 09/15/2021	Inspection Number: 3115881	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2334027		PLATE	
License Type: Permanent Food Service		2105 CORAL WAY, MIAMI 33145	
Inspection Date: 09/13/2021	Inspection Number: 3122718	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330224		WENDY'S #9390	
License Type: Permanent Food Service		9655 W FLAGLER ST, MIAMI 33174	
Inspection Date: 09/13/2021	Inspection Number: 3133480	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed a trash can blocking the exit door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2607565 DESERT RIDER SANDWICH SHOP
 License Type: Permanent Food Service 217 HOGAN ST, JACKSONVILLE 322024201

Inspection Date: 09/14/2021 Inspection Number: 3124857 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Employee fried egg in skillet on cooks line no hood suppression system above cooking equipment **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614780 WILD ATLANTIC SEAFOOD
 License Type: Permanent Food Service 622 CASSAT AVE #11-12, JACKSONVILLE 32205

Inspection Date: 09/14/2021 Inspection Number: 3114214 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Boxes, mgr removed boxes **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2607778 POPEYES LOUISIANA KITCHEN #148
 License Type: Permanent Food Service 5715 NORMANDY BLVD, JACKSONVILLE 322056263

Inspection Date: 09/15/2021 Inspection Number: 3106211 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By triple sink - From follow-up inspection 2021-09-15: Not seen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2652158 CHABELITAS MEXICAN CUISINE
 License Type: Mobile Food Dispensing Vehicle 5960 RICHARD ST, JACKSONVILLE 32216

Inspection Date: 09/15/2021 Inspection Number: 1237732 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: BIAVA, GRANT

Violation Code ObservationViolation Citation

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Mobile unit has a small fryer that is not under the hood system when in use. - From follow-up inspection 2021-08-30: **Time Extended** - From follow-up inspection 2021-09-15: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800871

CENTRAL SCOOPS

License Type: Permanent Food Service

602 S STATE ST STE B, BUNNELL 32110

Inspection Date: 09/16/2021

Inspection Number: 3092943

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Exit door at back of building blocked with wood. Items stored in the way of exit path.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912010

BIG GS PIZZA AND GRILLE INC

License Type: Permanent Food Service

3742 W LAMBRIANT ST, TAMPA 33614

Inspection Date: 09/15/2021

Inspection Number: 3137040

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JAIME, ANTONY

Violation Code

Observation

Violation Citation

47-03-4

Observed walk-in cooler light hanging wiring in disrepair. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606984

BURGER KING #23202

License Type: Permanent Food Service

4011 DEL PRADO BLVD N, NORTH FORT MYERS 33917

Inspection Date: 09/13/2021

Inspection Number: 3105618

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed exposed wiring in ceiling light above front counter in dining room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300708

THAI HOUSE

License Type: Permanent Food Service

829 NE JENSEN BEACH BLVD, JENSEN BEACH 34957-4797

Inspection Date: 09/16/2021

Inspection Number: 3113485

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Portable electric fryer with oil is under hood but no suppression coverage is provided by existing fire suppression system.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301393

OSCEOLA STREET CAFE

License Type: Permanent Food Service

26 W OSCEOLA ST, STUART 34994

Inspection Date: 09/14/2021

Inspection Number: 3097009

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By restroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814137		OMELET BAR	
License Type: Permanent Food Service		12250 STRATEGY BLVD STE 401-407, ORLANDO 32817	
Inspection Date: 09/15/2021	Inspection Number: 3133728	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: VAZQUEZ, JULITZA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810737		CHICK-FIL A AT THE MALL AT MILLENIA	
License Type: Permanent Food Service		4200 CONROY RD UNIT 245, ORLANDO 32839	
Inspection Date: 09/14/2021	Inspection Number: 3117720	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PASIECKI, VICTORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Dumpster cart blocking exit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814644		DUNKIN DONUTS	
License Type: Permanent Food Service		3011 CATHY ST, ORLANDO 32839	
Inspection Date: 09/15/2021	Inspection Number: 3115965	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PASIECKI, VICTORIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked with trashcan. Operator moved **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5812945		THE OCOEE TACO COMPANY	
License Type: Permanent Food Service		40 TAYLOR ST, OCOEE 34761	
Inspection Date: 09/14/2021	Inspection Number: 2986397	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: GREENE, MARVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer being used on table next to ice machine. **Repeat Violation** - From follow-up inspection 2021-06-14: **Time Extended** - From follow-up inspection 2021-07-15: **Time Extended** - From follow-up inspection 2021-09-14: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Palm Beach County

License Number: 6011000		CHEESECAKE FACTORY (THE)	
License Type: Permanent Food Service		5530 GLADES RD, BOCA RATON 33431	
Inspection Date: 09/15/2021	Inspection Number: 3094777	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, HAIDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate is expired since 03-23-2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6004302		WENDYS OLD FASHIONED HAMBURGERS	
License Type: Permanent Food Service		865 N FEDERAL HWY, BOCA RATON 33432	
Inspection Date: 09/14/2021	Inspection Number: 3155658	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STEUBER, RYAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. A front counter	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6021903		MARGARITAS MEXICAN RESTAURANT	
License Type: Permanent Food Service		6418 LAKE WORTH RD, LAKE WORTH 33467	
Inspection Date: 09/15/2021	Inspection Number: 3103178	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: AHLE, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 3 15 lbs propane tanks connect to portable stove in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pasco County

License Number: 6102686 APPLEBEES NEIGHBORHOOD GRILL & BAR
License Type: Permanent Food Service 28422 SR 54, WESLEY CHAPEL 33543

Inspection Date: 09/13/2021 Inspection Number: 3113685 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: COLE, GABRIELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By kitchen exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215233		ASTRA PIZZA	
License Type: Permanent Food Service		2915 16 ST N, ST. PETERSBURG 33704	
Inspection Date: 09/17/2021	Inspection Number: 3094554	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LOZANO, KELVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Establishment was a no seating establishment increased to four seats. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216496		HYATT REGENCY CLEARWATER BEACH RESORT & SPA	
License Type: Permanent Food Service		301 GULFVIEW BLVD, CLEARWATER 33767	
Inspection Date: 09/15/2021	Inspection Number: 3129808	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	Current insurance inspector boiler report or boiler certificates expired for boilers. For reporting purposes only. FI 123657, FI123658, FI123659, FI123660 all exp 7/25/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6216497		HYATT REGENCY CLEARWATER BEACH RESORT & SPA	
License Type: Permanent Food Service		301 GULF VIEW BLVD, CLEARWATER 33767	
Inspection Date: 09/15/2021	Inspection Number: 3096031	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	Current insurance inspector boiler report or boiler certificate expired for boilers. For reporting purposes only. FI 123657, FI123658, FI123659, FI123660 all exp 7/25/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6216188		WHISKEY WINGS	
License Type: Permanent Food Service		4013 TAMPA RD STE 19 AND 20, OLDSMAR 34677	
Inspection Date: 09/13/2021	Inspection Number: 3135644	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: ANDREE, GLEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Extension cord in use on cooks line for reach in freezer .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6217486

SAKI ENDLESS SUSHI & HIBACHI

License Type: Permanent Food Service

35927 US 19 N, PALM HARBOR 34684

Inspection Date: 09/13/2021

Inspection Number: 3103374

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HUNT, LISA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher class K, gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6350490 EL CABRITO TAQUERIA
 License Type: Mobile Food Dispensing Vehicle 119 N HWY 17-92, HAINES CITY 33844

Inspection Date: 09/17/2021 Inspection Number: 1244753 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805190

LITTLE CAESARS PIZZA

License Type: Permanent Food Service

4599 BEE RIDGE RD, SARASOTA 34233

Inspection Date: 09/14/2021

Inspection Number: 3134621

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in red zone, located next to back door. - From follow-up inspection 2021-09-14: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405846

NEW CHINA WOK

License Type: Permanent Food Service

2160 HOWLAND BLVD STE 100, DELTONA 32738

Inspection Date: 09/14/2021

Inspection Number: 3136676

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 Front door blocked by takeout window.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.