

Bay County

License Number: 1305184

CHILI'S GRILL AND BAR

License Type: Permanent Food Service

845 E 23RD STREET, PANAMA CITY 32405

Inspection Date: 09/21/2021

Inspection Number: 3158186

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. On wall behind back prep table, and on wall behind side prep cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1301344

PINEAPPLE WILLIES

License Type: Permanent Food Service

9875 S THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 09/20/2021

Inspection Number: 3088188

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by back door in steamer prep area in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1653360		EL CHEF MONTESINO	
License Type: Mobile Food Dispensing Vehicle		117 E HALLANDALE BEACH, HALLANDALE BEACH 33009	
Inspection Date: 09/21/2021	Inspection Number: 1236239	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1622634		CROCANTE	
License Type: Permanent Food Service		2708 N UNIVERSITY DR, CORAL SPRINGS 33065	
Inspection Date: 09/21/2021	Inspection Number: 3119475	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. -Observed several hot plates used in kitchen that produce grease laden vapors with no hood suppression system. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1623828		PEI WEI FRESH KITCHEN #0262	
License Type: Permanent Food Service		3112 UNIVERSITY DR BLDG A, CORAL SPRINGS 33065	
Inspection Date: 09/21/2021	Inspection Number: 3108460	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door block with boxes. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1600069		TROPICAL ACRES STEAK HOUSE	
License Type: Permanent Food Service		2500 GRIFFIN RD, FORT LAUDERDALE 33312-5921	
Inspection Date: 09/22/2021	Inspection Number: 3127760	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BARTON, GEOFFREY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher showing in overcharge zone. By hand sink in back prep kitchen .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Clay County

License Number: 2001306

PANERA BREAD #1741

License Type: Permanent Food Service

661 BLANDING BLVD STE 509, ORANGE PARK 32073

Inspection Date: 09/22/2021

Inspection Number: 3114499

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By exit door next to bathrooms in dining room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335302 THE UNION BEER STORE
 License Type: Permanent Food Service 1547 SW 8 STREET, MIAMI 33135

Inspection Date: 09/24/2021 Inspection Number: 3120992 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328836 FLORIDA COOKERY AT THE JAMES ROYAL PALM HOTEL
 License Type: Permanent Food Service 1545 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/21/2021 Inspection Number: 3132132 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 120333;120330; 120331; 120332, 120335 All expired on 4/23/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 120333;120330; 120331; 120332, 120335 All expired on 4/23/2021 - From follow-up inspection 2021-09-22: **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2328837 COFFEE BAR AT THE ROYAL PALM
 License Type: Permanent Food Service 1545 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/21/2021 Inspection Number: 3119590 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 120333; 120330; 120331; 120332, 120335 All expired on 4/23/2021.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2328840		POOL BAR AT THE ROYAL PALM	
License Type: Permanent Food Service		1545 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/21/2021	Inspection Number: 3113472	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 120333; 120330; 120331; 120332, 120335 All expired on 4/23/2021.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2329107		SETAI SOUTH BEACH	
License Type: Catering		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/22/2021	Inspection Number: 1119283	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 133619 expired 5/20/21; 093572; 093573; 093674 All expired 5/8/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2330875		SETAI POOL BAR/ OCEAN GRILL AT THE SETAI	
License Type: Permanent Food Service		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/22/2021	Inspection Number: 3120485	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 133619 expired 5/20/21; 093572; 093573; 093674 All expired 5/8/2021.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2331051		THE GRILL	
License Type: Permanent Food Service		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/22/2021	Inspection Number: 3095780	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 133619 expired 5/20/21; 093572; 093573; 093674 All expired 5/8/2021.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2331114		JAYA AT SETAI	
License Type: Permanent Food Service		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/22/2021	Inspection Number: 3114373	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 133619 expired 5/20/21; 093572; 093573; 093674 All expired 5/8/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2334948		LIVING ROOM/ MAIN KITCHEN	
License Type: Permanent Food Service		3201 COLLINS AVENUE, MIAMI 33140	
Inspection Date: 09/23/2021	Inspection Number: 3120676	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2335013		CABARET	
License Type: Permanent Food Service		3201 COLLINS AVENUE, MIAMI 33140	
Inspection Date: 09/23/2021	Inspection Number: 3114538	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2333367		QUALITY INN MIAMI AIRPORT	
License Type: Permanent Food Service		3959 NW 79 AVE, MIAMI 33166	
Inspection Date: 09/21/2021	Inspection Number: 3128850	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 080920, 123866. Expiration 11/27/2020. - From follow-up inspection 2021-09-21: At time of callback inspection observed Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 080920, 123866, Expiration 11/27/2020.. At time of callback inspection as per Operator they are changing Boilers and after that, they will receive the Boiler Inspection by DIVISION OF STATE FIRE MARSHAL. **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2334188 CHEF CREOLE # 4
 License Type: Permanent Food Service 20356 NW 2ND AVE, MIAMI GARDENS 33169

Inspection Date: 09/23/2021 Inspection Number: 3155647 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two LP tanks stored inside of the storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328612 THE DORAL STEAKHOUSE
 License Type: Permanent Food Service 4273-4285 NW 107 AVE, DORAL 33178

Inspection Date: 09/23/2021 Inspection Number: 3090682 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located by mop sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328615 SUBWAY 23150
 License Type: Permanent Food Service 7098 SW 117 AVE, MIAMI 33183

Inspection Date: 09/22/2021 Inspection Number: 3091050 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near kitchen entrance door. - From follow-up inspection 2021-09-22: Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near kitchen entrance door. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near kitchen entrance door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336886

SHAWARMA MIAMI

License Type: Permanent Food Service

9165 SW 162 AVE STE 100, MIAMI 33196

Inspection Date: 09/22/2021

Inspection Number: 3093621

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed table blocking exit door. Employee removed item. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612849		FIVE STAR PIZZA	
License Type: Permanent Food Service		3325 PLYMOUTH ST STE-2, JACKSONVILLE 32205	
Inspection Date: 09/21/2021	Inspection Number: 3126010	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By service window	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613506		SUBWAY #37825	
License Type: Permanent Food Service		6842 WILSON BLVD #1, JACKSONVILLE 32210	
Inspection Date: 09/21/2021	Inspection Number: 3128229	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: MERCER, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Exit door in kitchen has boxes blocking door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614791		JIMMY JOHN'S GOURMET SANDWICHES STORE #2023	
License Type: Permanent Food Service		510 AIRPORT CIRCLE DRIVE SUITE 106, JACKSONVILLE 32218	
Inspection Date: 09/21/2021	Inspection Number: 3145642	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by exit door near restrooms. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2615333		CHIPOTLE MEXICAN GRILL #2714	
License Type: Permanent Food Service		1758 3 ST S, JACKSONVILLE 32250	
Inspection Date: 09/21/2021	Inspection Number: 3133524	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Kitchen Exit door is being blocked by empty food boxes. Manager moved boxes to the side of the door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2610563

BONO'S

License Type: Permanent Food Service

8011 MERRILL RD #23, JACKSONVILLE 322773799

Inspection Date: 09/23/2021

Inspection Number: 3112411

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Twenty pound propane tank in side kitchen area across from pit. Employee moved outside **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800664 ISLAND FLAVAZ RESTAURANT
 License Type: Permanent Food Service 909 N OCEAN SHORE BLVD, FLAGLER BEACH 32136

Inspection Date: 09/22/2021 Inspection Number: 3105245 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back sliding door, silver extinguisher in red zone. Operator provided invoice from recent fire inspection 9/16/21.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800806 LATINO MARKET
 License Type: Permanent Food Service 300 PALM COAST PKWY SW #1, PALM COAST 32137

Inspection Date: 09/20/2021 Inspection Number: 3120394 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked with metal shelving by triple sink. Exit door in dining area blocked with metal bar.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3916535		CHIPOTLE MEXICAN GRILL COLORADO LLC	
License Type: Permanent Food Service		2223 N WESTSHORE BLVD, TAMPA 33607	
Inspection Date: 09/24/2021	Inspection Number: 3110868	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire on floor by back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3918299		THE BOOZY PIG	
License Type: Permanent Food Service		3255 W CYPRESS ST, TAMPA 33607	
Inspection Date: 09/23/2021	Inspection Number: 3109520	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: KOWAL, KYLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-05-4	Establishment increased seating from 10 to 26 without fire approval. Provided operator seating change evaluation form at time of inspection.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3918653		BURGER CULTURE	
License Type: Permanent Food Service		2223 N WEST SHORE BLVD, SUITE 200A, TAMPA 33607	
Inspection Date: 09/20/2021	Inspection Number: 3111470	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher stored under employee hand wash sink .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3916664		HAAGEN DAZS NESTLE TOLL HOUSE	
License Type: Permanent Food Service		8035 CITRUS PARK TOWN CENTER, TAMPA 33625	
Inspection Date: 09/23/2021	Inspection Number: 3125815	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: ZHANG, JACKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2021-09-23: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Indian River County

License Number: 4100649

BURGER KING 5605

License Type: Permanent Food Service

5790 20 ST, VERO BEACH 32966

Inspection Date: 09/22/2021

Inspection Number: 3104259

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-06-4

Pull stations for annul system, fire extinguisher is inaccessible. Black apron hanging on pull stations. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5104179

POPI'S PLACE III

License Type: Permanent Food Service

10508 US 41 N, PALMETTO 34221

Inspection Date: 09/21/2021

Inspection Number: 3089543

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BECHTOLD, NEIL

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Observed exposed wires on ceiling next to the cook line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301751

JR'S BBQ

License Type: Permanent Food Service

15492 SW WARFIELD BLVD, INDIANTOWN 34956

Inspection Date: 09/20/2021

Inspection Number: 3091205

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Was removed. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814335 HOLIDAY INN EXPRESS
 License Type: Permanent Food Service 10771 INTERNATIONAL DRIVE, ORLANDO 32821

Inspection Date: 09/21/2021 Inspection Number: 3121375 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed a Karcher floor cleaning machine blocking the kitchen exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805113 COURTYARD CAFE & LOUNGE
 License Type: Permanent Food Service 8501 PALM PKWY, ORLANDO 32836

Inspection Date: 09/23/2021 Inspection Number: 3130331 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Checked boiler certification 7/20/2021 expired	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5814919 JUICY BITES
 License Type: Permanent Food Service 12125 APOPKA VINELAND ROAD, ORLANDO 32836

Inspection Date: 09/23/2021 Inspection Number: 3116796 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Observed lighter fuel and charcoal stored on storage shelf.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5952810

CHANCHIS

License Type: Mobile Food Dispensing Vehicle

5811 W IRLO BRONSON MEMORIAL HWY, VIN 8017, KISSIMMEE 34746

Inspection Date: 09/20/2021

Inspection Number: 1244357

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FERTIL, SYLVERST

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. Operator forgot the fire extinguisher at home. The did have the purchase receipt from Fire Extinguisher Service, Inc. Advised operator not to operator the truck until the fire extinguisher is placed in the MFDV.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6051909		FOOD YACHT	
License Type: Mobile Food Dispensing Vehicle		967 ALTERNATE A1A, JUPITER 33477	
Inspection Date: 09/22/2021	Inspection Number: 1239192	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6010974		CAFFE LUNA ROSA	
License Type: Permanent Food Service		34 S OCEAN BLVD, DELRAY BEACH 33483	
Inspection Date: 09/21/2021	Inspection Number: 3114877	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located at wait station	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6022414		DADS FAVORITE BURGERS & PIES	
License Type: Permanent Food Service		33 SE 3 AVENUE #6, DELRAY BEACH 33483	
Inspection Date: 09/24/2021	Inspection Number: 3136678	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-09-24: Next unannounced **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6022416		BONA BONA ICE CREAM	
License Type: Permanent Food Service		33 SE 3 AVE #5, DELRAY BEACH 33483	
Inspection Date: 09/24/2021	Inspection Number: 3136610	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: GOODWIN, NICHOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-09-24: Next unannounced **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Pinellas County

License Number: 6212684

BAYOU CLUB

License Type: Permanent Food Service

7979 BAYOU CLUB BLVD, LARGO 33777

Inspection Date: 09/24/2021

Inspection Number: 3088156

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
-097097 6/12/21

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Sumter County

License Number: 7000664

AMERICAN WITH A LATIN TWIST

License Type: Permanent Food Service

2006 N CR 470, LAKE PANASOFFKEE 33538

Inspection Date: 09/24/2021

Inspection Number: 3154991

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By hand sink in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7404351 SUBWAY 6876
 License Type: Permanent Food Service 1609 N NOVA RD, HOLLY HILL 32117

Inspection Date: 09/22/2021 Inspection Number: 3103950 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear door blocked by garbage and boxes. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7402324 MANGO SUN CAFE & GRILLE
 License Type: Permanent Food Service 2209 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 09/22/2021 Inspection Number: 3120027 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. -east side door, marked with exit sign. Manager unlocked, and stated usually unlocked **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.