

Bay County

License Number: 1305526 TUDOR'S BISCUIT WORLD
 License Type: Permanent Food Service 2621 W23 RD STREET, PANAMA CITY 32405

Inspection Date: 09/29/2021 Inspection Number: 3161462 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher at drive through window in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305750 JERSEY MIKE'S SUBS
 License Type: Permanent Food Service 741 W 23RD ST, PANAMA CITY 32405

Inspection Date: 09/27/2021 Inspection Number: 3110596 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class near walk-in cooler in recharge zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1350314 BOOKIE'S BREAKFAST CAMP
 License Type: Mobile Food Dispensing Vehicle 3915 ERENO CT, PANAMA CITY 32405

Inspection Date: 09/29/2021 Inspection Number: 1240631 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Red Fire extinguisher by reach in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505423

CHINA PARK

License Type: Permanent Food Service

2301 SR 524 #115, COCOA 32926

Inspection Date: 09/29/2021

Inspection Number: 3095931

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Front door blocked by table. Service through window opening. No customer access allowed inside due to covid per operator **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1624010

ANOTHER BROKEN EGG CAFE

License Type: Permanent Food Service

175 N HIATUS RD STE 302, PEMBROKE PINES 33026

Inspection Date: 09/27/2021

Inspection Number: 3130571

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 -Observed trash can holding cardboard boxes blocking exit door in kitchen.
 Operator removed trash can and boxes. **Corrective Action Taken**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624835

JUST SALAD PEMBROKE PINES

License Type: Permanent Food Service

221 N HIATUS RD, PEMBROKE LAKES SQUARE, PEMBROKE PINES 33026

Inspection Date: 09/27/2021

Inspection Number: 3121971

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 -Observed exit door blocked by black trash bag in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1613419

DSI SUNRISE LLC

License Type: Permanent Food Service

2670 E SUNRISE BLVD, FORT LAUDERDALE 33304

Inspection Date: 10/01/2021

Inspection Number: 3098322

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.
 093563 exp 2-21-2021; 099900 exp 2-21-2021

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621071

DSI SUNRISE LLC

License Type: Permanent Food Service

2670 E SUNRISE BLVD, FORT LAUDERDALE 33304

Inspection Date: 10/01/2021

Inspection Number: 3135434

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.
 093563 exp 2-21-2021; 099900 exp 2-21-2021

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1621952 BLUE WATER RESTAURANT AND BAR
 License Type: Permanent Food Service 440 S SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 09/28/2021 Inspection Number: 3090139 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EVANS, EUGENE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 059086 059163, 059083. Exp 8/4/2019 **Repeat Violation**

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621955 SEABREEZE POOL BAR
 License Type: Permanent Food Service 440 S SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 09/28/2021 Inspection Number: 3090138 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EVANS, EUGENE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 059086 059163, 059083. Exp 8/4/2019

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623647 COURTYARD FT LAUDERDALE BEACH
 License Type: Permanent Food Service 440 S SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 09/28/2021 Inspection Number: 3127321 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EVANS, EUGENE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 059086 059163, 059083. Exp 8/4/2019

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1611982 DOUBLETREE BY HILTON DEERFIELD BEACH - BOCA RATON
 License Type: Permanent Food Service 100 FAIRWAY DR, DEERFIELD BEACH 33441

Inspection Date: 09/29/2021 Inspection Number: 3121562 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STEUBER, RYAN

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1616484

DOUBLETREE BY HILTON DEERFIELD BEACH - BOCA RATON

License Type: Permanent Food Service

100 FAIRWAY DR, DEERFIELD BEACH 33441

Inspection Date: 09/29/2021

Inspection Number: 3103070

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEUBER, RYAN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2324716 HAPPY HOUSE
 License Type: Permanent Food Service 28708 S DIXIE HWY, HOMESTEAD 33030

Inspection Date: 09/28/2021 Inspection Number: 3100426 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325031 TAQUERIA MARIANITA
 License Type: Permanent Food Service 29347 SW 152 AVE, HOMESTEAD 33033

Inspection Date: 09/29/2021 Inspection Number: 3133802 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed LP gas tank in AC room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329123 RICKY AREPAS AND HOT DOGS
 License Type: Catering 414 SW 22 AVE, MIAMI 33135

Inspection Date: 09/30/2021 Inspection Number: 1119743 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336781 THE GOODTIME HOTEL
 License Type: Permanent Food Service 601 WASHINGTON AVENUE, MIAMI BEACH 33139

Inspection Date: 09/29/2021 Inspection Number: 3093159 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler btu max 499,900.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2332002 CAFE CHUNG KING
 License Type: Permanent Food Service 1250 NW 54 STREET, MIAMI 33142

Inspection Date: 09/28/2021 Inspection Number: 3050227 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-01-4	- From initial inspection : Observed exposed electrical wires. For reporting purposes only. Located in wall and ceiling fixtures in kitchen area. - From follow-up inspection 2021-01-22: Observed exposed electrical wires. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. Observed electrical wires hanging from the ceiling of the establishment . **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Observed electrical wires hanging from the ceiling of the establishment . **Repeat Violation** - From follow-up inspection 2021-09-29: Observed s	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334028 DALE
 License Type: Permanent Food Service 1711 SW 22 ST, MIAMI 33145

Inspection Date: 10/01/2021 Inspection Number: 3109794 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2021-10-01: Observed cooking with no hood	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337009 AC KITCHEN AND LOUNGE
 License Type: Permanent Food Service 7695 N KENDALL DR, MIAMI 33156

Inspection Date: 09/29/2021 Inspection Number: 3079762 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed the water heater with the capacity of 1,000,000 BTU .	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2330259 CARLOS' SEA FOOD & RESTAURANT
 License Type: Permanent Food Service 17740 HOMESTEAD AVENUE, MIAMI 33157

Inspection Date: 09/28/2021 Inspection Number: 3099330 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in the storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332709 EL KONUCO CAFETERIA
 License Type: Permanent Food Service 8457 NW 61 ST, MIAMI 33166

Inspection Date: 09/29/2021 Inspection Number: 3098467 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two Propane tanks stored inside room by office. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2318018 GRACE DELI WEST
 License Type: Permanent Food Service 7372 NW 72 AVE, MIAMI 331662431

Inspection Date: 09/30/2021 Inspection Number: 3131040 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank stored dining room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614547		THE TREE CUP CATERED BY THE CHEF'S GARDEN	
License Type: Permanent Food Service		829 RIVERSIDE AVE, JACKSONVILLE 32204	
Inspection Date: 09/30/2021	Inspection Number: 3113892	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking shrimp with oil in one burner, kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613933		CASBAH CAFE	
License Type: Permanent Food Service		3628 ST JOHNS AVE, JACKSONVILLE 32205	
Inspection Date: 09/27/2021	Inspection Number: 3128620	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2608493		PEPPER POT RESTAURANT	
License Type: Permanent Food Service		4233 BRENTWOOD AVE, JACKSONVILLE 322066111	
Inspection Date: 09/29/2021	Inspection Number: 3131135	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613590		HAMBURGER MARY'S JACKSONVILLE	
License Type: Permanent Food Service		3333-1 BEACH BLVD, JACKSONVILLE 32207	
Inspection Date: 09/30/2021	Inspection Number: 3129286	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Walk in cooler is missing push bar to exit walk in cooler **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2608119

BONO'S PIT BAR B Q

License Type: Permanent Food Service

5903 NORWOOD AVE, JACKSONVILLE 322084345

Inspection Date: 09/29/2021

Inspection Number: 3145968

Inspection Type: Routine - Food

Inspection Disposition: Emergency
order recommended

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
One tank at pit and three in storage area. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612961

KFC

License Type: Permanent Food Service

9551 REGENCY SQUARE BLVD N, JACKSONVILLE 32225

Inspection Date: 09/29/2021

Inspection Number: 3130632

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher at rear door is in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400184

FAT BELLY'S

License Type: Permanent Food Service

16750 SPRING STREET, WHITE SPRINGS 32096

Inspection Date: 10/01/2021

Inspection Number: 3115338

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Large fire extinguisher in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917895

CHICK-FIL-A TAMPA STADIUM

License Type: Permanent Food Service

2551 N DALE MABRY HWY, TAMPA 33607

Inspection Date: 10/01/2021

Inspection Number: 3115228

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher stored on table next to grill.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3952757

TOTAL TACO LLC

License Type: Mobile Food Dispensing Vehicle

2320 W COLUMBUS DR, TAMPA 33607

Inspection Date: 09/30/2021

Inspection Number: 1242669

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored on floor in unit .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917791

LOLIS 2 LLC

License Type: Permanent Food Service

10011 W HILLSBOROUGH AVE, TAMPA 33615

Inspection Date: 09/29/2021

Inspection Number: 3128875

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: ZHANG, JACKY

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment uses 2 flat top grills, next to office. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105157

SUBWAY #36886

License Type: Permanent Food Service

2190 45 ST, VERO BEACH 32960

Inspection Date: 09/29/2021

Inspection Number: 3097017

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Door on south side of facility Blocked and locked.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202625

TAIPEI GARDEN

License Type: Permanent Food Service

2602 SW 19 AVE RD #203, OCALA 34471

Inspection Date: 09/29/2021

Inspection Number: 3133390

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: GARNER, DHANIQUA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in lobby area in overcharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202837

JOHNNY'S PIZZERIA

License Type: Permanent Food Service

9562 MARICAMP RD STE. 3, OCALA 34472

Inspection Date: 09/30/2021

Inspection Number: 3126400

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Four fryers set up, large amount of vapors present in establishment.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5806998 SHANNON'S CASUAL CAFE
 License Type: Permanent Food Service 4401 S ORANGE AVE UNIT 100, ORLANDO 328066946

Inspection Date: 09/28/2021 Inspection Number: 3088305 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806035 FLYERS WINGS & GRILL
 License Type: Permanent Food Service 5621 W COLONIAL DR, ORLANDO 32808

Inspection Date: 09/29/2021 Inspection Number: 3160701 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GREENE, MARVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door in dining room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815020 EL REY BAR & LOUNGE
 License Type: Permanent Food Service 2300 W OAKRIDGE RD, ORLANDO 32809

Inspection Date: 09/29/2021 Inspection Number: 3104356 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Tables blocking rear exit - From follow-up inspection 2021-09-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814288 TOWNEPLACE SUITES BY MARRIOTT
 License Type: Permanent Food Service 10731 INTERNATIONAL DR, ORLANDO 32821

Inspection Date: 09/30/2021 Inspection Number: 3115801 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in kitchen preparation area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809399

SUBWAY #18657

License Type: Permanent Food Service

13212 E COLONIAL DR, ORLANDO 32826

Inspection Date: 09/29/2021

Inspection Number: 3131235

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: VAZQUEZ, JULITZA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.Boxes blocking the exit path.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911668

GRAND HOTEL KISSIMMEE - BREAKFAST

License Type: Permanent Food Service

3104 PARKWAY BOULEVARD, KISSIMMEE 34747

Inspection Date: 09/27/2021

Inspection Number: 3130373

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6009517 ISLANDER GRILL & TIKI BAR
 License Type: Permanent Food Service 181 OCEAN AVE, PALM BEACH SHORES 33404

Inspection Date: 09/27/2021 Inspection Number: 3100743 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MCCARTHY, RAMONA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6021671 DJS BACKYARD SMOKIN&GRILL CATERING
 License Type: Permanent Food Service 5209 BROADWAY, WEST PALM BEACH 33407

Inspection Date: 09/29/2021 Inspection Number: 3109621 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MCCARTHY, RAMONA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a two basket deep fryer on top of prep table in the indoor kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a two basket deep fryer on top of prep table in the indoor kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021942 MALLORCA AT LA POSADA
 License Type: Permanent Food Service 11980 SAN CRISTOBAL GARDENS AVE, PALM BEACH GARDENS 33410

Inspection Date: 09/29/2021 Inspection Number: 3090911 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOLDMAN, BARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. J# 134527-09/10/2021	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6020194

EATHAI

License Type: Permanent Food Service

1832 S FEDERAL HIGHWAY, DELRAY BEACH 33483

Inspection Date: 09/28/2021

Inspection Number: 3143689

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Located at outlet next to triple sink - From follow-up inspection 2021-09-28: Next unannounced **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. Located at outlet next to triple sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211181

WATER COLOUR STEAK HOUSE AND GRILL

License Type: Permanent Food Service

1201 GULF BLVD, CLEARWATER BEACH 33767

Inspection Date: 10/01/2021

Inspection Number: 3109043

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: KOUSTIS, TIMOTHY

Violation Code ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. FL134097,FL134099,FL134100 all expired 9/12/2020.
Repeat Violation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6208560

BURGER KING #4010

License Type: Permanent Food Service

32375 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 09/29/2021

Inspection Number: 3161083

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANDREE, GLEN

Violation Code ObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Class K type extinguisher near handwash sink in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6308174

AZTECA D' ORO

License Type: Permanent Food Service

1235 PARKWAY FRONTAGE N, LAKELAND 33803

Inspection Date: 10/01/2021

Inspection Number: 3097823

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: BEAULIEU, STEPHANIE

Violation CodeObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. On cook line - From follow-up inspection 2021-10-01: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. On cook line

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6308533

EL AZUCARERO RESTAURANT INC

License Type: Permanent Food Service

15 S 10TH ST, HAINES CITY 33844

Inspection Date: 09/30/2021

Inspection Number: 3097714

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In the dry storage area behind the can good shelf.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905122

NOODLES AND COMPANY 9032

License Type: Permanent Food Service

850 S SUN DR, LAKE MARY 32746

Inspection Date: 09/28/2021

Inspection Number: 3092581

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code ObservationViolation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

License Number: 6905013

CARRABBA'S ITALIAN GRILL

License Type: Permanent Food Service

4675 SAINT JOHNS PARKWAY, SANFORD 32771

Inspection Date: 09/27/2021

Inspection Number: 3095310

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code ObservationViolation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Stored in hot water heater room. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-03-4	Flammables stored/debris present in hot water heater room. For reporting purposes only. Cloth napkins.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

St. Johns County

License Number: 6502164 WENDY'S
 License Type: Permanent Food Service 153 CAPITOL GREEN DR, PONTE VEDRA 32081

Inspection Date: 09/24/2021 Inspection Number: 3159590 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by boxes. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501026 SCHMAGEL'S BAGELS
 License Type: Permanent Food Service 69 HYPOLITA ST, SAINT AUGUSTINE 32084

Inspection Date: 09/27/2021 Inspection Number: 3098235 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HARTMANN, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment uses griddle to fry bacon and make eggs on.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501914 ANCIENT CITY BRUNCH BAR
 License Type: Permanent Food Service 210 SAINT GEORGE ST #C, SAINT AUGUSTINE 32084

Inspection Date: 09/28/2021 Inspection Number: 3111741 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HARTMANN, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment is using convection oven to fry bacon creating grease laden vapors.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment is using convection oven to fry bacon creating grease laden	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502287

GREEN PAPAYA THAI SUSHI CUISINE

License Type: Permanent Food Service

841 S PONCE DE LEON BLVD UNIT 10, SAINT AUGUSTINE 32084

Inspection Date: 09/29/2021

Inspection Number: 3115671

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HARTMANN, MICHELLE

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Back door was blocked by boxes. Person in charge moved boxes. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6502361

BONCHON

License Type: Permanent Food Service

475 DURBIN PAVILION DR UNIT K101, SAINT JOHNS 32259

Inspection Date: 09/24/2021

Inspection Number: 3159599

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GOSAI, MATT

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Rear exit blocked by boxes. Moved by manager. **Corrected On-Site** **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6502124

ONE THIRD ASIAN HOUSE

License Type: Permanent Food Service

164 EVEREST LANE # 5, ST. JOHNS 32259

Inspection Date: 09/30/2021

Inspection Number: 3089838

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Rear exit blocked. Kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7404396

DENNY'S #6927

License Type: Permanent Food Service

1830 SR 44, NEW SMYRNA BEACH 32168

Inspection Date: 09/28/2021

Inspection Number: 3102334

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

47-02-4

Observed scorch marks around electrical outlet on cookline and open electrical cover on the wall to the right. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407046

BRUNO'S PIZZA

License Type: Permanent Food Service

1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 09/27/2021

Inspection Number: 3089563

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.