

Alachua County

License Number: 1103366

TONY & AL'S

License Type: Permanent Food Service

14960 MAIN ST, ALACHUA 32615

Inspection Date: 10/05/2021

Inspection Number: 3089813

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed the fire extinguisher behind the pizza oven is in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1304790 O'CHARLEY'S #317
 License Type: Permanent Food Service 311 E 23RD ST, PANAMA CITY 32405

Inspection Date: 10/07/2021 Inspection Number: 3113662 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class extinguisher near fry station and extinguisher near meat walk-in in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305866 SLIM CHICKENS - PANAMA CITY
 License Type: Permanent Food Service 300 WEST 23RD STREET, PANAMA CITY 32405

Inspection Date: 10/07/2021 Inspection Number: 3116946 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class near office in over charge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1623606	PANDA EXPRESS #2464		
License Type: Permanent Food Service	4190 N STATE RD 7, CORAL SPRINGS 33073		
Inspection Date: 10/04/2021	Inspection Number: 3161091	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door block with chairs and boxes.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 1621073	KIDS GOURMET		
License Type: Catering	2230 NW 22 ST, FORT LAUDERDALE 33311		
Inspection Date: 10/06/2021	Inspection Number: 1119025	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: MATTIELLO-ATASSI, MARIA			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 1611063	BURGER KING 3639		
License Type: Permanent Food Service	6125 W SUNRISE BLVD, PLANTATION 33313		
Inspection Date: 10/05/2021	Inspection Number: 3104378	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROGERS, VERNEL			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by empty boxes and trash can. Operator removed trash can. **Corrected On-Site**		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
License Number: 1610560	BANYAN RESTAURANT		
License Type: Permanent Food Service	250 RACQUET CLUB RD, WESTON 33326		
Inspection Date: 10/06/2021	Inspection Number: 3095021	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MUIR, TRICIA			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certification expired.		61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1624576

TACOS EL PAPI AND BLANKA'S BAKERY

License Type: Permanent Food Service

3591 N ANDREWS AVE STE D, OAKLAND PARK 33334

Inspection Date: 10/07/2021

Inspection Number: 3161920

Inspection Type: Complaint Full

Inspection Disposition: Emergency
Order Callback Not Complied

Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 4 propane tanks at back door - From follow-up inspection 2021-10-07: Observed same **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 4 propane tanks at back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335556		GALLO DE ORO RESTAURANT	
License Type: Permanent Food Service		1067 SW 27 AV, MIAMI 33135	
Inspection Date: 10/04/2021	Inspection Number: 3143964	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank inside kitchen kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336125		SUGAR FACTORY	
License Type: Permanent Food Service		1060 OCEAN DR, MIAMI BEACH 33139	
Inspection Date: 10/08/2021	Inspection Number: 3102842	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located upstairs going towards office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327551		TRATTORIA DELLA SPIAGGIA	
License Type: Permanent Food Service		3010 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 10/04/2021	Inspection Number: 3091908	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2320543		PIZZA CUBANA	
License Type: Permanent Food Service		9350 SW 40 ST, MIAMI 33165	
Inspection Date: 10/08/2021	Inspection Number: 3108274	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2318247 POPEYES CHICKEN & BISCUITS #9
 License Type: Permanent Food Service 20690 NW 2 AVE, NORTH MIAMI 33169-2509

Inspection Date: 10/08/2021 Inspection Number: 3163846 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage can and multiple boxes are blocking the door marked exit. Employee removed all items. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614285		FIREHOUSE SUBS	
License Type: Permanent Food Service		1620 MARGARET ST STE 105, JACKSONVILLE 32204	
Inspection Date: 10/08/2021	Inspection Number: 3098949	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. With big trash can and boxes	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614547		THE TREE CUP CATERED BY THE CHEF'S GARDEN	
License Type: Permanent Food Service		829 RIVERSIDE AVE, JACKSONVILLE 32204	
Inspection Date: 10/05/2021	Inspection Number: 3113892	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking shrimp with oil in one burner, kitchen - From follow-up inspection 2021-10-05: Not seen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613499		PIZZA HUT 4259	
License Type: Permanent Food Service		5751 MAIN ST STE 106, JACKSONVILLE 32208	
Inspection Date: 10/07/2021	Inspection Number: 3111779	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door blocked by green rack.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2612337		WENDY'S #65	
License Type: Permanent Food Service		4453 SOUTHSIDE BLVD, JACKSONVILLE 32216	
Inspection Date: 10/05/2021	Inspection Number: 3162534	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back exit kitchen door block with trash. Moved by manager. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2612360 CINEMARK TINSEL TOWN AND XD
 License Type: Permanent Food Service 4535 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 10/06/2021 Inspection Number: 3143834 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Grey fire extinguisher located on wall of entrance to kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2651969 PILON BURGERS
 License Type: Mobile Food Dispensing Vehicle 5960 RICHARD ST, JACKSONVILLE 32216

Inspection Date: 10/05/2021 Inspection Number: 1241661 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher stored inside shed is not in red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105275 SAVOR
 License Type: Permanent Food Service 901 21 ST, VERO BEACH 32960

Inspection Date: 09/29/2021 Inspection Number: 3162248 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Hook at handwash sink near cookline with no device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4601704 EASTWOOD GOLF COURSE
 License Type: Permanent Food Service 4600 BRUCE HERD LN, FORT MYERS 33905

Inspection Date: 10/04/2021 Inspection Number: 3123886 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed silver extinguisher next to flat top in the red for recharge.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4604659 MILLER'S FORT MYERS ALE HOUSE
 License Type: Permanent Food Service 4400 KERNEL CIRCLE, FORT MYERS 33916

Inspection Date: 10/05/2021 Inspection Number: 3162533 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FREED, JOSEPH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by kitchen entryway with needle in the red recharge area. Operator put in office. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5813022 TAKA TAKAS CAFE
 License Type: Permanent Food Service 9318 E COLONIAL DR, SUITE A-5 AND A-6, ORLANDO 32817

Inspection Date: 10/08/2021 Inspection Number: 3139251 Inspection Type: Routine - Food Inspection Disposition: Emergency Order Callback Complied
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	- From initial inspection : Exit door locked. For reporting purposes only. Exit door from dining room on North side of building, is locked and has table and chair in front of door area - From follow-up inspection 2021-10-08: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	Exit door locked. For reporting purposes only. Exit door from dining room on North side of building, is locked and has table and chair in front of door area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810117 ROCCO'S TACOS & TEQUILA BAR
 License Type: Permanent Food Service 7468 W SAND LAKE ROAD, ORLANDO 32819

Inspection Date: 10/07/2021 Inspection Number: 3162814 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by mixer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813285 BEN'S DOG HOUSE
 License Type: Permanent Food Service 4951 INTERNATIONAL DR K-95, ORLANDO 32819

Inspection Date: 10/06/2021 Inspection Number: 3099152 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer next to the grill not under a hood. - From follow-up inspection 2021-10-06: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5813293

MCDONALD'S WOODBURY

License Type: Permanent Food Service

12301 E COLONIAL DR, ORLANDO 32826

Inspection Date: 10/05/2021

Inspection Number: 3097345

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VAZQUEZ, JULITZA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005485 TIDELINE OCEAN RESORT AND SPA - PALM BEACH, A KIMPTON HOTEL
 License Type: Permanent Food Service 2842 S OCEAN BLVD, PALM BEACH 33480
 Inspection Date: 10/08/2021 Inspection Number: 3107507 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AHLE, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed deep fat fryer at sushi bar. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6022415 SURRY CO SMOKE HOUSE
 License Type: Permanent Food Service 33 SE 3 AVENUE #1, DELRAY BEACH 33483
 Inspection Date: 10/05/2021 Inspection Number: 3093386 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-10-05: Next unannounced **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6217593		CLEAR SKY ON CLEVELAND	
License Type: Permanent Food Service		418 CLEVELAND ST, CLEARWATER 33755	
Inspection Date: 10/04/2021	Inspection Number: 3098704	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HUNT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Under 3 tier sink by walk-in. Discussed with manager.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6207503		HOOTERS	
License Type: Permanent Food Service		2800 GULF TO BAY BLVD, CLEARWATER 33759	
Inspection Date: 10/05/2021	Inspection Number: 3135102	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HUNT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. High chair and garbage can blocking door n front wait station area. Back door blocked by cone. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215697		SMOKEY BONES BAR & FIRE GRILL #7588	
License Type: Permanent Food Service		2693 GULF TO BAY BLVD, CLEARWATER 33759	
Inspection Date: 10/06/2021	Inspection Number: 3113656	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HUNT, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher stored on floor .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Seminole County

License Number: 6902905 MCDONALDS #4199
 License Type: Permanent Food Service 3785 ORLANDO DR, SANFORD 32773

Inspection Date: 10/07/2021 Inspection Number: 3117140 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Large 3 inch conduit to the breaker panel is no longer secure. A junction box 4x8x12 is resting on the floor in the kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903945 HABANEROS MEXICAN RESTAURANT
 License Type: Permanent Food Service 220 WEKIVA SPRINGS RD, LONGWOOD 32779

Inspection Date: 10/08/2021 Inspection Number: 3163524 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501026

SCHMAGEL'S BAGELS

License Type: Permanent Food Service

69 HYPOLITA ST, SAINT AUGUSTINE 32084

Inspection Date: 10/08/2021

Inspection Number: 3098235

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Establishment uses griddle to fry bacon and make eggs on. - From follow-up inspection 2021-10-08: No change. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6603195

THE ISLAND KITCHEN

License Type: Permanent Food Service

2010 ORANGE AVE, FORT PIERCE 34950

Inspection Date: 10/07/2021

Inspection Number: 3143636

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tank in water heater room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407570		THE CITY OF DAYTONA BEACH (CONCESSION 2 SOUTHWEST)	
License Type: Permanent Food Service		3917 LPGA BLVD, DAYTONA BEACH 32124	
Inspection Date: 10/04/2021	Inspection Number: 3084963	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Electric boiler - fl81484 Viewed invoice	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 7405384		CHASES ON THE BEACH	
License Type: Permanent Food Service		3401 S ATLANTIC AVE, NEW SMYRNA BEACH 32169	
Inspection Date: 10/05/2021	Inspection Number: 3110800	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PICHARDO, RENEE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Main bar near handsink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7407439		WAKE UP NORTH	
License Type: Permanent Food Service		306 NORTH CAUSEWAY, NEW SMYRNA BEACH 32169	
Inspection Date: 10/06/2021	Inspection Number: 3102590	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: PICHARDO, RENEE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back door - From follow-up inspection 2021-10-06: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Volusia County

License Number: 7450866

SWEET & SALAO BY CHEF CARMEN

License Type: Mobile Food Dispensing Vehicle

923 S VOLUSIA AVE, VIN 1277, ORANGE CITY 32763

Inspection Date: 10/06/2021

Inspection Number: 1244419

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Washington County

License Number: 7700295 POPEYES LOUISIANA KITCHEN
 License Type: Permanent Food Service 1243 MAIN ST, CHIPLEY 32428

Inspection Date: 10/08/2021 Inspection Number: 3123902 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MEADOWS, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher on floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.