

Broward County

License Number: 1620235 PLAYA
 License Type: Permanent Food Service 3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3127550 Inspection Type: Routine - Food
 Inspector Name: MARTINEZ, RHEANNE

Inspection Disposition: Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected but still waiting for certificates. Operator showed invoice from 8/10/2021. **Corrective Action Taken**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620236 DRY STORAGE P2
 License Type: Permanent Food Service 3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3089575 Inspection Type: Routine - Food
 Inspector Name: MARTINEZ, RHEANNE

Inspection Disposition: Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected. Operator showed invoice 8/10/2021. **Corrective Action Taken**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620237 EMPLOYEE CAFETERIA
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3134342 Inspection Type: Routine - Food
 Inspector Name: MARTINEZ, RHEANNE

Inspection Disposition: Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected but still waiting for certificates. Per operator, boilers have been reinspected but still waiting for certificates. Operator showed invoice for 8/10/2021. **Corrective Action Taken**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620238 KOSHER KITCHEN
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3095881 Inspection Type: Routine - Food
 Inspector Name: MARTINEZ, RHEANNE

Inspection Disposition: Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected but still waiting for certificates. Operator showed invoice for 8/10/2021. **Corrective Action Taken**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1620239 BANQUET HALL KITCHEN LEVEL 700
 License Type: Permanent Food Service 3775 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3134343 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected but still waiting for the certificates. Operator showed invoice for 8/10/2021. **Corrective Action Taken**

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620240 BANQUET HALL MAIN KITCHEN
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3121451 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected but still waiting for certificates. Operator showed invoice 8/10/2021. **Corrective Action Taken**

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620241 GARDE MANGER 1M CONVENTION
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 10/27/2021 Inspection Number: 3120664 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, RHEANNE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers have been reinspected but still waiting for certificates. Operator showed invoice for 8/10/2021. **Corrective Action Taken**

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1625242 ACKEE THREE GRILL
 License Type: Permanent Food Service 8874 MIRAMAR PKWY STE 2, MIRAMAR 33025

Inspection Date: 10/26/2021 Inspection Number: 3111645 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MARTINEZ, RHEANNE

Violation Code Observation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in recharge zone next to unisex bathroom.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1622963

BAWARCHI BIRYANIS - FORT LAUDERDALE

License Type: Permanent Food Service

10190 W SAMPLE RD, CORAL SPRINGS 33065

Inspection Date: 10/26/2021

Inspection Number: 3139140

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624200

ACHSAH'S DELIGHT BAKERY

License Type: Permanent Food Service

977 SW 71 AVE, NORTH LAUDERDALE 33068

Inspection Date: 10/27/2021

Inspection Number: 3121274

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: ROGERS, VERNEL

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed Main kitchen exit door being blocked by mop bucket.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621453

HILTON FT LAUDERDALE BALLROOM & PANTRY

License Type: Permanent Food Service

505 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 10/26/2021

Inspection Number: 3119518

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1622025

HILTON FORT LAUDERDALE BEACH RESORT LE MARCHE

License Type: Permanent Food Service

505 N FT LAUDERDALE BEACH BLVD 102, FORT LAUDERDALE 33304

Inspection Date: 10/26/2021

Inspection Number: 3119517

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-10-26: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1621936

BURGER KING 16438

License Type: Permanent Food Service

4003 W OAKLAND PARK BLVD, LAUDERDALE LAKES 33313

Inspection Date: 10/29/2021

Inspection Number: 3104594

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROGERS, VERNEL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed main kitchen exit door path being blocked by empty boxes and trash can. Operator removed boxes and trash can. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801761

NACHOS MEXICAN BBQ

License Type: Permanent Food Service

320 N TAMIAMI TRL, PORT CHARLOTTE 33953

Inspection Date: 10/28/2021

Inspection Number: 3124575

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: KEATING, PATRICK

Violation Code

Observation

Violation Citation

49-05-4 Flammables stored near a source of ignition. For reporting purposes only. Operator moved item. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336801

MOXY SOUTH BEACH BAR MOXY

License Type: Permanent Food Service

915-955 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 10/28/2021

Inspection Number: 3136710

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Located in prep kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331228

DELICIAS DE ESPANA 2

License Type: Permanent Food Service

7382 -84 SW 40 ST, MIAMI 33155

Inspection Date: 10/28/2021

Inspection Number: 3122329

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ELDER, AUDREY

Violation Code ObservationViolation Citation48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Observed 3 propane tanks across from cook line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332367

SOKAI SUSHI BAR

License Type: Permanent Food Service

10726 NW 74 STREET, DORAL 33178

Inspection Date: 10/22/2021

Inspection Number: 3125648

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: CABANAS, NATALIE

Violation Code ObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2021-10-22: Portable fire extinguisher gauge in red zone. For reporting purposes only. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322895

HAMMOCKS GRILL

License Type: Permanent Food Service

14617 SW 104 ST, MIAMI 33186

Inspection Date: 10/27/2021

Inspection Number: 3137425

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code ObservationViolation Citation48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Observed by the 3 compartment sink. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613709 DOMINO'S #5103
 License Type: Permanent Food Service 870 CASSAT AVE, JACKSONVILLE 32205

Inspection Date: 10/26/2021 Inspection Number: 3102755 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Lots of boxes on the way	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614023 TOMMY MATTHEWS CONVENIENCE STORE
 License Type: Permanent Food Service 1540 WALNUT ST, JACKSONVILLE 32206

Inspection Date: 10/27/2021 Inspection Number: 3106668 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614511 SHA-GAREE'S SEAFOOD & MORE
 License Type: Permanent Food Service 1156 E 21 ST, JACKSONVILLE 32206

Inspection Date: 10/27/2021 Inspection Number: 3111360 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In storage closet/walk in cooler. Mgr removed it **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614730 MAGNUSON HOTEL
 License Type: Permanent Food Service 2228 PHILLIPS HWY, JACKSONVILLE 32207

Inspection Date: 10/27/2021 Inspection Number: 3119722 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired 4/24/21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Flagler County

License Number: 2800798

EL POLLO COLORAO

License Type: Permanent Food Service

227 ST JOE PLAZA DR STE A, PALM COAST 32164

Inspection Date: 10/27/2021

Inspection Number: 3111781

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Range in back of kitchen with no hood, also two fryers to the left of the rotisserie with no hood. Person in charge states is currently under construction, has new hood that will be installed soon. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3953241

TRISTANS AMAZING BITES

License Type: Mobile Food Dispensing Vehicle

5224 S DALE MABRY HWY, TAMPA 33611

Inspection Date: 10/27/2021

Inspection Number: 1245535

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. Owner ordered extinguisher, picking up today.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918192

CHINA 1

License Type: Permanent Food Service

4350 W WATER AVE STE 103, TAMPA 33614

Inspection Date: 10/26/2021

Inspection Number: 3097077

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JAIME, ANTONY

Violation CodeObservationViolation Citation

49-05-4

Increase in seating from 0 to 8. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4607286

EMBER KOREAN STEAKHOUSE

License Type: Permanent Food Service

7091 COLLEGE PKWY STE 9, FORT MYERS 33907

Inspection Date: 10/28/2021

Inspection Number: 3097481

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, ADADBELLA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher across from dish washer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703835

MIRANDA'S

License Type: Permanent Food Service

5323 W TENNESSEE ST, TALLAHASSEE 32304

Inspection Date: 10/27/2021

Inspection Number: 3130724

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: CHARLES, BRENDA

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-10-27: Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202374

YESTERDAYS RESTAURANT

License Type: Permanent Food Service

5174 NW 26 ST, OCALA 34482

Inspection Date: 10/26/2021

Inspection Number: 3110930

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARNER, DHANIQUA

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed fire extinguisher in dry storage area across from walk-in cooler in "re-charge" zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301803

JUPITER ISLAND CLUB - BEACH CLUB

License Type: Permanent Food Service

1 ESTRADA RD, HOBE SOUND 33455

Inspection Date: 10/26/2021

Inspection Number: 3114479

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.electrical panel door not set properly/by dishmachine area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809908 LITTLE CAESARS 601
 License Type: Permanent Food Service 11222 E COLONIAL DR, ORLANDO 32817

Inspection Date: 10/28/2021 Inspection Number: 3102089 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	Exit door locked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813566 CHEDDAR'S CASUAL CAFE
 License Type: Permanent Food Service 12201 E COLONIAL DR, ORLANDO 32826

Inspection Date: 10/25/2021 Inspection Number: 3156372 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Speed rack blocking back exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811853 PIZZA HUT
 License Type: Permanent Food Service 10395 NARCOOSSEE RD UNIT 200, ORLANDO 32832

Inspection Date: 10/26/2021 Inspection Number: 3117383 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - multiple trash cans **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814910

MOMO BLESSING BAKERY INC

License Type: Permanent Food Service

1350 HOLDEN AVE STE 105, ORLANDO, 32839

Inspection Date: 10/29/2021

Inspection Number: 3136977

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PASIECKI, VICTORIA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Equipment blocking rear exit door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911542

TIJUANA FLATS

License Type: Permanent Food Service

6113 W IRLO BRONSON MEMORIAL HWY, UNIT 101, KISSIMMEE 34747

Inspection Date: 10/26/2021

Inspection Number: 3151016

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked by trash can. Manager corrected **Corrected On-Site** - From follow-up inspection 2021-10-26: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005435

DEL AIRE GOLF CLUB

License Type: Permanent Food Service

4646 WHITE CEDAR LN, DELRAY BEACH 33445-7027

Inspection Date: 10/27/2021

Inspection Number: 3119542

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2021-10-27: Next unannounced. Operator called for inspection. Boiler certificate expired. Boiler on site used for sauna, not food production areas **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pasco County

License Number: 6113712

DUNKIN DONUTS

License Type: Permanent Food Service

28343 STATE ROAD 54, WESLEY CHAPEL 33543

Inspection Date: 10/27/2021

Inspection Number: 3105785

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher in red by kitchen exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

