

Alachua County

License Number: 1103063

BAYMONT INN & SUITES

License Type: Permanent Food Service

6901 NW 4 BLVD, GAINESVILLE 32607

Inspection Date: 11/22/2021

Inspection Number: 3134792

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Observed one boiler no certificate. ****Repeat Violation****

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Baker County

License Number: 1200050 MCDONALDS
 License Type: Permanent Food Service 1381 S 6 ST, MACCLENNY 32063

Inspection Date: 11/19/2021 Inspection Number: 3171147 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Side exit door is locked. Lock is broken. Lock smith has been called. Recommend putting a sign up so that your guest will know they cannot exit through the door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1200166 LAREDO'S
 License Type: Permanent Food Service 698F W MACCLENNY AVE, MACCLENNY 32063

Inspection Date: 11/22/2021 Inspection Number: 3157778 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By prep sink in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621169

ATLANTIC HOTEL & SPA - WILD THYME

License Type: Permanent Food Service

601 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 11/23/2021

Inspection Number: 3141820

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621170

ATLANTIC HOTEL & SPA - POOL BAR

License Type: Permanent Food Service

601 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 11/23/2021

Inspection Number: 3146785

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1611912

LONG JOHN SILVERS #31831

License Type: Permanent Food Service

2799 W OAKLAND PARK BLVD, OAKLAND PARK 33311

Inspection Date: 11/22/2021

Inspection Number: 3131823

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. For 3 extinguishers in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2332928 JW MARRIOT MARQUIS HOTEL BANQUET KITCHEN LEVEL 3
 License Type: Permanent Food Service 255 BISCAYNE BLVD WAY, MIAMI 33131

Inspection Date: 11/23/2021 Inspection Number: 3113323 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL123651 expired 10/18/21, FL123652 expired 10/18/21, FL123653 expired 10/18/21, FL123654 expired -10/18/21, FL123655 expired -10/18/21, FL123656, expired 10/18/21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332929 BOULUDSUD MEDITERRANEE
 License Type: Permanent Food Service 255 BISCAYNE BLVD WAY, MIAMI 33131

Inspection Date: 11/23/2021 Inspection Number: 3125717 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL123651, expiration date 10/18/21; FL 123652, expiration date 10/18/21; FL123653, expiration date 10/18/21; FL123654 Expiration date 10/18/21; FL123655, expiration date 10/18/21; FL123656, expiration date, 10/18/21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332977 JW MARRIOTT MARQUIS HOTEL CONCIERGE LOUNGE
 License Type: Permanent Food Service 255 BISCAYNE BLVD WAY, MIAMI 33131

Inspection Date: 11/23/2021 Inspection Number: 3107129 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL123651 expired 10/18/21, FL123652 expired 10/18/21, FL123653 expired 10/18/21, FL123654 expired -10/18/21, FL123655 expired -10/18/21, FL123656, expired 10/18/21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332978 BEAUX ARTS CONCIERGE LOUNGE
 License Type: Permanent Food Service 255 BISCAYNE BLVD WAY, MIAMI 33131

Inspection Date: 11/23/2021 Inspection Number: 3101046 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL123651 expired 10/18/21, FL123652 expired 10/18/21, FL123653 expired 10/18/21, FL123654 expired -10/18/21, FL123655 expired -10/18/21, FL123656, expired 10/18/21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2335302 THE UNION BEER STORE
 License Type: Permanent Food Service 1547 SW 8 STREET, MIAMI 33135

Inspection Date: 11/24/2021 Inspection Number: 3120992 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2021-11-24: observed vapors from cooked beef. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333852 SHIRAZ BISTRO & MARKET
 License Type: Permanent Food Service 9630 SW 77 AVE, MIAMI 33156

Inspection Date: 11/22/2021 Inspection Number: 3143384 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed a garbage can on front of the exit door. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614791

JIMMY JOHN'S GOURMET SANDWICHES STORE #2023

License Type: Permanent Food Service

510 AIRPORT CIRCLE DRIVE SUITE 106, JACKSONVILLE 32218

Inspection Date: 11/23/2021

Inspection Number: 3159591

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912144

CHIPOTLE MEXICAN GRILL #1626

License Type: Permanent Food Service

829 EAST BLOOMINGDALE AVE, BRANDON 33511

Inspection Date: 11/22/2021

Inspection Number: 3172020

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Near back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Observed back exit door blocked by boxes
Corrected-observed employee remove boxes from door way **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3915485

CHICK-FIL-A

License Type: Permanent Food Service

1504 E BRANDON BOULEVARD, BRANDON 33511-5625

Inspection Date: 11/22/2021

Inspection Number: 3127280

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code ObservationViolation Citation45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only.
On silver extinguisher stored under hand sink near walk-in freezer
Corrected-observed employee move to proper location **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917857

SWEETFISH

License Type: Permanent Food Service

811 N TAMPA ST STE 130, TAMPA 33602

Inspection Date: 11/24/2021

Inspection Number: 3172805

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: EHLERS, MICHAEL

Violation Code ObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Establishment added counter top fryers for frying tempura rolls.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3909017

MAMAS KITCHEN 3

License Type: Permanent Food Service

9312 N FLORIDA AVE, TAMPA 33612

Inspection Date: 11/23/2021

Inspection Number: 3125677

Inspection Type: Routine - Food

Inspection Disposition: Emergency Order Callback Complied

Inspector Name: CESAR, RACHEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Next to walk in freezer and on the right side of the dish machine. - From follow-up inspection 2021-11-22: **Time Extended** - From follow-up inspection 2021-11-23: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Next to walk in freezer and on the right side of the dish machine. - From follow-up inspection 2021-11-22: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. Next to walk in freezer and on the right side of the dish machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600711

ROCKY BAYOU C C SNACK BAR

License Type: Permanent Food Service

600 GOLF COURSE DR, NICEVILLE 32578

Inspection Date: 11/23/2021

Inspection Number: 3115142

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

49-02-4

Flammables stored/debris present in attic/basement. For reporting purposes only.
 - three propane tanks stored in downstairs storage room next to chest reach-in freezer. Manager took outside. ****Corrected On-Site****

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Orange County

License Number: 5815302

MARCO'S PIZZA

License Type: Permanent Food Service

2414 W OAK RIDGE ROAD UNIT A, ORLANDO 32809

Inspection Date: 11/23/2021

Inspection Number: 3130823

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Rear door exit blocked with cardboard boxes

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6021586 SILVERBALL MUSEUM
 License Type: Permanent Food Service 19 NE 3RD AVE, DELRAY BEACH 33483

Inspection Date: 11/22/2021 Inspection Number: 3144898 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located next to shipwreck bar. Fire extinguisher located at downstairs bar	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019178 CRAZY UNCLE MIKE'S
 License Type: Permanent Food Service 6450 N FEDERAL HWY, BOCA RATON 33487

Inspection Date: 11/23/2021 Inspection Number: 3137354 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6850308

EL CARRITO GRILL

License Type: Mobile Food Dispensing Vehicle

5303 14TH ST W, BRADENTON 34207

Inspection Date: 11/23/2021

Inspection Number: 1240722

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CATTLEY, RAYMOND

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on truck, extinguisher not charged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.