

Broward County

License Number: 1623984 WINGSTOP
 License Type: Permanent Food Service 9907 MIRAMAR PKWY, MIRAMAR 33025

Inspection Date: 12/22/2021 Inspection Number: 3143798 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NEALY, VALENCIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door block by discarded boxes in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621189 WINGSTOP RESTAURANT
 License Type: Permanent Food Service 5574 W OAKLAND PARK BLVD, LAUDERHILL 33313

Inspection Date: 12/21/2021 Inspection Number: 3170096 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROGERS, VERNEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319234 PULLMAN MIAMI AIRPORT - LE BAR
 License Type: Permanent Food Service 5800 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 12/20/2021 Inspection Number: 3122398 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2319235 PULLMAN MIAMI AIRPORT - TAVOLLO
 License Type: Permanent Food Service 5800 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 12/21/2021 Inspection Number: 3103563 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done. - From follow-up inspection 2021-12-21: At the time of the callback inspection observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done. **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2319236 PULLMAN MIAMI AIRPORT - EMPLOYEE CAFETERIA
 License Type: Permanent Food Service 5800 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 12/20/2021 Inspection Number: 3091340 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2331958 PULLMAN MIAMI AIRPORT - THE COFFEE CLUB
 License Type: Permanent Food Service 5800 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 12/20/2021 Inspection Number: 3134909 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332571 PULLMAN MIAMI AIRPORT - LA RIVIERA BAKERY KITCHEN
 License Type: Permanent Food Service 5800 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 12/20/2021 Inspection Number: 3122373 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed two new boilers without certificate, boilers number 4 and 5. As per Operator they purchase two new boilers, boiler number 4 and 5, waiting for certification to be done.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2335670 CAFE LA CARRETA
 License Type: Permanent Food Service 901 NW 17 ST L-M, MIAMI 33136

Inspection Date: 12/21/2021 Inspection Number: 3137317 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system. Notified Fire AHJ. For reporting purposes only. Observed in the kitchen on a prep table, an in-use portable gas fryer without a hood. Observed employee frying croquettes in the fryer at the time of the inspection.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332535 VIA EMILIA
 License Type: Permanent Food Service 1120 15 ST, MIAMI BEACH 33139

Inspection Date: 12/21/2021 Inspection Number: 3109464 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Observed plastic container and chairs stored in front of back exit door. - From follow-up inspection 2021-12-21: Marked exit/path to marked exit blocked. For reporting purposes only. Observed plastic container and chairs stored in front of back exit door. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329414 MUNCHKIN CATERERS
 License Type: Catering 5301 NW 23 AVE, MIAMI 33142

Inspection Date: 12/21/2021 Inspection Number: 1119786 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler, temperature 250 F. No certificate provided. - From follow-up inspection 2021-12-21: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler, temperature 250 F. No certificate provided. **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler, temperature 250 F. No certificate provided.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2336495 PATE CREOL
 License Type: Permanent Food Service 12997 W DIXIE HWY, NORTH MIAMI 33161

Inspection Date: 12/21/2021 Inspection Number: 3091473 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tanks larger than 2.5 lb. in kitchen area - From follow-up inspection 2021-12-21: On 12/21/2021 at the time of callback inspection Observed propane tanks larger than 2.5 lb. in kitchen area **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324832 POLLO TROPICAL 8
 License Type: Permanent Food Service 4211 NW 36 ST, MIAMI SPGS 331667301

Inspection Date: 12/20/2021 Inspection Number: 3153104 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed garbage container blocking the exit door in the backside of the establishment. Employee moved the garbage container. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2333687

MIAMI AIRPORT WEST/DORAL TOWNEPLACE SUITES

License Type: Permanent Food Service

10505 NW 36 ST, MIAMI 33178

Inspection Date: 12/20/2021

Inspection Number: 3102181

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2614668 FARM TO TABLE CAFE
 License Type: Permanent Food Service 807 CHILDRENS WAY, JACKSONVILLE 32207

Inspection Date: 12/20/2021 Inspection Number: 3128592 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment cook food products on stove with out a hood suppression system - From follow-up inspection 2021-12-20: No change **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615799 LA NUEVA OLA FOOD COMPANY
 License Type: Permanent Food Service 8106 OLD KINGS RD S STE 7, JACKSONVILLE 32217

Inspection Date: 12/20/2021 Inspection Number: 3176866 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large LP tank inside building by restroom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606521

C LEVEL WINE BAR AND BISTRO

License Type: Permanent Food Service

4450 BONITA BEACH RD STE #1, BONITA SPRINGS 34134

Inspection Date: 12/20/2021

Inspection Number: 3121671

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOMKOWSKI, DANIEL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit in back of restaurant near guest restroom blocked with boxes, unused chairs, and cleaning equipment.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216933 BACON BITCH
 License Type: Permanent Food Service 1120 CENTRAL AVE, ST. PETERSBURG 33705

Inspection Date: 12/22/2021 Inspection Number: 3124696 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: RANVILLE, AMANDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small flat top grill near cook line not being used under the hood and two small flat top griddles with 2 waffle presses in kitchen in use not under a hood. Observed oil based cooking spray being used. Inspector will notify fire codes. - From follow-up inspection 2021-12-22:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small flat top grill near cook line not being used under the hood and two small flat top griddles with 2 waffle presses in kitchen in use not under a hood. Observed oil based cooking spray being used. Inspector will notify fire codes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216673 COCONUT CHARLIE'S GRILL
 License Type: Permanent Food Service 6110 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 12/20/2021 Inspection Number: 3093605 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Polk County

License Number: 6308135 STREAMSONG RESORT- ROOF TOP BAR
 License Type: Permanent Food Service 1000 STREAMSONG DR, STREAMSONG 33834

Inspection Date: 12/20/2021 Inspection Number: 3113827 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6308136 STREAMSONG RESORT-3 MEAL RESTAURANT (P205)
 License Type: Permanent Food Service 1000 STREAMSONG DR, STREAMSONG 33834

Inspection Date: 12/20/2021 Inspection Number: 3107616 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, GUADALUPE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 124582 expired 6/18/21 124583 exp 6/18/21 124584 exp 6/18/21 124585 exp 6/18/21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Sarasota County

License Number: 6805221 THE ROSEMARY
 License Type: Permanent Food Service 411 N. ORANGE AVE, SARASOTA 34236

Inspection Date: 12/20/2021 Inspection Number: 3114541 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MCKEON, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Employee placed the tank outside. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. . **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805781 ROSEMARY & THYME
 License Type: Permanent Food Service 511 N ORANGE AVE, SARASOTA 34236

Inspection Date: 12/20/2021 Inspection Number: 3098166 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MCKEON, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Manager unlock the door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6500589 THE BEACON
 License Type: Permanent Food Service 830 ANASTASIA BLVD, ST AUGUSTINE 32080

Inspection Date: 12/21/2021 Inspection Number: 3175379 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Marked exit by restrooms blocked by screen. Person in charge states is non functioning door. Person in charge states fire inspector stated they did not need the exit, covered exit light during inspection. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501483 JACKS BAR B QUE
 License Type: Permanent Food Service 691 A1A BEACH BLVD, ST AUGUSTINE 32080

Inspection Date: 12/20/2021 Inspection Number: 3138264 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Establishment has a boiler in brewery room. Not turned on at time of inspection. Certification pending.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.