

Dade County

License Number: 2317115		CARVEL ICE CREAM # 788	
License Type: Permanent Food Service		4900 E 4 AVE, HIALEAH 330131509	
Inspection Date: 12/28/2021	Inspection Number: 3177495	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: JOSEPH, VANRIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed wood obstructing the backdoor. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2331150		POLLO TROPICAL RESTAURANT #89	
License Type: Permanent Food Service		19700 NW 27 AVE, MIAMI 33056	
Inspection Date: 12/28/2021	Inspection Number: 3150601	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: STUBBS, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage bin is blocking door marked exit. Manager removed garbage bin. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2334140		SPRIS PIZZA	
License Type: Permanent Food Service		3201 N MIAMI AVE #102, MIAMI 33127	
Inspection Date: 12/28/2021	Inspection Number: 3151115	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BROWN, JARON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 20 gallon propane tanks in prep area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2357660		NYC HOT DOGS	
License Type: Mobile Food Dispensing Vehicle		292 NW 54 ST, MIAMI 33127	
Inspection Date: 12/27/2021	Inspection Number: 1238968	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3913368

CBK CATERING & EVENTS

License Type: Catering

124 S FRANKLIN ST, TAMPA 33602

Inspection Date: 12/29/2021

Inspection Number: 1118916

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

49-05-4 Increase in seating from 0 to 28. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300662

MULLIGANS BEACH HOUSE BAR & GRILL

License Type: Permanent Food Service

2019 NE JENSEN BEACH BLVD, JENSEN BEACH 34957

Inspection Date: 12/29/2021

Inspection Number: 3133365

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At upstairs bar. Removed from use for service. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600090

TROPICAL PALM

License Type: Permanent Food Service

286 N MAIN ST, CRESTVIEW 32536

Inspection Date: 12/27/2021

Inspection Number: 3140742

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
- in upstairs storage room. Owner removed. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603961

JIMMY BUFFETT'S MARGARITAVILLE

License Type: Permanent Food Service

76 HARBOR BLVD, DESTIN 32541

Inspection Date: 12/27/2021

Inspection Number: 3151845

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
2 year expired 11/5/21

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5603962

JIMMY BUFFETT'S MARGARITAVILLE CAFE 2ND FLOOR

License Type: Permanent Food Service

76 HARBOR BLVD, DESTIN 32541

Inspection Date: 12/27/2021

Inspection Number: 3089325

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
2 year expired 11/5/21

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5810494

LOS AUTENTICOS CUBAN CAFE

License Type: Permanent Food Service

7339 E COLONIAL DR SUITE 1, ORLANDO 32807

Inspection Date: 12/27/2021

Inspection Number: 3107636

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: VALERIO, GRACE

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
- Facility added cooking stove next to three compartment sink for cooking shredded beef.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814910

MOMO BLESSING BAKERY INC

License Type: Permanent Food Service

1350 HOLDEN AVE STE 105, ORLANDO, 32839

Inspection Date: 12/28/2021

Inspection Number: 3136977

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.
Equipment blocking rear exit door - From follow-up inspection 2021-12-28:
Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6022450

JAMON JAMON

License Type: Permanent Food Service

33 SE 3 AVE UNIT 24, DELRAY BEACH 33483

Inspection Date: 12/28/2021

Inspection Number: 3175844

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6022179

COURTYARD BY MARRIOTT DELRAY BEACH

License Type: Permanent Food Service

135 SE 6 AVE, DELRAY BEACH 33483-5224

Inspection Date: 12/28/2021

Inspection Number: 3146230

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pasco County

License Number: 6113754

TREBLE MAKERS DUELING PIANO BAR & RESTAURANT

License Type: Permanent Food Service

6034 WESLEY GROVE BLVD, WESLEY CHAPEL 33544

Inspection Date: 12/28/2021

Inspection Number: 3177497

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DODGE, DAVID

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. 2 Blue Buffalo propane tanks On serving line under soda machine and coffee maker on serving line. Operator moved to outside building. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217400

CHECKERS F131

License Type: Permanent Food Service

6401 PARK BLVD, PINELLAS PARK 33781

Inspection Date: 12/27/2021

Inspection Number: 3120801

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

49-05-4

Increased seating from 0 to 19 seats

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407312

PANDA EXPRESS 2555

License Type: Permanent Food Service

5441 S WILLIAMSON BLVD, PORT ORANGE 32128

Inspection Date: 12/27/2021

Inspection Number: 3098868

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

46-01-4

Marked exit blocked. For reporting purposes only.
 -Observed marked exit door unable to be opened due to broken push bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.