

Alachua County

License Number: 1103534 GAINESVILLE SOULFOOD KITCHEN
License Type: Permanent Food Service 2201 NE 2 ST, GAINESVILLE 32609

Inspection Date: 01/07/2022 Inspection Number: 3156152 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CASEY, KEITH

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the red fire extinguisher by the back door is indicated in the recharge zone. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Brevard County

License Number: 1507056

B&B CARIBBEAN RESTAURANT

License Type: Permanent Food Service

6050 BADCOCK ST SE 1, PALM BAY 32909

Inspection Date: 01/07/2022

Inspection Number: 3149872

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in the kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

| | |
|--------------------------------------|---|
| License Number: 1625140 | OUTBACK AND CARRABBA'S EXPRESS |
| License Type: Permanent Food Service | 2307 E HALLANDALE BEACH BLVD, HALLANDALE BEACH 33009 |
| Inspection Date: 01/07/2022 | Inspection Number: 3140518 |
| Inspector Name: GANPAT, INDAR | Inspection Type: Routine - Food |
| | Inspection Disposition: Inspection Completed - No Further Action |
| <u>Violation Code</u> | <u>Observation</u> |
| 46-01-4 | Marked exit/path to marked exit blocked by garage cans .For reporting purposes only. Operator removed **Corrected On-Site** |
| | <u>Violation Citation</u> |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| License Number: 1624860 | CHINA GARDEN |
| License Type: Permanent Food Service | 7954 MCNAB RD, NORTH LAUDERDALE 33068 |
| Inspection Date: 01/07/2022 | Inspection Number: 3148849 |
| Inspector Name: ROGERS, VERNEL | Inspection Type: Routine - Food |
| | Inspection Disposition: Inspection Completed - No Further Action |
| <u>Violation Code</u> | <u>Observation</u> |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by empty boxes. Operator removed empty boxes. **Corrected On-Site** |
| | <u>Violation Citation</u> |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| License Number: 1621154 | BOONOOONOONOOS INC |
| License Type: Permanent Food Service | 2439 N STATE RD 7, LAUDERHILL 33313 |
| Inspection Date: 01/05/2022 | Inspection Number: 3155761 |
| Inspector Name: ROGERS, VERNEL | Inspection Type: Routine - Food |
| | Inspection Disposition: Inspection Completed - No Further Action |
| <u>Violation Code</u> | <u>Observation</u> |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by trash can. Operator removed trash can. **Corrected On-Site** |
| | <u>Violation Citation</u> |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| License Number: 1615835 | MIAMI SUBS |
| License Type: Permanent Food Service | 210 SW 40 AVE, PLANTATION 33317 |
| Inspection Date: 01/03/2022 | Inspection Number: 3168039 |
| Inspector Name: NEALY, VALENCIA | Inspection Type: Routine - Food |
| | Inspection Disposition: Inspection Completed - No Further Action |
| <u>Violation Code</u> | <u>Observation</u> |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. -Observed garbage can blocking exit door in kitchen. |
| | <u>Violation Citation</u> |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Columbia County

License Number: 2200678

SUBWAY 52619

License Type: Permanent Food Service

3586 W US HWY 90, LAKE CITY 32055

Inspection Date: 12/29/2021

Inspection Number: 3096702

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the back door in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

| | |
|--------------------------------------|---|
| License Number: 2335640 | CILANTRO AND LIMES |
| License Type: Permanent Food Service | 941 W PALM DR STE 7 AND 8, FLORIDA CITY 33034 |
| Inspection Date: 01/05/2022 | Inspection Number: 3137394 |
| Inspector Name: LEIDECKER, EDILMA | Inspection Type: Routine - Food |
| | Inspection Disposition: Inspection Completed - No Further Action |
| <u>Violation Code</u> | <u>Observation</u> |
| 46-04-4 | Exit door locked. For reporting purposes only. **Repeat Violation** |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| License Number: 2319392 | FISHER ISLAND BEACH CLUB |
| License Type: Permanent Food Service | 1 FISHER ISLAND DR, MIAMI 331090001 |
| Inspection Date: 01/06/2022 | Inspection Number: 3131088 |
| Inspector Name: WILLIAMS, ALFREDA | Inspection Type: Routine - Food |
| | Inspection Disposition: Warning Issued |
| <u>Violation Code</u> | <u>Observation</u> |
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in patio area. |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| License Number: 2302701 | FRITANGA CANA BRAVA 3 |
| License Type: Permanent Food Service | 2795 NW 7 ST, MIAMI 33125 |
| Inspection Date: 01/05/2022 | Inspection Number: 3107970 |
| Inspector Name: SAENZ, HILDA | Inspection Type: Routine - Food |
| | Inspection Disposition: Inspection Completed - No Further Action |
| <u>Violation Code</u> | <u>Observation</u> |
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| License Number: 2332507 | THE COCINITA MIAMI |
| License Type: Permanent Food Service | 70 SE 5 ST #107W, MIAMI 33131 |
| Inspection Date: 01/07/2022 | Inspection Number: 3155537 |
| Inspector Name: HENLEY, LATONYA | Inspection Type: Routine - Food |
| | Inspection Disposition: Administrative complaint recommended |
| <u>Violation Code</u> | <u>Observation</u> |
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed in the kitchen a flat top grill and grease fryer with no hood suppression system. |
| | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Dade County

License Number: 2322453 POLLO TROPICAL # 3
 License Type: Permanent Food Service 8975 S DIXIE HWY, MIAMI 33156

Inspection Date: 01/07/2022 Inspection Number: 3151070 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Observed a garbage can blocking the back exit **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2334240 PANNA NEW LATINO FOOD
 License Type: Permanent Food Service 3887 NW 107 AVE STE 101, DORAL 33178

Inspection Date: 01/06/2022 Inspection Number: 3153513 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CURRAS, YANLEE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Duval County

| | | | |
|--|---|---|--|
| License Number: 2615885 | BIRDIES | | |
| License Type: Permanent Food Service | 1044 PARK STREET, JACKSONVILLE | 32204 | |
| Inspection Date: 01/06/2022 | Inspection Number: 3138303 | Inspection Type: Routine - Food | Inspection Disposition: Administrative complaint recommended |
| Inspector Name: ESPINOSA-BECKERT, ILIANA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 4 tanks by office | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2614023 | TOMMY MATTHEWS CONVENIENCE STORE | | |
| License Type: Permanent Food Service | 1540 WALNUT ST, JACKSONVILLE | 32206 | |
| Inspection Date: 01/05/2022 | Inspection Number: 3106668 | Inspection Type: Routine - Food | Inspection Disposition: Call Back - Complied |
| Inspector Name: ESPINOSA-BECKERT, ILIANA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. K class - From follow-up inspection 2022-01-05: | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2615022 | V PIZZA | | |
| License Type: Permanent Food Service | 1406 HENDRICKS AVE, JACKSONVILLE | 32207 | |
| Inspection Date: 01/04/2022 | Inspection Number: 3154027 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: FIELDER, ANDREW | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20lb propane tank by back door of Sidecar Bar | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2612932 | EL TAPATIO ORIGINAL | | |
| License Type: Permanent Food Service | 7900 103 ST STE 32, JACKSONVILLE | 32210 | |
| Inspection Date: 01/04/2022 | Inspection Number: 3107821 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: MERCER, THOMAS | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two gas grill tanks stored inside, near back door | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Duval County

| | | | |
|--------------------------------------|---|--|--|
| License Number: 2610711 | NIYA MG | | |
| License Type: Permanent Food Service | 4500 SALISBURY RD #185, JACKSONVILLE | 32216 | |
| Inspection Date: 01/04/2022 | Inspection Number: 3144662 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: VILBRUN, JOSUE | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator using stove top for cooking with no hood suppression system | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2612656 | JACKSONVILLE SPRINGHILL SUITES | | |
| License Type: Permanent Food Service | 4385 SOUTHSIDE BLVD, JACKSONVILLE | 32216 | |
| Inspection Date: 01/07/2022 | Inspection Number: 3135325 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: VILBRUN, JOSUE | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Jurisdiction 135005 exp 06/06/2021 & Jurisdiction 135006 exp 06/06/2021 | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. | |
| License Number: 2600241 | VOO SWAR RESTAURANT & LOUNGE | | |
| License Type: Permanent Food Service | 51 ROBERT ST, ATLANTIC BEACH | 32233 | |
| Inspection Date: 01/07/2022 | Inspection Number: 3093686 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: GONZALEZ, MAYRA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. In use burner not under a hood system on cook line | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2615410 | BIGGIE'S PIZZA | | |
| License Type: Permanent Food Service | 13423 BEACH BLVD UNIT 203, JACKSONVILLE | 32246 | |
| Inspection Date: 01/03/2022 | Inspection Number: 3092750 | Inspection Type: Routine - Food | Inspection Disposition: Call Back - Extension given, pending |
| Inspector Name: FICHTER, GARRICK | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wall between dish area and office has a gauge in the red. - From follow-up inspection 2022-01-03: No change **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Duval County

License Number: 2613067

BAR-B-Q STICKS

License Type: Permanent Food Service

120 1/2 LEMON ST, NEPTUNE BEACH 32266

Inspection Date: 01/07/2022

Inspection Number: 3100536

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, MAYRA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryers and flat grills use for cooking not installed under a hood suppression system. **Repeat Violat

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800771 CARRABBA'S ITALIAN GRILL
 License Type: Permanent Food Service 160 CYPRESS EDGE PKWY, PALM COAST 32164

Inspection Date: 01/04/2022 Inspection Number: 3139362 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BADDING, MELANIE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. At bar area, extinguisher in red. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2800860 REDEFINED FOOD CO
 License Type: Permanent Food Service 160 CYPRESS POINT PKWY UNIT A106, PALM COAST 32164

Inspection Date: 01/06/2022 Inspection Number: 3177851 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-06-4 | Portable fire extinguisher is inaccessible. For reporting purposes only. Fire extinguisher by back door blocked by shelving unit. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by shelving on wheels. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Hillsborough County

| | | | |
|--------------------------------------|---|---|--|
| License Number: 3917332 | | VALE FOOD COMPANY TAMPA | |
| License Type: Permanent Food Service | | 501 N FRANKLIN ST, TAMPA 33602 | |
| Inspection Date: 01/06/2022 | Inspection Number: 3170333 | Inspection Type: Routine - Food | Inspection Disposition: Administrative complaint recommended |
| Inspector Name: SINGER, ROBERT | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-06-4 | Portable fire extinguisher is inaccessible. For reporting purposes only. Fire extinguisher stored behind reach in cooler. **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 3917203 | | BAY GARDENS RETIREMENT VILLAGE | |
| License Type: Permanent Food Service | | 1415 E 124TH AVE, TAMPA 33612 | |
| Inspection Date: 01/06/2022 | Inspection Number: 3097590 | Inspection Type: Routine - Food | Inspection Disposition: Warning Issued |
| Inspector Name: REGAS, ANTHONY | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher 4/2000 in red at left of kitchen. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher 4/2000 in red at left of kitchen. - From follow-up inspection 2022-01-07: **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 3918548 | | DUNKIN DONUTS | |
| License Type: Permanent Food Service | | 410 S 50 ST, TAMPA 33619 | |
| Inspection Date: 01/07/2022 | Inspection Number: 3117385 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: SANDERS, CLEVELAND | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher gauge in the red, located next to manager's office. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Leon County

License Number: 4703352 ALOFT
 License Type: Permanent Food Service 150 E CALL ST, TALLAHASSEE 32301

Inspection Date: 01/05/2022 Inspection Number: 3155755 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: STESLOW, KEVIN

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired, unable to renew certificate until new carbon monoxide detectors are installed **Warning** | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

Manatee County

License Number: 5105854

SOLORZANOS PIZZERIA LBK

License Type: Permanent Food Service

5610 GULF OF MEXICO DR STE 4, LONGBOAT KEY 34228

Inspection Date: 01/04/2022

Inspection Number: 3122662

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only
Above the small fryer in the preparation area.
As a repeat violation the importance of following proper

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301515

BIG APPLE PIZZA

License Type: Permanent Food Service

1858 JENSEN BEACH BLVD, JENSEN BEACH 34957

Inspection Date: 01/05/2022

Inspection Number: 3139817

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

| | | | |
|--------------------------------------|---|---|--|
| License Number: 5812729 | | TEAK NEIGHBORHOOD GRILL | |
| License Type: Permanent Food Service | | 901 S ORLANDO AVE, MAITLAND 32751 | |
| Inspection Date: 01/03/2022 | Inspection Number: 3174472 | Inspection Type: Complaint Partial | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: MONTGOMERY, DOREEN | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 LP tanks stored inside by back door | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 5814006 | | DUNKIN DONUTS #236 | |
| License Type: Permanent Food Service | | 486 N ORANGE AVE STE 5, ORLANDO 32801 | |
| Inspection Date: 01/06/2022 | Inspection Number: 3177841 | Inspection Type: Food-Licensing Inspection | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: PLEICONES, KIM | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Back kitchen exit door blocked by rolling rack and trash bags **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 5808468 | | SONNY'S REAL PIT BAR-B-Q | |
| License Type: Permanent Food Service | | 7423 S ORANGE BLOSSOM TRL, ORLANDO 32809 | |
| Inspection Date: 01/07/2022 | Inspection Number: 3178234 | Inspection Type: Complaint Full | Inspection Disposition: Call Back - Complied |
| Inspector Name: PASIECKI, VICTORIA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 46-01-4 | - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Trash bin and boxes blocking back exit. Operator moved items **Corrected On-Site** - From follow-up inspection 2022-01-07: **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Trash bin and boxes blocking back exit. Operator moved items **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Palm Beach County

License Number: 6011000 CHEESECAKE FACTORY (THE)
 License Type: Permanent Food Service 5530 GLADES RD, BOCA RATON 33431

Inspection Date: 01/04/2022 Inspection Number: 3177982 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, HAIDA

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expire since 03.25.2021. | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

License Number: 6019301 TRAMONTI RESTAURANT
 License Type: Permanent Food Service 111 E ATLANTIC AVE, DELRAY BEACH 33444

Inspection Date: 01/03/2022 Inspection Number: 3144480 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to hand wash sink next to cook line, and at bar | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Pinellas County

License Number: 6216933

BACON BITCH

License Type: Permanent Food Service

1120 CENTRAL AVE, ST. PETERSBURG 33705

Inspection Date: 01/06/2022

Inspection Number: 3124696

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: RANVILLE, AMANDA

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small flat top grill near cook line not being used under the hood and two

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805141

PATRICK'S 1481

License Type: Permanent Food Service

1481 MAIN STREET, SARASOTA 34236

Inspection Date: 01/05/2022

Inspection Number: 3151112

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Exposed wiring above the door of the walk in cooler.
As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. **Repeat V

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905153 DUNKIN DONUTS 204
License Type: Permanent Food Service 801 W SR 434, LONGWOOD 32750

Inspection Date: 01/05/2022 Inspection Number: 3176870 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only. At the back door a sign directs to a fire extinguisher with no extinguisher in the area | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6905318 TACO BELL 036021
License Type: Permanent Food Service 126 S RONALD REAGAN BLVD, LONGWOOD 32750

Inspection Date: 01/04/2022 Inspection Number: 3177872 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

St. Johns County

License Number: 6502071

BURGER KING

License Type: Permanent Food Service

2455 SR 207, SAINT AUGUSTINE 32084

Inspection Date: 01/04/2022

Inspection Number: 3127765

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Garbage can/boxes blocking back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407477

DUNKIN DONUTS

License Type: Permanent Food Service

2450 S RIDGEWOOD AVE, SOUTH DAYTONA 32119

Inspection Date: 01/04/2022

Inspection Number: 3177979

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
-trash can and cardboard boxes blocking marked exit. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407232

RED BOWL

License Type: Permanent Food Service

1820 DUNLAWTON AVE #105, PORT ORANGE 32127

Inspection Date: 01/07/2022

Inspection Number: 3141903

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. Access to back exit door blocked by bicycle, chairs. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.