

Brevard County

License Number: 1506708

FLAVORS OF INDIA

License Type: Permanent Food Service

5675 N ATLANTIC AVE # 117, COCOA BEACH 32931

Inspection Date: 01/24/2022

Inspection Number: 3157090

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1625282

HOLI VEGAN KITCHEN

License Type: Permanent Food Service

701 N FEDERAL HWY SUITE 103, HALLANDALE BEACH 33009

Inspection Date: 01/25/2022

Inspection Number: 3148334

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code ObservationViolation Citation

45-04-4

Use of cooking equipment producing vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Operator cooking scrambled tofu on electric counter top burner. No oil or grease used for cooking per chef. Reported to fire inspector Charles.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617448

LA PARALLA DE PANCHO

License Type: Permanent Food Service

628 S SR 7, MARGATE 33068

Inspection Date: 01/24/2022

Inspection Number: 3139702

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROGERS, VERNEL

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by stove.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621172

WINGSTOP

License Type: Permanent Food Service

4570 LYONS RD STE 104, COCONUT CREEK 33073

Inspection Date: 01/24/2022

Inspection Number: 3157933

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door block with garbage containers.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1613419

VUE KITCHEN

License Type: Permanent Food Service

2670 E SUNRISE BLVD, FORT LAUDERDALE 33304

Inspection Date: 01/24/2022

Inspection Number: 3162311

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093563 exp 2-21-2021; 099900 exp 2-21-2021 **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093563 exp 2-21-2021; 099900 exp 2-21-2021 **Repeat Violation** - From follow-up inspection 2022-01-25: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093563 exp 2-21-2021; 099900 exp 2-21-2021 **Repeat Violation** **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621071

BANQUET KITCHEN

License Type: Permanent Food Service

2670 E SUNRISE BLVD, FORT LAUDERDALE 33304

Inspection Date: 01/24/2022

Inspection Number: 3162442

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093563 exp 2-21-2021; 099900 exp 2-21-2021 **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--

Dade County

License Number: 2336318

WORLD FAMOUS

License Type: Permanent Food Service

19401 NW 27 AVE UNIT 701, MIAMI GARDENS 33056

Inspection Date: 01/27/2022

Inspection Number: 3156664

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: STUBBS, CHRISTINE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage can blocking marked exit. Manager removed garbage. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327943

PASTA PREP COMMON AREA

License Type: Permanent Food Service

1753 SW 3 AVE, MIAMI 33129

Inspection Date: 01/26/2022

Inspection Number: 3164673

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333486

LA GUADALUPANA ICE CREAM INC

License Type: Permanent Food Service

1058 SW 1 ST, MIAMI 33130

Inspection Date: 01/26/2022

Inspection Number: 3165255

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334796

PUROAST COFFEE

License Type: Permanent Food Service

632 S MIAMI AVE, MIAMI 33130

Inspection Date: 01/28/2022

Inspection Number: 3156872

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336808

HOTEL INDIGO MIAMI BRICKELL/ ATWELL SUITES MIAMI BRICKELL

License Type: Permanent Food Service

145 SW 11 STREET, MIAMI 33130

Inspection Date: 01/25/2022

Inspection Number: 3156149

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: CABANAS, NATALIE

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
At the time of the inspection observed two boilers with 700,000 btu. No boiler certificate provided establishment is still in process to get boilers certified. -
From follow-up inspection 2022-01-25: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
At the time of the inspection observed two boilers with 700,000 btu. No boiler certificate provided establishment is still in process to get boilers certified. **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
At the time of the inspection observed two boilers with 700,000 btu. No boiler certificate provided establishment is still in process to get boilers certified.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2336996

CARROT EXPRESS

License Type: Permanent Food Service

1111 BRICKELL AVE UNIT 155, MIAMI 33131

Inspection Date: 01/25/2022

Inspection Number: 3157676

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed in the back prep area, fire extinguisher missing behind small reach in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332777

CATCH GRILL AND BAR

License Type: Permanent Food Service

1633 N BAYSHORE DR, MIAMI 33132

Inspection Date: 01/26/2022

Inspection Number: 3149115

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2330553 PARADISE CAFE
 License Type: Permanent Food Service 4333 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/26/2022 Inspection Number: 3170896 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 1 missing certificate for boiler 130111.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2333138 HOLIDAY INN HOTEL 4TH FLOOR
 License Type: Permanent Food Service 4333 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/26/2022 Inspection Number: 3165501 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed missing certificate for one of the boilers.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334027 PLATE
 License Type: Permanent Food Service 2105 CORAL WAY, MIAMI 33145

Inspection Date: 01/25/2022 Inspection Number: 3157258 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed cooking bacon. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330369

MOJO DONUTS + FRIED CHICKEN

License Type: Permanent Food Service

8870 SW 40 ST UNIT 13, MIAMI 33165

Inspection Date: 01/24/2022

Inspection Number: 3165509

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WILLIAMS, ALFREDA

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Observed exit door blocked, reach in cooler blocking door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337140

SWEET MANIFESTO

License Type: Permanent Food Service

9420 NW 41 ST STALL 7, DORAL 33178

Inspection Date: 01/28/2022

Inspection Number: 3180141

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
At the time of the inspection observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per operator establishment is still in process of certification.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2322161

COMPASS GROUP USA INC

License Type: Permanent Food Service

11800 SW 147 AVE, MIAMI 33196

Inspection Date: 01/26/2022

Inspection Number: 3166398

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed 2 boilers with 500,000 BTU. No boiler certificate available.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2613625

LITTLE JOE'S CAFE BY AKEL'S

License Type: Permanent Food Service

245 RIVERSIDE AVENUE #195, JACKSONVILLE 32202

Inspection Date: 01/24/2022

Inspection Number: 3149347

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking eggs

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615171

FRED COTTENS LANDMARK BBQ

License Type: Permanent Food Service

1417 N MAIN ST, JACKSONVILLE 32206

Inspection Date: 01/25/2022

Inspection Number: 3168684

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. By cook line

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608983

PICCADILLY CAFETERIA

License Type: Permanent Food Service

3216 S UNIVERSITY BLVD, JACKSONVILLE 32216

Inspection Date: 01/26/2022

Inspection Number: 3169379

Inspection Type: Routine - Food

Inspection Disposition: Emergency Order Callback Complied

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. No boiler certificate posted for two boilers in storage room. **Repeat Violation**
- From follow-up inspection 2022-01-26: At Callback : still the same **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. No boiler certificate posted for two boilers in storage room. **Repeat Violation**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2609701 KUSINA
 License Type: Permanent Food Service 4190 BELFORT RD SUITE 120, JACKSONVILLE 32216

Inspection Date: 01/28/2022 Inspection Number: 3171702 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator has 2 electric stove tops on cook line used to cook foods that are not under a hood system **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2651969 PILON BURGERS
 License Type: Mobile Food Dispensing Vehicle 5960 RICHARD ST, JACKSONVILLE 32216

Inspection Date: 01/27/2022 Inspection Number: 1245479 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher stored inside shed is not in red **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615422 SUPER TIENDA LATINA Y RESTAURANTE
 License Type: Permanent Food Service 3935 TOLEDO RD STE 6, JACKSONVILLE 32217

Inspection Date: 01/24/2022 Inspection Number: 3149428 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by large utensils	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611366 KRYSTAL
 License Type: Permanent Food Service 1009 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 01/27/2022 Inspection Number: 3142324 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by rear exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615762 WINGSTOP
 License Type: Permanent Food Service 9416 ARLINGTON EXPRESSWAY, JACKSONVILLE 32225

Inspection Date: 01/24/2022 Inspection Number: 3144916 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Gasoline can for power washer half full stored in back of kitchen near wall mounted hot water heaters	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614747 DANO'S DINER
 License Type: Permanent Food Service 1487 MAYPORT RD UNITS 7-9, ATLANTIC BEACH 32233

Inspection Date: 01/24/2022 Inspection Number: 3134645 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: GONZALEZ, MAYRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Pathway to marked exit blocked by miscellaneous, located by bathroom. - From follow-up inspection 2022-01-12: Pathway still blocked. **Time Extended** - From follow-up inspection 2022-01-24: Exit door pathway still blocked. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800836

SUSHI 99

License Type: Permanent Food Service

250 PALM COAST PKWY NE UNIT 213, PALM COAST 32137

Inspection Date: 01/24/2022

Inspection Number: 3151933

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Back exit door blocked by partition, items stored at end of hallway past restrooms.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800868

SYLVAIN'S CARIBBEAN RESTAURANT & CATERING

License Type: Permanent Food Service

1000 PALM COAST PKWY SW, SUITES 101 AND 102, PALM COAST 32137

Inspection Date: 01/24/2022

Inspection Number: 3151229

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Marked exit by hot holding line blocked by items.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917857 SWEETFISH
 License Type: Permanent Food Service 811 N TAMPA ST STE 130, TAMPA 33602

Inspection Date: 01/24/2022 Inspection Number: 3172805 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment added counter top fryers for frying tempura rolls. - From follow-up inspection 2022-01-24: Establishment added counter top fryers for frying tempura rolls. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917682 BIG EASY BAR
 License Type: Permanent Food Service 1704 E 7 AVE, TAMPA 33605

Inspection Date: 01/27/2022 Inspection Number: 3123580 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: KLUSENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer in new storage/prep area - From follow-up inspection 2022-01-27: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer in new storage/prep area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3916066 CHIPOTLE MEXICAN GRILL #828
 License Type: Permanent Food Service 2576 E FOWLER AVE, TAMPA 33612

Inspection Date: 01/28/2022 Inspection Number: 3144889 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CESAR, RACHEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. It is missing from handwash sink near cook line. For reporting purposes only. K Class fire extinguisher stored in managers office.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3952595

MARLENE'S ORIGINAL BREAKFAST SANDWICH

License Type: Mobile Food Dispensing Vehicle

7206 N DALE MABRY, TAMPA 33614

Inspection Date: 01/28/2022

Inspection Number: 1248189

Inspection Type: Complaint Full

Inspection Disposition: Emergency
Order Callback Time Extension

Inspector Name: SANDERS, CLEVELAND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Stored inside shed. - From follow-up inspection 2022-01-28: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Stored inside shed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105752

UNCLE NICKS NY BAGELS SUBS AND SALADS

License Type: Permanent Food Service

5917 MANATEE AVE W, BRADENTON 34209

Inspection Date: 01/26/2022

Inspection Number: 3139903

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
4 propane tanks stored inside the establishment.
Manager placed the tanks outside. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301530

THE TWISTED TUNA

License Type: Permanent Food Service

4290 SE SALERNO RD, STUART 34997

Inspection Date: 01/25/2022

Inspection Number: 3179969

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. One extra Fire extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5601795

CHICKEN N THE EGG

License Type: Permanent Food Service

348 MIRACLE STRIP PKWY, FT WALTON BCH 325485200

Inspection Date: 01/25/2022

Inspection Number: 3151069

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

47-03-4

Observed exposed electrical wiring due to cover missing next to hand washing sink between prep line and cook line. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814057 SAISEI KITCHEN AND BAR
 License Type: Permanent Food Service 100 S EOLA DR UNIT 104, ORLANDO 32801

Inspection Date: 01/25/2022 Inspection Number: 3097300 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 1 tank by kitchen exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810922 CRACKER BARREL #499
 License Type: Permanent Food Service 13300 S ORANGE BLOSSOM TRL, ORLANDO 32837

Inspection Date: 01/24/2022 Inspection Number: 3152229 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - trash stored in front of door - operator removed trash **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6020870

FURIN SUSHI AND THAI

License Type: Permanent Food Service

4801 LINTON BLVD STE B-2, DELRAY BEACH 33445

Inspection Date: 01/25/2022

Inspection Number: 3166207

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6010474

WENDY'S OLD FASHION HAMBURGERS

License Type: Permanent Food Service

4950 LINTON BLVD, DELRAY BEACH 33445-6647

Inspection Date: 01/25/2022

Inspection Number: 3142824

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only. Operator replaced **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020537

CASA MIA

License Type: Permanent Food Service

337 E INDIANTOWN RD, JUPITER 33477

Inspection Date: 01/26/2022

Inspection Number: 3150252

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Kitchen/corrective action taken/operator stored LP gas tank outside. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6022422

SALVO'S

License Type: Permanent Food Service

33 SE 3 AVE UNIT 17, DELRAY BEACH 33483

Inspection Date: 01/26/2022

Inspection Number: 3176697

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6216008 DON'S TACO AUTHENTIC MEXICAN RESTAURANT
 License Type: Permanent Food Service 672 E TARPON AVE, TARPON SPRINGS 34689

Inspection Date: 01/26/2022 Inspection Number: 3091513 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217434 FUSION STREET EATERY LLC
 License Type: Permanent Food Service 422 PATRICIA AVE, DUNEDIN 34698

Inspection Date: 01/27/2022 Inspection Number: 3092221 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed back door blocked by reachin freezer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6800060

SANDCASTLE RESTAURANT

License Type: Permanent Food Service

1540 BEN FRANKLIN DR, SARASOTA 34236

Inspection Date: 01/27/2022

Inspection Number: 3151259

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exposed wiring under the heating unit on the cook line server side.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904918

BREAKFAST CLUB OF CASSELBERRY

License Type: Permanent Food Service

3385 SOUTH HIGHWAY 17-92 SUITE 189, CASSELBERRY 32707

Inspection Date: 01/24/2022

Inspection Number: 3146246

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
New stove top oven installed 2 burner are extended beyond hood system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501023 PURPLE OLIVE
 License Type: Permanent Food Service 4255 A1A SOUTH UNIT 6, SAINT AUGUSTINE 32080

Inspection Date: 01/28/2022 Inspection Number: 3100342 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GROTZ, CINDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. For reporting purposes only. Table top fryer in use opposite from cookline hood.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501740 BURGER KING
 License Type: Permanent Food Service 141 GATEWAY CIR, ST. JOHNS 32259

Inspection Date: 01/27/2022 Inspection Number: 3180296 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in red zone. (low charge)Unit by rear kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6650505 HOT GIRLZ SOULFOOD
License Type: Mobile Food Dispensing Vehicle 100 N KING HWY, VIN 6626, FORT PIERCE 34945

Inspection Date: 01/25/2022 Inspection Number: 1248014 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602788 HILTON GARDEN INN @ PGA VILLAGE
License Type: Permanent Food Service 8540 COMMERCE CENTRE DR, PORT ST LUCIE 34986

Inspection Date: 01/26/2022 Inspection Number: 3147171 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HYNES, MONICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

