

Alachua County

License Number: 1102497

THE ATRIUM AT GAINESVILLE

License Type: Permanent Food Service

2431 NW 41ST ST, GAINESVILLE 32606

Inspection Date: 02/14/2022

Inspection Number: 3168855

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed the silver fire extinguisher on the dish wash machine wall is in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506372

JOANNE'S BEACHSIDE CAFE INC

License Type: Permanent Food Service

6006 N ATLANTIC AVE, CAPE CANAVERAL 32920

Inspection Date: 02/16/2022

Inspection Number: 3091385

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: FRANZ, LINDA

Violation CodeObservationViolation Citation

47-03-4

- From initial inspection : Observed electrical wiring exposed in breaker box.
Breaker box missing cover. For reporting purposes only. - From follow-up
inspection 2022-02-16: Corrected **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506553

LA CREPE DE FRANCE

License Type: Permanent Food Service

7720 NORTH WICKHAM ROAD, SUITE 109-110, MELBOURNE 32940

Inspection Date: 02/16/2022

Inspection Number: 3155496

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Red one
by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1901353

TACO BELL #6145

License Type: Permanent Food Service

3763 S SUNCOAST BLVD, HOMOSASSA 34448

Inspection Date: 02/18/2022

Inspection Number: 3147170

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEMARCO, AMBER

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher by front counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200686

CHICK-FIL-A

License Type: Permanent Food Service

3200 US 90 W, LAKE CITY 32055

Inspection Date: 02/16/2022

Inspection Number: 3142787

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In recharge zone by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335048

NEW YORK/ROMA PIZZA & PASTA

License Type: Permanent Food Service

125 SE 2 AVE, MIAMI 33131

Inspection Date: 02/14/2022

Inspection Number: 3090435

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed establishment has a portable double grease fryer in the kitchen set up on top of a flip top r

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335302

THE UNION BEER STORE

License Type: Permanent Food Service

1547 SW 8 STREET, MIAMI 33135

Inspection Date: 02/18/2022

Inspection Number: 3160519

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed no cooking at time of inspection (no hood available) when cooking.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335289

MINA BISTRO

License Type: Permanent Food Service

63 NW 9 ST, MIAMI 33136

Inspection Date: 02/14/2022

Inspection Number: 3151086

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed employee frying empanadas in the small double portable grease fryer during the inspection.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2331114

JAYA AT SETAI

License Type: Permanent Food Service

2001 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 02/18/2022

Inspection Number: 3160475

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ELDER, AUDREY

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near Buffet area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificates expired on 03-01-2019.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2336990

SWEETGREEN

License Type: Permanent Food Service

1929 PURDY AVE, MIAMI BEACH 33139

Inspection Date: 02/15/2022

Inspection Number: 3155124

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed 2 rolling carts blocking back exit door at ware washing area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336009

CENTERPLATE

License Type: Permanent Food Service

1901 CONVENTION CENTER DRIVE, MIAMI BEACH 33139-1820

Inspection Date: 02/14/2022

Inspection Number: 3128169

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number 096978 expired on 9/05/2021. Observed a Fire Pressure Vessel Report posted in boiler room, no boiler

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2334186 POLLO TROPICAL
 License Type: Permanent Food Service 7090 CORAL WAY, MIAMI 33155

Inspection Date: 02/15/2022 Inspection Number: 3173828 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-03-4	Gas water heater exhaust not venting properly/ in disrepair. Observed gas water heater vent exhaust in disrepair, not affixed to exhaust pipe to allow proper ventilation. For reporting purposes only.	509.211(2)(a) FS Reporting: (2) (a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.

License Number: 2315390 WENDY'S 1703
 License Type: Permanent Food Service 1532 NE 163 ST, NORTH MIAMI BEACH 33162

Inspection Date: 02/14/2022 Inspection Number: 3180089 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed blocked by bun trays, and trolley cart.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331029 PANDA EXPRESS #1174
 License Type: Permanent Food Service 1405 NE 163 STREET, NORTH MIAMI BEACH 33162

Inspection Date: 02/18/2022 Inspection Number: 3151837 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed blocked by boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325136 PAPA JOHNS #555
 License Type: Permanent Food Service 20312 NW 2 AVE, MIAMI 33169

Inspection Date: 02/14/2022 Inspection Number: 3181793 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed blocked with 2 garbage bins. **Repeat Violation** **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2337032		ELLAS OYSTER BAR	
License Type: Permanent Food Service		9420 NW 41 ST UNIT 105, DORAL 33178	
Inspection Date: 02/17/2022		Inspection Number: 3180943	
Inspector Name: CRUZ, EDGAR		Inspection Type: Food-Licensing Inspection	
		Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. At the time of the inspection observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per opera	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2337171		JUICE & JAVA DORAL	
License Type: Permanent Food Service		9420 NW 41 ST # 115, DORAL 33178	
Inspection Date: 02/17/2022		Inspection Number: 3168497	
Inspector Name: CRUZ, EDGAR		Inspection Type: Food-Licensing Inspection	
		Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per operator establishment is still in	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2337173		THE MARKET MILKSHAKE BAR	
License Type: Permanent Food Service		9420 NW 41 ST # 114, DORAL 33178	
Inspection Date: 02/17/2022		Inspection Number: 3179395	
Inspector Name: CRUZ, EDGAR		Inspection Type: Food-Licensing Inspection	
		Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per operator establishment is still in	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2337174		POKE MIA	
License Type: Permanent Food Service		9420 NW 41 ST 101, DORAL 33178	
Inspection Date: 02/17/2022		Inspection Number: 3179810	
Inspector Name: CRUZ, EDGAR		Inspection Type: Food-Licensing Inspection	
		Inspection Disposition: Inspection Completed - No Further Action	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per operator establishment is still in	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2337175 IN RAMEN, ASIAN STREET EATERY
 License Type: Permanent Food Service 9420 NW 41 ST UNIT 102, DORAL 33178

Inspection Date: 02/17/2022 Inspection Number: 3181391 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CURRAS, YANLEE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337176 TRATTORIA DAL PLIN
 License Type: Permanent Food Service 9420 NW 41 ST #109, DORAL 33178

Inspection Date: 02/17/2022 Inspection Number: 3181259 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.
 At the time of the inspection observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per opera

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337177 PUBBELLY SUSHI
 License Type: Permanent Food Service 9420 NW 41 ST UNIT 103, DORAL 33178

Inspection Date: 02/17/2022 Inspection Number: 3181392 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.
 At the time of the inspection observed two boilers with an input rating of 650,000 BTU's. No boiler certification provided. As per opera

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337178 BFF BURGERS
 License Type: Permanent Food Service 9420 NW 41 ST #110, DORAL 33178

Inspection Date: 02/17/2022 Inspection Number: 3181908 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CURRAS, YANLEE

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2337181

ASH PIZZA DORAL

License Type: Permanent Food Service

9420 NW 41 ST, # 108, DORAL 33178

Inspection Date: 02/18/2022

Inspection Number: 3182169

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2614739 COURTHOUSE CAFE
 License Type: Permanent Food Service 501 W ADAMS ST, JACKSONVILLE 32202

Inspection Date: 02/17/2022 Inspection Number: 3181772 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Grits cooking on burner, frying oil for fish on separate burner for lunch hours. No hood suppression s	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614857 JAZZYS RESTAURANT AND LOUNGE
 License Type: Permanent Food Service 901 KING ST, JACKSONVILLE 32204

Inspection Date: 02/17/2022 Inspection Number: 3157947 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At barn	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614668 FARM TO TABLE CAFE
 License Type: Permanent Food Service 807 CHILDRENS WAY, JACKSONVILLE 32207

Inspection Date: 02/18/2022 Inspection Number: 3128592 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment cook food products on stove with out a hood suppression syst	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609829 MONROE'S SMOKEHOUSE BAR-B-Q
 License Type: Permanent Food Service 10771 BEACH BLVD, JACKSONVILLE 32246

Inspection Date: 02/17/2022 Inspection Number: 3157426 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Light switch to right of walk in freezer door is in disrepair with exposed wiring.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614871

CANTINA LOUIE

License Type: Permanent Food Service

9726 TOUCHTON ROAD, JACKSONVILLE 32246

Inspection Date: 02/18/2022

Inspection Number: 3160849

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Observed 7 propane tanks larger than 2.7 pounds stored inside dining room area near front door entrance by bar

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800702

FAIRFIELD INN & SUITE

License Type: Permanent Food Service

400 OLD KING RD N, PALM COAST 32137

Inspection Date: 02/17/2022

Inspection Number: 3097805

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. At the time of inspection boiler certificate expired 12/17/21.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hillsborough County

License Number: 3917587

FALAFEL MARKET

License Type: Permanent Food Service

1076 E BRANDON BLVD, BRANDON 33511

Inspection Date: 02/18/2022

Inspection Number: 3160868

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small fryer not located under hood system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3915807

NORTH 30TH SPORTS PUB & GRILLE

License Type: Permanent Food Service

11402 N 30 ST, TAMPA 33612

Inspection Date: 02/17/2022

Inspection Number: 3140288

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CESAR, RACHEL

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks in the back prep area. Operator removed propane tanks from building and placed in outside shed. **Corrected

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606005

PAPA JOHN'S PIZZA 3472

License Type: Permanent Food Service

4901 PALM BEACH BLVD STE 60, FORT MYERS 33905

Inspection Date: 02/17/2022

Inspection Number: 3176320

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by office in red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105195

ELENI'S PIZZA WORKS

License Type: Permanent Food Service

6711 15 ST E, SARASOTA 34243

Inspection Date: 02/16/2022

Inspection Number: 3128878

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.
Electrical outlet in the dining room next to the wine rack.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201415

CHARLIE HORSE

License Type: Permanent Food Service

2426 E SILVER SPRINGS BLVD, OCALA 34470

Inspection Date: 02/14/2022

Inspection Number: 3139725

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near kitchen entrance door. Silver extinguisher is in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019103

G K DUMPLIN

License Type: Permanent Food Service

1675 B FORUM PLACE, WEST PALM BEACH 33401

Inspection Date: 02/14/2022

Inspection Number: 3177464

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTILLA, NATHALIE

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed counter deep fryer next to stove but not under hood.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6022449

DELRAY BEACH MARKET

License Type: Permanent Food Service

33 SE 3 AVE #12, DELRAY BEACH 33483

Inspection Date: 02/15/2022

Inspection Number: 3171651

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6006616

BOCAIRE COUNTRY CLUB

License Type: Permanent Food Service

4989 BOCAIRE BLVD, BOCA RATON 33487-1163

Inspection Date: 02/18/2022

Inspection Number: 3169346

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certifications expired

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6218302

DEAD PRESIDENTS

License Type: Permanent Food Service

1742 E CENTRAL AVE, ST PETERSBURG 33712

Inspection Date: 02/14/2022

Inspection Number: 3168060

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: HOBBS, ANDREW

Violation Code ObservationViolation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryers in use on cooks line with no hood system installed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryers in use on cooks line with no hood system installed. -	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216936

DALGISFLAMFO BROILED BURGERS LLC

License Type: Permanent Food Service

10754 70 AVE N UNIT C, SEMINOLE 33772

Inspection Date: 02/14/2022

Inspection Number: 3149412

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: WILMOT, TASHARA

Violation Code ObservationViolation Citation

46-04-4	Exit door locked. For reporting purposes only. -blocked with boxes and chair	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

Seminole County

License Number: 6904872	GRAFFITI JUNKTION 4
License Type: Permanent Food Service	950 MARKET PROMENADE AVE, SUITE 1200, LAKE MARY 32746
Inspection Date: 02/17/2022	Inspection Number: 3182045
Inspector Name: THORNCROFT, ROBERT	Inspection Type: Complaint Full
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. Outlet at the corner of the cooks line at the fryer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904919	4 RIVERS SMOKEHOUSE
License Type: Permanent Food Service	1869 W SR 434 STE 230, LONGWOOD 32750
Inspection Date: 02/10/2022	Inspection Number: 3141479
Inspector Name: THORNCROFT, ROBERT	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the cooks line/prep	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502067

SUMO SUSHI

License Type: Permanent Food Service

107 NATURE WALK PKWY STE 109, SAINT AUGUSTINE 32092

Inspection Date: 02/16/2022

Inspection Number: 3151060

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Rear exterior exit door from the back portion of the dining room blocked by single service boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406391

D I S PRODUCTION KITCHEN AREA 1 AND 2

License Type: Catering

1801 W INTNL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 02/17/2022

Inspection Number: 1120045

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation Code ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Operator provided jurisdiction number and verified boilers are listed on <https://www.citizenserve.com/120>.

On current warning and cer

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 7407790

STOKED POKE

License Type: Permanent Food Service

260 DAYTONA BLVD D-440, DAYTONA BEACH 32114

Inspection Date: 02/15/2022

Inspection Number: 3181711

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
- exit path partial block in hallway by trash and storage

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.
- exit path partial block in hallway by trash and storage - From follow-up inspection 2022-02-16: Storage shelving along hallway in marked exit path **

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403165

WENDY'S 1759

License Type: Permanent Food Service

335 W GRANDA BLVD, ORMOND BEACH 32174

Inspection Date: 02/16/2022

Inspection Number: 3182012

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code ObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. K class.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405792

WENDY'S 2635

License Type: Permanent Food Service

2110 SAXON BLVD, DELTONA 32725

Inspection Date: 02/17/2022

Inspection Number: 3182014

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by boxes. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7600838

FREEPORT CAFE INC

License Type: Permanent Food Service

39 E HWY 20, FREEPORT 32439

Inspection Date: 02/14/2022

Inspection Number: 3171000

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near cook line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.