

Alachua County

License Number: 1103196

SAMURAI JAPANESE STEAK HOUSE & SUSHI BAR

License Type: Permanent Food Service

3720 NW 13 ST STE 1, GAINESVILLE 32609

Inspection Date: 03/02/2022

Inspection Number: 3166766

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Observed the exit in dry storage has multiple boxes blocking egress.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1302323

SCHOONERS

License Type: Permanent Food Service

5121 GULF DR, PANAMA CITY BEACH 32408

Inspection Date: 03/01/2022

Inspection Number: 3151787

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code ObservationViolation Citation

48-03-4	Fuel-burning, wick-type, unvented space heater in use inside an enclosed building or patio area. For reporting purposes only.	509.211(2)(a) FS Reporting: (2) (a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Approximately 15 tanks stored outside bathrooms.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506108

GATORS DOCKSIDE

License Type: Permanent Food Service

683 DAVE NISBET DR, CAPE CANAVERAL 32920

Inspection Date: 02/28/2022

Inspection Number: 3134941

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door. - From follow-up inspection 2022-02-28: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001451

DESTINY FISH

License Type: Permanent Food Service

7317 GASLINE RD, KEYSTONE HEIGHTS 32656

Inspection Date: 02/28/2022

Inspection Number: 3180157

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328370 THREE FRIEND BISTRO
 License Type: Permanent Food Service 1212 NW 82 AVE, MIAMI 33126

Inspection Date: 02/26/2022 Inspection Number: 3157506 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Inspector Name: MARTINEZ, YANET Complied

Violation Code ObservationViolation Citation

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed operator frying eggs with no hood system. - From follow-up inspection 2022-02-26: At the time of the callback inspection observed operator cooking eggs with no hood system. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334642 HABITAT
 License Type: Permanent Food Service 2301 2377 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/01/2022 Inspection Number: 3122334 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Inspector Name: HODGE, KRISTEN Extension given, pending

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Observed 2 boilers in room next to bar located in upstairs area. Observed a BTU count 800,000, 132 gallons, 210F Temperature to indicate as boilers. As well as no Carbon Monoxide detector in room where boilers are located. - From follow-up inspection 2022-03-01: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Observed 2 boilers in room next to bar located in upstairs area. Observed a BTU count 800,000, 132 gallons, 210F Temperature to indicate as boilers. As well as no Carbon Monoxide detector in room where boilers are located. - From follow-up inspection 2022-03-01: **Time Extended** - From follow-up inspection 2022-03-03: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 48-01-5 Observed: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Observed 2 boilers in room next to bar located in upstairs area. Observed a BTU count 800,000, 132 gallons, 210F Temperature to indicate as boilers. As well as no Carbon Monoxide detector in room where boilers are located. - From follow-up inspection 2022-03-03: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 48-01-5 Observed: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Observed 2 boilers in room next to bar located in upstairs area. Observed a BTU count 800,000, 132 gallons, 210°F Temperature to indicate as boilers. As well as no Carbon Monoxide detector in room where boilers are located.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2320536 EL NOVILLO RESTAURANT
 License Type: Permanent Food Service 6830 SW 40 ST, MIAMI 331553708

Inspection Date: 03/03/2022 Inspection Number: 3177548 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located at bar area. - From follow-up inspection 2022-03-03: Portable fire extinguisher gauge in red zone. For reporting purposes only. Located at bar area. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326341 PAELLA PARTY
 License Type: Permanent Food Service 16155 SW 117 AVE STE 8, MIAMI 33177

Inspection Date: 02/28/2022 Inspection Number: 3171721 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed by the back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327102 FRITANGA MANAGUITA
 License Type: Permanent Food Service 11323 SW 211 ST #12,13,14, MIAMI 33189

Inspection Date: 03/01/2022 Inspection Number: 3182776 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: SWIGERT, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in the back of the kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dixie County

License Number: 2500009

SAMANTHAS CYPRESS INN

License Type: Permanent Food Service

15568 US HWY 19, CROSS CITY 32628

Inspection Date: 03/03/2022

Inspection Number: 3150331

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher at end of front counter.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614547

THE TREE CUP CATERED BY THE CHEF'S GARDEN

License Type: Permanent Food Service

829 RIVERSIDE AVE, JACKSONVILLE 32204

Inspection Date: 03/01/2022

Inspection Number: 3162077

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood
suppression system installed. Notified Fire AHJ. For reporting purposes only.
Cooking salmon patty and veggie burger with oil **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608970

BLUE FISH

License Type: Permanent Food Service

3551 ST JOHNS AVE, JACKSONVILLE 32205

Inspection Date: 03/01/2022

Inspection Number: 3160737

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside
of the building. For reporting purposes only. One in upstairs storage

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613933

CASBAH CAFE

License Type: Permanent Food Service

3628 ST JOHNS AVE, JACKSONVILLE 32205

Inspection Date: 02/28/2022

Inspection Number: 3160958

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside
of the building. For reporting purposes only. Hakka area **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613741

BALKAN CAFE

License Type: Permanent Food Service

8595 BEACH BLVD STE #305, JACKSONVILLE 32216

Inspection Date: 03/04/2022

Inspection Number: 3174021

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.
Electrical cover panel in disrepair at dining room area next to front door under
standing floating table

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615243

EL TAINO BAR AND GRILL

License Type: Permanent Food Service

4347 UNIVERSITY BLVD S STE 5, JACKSONVILLE 32216

Inspection Date: 03/02/2022

Inspection Number: 3176003

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Back door block by tables and equipments in back storage area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615487

STONER'S PIZZA JOINT NORTH JACKSONVILLE

License Type: Permanent Food Service

11565 N MAIN ST STE 200, JACKSONVILLE 32218

Inspection Date: 02/28/2022

Inspection Number: 3137168

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Back door blocked by large piece of wood.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3910985

JOE'S NEW YORK DINER LLC

License Type: Permanent Food Service

11701 N FLORIDA AVE, TAMPA 33612

Inspection Date: 03/01/2022

Inspection Number: 3137753

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: CESAR, RACHEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Red door leading to patio blocked by water line, table and fan. - From follow-up inspection 2022-03-01: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Red door leading to patio blocked by water line, table and fan.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105487

TRUMAN'S TAP AND GRILL

License Type: Permanent Food Service

11161 SR70 E, LAKEWOOD RANCH 34202

Inspection Date: 02/28/2022

Inspection Number: 3105703

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone in rear of kitchen to the right of the back exit door. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811600

CHIPOTLE MEXICAN GRILL #844

License Type: Permanent Food Service

6607 S SEMORAN BLVD #108, ORLANDO 32822

Inspection Date: 03/03/2022

Inspection Number: 3159359

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only./ boxes exit door **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814910

MOMO BLESSING BAKERY INC

License Type: Permanent Food Service

1350 HOLDEN AVE STE 105, ORLANDO, 32839

Inspection Date: 02/28/2022

Inspection Number: 3136977

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: PASIECKI, VICTORIA

Violation Code ObservationViolation Citation46-01-4 - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.
Equipment blocking rear exit door - From follow-up inspection 2021-12-28:
Time Extended - From follow-up inspection 2022-02-28: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019926

COFFEE DISTRICT

License Type: Permanent Food Service

325 NE 2 AVE STE 104, DELRAY BEACH 33444

Inspection Date: 03/02/2022

Inspection Number: 3152647

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed table top fryer in BOH with no hood.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211181 WATER COLOUR STEAK HOUSE AND GRILL
 License Type: Permanent Food Service 1201 GULF BLVD, CLEARWATER BEACH 33767

Inspection Date: 03/03/2022 Inspection Number: 3162349 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. One boiler FI134099 expired 9/12/2020 **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6211849 MARRIOTT KOKOMOS GRILL
 License Type: Permanent Food Service 1201 GULF BLVD, CLEARWATER BEACH 33767

Inspection Date: 03/03/2022 Inspection Number: 3139792 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. One expired FI 134099 exp 9/12/2020 **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6205716 PAJANOS PIZZA AND SUB
 License Type: Permanent Food Service 1307 GULF BLVD, INDIAN ROCKS BCH 337852748

Inspection Date: 03/01/2022 Inspection Number: 3152655 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Items moved. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100072

BROWN LANTERN

License Type: Permanent Food Service

417 E HOWARD ST, LIVE OAK 32064

Inspection Date: 03/01/2022

Inspection Number: 3167384

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In the recharge zone behind the bar by the door into the outside dining area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405846

NEW CHINA WOK

License Type: Permanent Food Service

2160 HOWLAND BLVD STE 100, DELTONA 32738

Inspection Date: 02/28/2022

Inspection Number: 3182799

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Front door blocked by Togo window.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7650107

SCOOPS, SWEETS, & TREATS

License Type: Mobile Food Dispensing Vehicle

1045 US HWY 331 SOUTH STE H, DEFUNIAK SPRINGS 32435

Inspection Date: 03/01/2022

Inspection Number: 1237266

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By 3 compartment sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.