



**Broward County**

License Number: 1621848

EMPLOYEE CAFETERIA 2ND FLOOR

License Type: Permanent Food Service

1 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 03/08/2022

Inspection Number: 3094787

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code   ObservationViolation Citation48-01-5      No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621852

BURLOCK COAST

License Type: Permanent Food Service

1 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 03/08/2022

Inspection Number: 3154430

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code   ObservationViolation Citation48-01-5      No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1622847

THE CLUB LOUNGE

License Type: Permanent Food Service

1 N FT LAUDERDALE BLVD, FORT LAUDERDALE 33304

Inspection Date: 03/08/2022

Inspection Number: 3171857

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code   ObservationViolation Citation48-01-5      No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Dade County**

License Number: 2333301

FOOQ'S

License Type: Permanent Food Service

1035 N MIAMI AVE #103, MIAMI 33136

Inspection Date: 03/09/2022

Inspection Number: 3167160

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code    ObservationViolation Citation

45-04-4    Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a portable double-sided grease fryer on a prep table in front of the cookline. Discussed wit

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333445

BACON BITCH

License Type: Permanent Food Service

1001 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 03/10/2022

Inspection Number: 3183590

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: WILLIAMS, ALFREDA

Violation Code    ObservationViolation Citation

45-04-4    Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed the use of cooking equipment in new upstairs food preparation room without a hood system.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329264

G AND S EVENTS

License Type: Catering

16205 SW 117 AVE 5, MIAMI 33177

Inspection Date: 03/08/2022

Inspection Number: 1120370

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code    ObservationViolation Citation

48-04-4    Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2615236

HEADROOM COFFEE BAR

License Type: Permanent Food Service

15 N OCEAN ST STE 15 17 19, JACKSONVILLE 32202

Inspection Date: 03/10/2022

Inspection Number: 3163689

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation Code    ObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Employee reheating meats and cooking bacon on flat top grill without hood suppression system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614180

TOWN HALL

License Type: Permanent Food Service

2012 SAN MARCO BLVD, JACKSONVILLE 32207

Inspection Date: 03/10/2022

Inspection Number: 3142402

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: YOUNG, JENNIFER

Violation Code    ObservationViolation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Several 15lb propane tanks in room outside of kitchen - From follow-up inspection 2022-03-10

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Several 15lb propane tanks in room outside of kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hillsborough County**

License Number: 3918831

TAQUERIA FAMILIAR

License Type: Permanent Food Service

1450 SKIPPER RD, TAMPA 33613

Inspection Date: 03/10/2022

Inspection Number: 3163105

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Observed a gas grill and a hot plate used with propane inside the kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lake County**

License Number: 4508360

OAKWOOD SMOKEHOUSE & GRILL

License Type: Permanent Food Service

2911 DAVID WALKER DR, EUSTIS 32726

Inspection Date: 03/08/2022

Inspection Number: 3153562

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWN, PAULETTE

Violation Code

Observation

Violation Citation

49-05-4

Flammables gas cans accords from mop sink. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Manatee County**

License Number: 5105487

TRUMAN'S TAP AND GRILL

License Type: Permanent Food Service

11161 SR70 E, LAKEWOOD RANCH 34202

Inspection Date: 03/07/2022

Inspection Number: 3105703

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone in rear of kitchen to the right of the back exit door. For reporting purposes only. - From follow-up inspection 2022-03-07: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811461

POM POM'S TEAHOUSE &amp; SANDWICHERIA

License Type: Permanent Food Service

67 N BUMBY AVE, ORLANDO 32803

Inspection Date: 03/11/2022

Inspection Number: 3126433

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: VALERIO, GRACE

Violation Code    ObservationViolation Citation

45-04-4      Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
- During inspection observed one pan burner used in the back to cook soups.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814306

PANDA EXPRESS #2866

License Type: Permanent Food Service

9985 TAGORE PL, ORLANDO 32832

Inspection Date: 03/10/2022

Inspection Number: 3182891

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation Code    ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only.  
- boxes stored in front of exit door  
- manager removed boxes \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6022427

THE MODERN ROSE DELRAY

License Type: Permanent Food Service

33 SE 3 AVE #14, DELRAY BEACH 33483

Inspection Date: 03/11/2022

Inspection Number: 3165974

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Pinellas County**

License Number: 6217912 WINGSTOP  
 License Type: Permanent Food Service 1925 W BRANDON BLVD, BRANDON 33511

Inspection Date: 03/10/2022 Inspection Number: 3155492 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at extinguisher near back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213914 ACROPOLIS  
 License Type: Permanent Food Service 515 CENTRAL AVE, ST PETERSBURG 33701

Inspection Date: 03/07/2022 Inspection Number: 3117390 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 12.5# propane tanks in dry stock. Manager took propane outside. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215233 ASTRA PIZZA  
 License Type: Permanent Food Service 2915 16 ST N, ST. PETERSBURG 33704

Inspection Date: 03/08/2022 Inspection Number: 3158761 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Establishment was a no seating establishment increased to 2 seats. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215988 FORTUNATO'S ALFRESCO  
 License Type: Permanent Food Service 212 37 AVE N, ST. PETERSBURG 33704

Inspection Date: 03/10/2022 Inspection Number: 3161010 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LOZANO, KELVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Establishment was a 20-seat establishment increased to 40 seats	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6307803

BROADWAY DINER

License Type: Permanent Food Service

1380 N BROADWAY AVE, BARTOW 33830

Inspection Date: 03/08/2022

Inspection Number: 3143461

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At k class extinguisher next to cook line \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6605143

TASTY LINKS

License Type: Permanent Food Service

720 DELAWARE AVE UNIT N, FORT PIERCE 34950

Inspection Date: 03/07/2022

Inspection Number: 3160569

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer on counter call AHJ called left message advised manager unplugged and told me they would remove

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7407046

BRUNO'S PIZZA

License Type: Permanent Food Service

1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 03/07/2022

Inspection Number: 3160735

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.