

Broward County

License Number: 1615158

AND FISH KITCHEN & BAR

License Type: Permanent Food Service

1200-1208 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 03/14/2022

Inspection Number: 3173991

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: FRANCE, GASTON

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired 9/19/21.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired 9/19/21. - From follow-up inspection 2022-03-15: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1624539

OLNET JEAN

License Type: Permanent Food Service

1952 NW 9 AVE, FORT LAUDERDALE 33311

Inspection Date: 03/16/2022

Inspection Number: 3178582

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Complied

Inspector Name: DEJONG, STEVEN

Violation Code ObservationViolation Citation

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Fryer not fully under hood system. Operator stated fryer not working and to be removed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2022-01-13: **Time Extended** - From follow-up inspection 2022-03-16: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1615072

GOLDEN RICE BOWL

License Type: Permanent Food Service

3276 N SR 7, LAUDERDALE LAKES 33319

Inspection Date: 03/15/2022

Inspection Number: 3166125

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROGERS, VERNEL

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen exit door- observed exit door being blocked by empty boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1610560

BANYAN RESTAURANT

License Type: Permanent Food Service

250 RACQUET CLUB RD, WESTON 33326

Inspection Date: 03/18/2022

Inspection Number: 3163186

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WATSON, TRICIA

Violation Code ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed current insurance boiler inspection report expiration in September.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621509

TIJUANA FLATS BURRITO CO

License Type: Permanent Food Service

8703 STIRLING RD, COOPER CITY 33328

Inspection Date: 03/14/2022

Inspection Number: 3164882

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
-Observed exit door blocked by discarded cardboard boxes in kitchen. Operator removed all boxes. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801657

HOLIDAY INN EXPRESS

License Type: Permanent Food Service

24440 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 03/19/2022

Inspection Number: 3150829

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. The operator is currently waiting to receive the Broiler certificate. ****Repeat Violation****

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2334483

NEW YORK PIZZAA

License Type: Permanent Food Service

1755 NW 7 ST, MIAMI 33125

Inspection Date: 03/14/2022

Inspection Number: 3139170

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336779

PASTA MARKET HANDMADE

License Type: Permanent Food Service

209 NE 82 STREET, MIAMI 33138

Inspection Date: 03/17/2022

Inspection Number: 3154522

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: SEYBA, JAMES

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301749

SHELBORNE CAFFE

License Type: Permanent Food Service

1801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/16/2022

Inspection Number: 3166406

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code ObservationViolation Citation

48-01-5 No current/expired inspector boiler report or boiler certificate available for boiler. Observed boiler jurisdiction number's 055333; 055334 All expired 4/28/2019. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2332244 THE RESTAURANT W SOUTH BEACH
 License Type: Permanent Food Service 2201 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/11/2022 Inspection Number: 3167968 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current/expired insurance inspector boiler report or boiler certificate available for boiler. Observed boiler jurisdiction number's 059189, 059093,059161 all expires 11/20/21. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Inspection Date: 03/15/2022 Inspection Number: 3167968 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current/expired insurance inspector boiler report or boiler certificate available for boiler. Observed boiler jurisdiction number's 059189, 059093,059161 all expires 11/20/21. For reporting purposes only. - From follow-up inspection 2022-03-15: **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332984 OASIS BEER GARDEN
 License Type: Permanent Food Service 1801 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 03/16/2022 Inspection Number: 3166616 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current/expired insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 055333; 055334 All expired 4/28/2019.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2333189 DAVID'S CAFE CUBAN CUISINE
 License Type: Permanent Food Service 1801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/16/2022 Inspection Number: 3166363 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current/expired insurance inspector boiler report or boiler certificate available for boiler. Observed boiler jurisdiction number's 055333; 055334 All expired 4/28/2019. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2332002 CAFE CHUNG KING
 License Type: Permanent Food Service 1250 NW 54 STREET, MIAMI 33142

Inspection Date: 03/16/2022 Inspection Number: 3161436 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed exposed wiring throughout kitchen **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330206 MICHY'S KITCHEN
 License Type: Permanent Food Service 4635 SW 75 AVE, MIAMI 33155

Inspection Date: 03/14/2022 Inspection Number: 3093340 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near reach in cooler at preparation area. - From follow-up inspection 2022-03-14: Portable fire extinguisher gauge in red zone. For reporting purposes only. Located near reach in cooler at preparation area. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2359885 LE ROUTE
 License Type: Mobile Food Dispensing Vehicle 21601 SW 155 AVE, MIAMI 33170

Inspection Date: 03/17/2022 Inspection Number: 1247666 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332367 SOKAI SUSHI BAR
 License Type: Permanent Food Service 10726 NW 74 STREET, DORAL 33178

Inspection Date: 03/15/2022 Inspection Number: 3166893 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CURRAS, YANLEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335824 CARROT EXPRESS
 License Type: Permanent Food Service 19501 BISCAYNE BLVD K-1993, AVENTURA 33180

Inspection Date: 03/08/2022 Inspection Number: 3173063 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed establishment with 2 tabletop stoves and 1 tabletop deep fryer with no hood suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324104 MACITAS RESTAURANT
 License Type: Permanent Food Service 14685 SW 104 ST, MIAMI 33186

Inspection Date: 03/14/2022 Inspection Number: 3183771 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 cylinders by the back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612802 TERRA GAUCHA BRAZILIAN STEAKHOUSE
 License Type: Permanent Food Service 4483 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 03/15/2022 Inspection Number: 3174768 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door next to walk in cooler block with utility cart **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615312 TRIO HOOKAH LOUNGE
 License Type: Permanent Food Service 8725 OLD KINGS RD S, JACKSONVILLE 32217

Inspection Date: 03/16/2022 Inspection Number: 3176014 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 large LP tanks in dry goods room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614747 DANO'S DINER
 License Type: Permanent Food Service 1487 MAYPORT RD UNITS 7-9, ATLANTIC BEACH 32233

Inspection Date: 03/16/2022 Inspection Number: 3134645 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: GONZALEZ, MAYRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Pathway to marked exit blocked by miscellaneous, located by bathroom. - From follow-up inspection 2022-01-12: Pathway still blocked. **Time Extended** - From follow-up inspection 2022-01-24: Exit door pathway still blocked. **Time Extended** - From follow-up inspection 2022-03-16: Pathway still blocked. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615645 MODU RAMEN
 License Type: Permanent Food Service 8602 BAYMEADOWS RD UNIT 24, JACKSONVILLE 32256

Inspection Date: 03/16/2022 Inspection Number: 3168367 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Multiple Propane tanks larger than 2.7 lb stored inside building in dry food storage room **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3918796 JUNMAI STATION
 License Type: Permanent Food Service 325 N FLORIDA AVE STE C, TAMPA 33602

Inspection Date: 03/16/2022 Inspection Number: 3142583 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Increase in seating from 0 to 9. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918377 POKEWORKS 004
 License Type: Permanent Food Service 2223 N WEST SHORE BLVD STE 230-B, TAMPA 33607

Inspection Date: 03/14/2022 Inspection Number: 3139386 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. 5 gallon propane tank stored next to hot water heater.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	- From initial inspection : Flammables stored near a source of ignition. For reporting purposes only. 5 gallon propane tank stored next to hot water heater. - From follow-up inspection 2022-03-15: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604207

TACO BELL #24552

License Type: Permanent Food Service

4860 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 03/15/2022

Inspection Number: 3162388

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by back exit door in the red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4651141

PUPUSERIA LA GUANAQUITA DE LOS HERMANOS FLORES

License Type: Mobile Food Dispensing Vehicle

4812 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 03/15/2022

Inspection Number: 1243943

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by exit door in the red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200998

WENDYS 1918

License Type: Permanent Food Service

3617 W SILVER SPRINGS BLVD, OCALA 34475

Inspection Date: 03/16/2022

Inspection Number: 3164703

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202331

TACO BELL- 26466

License Type: Permanent Food Service

3501 W SILVER SPRINGS BLVD, OCALA 34475

Inspection Date: 03/16/2022

Inspection Number: 3146240

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher near back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5427994

ELEMENTS LOUNGE AND RESTAURANT

License Type: Permanent Food Service

82100 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 03/17/2022

Inspection Number: 3160573

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher next to wait station doors ,showing in red zone	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Glass Exit Door near kitchen blocked by garbage can and food tray stand holding coffee items	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500817

THE OCEAN CLUB

License Type: Permanent Food Service

5 OCEAN CLUB DR, AMELIA ISLAND 32034

Inspection Date: 03/16/2022

Inspection Number: 3160671

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Portable fry station or under hood, management states will place under hood

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5604133

DON CHA PERUVIAN FOOD LLC

License Type: Permanent Food Service

100 PERRY AVE, FORT WALTON BEACH 32548

Inspection Date: 03/14/2022

Inspection Number: 3153403

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Upon inspection observed ceiling wire exposed over prep cooler across from cook line and close to dish washing area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808441 KING BUFFET
 License Type: Permanent Food Service 2157 E SEMORAN BLVD, APOPKA 32703

Inspection Date: 03/15/2022 Inspection Number: 3179295 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only, by back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803835 SHERATON ORLANDO NORTH GRANFE CAFE & LOUNGE& LINK
 License Type: Permanent Food Service 600 NORTH LAKE DESTINY DR, MAITLAND 32751

Inspection Date: 03/14/2022 Inspection Number: 3172379 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 2 boilers - expired 12/17/21 #s 134960 & 134898	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 2 boilers - expired 12/17/21 #s 134960 & 134898 - From follow-up inspection 2022-03-15: **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5803839 SHERATON ORLANDO EMPLOYEE CAFETERIA
 License Type: Permanent Food Service 600 N LAKE DESTINY DR, MAITLAND 32751

Inspection Date: 03/14/2022 Inspection Number: 3172365 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 2 boiler certificates expired 12/7/21 #134960 & #134989	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5811265

Q'KENAN

License Type: Permanent Food Service

8117 VINELAND AVE, ORLANDO 32821

Inspection Date: 03/16/2022

Inspection Number: 3167621

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Observed in server's station.

Operator moved the propane tank and stored outside. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6303668

THE OLIVE GARDEN

License Type: Permanent Food Service

411 CYPRESS GARDENS BLVD, WINTER HAVEN 33880

Inspection Date: 03/17/2022

Inspection Number: 3164692

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Sarasota County

License Number: 6805732

METRO DINER

License Type: Permanent Food Service

6056 LOCKWOOD RIDGE RD, SARASOTA 34243

Inspection Date: 03/16/2022

Inspection Number: 3153573

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: EASLER, VERONICA

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone to the right of employee restroom next
to ice machine. For reporting purposes only.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 6805592

BLUE TEQUILA

License Type: Permanent Food Service

14525 TAMIAMI TRL 5,6,7, NORTH PORT 34287

Inspection Date: 03/14/2022

Inspection Number: 3149728

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KEATING, PATRICK

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher next to dishwasher area gauge in red zone. For reporting
purposes only.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Seminole County

License Number: 6902064 HEATHROW COUNTRY CLUB
 License Type: Permanent Food Service 1200 BRIDGEWATER DR, HEATHROW 32746

Inspection Date: 03/15/2022 Inspection Number: 3183761 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: GUTTERMAN, KENNETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 small lo tanks stored on cooks line.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6902309 CHENG'S CHINESE RESTAURANT
 License Type: Permanent Food Service 3705 LAKE EMMA ROAD, LAKE MARY 32746

Inspection Date: 03/16/2022 Inspection Number: 3159350 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Large k class extinguisher in the red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905103 WOP'S HOP BREWING COMPANY
 License Type: Permanent Food Service 419 S. SANFORD AVE, SANFORD 32771

Inspection Date: 03/16/2022 Inspection Number: 3154394 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two table top fryers. Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501026 SCHMAGEL'S BAGELS
 License Type: Permanent Food Service 69 HYPOLITA ST, SAINT AUGUSTINE 32084

Inspection Date: 03/14/2022 Inspection Number: 3160776 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MAKOWSKI, JARED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No hood above flat top stove. Operator prepared bacon and eggs. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501941 THE GOURMET HUT
 License Type: Permanent Food Service 17 CUNA ST, SAINT AUGUSTINE 32084

Inspection Date: 03/17/2022 Inspection Number: 3091823 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MAKOWSKI, JARED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No fire hood above stove. Evidence of grease laden vapors due to grease build up on ceiling and walls near stove.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No fire hood above stove. Evidence of grease laden vapors due to grease build up on ceiling and walls near stove. - From follow-up inspection 2022-03-18: Operator does not have fire suppression system or hood over stove. On call back kitchen was filled with grease laden vapors. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100354

MCALPIN KOUNTRY KITCHEN

License Type: Permanent Food Service

9929 170 TERR STE 101, MCALPIN 32062

Inspection Date: 03/15/2022

Inspection Number: 3183903

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to front door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407237

DICKEY'S BARBECUE PIT DAYTONA BEACH

License Type: Permanent Food Service

1388 W INTL SPEEDWAY BLVD STE 110, DAYTONA BEACH 32114

Inspection Date: 03/15/2022

Inspection Number: 3164491

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
-wires exposed were emergency light was attached in restroom north side

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7602081 SUBWAY #17970
 License Type: Permanent Food Service 2951 N HWY 81, PONCE DE LEON 32455

Inspection Date: 03/14/2022 Inspection Number: 3178524 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SHANKLIN, CYNTHIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. 3 fire extinguishers stored on floor in dry storage.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7602004 THAI 9 CUISINE
 License Type: Permanent Food Service 10916 EMERALD COAST PKWY W, MIRAMAR BEACH 32550

Inspection Date: 03/15/2022 Inspection Number: 3178920 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Washington County

License Number: 7700184

EBRO CATERERS

License Type: Permanent Food Service

6558 DOG TRACK RD, EBRO 32437

Inspection Date: 03/14/2022

Inspection Number: 3180532

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. In hallway near dish pit window.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Exit sign hanging from ceiling by wire at back exit. Outlet cover missing in service area near kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.