

Broward County

License Number: 1622800

CHEETAH- HALLANDALE

License Type: Permanent Food Service

100 ANSIN BLVD, HALLANDALE 33009

Inspection Date: 03/30/2022

Inspection Number: 3155839

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324716 HAPPY HOUSE
 License Type: Permanent Food Service 28708 S DIXIE HWY, HOMESTEAD 33030

Inspection Date: 03/28/2022 Inspection Number: 3161197 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-03-4	Fuel-burning, wick-type, unvented space heater in use inside an enclosed building or patio area. For reporting purposes only. Observed a propane gas tank connected and in use to a LoCo Cooker 1-burner at kitchen area next to smoker. Operator turn off the cooker, disconnect the propane gas tank and removed from the kitchen area.	509.211(2)(a) FS Reporting: (2) (a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a propane tank inside of establishment. **Corrective Action Taken** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336405 CORAL CAY - BK-24150
 License Type: Permanent Food Service 3600 NW 199 ST, UNIT A, MIAMI GARDENS 33056

Inspection Date: 03/31/2022 Inspection Number: 3185120 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed 2 garbage bins filled with boxes blocking door marked exit. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334305 DUNKIN DONUTS 07
 License Type: Permanent Food Service 12561 BISCAYNE BLVD, MIAMI 33181

Inspection Date: 04/01/2022 Inspection Number: 3185200 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609060

KRYSTAL

License Type: Permanent Food Service

2023 N MAIN ST, JACKSONVILLE 32206

Inspection Date: 03/30/2022

Inspection Number: 3169409

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Front counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917638 SARKU JAPAN
 License Type: Permanent Food Service 459 BRANDON TOWN CENTER, WESTFIELD BRANDON, BRANDON 33511

Inspection Date: 03/28/2022 Inspection Number: 3169938 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918004 GOFRUIT
 License Type: Permanent Food Service 2223 N WEST SHORE BLVD K202, TAMPA 33607

Inspection Date: 03/31/2022 Inspection Number: 3171404 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored on the floor by door .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105310 EL SAUSSIE
 License Type: Permanent Food Service 4211 20 ST, VERO BEACH 32960

Inspection Date: 03/28/2022 Inspection Number: 3183207 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks in building. Manager moved them to outside fenced area **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4105383 RED WOK LLC
 License Type: Permanent Food Service 737 22 ST, VERO BEACH 32960

Inspection Date: 03/30/2022 Inspection Number: 3184373 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. On cooks line hooked to a portable stove. Manager removed and placed tank outside Called local fire and left message with Jennifer M. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4508469

BELLA NONNA PIZZERIA AND MORE

License Type: Permanent Food Service

280 SILVERADO ST, TAVARES 32778

Inspection Date: 03/30/2022

Inspection Number: 3150391

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWN, PAULETTE

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Wire in reach in freezer hang on the interior of freezer in back prep area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605824

POLLO TROPICAL INC

License Type: Permanent Food Service

1652 NE PINE ISLAND RD, CAPE CORAL 33909

Inspection Date: 04/01/2022

Inspection Number: 3146928

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOREHEAD, PHILIP

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603837

THE SUMMIT OF FORT MYERS

License Type: Permanent Food Service

1499 S BRANDYWINE CIR, FORT MYERS 33919

Inspection Date: 03/28/2022

Inspection Number: 3111911

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed old boiler certification expired on 02-03-2022. Operator printed and posted current certificate. **Corrected On-Site**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Martin County

License Number: 5301551

THREE GUYS PIZZERIA LLC

License Type: Permanent Food Service

3359 NW MAIN AVE, JENSEN BEACH 34957

Inspection Date: 03/28/2022

Inspection Number: 3166654

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
3 portable fat fryers on use on counters, no hood suppression system provided.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301593

PANERA BREAD STORE 2786

License Type: Permanent Food Service

2894 SW TOWN CENTER, PALM CITY 34990

Inspection Date: 03/28/2022

Inspection Number: 3145119

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEUBER, RYAN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5853652 MR MOFONGO
 License Type: Mobile Food Dispensing Vehicle 1322 25TH ST, ORLANDO 32805

Inspection Date: 03/31/2022 Inspection Number: 1236760 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, LESLIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. -tabletop fryers.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801929 ARBY'S
 License Type: Permanent Food Service 2600 S ORANGE AVE, ORLANDO 32806

Inspection Date: 03/28/2022 Inspection Number: 3184769 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back kitchen exit door blocked by trash can and small ladder **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812568 LOS AMECA'S RESTAURANTE Y TAQUERIA
 License Type: Permanent Food Service 3558 S ORANGE AVE, ORLANDO 32806

Inspection Date: 03/28/2022 Inspection Number: 3184826 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Numerous propane tanks in back storage , prep area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013835

VIP CATERERS OF B'NAI TORAH LLC

License Type: Catering

6261 SW 18 ST, BOCA RATON 33433

Inspection Date: 03/31/2022

Inspection Number: 1120690

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEWIS, LYNDEN

Violation Code ObservationViolation Citation45-05-4 Portable fire extinguisher missing from its designated location. For reporting
purposes only.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 6022002

PAPI CHULO

License Type: Permanent Food Service

1556 US HWY 1, JUPITER 33469

Inspection Date: 03/31/2022

Inspection Number: 3185026

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Electrical
cover plate missing/by rice cooker/cookline509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Pinellas County

License Number: 6210912

DAIQUIRI SHAK RAW BAR AND GRILL

License Type: Permanent Food Service

14995 GULF BLVD SUITE A, MADEIRA BEACH 33708

Inspection Date: 03/28/2022

Inspection Number: 3183596

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

46-04-4 Exit door locked. For reporting purposes only.
-blocked by umbrellas

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216008

DON'S TACO AUTHENTIC MEXICAN RESTAURANT

License Type: Permanent Food Service

672 E TARPON AVE, TARPON SPRINGS 34689

Inspection Date: 03/28/2022

Inspection Number: 3091513

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.
In kitchen - From follow-up inspection 2022-03-28: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400884 HOOT OWL FARM HOUSE
 License Type: Permanent Food Service 1821 REID ST, PALATKA 32177

Inspection Date: 03/29/2022 Inspection Number: 3110751 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Marked exit in back of drive thru blocked by prep table.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6400905 MARINA ST JOHNS
 License Type: Permanent Food Service 1 PALMETTO ST, WELAKA 32193-0403

Inspection Date: 03/30/2022 Inspection Number: 3110534 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-03-4	Fuel-burning, wick-type, unvented space heater in use inside an enclosed building or patio area. For reporting purposes only. Non operating space heater in dining area. Manager instructed employee to remove. **Corrective Action Taken**	509.211(2)(a) FS Reporting: (2) (a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.

Sarasota County

License Number: 6805459

MADE IN ITALY

License Type: Permanent Food Service

117 W VENICE AVE, VENICE 34285

Inspection Date: 03/28/2022

Inspection Number: 3146215

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KEATING, PATRICK

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed emergency exit at back dining room block by empty kegs and equipment.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900823

BURGER KING

License Type: Permanent Food Service

301 N. HIGHWAY 17-92, LONGWOOD 32750

Inspection Date: 03/30/2022

Inspection Number: 3152544

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. Cooks line electrical box scorched	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6900692

WEKIVA GOLF CLUB

License Type: Permanent Food Service

4100 WEKIVA CLUB CT, LONGWOOD 32779

Inspection Date: 03/29/2022

Inspection Number: 3177415

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only. Outlet on the line scorch marks	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502189

KAZU SUSHI BURRITO

License Type: Permanent Food Service

1000 S PONCE DE LEON BLVD STE 5, SAINT AUGUSTINE 32084

Inspection Date: 04/01/2022

Inspection Number: 3170169

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: MAKOWSKI, JARED

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Establishment has partition blocked pathway to back fire exit. Discussed with operator risk of fire hazard. Operator moved partition to unblock fire exit.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405261 DELICIAS CENTROAMERICANAS LLC
 License Type: Permanent Food Service 722 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 03/28/2022 Inspection Number: 3153574 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Flat grill and fryers. Heavy grease accumulation on walls and ceiling. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407648 MACKER SEAFOOD
 License Type: Permanent Food Service 600 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 03/28/2022 Inspection Number: 3156930 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406138 NEW YORK PIZZA & SUB
 License Type: Permanent Food Service 637 N GRANDVIEW AVE, DAYTONA BEACH 32118

Inspection Date: 03/31/2022 Inspection Number: 3184892 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	Exit door locked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407199

MOE'S SOUTHWEST GRILL # 34

License Type: Permanent Food Service

1812 DUNLAWTON AVE, PORT ORANGE 32127

Inspection Date: 03/28/2022

Inspection Number: 3176338

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code ObservationViolation Citation47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.
-plate cover missing for plug on wall to right of breaker panels

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405271

MCDONALD'S 13781

License Type: Permanent Food Service

1842 SR 44, NEW SMYRNA BEACH 32168

Inspection Date: 03/30/2022

Inspection Number: 3112202

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
-piles of cardboard boxes blocking exit path

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407795

CHIPOTLE MEXICAN GRILL 3914

License Type: Permanent Food Service

1798 STATE RD 44, NEW SMYRNA BEACH 32168

Inspection Date: 03/31/2022

Inspection Number: 3176671

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
-pile of cardboard boxes blocking exit path **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7602079 MI CASITA MEXICAN RESTAURANT
 License Type: Permanent Food Service 4141 E CO HWY 30A, SANTA ROSA BEACH 32459

Inspection Date: 03/31/2022 Inspection Number: 3175323 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SHANKLIN, CYNTHIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Above reach in freezer.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7602249 SUNRISE CANDY COMPANY LLC
 License Type: Permanent Food Service 37 TOWN CENTER LOOP UNIT C9, SANTA ROSA BEACH 32459

Inspection Date: 03/30/2022 Inspection Number: 3109249 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: SHANKLIN, CYNTHIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical outlet in disrepair. For reporting purposes only.no cover on electrical out let on wall.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.