

Broward County

License Number: 1621850

POOL BAR

License Type: Permanent Food Service

1 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 04/14/2022

Inspection Number: 3154429

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Clay County

License Number: 2000577

L'S COUNTRY KITCHEN

License Type: Permanent Food Service

1600 IDLEWILD AVE, GREEN COVE SPRINGS 32043

Inspection Date: 04/14/2022

Inspection Number: 3165901

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer on cook line not under hood.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2332112 CHAMPIONS SPORTS BAR
 License Type: Permanent Food Service 1201 NW LEJEUNE RD, MIAMI 33126

Inspection Date: 04/13/2022 Inspection Number: 3178636 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed all boiler certificate expired since October 8, 2021.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2303405 CANE FIRE GRILLE
 License Type: Permanent Food Service 1201 NW 42 AVE, MIAMI 331262656

Inspection Date: 04/13/2022 Inspection Number: 3178661 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed all boilers certificate expired since October 08, 2021.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334468 PUMMAROLA.
 License Type: Permanent Food Service 3328 N MIAMI AVE, MIAMI 33127

Inspection Date: 04/12/2022 Inspection Number: 3166527 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: STUBBS, CHRISTINE

Violation Code Observation

46-01-4 Marked exit/path to marked exit blocked with multiple boxes. For reporting purposes only. **Warning**

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336728 MAXWELL BROS
 License Type: Permanent Food Service 17395 SOUTH DIXIE HIGHWAY, PALMETTO BAY 33157

Inspection Date: 04/13/2022 Inspection Number: 3160602 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 20 pound tanks in the office.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301244 TRUMP DORAL/CHAMPIONS PATIO GRILL
 License Type: Permanent Food Service 4400 NW 87 AVE, DORAL 33178

Inspection Date: 04/11/2022 Inspection Number: 3091787 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARVIE, HARUKO

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2318051 TRUMP DORAL/MAIN KITCHEN
 License Type: Permanent Food Service 4400 NW 87TH AVE, DORAL 33178

Inspection Date: 04/11/2022 Inspection Number: 3110285 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RAMMELMEIER, JENS

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334643 TRUMP DORAL MARKET PLACE
 License Type: Permanent Food Service 4400 NW 87TH AVE, DORAL 33178

Inspection Date: 04/11/2022 Inspection Number: 3122492 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RAMMELMEIER, JENS

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2317869 TRUMP DORAL/EMPLOYEE CAFETERIA
 License Type: Permanent Food Service 4400 NW 87TH AVE, MIAMI 33178

Inspection Date: 04/11/2022 Inspection Number: 3091775 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HARVIE, HARUKO

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2319924

PRITIKIN LONGEVITY CENTER & SPA

License Type: Permanent Food Service

4400 NW 87 AVE, MIAMI 33178

Inspection Date: 04/11/2022

Inspection Number: 3091769

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARVIE, HARUKO

Violation Code ObservationViolation Citation48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2331211

TRUMP DORAL BANQUET DJT

License Type: Permanent Food Service

4400 NW 87TH AVE, MIAMI 33178

Inspection Date: 04/11/2022

Inspection Number: 3122773

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARVIE, HARUKO

Violation Code ObservationViolation Citation48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2652324 HOLY SMOKE BARBEQUE
 License Type: Mobile Food Dispensing Vehicle 1164 EDGEWOOD AVE S, JACKSONVILLE 32205

Inspection Date: 04/12/2022 Inspection Number: 1246576 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2022-04-13: Same	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614668 FARM TO TABLE CAFE
 License Type: Permanent Food Service 807 CHILDRENS WAY, JACKSONVILLE 32207

Inspection Date: 04/13/2022 Inspection Number: 3177288 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking multiple food items on stove top no hood suppression system **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615377 TROPICAL SMOOTHIE CAFE
 License Type: Permanent Food Service 13159 CITY CENTER BLVD UNIT 101, JACKSONVILLE 32218

Inspection Date: 04/12/2022 Inspection Number: 3185377 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by back exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614900

EPIK BURGER

License Type: Permanent Food Service

12740 ATLANTIC BLVD SUITE 105, JACKSONVILLE 32225

Inspection Date: 04/11/2022

Inspection Number: 3159788

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Two 20lb propane tanks stored in plastic closet outside mens room near water heater closet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2652199

EL TROMPO LOCO

License Type: Mobile Food Dispensing Vehicle

1712 OGILVIE PARK LN, JACKSONVILLE 32246

Inspection Date: 04/15/2022

Inspection Number: 1242178

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: THOMAS, PHILIP

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
20lb LP tank stored neat to upright cooler on MFDV

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906985

TAMPA PALMS GOLF & CC

License Type: Permanent Food Service

5811 TAMPA PALMS BLVD, TAMPA 336471090

Inspection Date: 04/13/2022

Inspection Number: 3168152

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: POWELL, DAVID

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Manatee County

License Number: 5105642

PDQ RESTAURANT, SR 70

License Type: Permanent Food Service

5484 SW LENA RD, BRADENTON 34211

Inspection Date: 04/12/2022

Inspection Number: 3157004

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone to the left of the office door and right of fryer station. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5101916

GULF DRIVE CAFE

License Type: Permanent Food Service

900 N GULF DRIVE, BRADENTON BEACH 34217

Inspection Date: 04/13/2022

Inspection Number: 3100354

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Observed Breaker panel in kitchen showing exposed wires/disrepair.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300790

SOCIETY MARKET CAFE

License Type: Permanent Food Service

320 SE DENVER ST, STUART 34994

Inspection Date: 04/13/2022

Inspection Number: 3176454

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet cover missing/by restroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400256

MARKETPLACE SIXTY-ONE PRIME

License Type: Permanent Food Service

61 HAWKS CAY BLVD, DUCK KEY 33050

Inspection Date: 04/15/2022

Inspection Number: 3169390

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In hallway near kitchen entrance.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5806945 CHILI'S SOUTHWEST GRILL & BAR
 License Type: Permanent Food Service 12181 E COLONIAL DR, ORLANDO 328264708

Inspection Date: 04/11/2022 Inspection Number: 3173852 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2022-04-12: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815367 SALT AND STRAW
 License Type: Permanent Food Service 1502 E BUENA VISTA DR STE B22, LAKE BUENA VISTA 32830

Inspection Date: 04/12/2022 Inspection Number: 3185793 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	Licensing inspection - Per Temporary Certificate of Occupancy -A fire watch shall be provided until fire alarm drawings for duct smoke detector .For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900680

HOLIDAY INN ORLANDO SW CELEBRATION AREA

License Type: Permanent Food Service

5711 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 04/14/2022

Inspection Number: 3145704

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5900681

HOLIDAY INN ORLANDO SW CELEBRATION AREA

License Type: Permanent Food Service

5711 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 04/14/2022

Inspection Number: 3145760

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6022361 NOMAD @ SEAN RUSH
 License Type: Permanent Food Service 3700 S DIXIE HWY SUITE 3, WEST PALM BEACH 33405

Inspection Date: 04/13/2022 Inspection Number: 3185949 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Both exit doors in the kitchen area. As per operator these are not exit doors as per fire department. as per operator building plan have 3 exit doors .these are not exit doors. Operator removed the bulbs an	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020252 DEVINE BISTRO
 License Type: Permanent Food Service 2465 SR 7 STE #300, VILLAGE OF WELLINGTO 33414

Inspection Date: 04/12/2022 Inspection Number: 3154469 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEVILLA, FREDDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020330 BAGEL BISTRO
 License Type: Permanent Food Service 173 N. US HIGHWAY 1, TEQUESTA 33469

Inspection Date: 04/12/2022 Inspection Number: 3185852 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STEUBER, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At entrance to kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217662 TROPEZ
 License Type: Permanent Food Service 437 CENTRAL AVE, ST. PETERSBURG 33701

Inspection Date: 04/14/2022 Inspection Number: 3096559 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In rear electrical storage room 20 lb propane tank.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205584 BERMUDA'S
 License Type: Permanent Food Service 5700 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 04/15/2022 Inspection Number: 3167462 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 096525 8/24/2021 displayed.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6218302 DEAD PRESIDENTS
 License Type: Permanent Food Service 1742 E CENTRAL AVE, ST PETERSBURG 33712

Inspection Date: 04/15/2022 Inspection Number: 3168060 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryers in use on cooks line with no hood system installed. -	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212123 TAVERN ON THE OAKS
 License Type: Permanent Food Service 2751 REGENCY OAKS BLVD, CLEARWATER 33759

Inspection Date: 04/12/2022 Inspection Number: 3143791 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL131464,070912,058629,124154,085674,085675,085677 all expired 2/10/2022 FL124160 expired 11/28/2018	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6212124

REGENCY OAKS ILF NORTH

License Type: Permanent Food Service

2751 REGENCY OAKS BLVD, CLEARWATER 33759

Inspection Date: 04/12/2022

Inspection Number: 3106046

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
FL131464,070912,058629,124154,085674,085675,085677 all expired 2/10/2022
FL124160 expired 11/28/2018

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6213612

REGENCY OAKS ILF SOUTH

License Type: Permanent Food Service

2701 REGENCY OAKS BLVD., CLEARWATER 33759

Inspection Date: 04/12/2022

Inspection Number: 3128081

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code ObservationViolation Citation

48-01-5 Boiler certificates expired. For reporting purposes only.
FL131464,070912,058629,124154,085674,085675,085677 all expired 2/10/2022
FL124160 expired 11/28/2018

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Putnam County

License Number: 6400898

DUNKIN DONUTS

License Type: Permanent Food Service

218 S HIGHWAY 17, EAST PALATKA 32131

Inspection Date: 04/12/2022

Inspection Number: 3185855

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher by walk in cooler in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805348

CHIANTI

License Type: Permanent Food Service

3900 CLARK RD BLDG M 1 2 3, SARASOTA 34233

Inspection Date: 04/11/2022

Inspection Number: 3136145

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: CATTLEY, RAYMOND

Violation CodeObservationViolation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Observed open electrical box on cooks line. - From follow-up inspection 2022-04-11: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805597

OFF THE WAGON

License Type: Permanent Food Service

2107 TAMIAMI TRL, VENICE 34293

Inspection Date: 04/13/2022

Inspection Number: 3151510

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: KEATING, PATRICK

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit near office hall blocked by boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903106 THE DANCING CRAB
 License Type: Permanent Food Service 884 W SR 436, ALTAMONTE SPRINGS 32714

Inspection Date: 04/11/2022 Inspection Number: 3185830 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, LESLIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. -boiler certificate posted expired 12/2017.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6905095 COCINA MAYA MEXICAN GRILL & MEZCALERIA
 License Type: Permanent Food Service 3590 N US HWY 17/ 92, LAKE MARY 32746

Inspection Date: 04/11/2022 Inspection Number: 3172929 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Items in front of the back door , operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904559 GATEWAY TO INDIA
 License Type: Permanent Food Service 790 EAST SR 434, LONGWOOD 32750

Inspection Date: 04/14/2022 Inspection Number: 3166199 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406887

U CHINA

License Type: Permanent Food Service

326 SEABREEZE BLVD, DAYTONA BEACH 32118

Inspection Date: 04/12/2022

Inspection Number: 3138961

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.

-Front door, blocked by Large wooden barricade used for a makeshift window service under marked exit sign. - From follow-up inspection 2022-04-12:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.