

Alachua County

License Number: 1103188

EAT AT TINKER

License Type: Permanent Food Service

502 S MAIN ST, GAINESVILLE 32601

Inspection Date: 05/02/2022

Inspection Number: 3156591

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed the fire extinguisher inside the back door indicates in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1504679 FLORIDA'S SEAFOOD BAR AND GRILL
 License Type: Permanent Food Service 480 W COCOA BEACH CSWY, COCOA BEACH 32931

Inspection Date: 04/25/2022 Inspection Number: 3164355 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HICKS, GEORGE RANDY

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver by double bay sink. - From follow-up inspection 2022-04-25: **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 1506794 USSA SPACE COAST COMPLEX
 License Type: Permanent Food Service 5800 STADIUM PKWY, MELBOURNE 32940

Inspection Date: 04/27/2022 Inspection Number: 3172224 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FICHTER, GARRICK

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler onsite is functional and has not been inspected since 2018. Boilers in main stadium 5800 and 5600 offices | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

Broward County

License Number: 1600955

MCHAIG INC

License Type: Permanent Food Service

1140 N SR 7, LAUDERHILL 33313

Inspection Date: 04/29/2022

Inspection Number: 3186720

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROGERS, VERNEL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Main kitchen rear exit door- observed exit door being blocked by trash.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001123

BIG DAWGS FAMILY SPORTS RESTAURANT

License Type: Permanent Food Service

1330 BLANDING BLVD 135, ORANGE PARK 32065

Inspection Date: 04/25/2022

Inspection Number: 3167461

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher next to kitchen entrance.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200741

TWO FAT GUYS BURGERS AND FRIES

License Type: Permanent Food Service

135 SW BAYA DR, LAKE CITY 32025

Inspection Date: 04/25/2022

Inspection Number: 3182518

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. In the storage closet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2322247

MENA CATERING

License Type: Catering

7462 SW 48 ST, MIAMI 331554469

Inspection Date: 04/26/2022

Inspection Number: 1120466

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330259

CARLOS' SEA FOOD & RESTAURANT

License Type: Permanent Food Service

17740 HOMESTEAD AVENUE, MIAMI 33157

Inspection Date: 04/28/2022

Inspection Number: 3161189

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: SWIGERT, RICHARD

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a 20 pound propane tank in the back room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2360152

RIB'S ON WHEELS INC

License Type: Mobile Food Dispensing Vehicle

12248 SW 130 ST, MIAMI 33186

Inspection Date: 04/27/2022

Inspection Number: 1249275

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code ObservationViolation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600718

FLA YACHT CLUB

License Type: Permanent Food Service

5210 YACHT CLUB RD, JACKSONVILLE 322108398

Inspection Date: 04/26/2022

Inspection Number: 3171033

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Inspection report posted expired 11/14/2020.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2615867

YUMMY LATINA CAFE

License Type: Permanent Food Service

11041 BEACH BLVD UNIT CR2, JACKSONVILLE 32246

Inspection Date: 04/28/2022

Inspection Number: 3186882

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Stove top in back kitchen across from three compartment sink with no hood suppression system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3910170 RIVER'S EDGE
 License Type: Permanent Food Service 6226 OHIO AVENUE, GIBSONTON 33534

Inspection Date: 04/29/2022 Inspection Number: 3170218 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: CRUZ, JABULANI

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 49-05-4 | - From initial inspection : Increased seating from 75 to approximately 298. Establishment on septic. For reporting purposes only. - From follow-up inspection 2022-04-29: | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 49-05-4 | Increased seating from 75 to approximately 298. Establishment on septic. For reporting purposes only. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 3918478 POPEYE'S LOUISIANA KITCHEN
 License Type: Permanent Food Service 7430 E HILLSBOROUGH AVENUE, TAMPA 33610

Inspection Date: 04/25/2022 Inspection Number: 3171351 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: COLEMAN, TONYA

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Backed door to kitchen blocked my cardboard boxes | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 3910985 JOE'S NEW YORK DINER LLC
 License Type: Permanent Food Service 11701 N FLORIDA AVE, TAMPA 33612

Inspection Date: 04/29/2022 Inspection Number: 3137753 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: CESAR, RACHEL

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 46-01-4 | - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Red door leading to patio blocked by water line, table and fan. - From follow-up inspection 2022-03-01: **Time Extended** - From follow-up inspecti | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Hillsborough County

License Number: 3912268

THINH AN KITCHEN & TOFU

License Type: Permanent Food Service

8104 W WATERS AVE, TAMPA 33615

Inspection Date: 04/25/2022

Inspection Number: 3182990

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: ZHANG, JACKY

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2022-04-21: ****Time Extended**** - From follow-up inspection 2022-04-25:

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4600078

GASPARILLA INN DINING ROOM

License Type: Permanent Food Service

500 PALM AVE, BOCA GRANDE 339219999

Inspection Date: 04/30/2022

Inspection Number: 3176568

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Leon County

License Number: 4703448

PANDA EXPRESS #2029

License Type: Permanent Food Service

2247 CAPITAL CIR NE, TALLAHASSEE 32308

Inspection Date: 04/27/2022

Inspection Number: 3147526

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVILA, NELSON

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.
 Observed a fire extinguisher on the floor in the back of the kitchen by the exit door.
 Observed the manager remove the fire extinguisher from the floor. **Corre

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105819 PANERA BREAD #6119
 License Type: Permanent Food Service 6351 MANATEE AVENUE W, BRADENTON 34209

Inspection Date: 04/27/2022 Inspection Number: 3186818 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MCKEON, MICHAEL

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door off the kitchen blocked by the trash cart. Manager removed the cart. **Corrected On-Site** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5105854 SOLORZANOS PIZZERIA LBK
 License Type: Permanent Food Service 5610 GULF OF MEXICO DR STE 4, LONGBOAT KEY 34228

Inspection Date: 04/25/2022 Inspection Number: 3178199 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MCKEON, MICHAEL

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Above the small fryer in the back kitchen area. As a repeat violation the importance of following prop | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Monroe County

License Number: 5428164

MEAT EATERY AND TAPROOM

License Type: Permanent Food Service

88005 OVERSEAS HWY #15, ISLAMORADA 33036

Inspection Date: 04/28/2022

Inspection Number: 3162411

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814537

DAJEN EATS LLC

License Type: Permanent Food Service

323 E KENNEDY BLVD UNIT F, EATONVILLE 32751

Inspection Date: 04/26/2022

Inspection Number: 3174067

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer and flat top grill no hood.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810961

NEW YORK DELI

License Type: Permanent Food Service

2301 MAITLAND CENTER PKWY STE 124, MAITLAND 32751

Inspection Date: 04/27/2022

Inspection Number: 3176557

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Tabletop griddle in use, cooking eggs

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813399

MAITLAND CAFE

License Type: Permanent Food Service

500 WINDERLEY PL, SUITE 109, MAITLAND 32751

Inspection Date: 04/27/2022

Inspection Number: 3173867

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Tabletop flattop grill and household stove, no overhead exhaust. Cooked eggs on stove.. Operator sta

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800003

DQ GRILL AND CHILL

License Type: Permanent Food Service

3728 CURRY FORD ROAD, ORLANDO 32806

Inspection Date: 04/25/2022

Inspection Number: 3182643

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PLEICONES, KIM

Violation Code ObservationViolation Citation

46-04-4 Exit door locked. For reporting purposes only. Side door from dining room marked as an exit locked while facility is open and operating. Owner unlocked door **Corrected On-Site** **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5815358

GATLIN HALL BREWING

License Type: Permanent Food Service

4721 S. ORANGE AVE, ORLANDO 32806

Inspection Date: 04/29/2022

Inspection Number: 3153691

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PLEICONES, KIM

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
2 Tanks in new prep area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815060

MOOYAH

License Type: Permanent Food Service

8050 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 04/29/2022

Inspection Number: 3162662

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only.
On floor across from three compartment sink. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806324

EMBASSY SUITES RESORT - LAKE BUENA VISTA

License Type: Permanent Food Service

8100 LAKE ST, ORLANDO 32836-6401

Inspection Date: 04/29/2022

Inspection Number: 3142846

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./all three boiler certificates expired 2/4/2022.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5911392

PIENEZZA PIZZA

License Type: Permanent Food Service

3236 N JOHN YOUNG PKWY, KISSIMMEE 34741

Inspection Date: 04/28/2022

Inspection Number: 3143264

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only./ observed speed cart with slicer , other containers

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217283 TONY'S PIZZA
 License Type: Permanent Food Service 533 CENTRAL AVE, SAINT PETERSBURG 33701

Inspection Date: 04/25/2022 Inspection Number: 3158052 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MURPHY, JAMES

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In office in rear of establishment. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6217503 DUNKIN DONUTS/BASKIN ROBBINS
 License Type: Permanent Food Service 1525 4 ST SOUTH, ST. PETERSBURG 33701

Inspection Date: 04/27/2022 Inspection Number: 3102678 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MURPHY, JAMES

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. Bread racks blocking rear exit to dumpster area. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6217313 BRGR KITCHEN & BAR
 License Type: Permanent Food Service 10800 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 04/28/2022 Inspection Number: 3173037 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 123734 2/27/22, 124528 2/27/22, 124549 2/27/22, 124550 2/27/22, | 61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

License Number: 6216541 MONKEY BAR OF CLEARWATER
 License Type: Permanent Food Service 1681 GULF TO BAY BLVD, CLEARWATER 33755

Inspection Date: 04/25/2022 Inspection Number: 3143521 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOLDMAN, BARRY

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer not under hood system. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Sarasota County

License Number: 6805362

LA MUCCA BALLERINA

License Type: Permanent Food Service

1668 MAIN ST, SARASOTA 34236

Inspection Date: 04/25/2022

Inspection Number: 3173615

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Wires in the dry storage area. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904629

THE OLIVE GARDEN ITALIAN RESTAURANT #1702

License Type: Permanent Food Service

300 W 436, ALTAMONTE SPRINGS 32714

Inspection Date: 04/29/2022

Inspection Number: 3183458

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. 2 extinguishers by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904937

KEKE'S BREAKFAST CAFE

License Type: Permanent Food Service

1032 MONTGOMERY RD, ALTAMONTE SPRINGS 32714

Inspection Date: 04/29/2022

Inspection Number: 3179917

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Red extinguisher at entry to kitchen right door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903479

TEXAS ROADHOUSE

License Type: Permanent Food Service

100 TOWNE CENTER BLVD, SANFORD 32771

Inspection Date: 04/26/2022

Inspection Number: 3174325

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ANGEL, TERRY

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Rear kitchen door blocked by rack with glasses. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904941

SAN MIGUEL MEXICAN GRILL

License Type: Permanent Food Service

2715 S ORLANDO DR, SANFORD 32773

Inspection Date: 04/26/2022

Inspection Number: 3169222

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: THORNCROFT, ROBERT

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 47-03-4 | Observed electrical wiring in disrepair. For reporting purposes only. Cover plate missing on the switch at the chest freezer in the kitchen | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 47-03-4 | - From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Cover plate missing on the switch at the chest freezer in the kitchen - From follow-up inspection 2022-04-29: **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

St. Johns County

License Number: 6500466

CONCH HOUSE MARINA RESORT

License Type: Permanent Food Service

57 COMARES AVE, ST AUGUSTINE 32080

Inspection Date: 04/25/2022

Inspection Number: 3176296

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher by server station.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6500103

TACO LIBRE

License Type: Permanent Food Service

2600 N PONCE DE LEON BLVD, SAINT AUGUSTINE 32084

Inspection Date: 04/26/2022

Inspection Number: 3138674

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: HARTMANN, MICHELLE

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6500464

SCARLETT'S ST AUGGY & DOS GATOS ST AUGGY

License Type: Permanent Food Service

70 HYPOLITA ST, SAINT AUGUSTINE 32084

Inspection Date: 04/27/2022

Inspection Number: 3167159

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HARTMANN, MICHELLE

Violation Code ObservationViolation Citation48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Two propane tanks inside. Person in charge removed tanks and placed outside.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407433

CMX DAYTONA

License Type: Permanent Food Service

1850 LEGENDS LANE STE 100E, DAYTONA BEACH 32114

Inspection Date: 04/27/2022

Inspection Number: 3176492

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 -chair in front of door partially blocking path- side door but ticket area **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405385

BOSTON MARKET #0734

License Type: Permanent Food Service

1037 DUNLAWTON AVE, PORT ORANGE 321277968

Inspection Date: 04/28/2022

Inspection Number: 3176313

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407311

BACI PIZZERIA & RISTORANTE

License Type: Permanent Food Service

830 N DIXIE FREEWAY, NEW SMYRNA BEACH 32168

Inspection Date: 04/27/2022

Inspection Number: 3171348

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PICHARDO, RENEE

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Pizza oven area in tiki bar **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7402521

FLAGLER TAVERN

License Type: Permanent Food Service

414 FLAGLER AVE, NEW SMYRNA BEACH 32169

Inspection Date: 04/27/2022

Inspection Number: 3177195

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: PICHARDO, RENEE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Main bar | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Main bar **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |