

**Alachua County**

License Number: 1103188

EAT AT TINKER

License Type: Permanent Food Service

502 S MAIN ST, GAINESVILLE 32601

Inspection Date: 05/02/2022

Inspection Number: 3156591

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed the fire extinguisher inside the back door indicates in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Gadsden County**

License Number: 3000354

EL TAMAULIPECO

License Type: Permanent Food Service

40 PAVILION DRIVE, QUINCY 32351

Inspection Date: 04/26/2022

Inspection Number: 3154938

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: YANDELL, TIMOTHY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By entry door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3906760

D & D DELIGHTS

License Type: Permanent Food Service

1301 S 20 ST, TAMPA 336056605

Inspection Date: 05/04/2022

Inspection Number: 3184361

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Observed 2 propane tanks in kitchen at time of inspection

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4600078

GASPARILLA INN DINING ROOM

License Type: Permanent Food Service

500 PALM AVE, BOCA GRANDE 339219999

Inspection Date: 04/30/2022

Inspection Number: 3176568

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Leon County**

License Number: 4703718

TIJUANA FLATS

License Type: Permanent Food Service

1400 VILLAGE SQUARE BLVD UNIT 40, TALLAHASSEE 32312

Inspection Date: 05/03/2022

Inspection Number: 3185230

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAVILA, NELSON

Violation Code

Observation

Violation Citation

45-05-4      Portable fire extinguisher missing from its designated location. For reporting purposes only.  
 Observed a fire extinguisher on the floor not in its designated location.  
 Observed the manager remove and place the extinguisher at its designated location. \*\*C

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5105716

OAK AND STONE

License Type: Permanent Food Service

5405 UNIVERSITY PKWY 101, BRADENTON 34201

Inspection Date: 05/03/2022

Inspection Number: 3186751

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone to the right of the pizza ovens and kitchen entry door. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Marion County**

License Number: 5202044

HARRY'S SEAFOOD BAR & GRILLE

License Type: Permanent Food Service

24 SE 1 AVE, OCALA 344712152

Inspection Date: 05/04/2022

Inspection Number: 3186625

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARNER, DHANIQUA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located in dry storage area in the " recharge " zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5300501

SAILFISH POINT CLUBHOUSE

License Type: Permanent Food Service

2201 SE SAILFISH POINT BLVD, STUART 34996-1911

Inspection Date: 05/05/2022

Inspection Number: 3175416

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Cover plate broken/prep area/kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5428267 MELLOW VENTURES  
 License Type: Permanent Food Service 1605 N. ROOSEVELT BLVD., KEY WEST 33040

Inspection Date: 05/02/2022 Inspection Number: 3184448 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed table top stove in kitchen area with no hood suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402740 FLORIDA KEYS COUNTRY CLUB  
 License Type: Permanent Food Service 4000 SOMBRERO BLVD, MARATHON 33050

Inspection Date: 05/06/2022 Inspection Number: 3168394 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: WHITEHURST, SCOTT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no up to date and inspected hood suppression system installed. Notified Fire AHJ. For reporting purposes only. In the downstairs licensed kitchen area the hood system is rusting and expire	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5810461 THE MELTING POT OF ORLANDO  
 License Type: Permanent Food Service 7549 W SANDLAKE RD, ORLANDO 32819

Inspection Date: 05/03/2022 Inspection Number: 3176493 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. By the dry stock area. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814525 THE H  
 License Type: Permanent Food Service 7512 DR PHILLIPS BLVD STE 80, ORLANDO 32819

Inspection Date: 05/06/2022 Inspection Number: 3187330 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Back kitchen and they have person coming out to install. <b>**Corrective Action Taken**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6022416

SCOOPS & CONES

License Type: Permanent Food Service

33 SE 3 AVE UNIT 5, DELRAY BEACH 33483

Inspection Date: 05/06/2022

Inspection Number: 3187317

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Pinellas County**

License Number: 6214864

DON CESAR RESORT SPA - TAKE 5

License Type: Permanent Food Service

3400 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 05/02/2022

Inspection Number: 3109591

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Putnam County**

License Number: 6450122

MARIA LA MEXICANA

License Type: Mobile Food Dispensing Vehicle

100 MOSELEY AVE, PALATKA 32177

Inspection Date: 05/06/2022

Inspection Number: 1249563

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher in red by front passenger door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6904937

KEKE'S BREAKFAST CAFE

License Type: Permanent Food Service

1032 MONTGOMERY RD, ALTAMONTE SPRINGS 32714

Inspection Date: 05/04/2022

Inspection Number: 3179917

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Red extinguisher at entry to kitchen right door. - From follow-up inspection 2022-05-04: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**St. Lucie County**

License Number: 6602441

ECKLES LOUNGE RESTAURANT

License Type: Permanent Food Service

1520 ORANGE AVE, FORT PIERCE 34950

Inspection Date: 05/03/2022

Inspection Number: 3186921

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer on top of freezer not in use at this time. Let them know that it is not acceptable in the kitche

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7405866

LONGHORN STEAKS OF DAYTONA BCH 5114

License Type: Permanent Food Service

2504 W INTL SPDWY BLVD, DAYTONA BCH 32114

Inspection Date: 05/05/2022

Inspection Number: 3177098

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code    ObservationViolation Citation49-01-4    Flammables stored/debris present in meter room. For reporting purposes only.  
-Boxes of single service items stored in electrical panel room

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7406383

BENNETTS CATERING AND GIFTS

License Type: Catering

625 N OLEANDER AVE, DAYTONA BEACH 32118

Inspection Date: 05/04/2022

Inspection Number: 1120235

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code    ObservationViolation Citation

48-04-4    Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405886

OFF THE HOOK AT INLET HARBOR

License Type: Permanent Food Service

133 INLET HARBOR RD, PONCE INLET 32127

Inspection Date: 05/03/2022

Inspection Number: 3168297

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code    ObservationViolation Citation45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only.  
  
-tyke k extinguisher on wall near walk in cooler door/stairs

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Walton County**

License Number: 7601838		GRACE PIZZA AND SHAKES	
License Type: Permanent Food Service		38 CLAYTON LN STE 19, SANTA ROSA BEACH 32459	
Inspection Date: 05/03/2022	Inspection Number: 3184809	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by walk-in in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7602067		VKI JAPANESE STEAK HOUSE & SUSHI BAR	
License Type: Permanent Food Service		4552 US HWY 98 WEST 1 & 2, SANTA ROSA BEACH 32459	
Inspection Date: 05/04/2022	Inspection Number: 3178485	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SHANKLIN, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in dining room near hand wash sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7650099		TACO 30A	
License Type: Mobile Food Dispensing Vehicle		4821 HIGHWAY 98 W STE 101, SANTA ROSA BEACH 32459	
Inspection Date: 05/02/2022	Inspection Number: 1237615	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SHANKLIN, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7602145		MAMA CLEMENZA	
License Type: Permanent Food Service		12273 US HWY 98 SUITE 102, MIRAMAR BEACH 32550	
Inspection Date: 05/04/2022	Inspection Number: 3176441	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HAASE, TINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed fry daddy on side table in kitchen not under hood vent in use.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Walton County**

License Number: 7602230

OUTCAST SEAFOOD

License Type: Permanent Food Service

10859 EMERALD COAST PKWY #404, MIRAMAR BEACH 32550

Inspection Date: 05/03/2022

Inspection Number: 3177393

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in over charge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.