

Broward County

License Number: 1621577

CHICK-FIL-A AT THE FOUNTAINS OF MIRAMAR FSR

License Type: Permanent Food Service

3211 SW 160 AVE, MIRAMAR 33027-4215

Inspection Date: 05/09/2022

Inspection Number: 3186512

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code ObservationViolation Citation47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.
-Observed electrical outlet at walk in freezer needed a cover.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623272

SOFI'S CAFE

License Type: Permanent Food Service

200 E BROWARD BLVD SE 110, FORT LAUDERDALE 33301

Inspection Date: 05/12/2022

Inspection Number: 3150714

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code ObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Countertop fryer in use on back storage area shelf.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327551

TRATTORIA DELLA SPIAGGIA

License Type: Permanent Food Service

3010 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 05/09/2022

Inspection Number: 3162559

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: UNZAGA, MILADYS

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. ****Repeat Violation****
 - From follow-up inspection 2022-05-09: ****Time Extended****

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2312591

VALERIE'S CAFE

License Type: Permanent Food Service

2148 NW 17 AVE #2, MIAMI 33142

Inspection Date: 05/11/2022

Inspection Number: 3163238

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
 Observed at the right side of the main entrance.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317813

TROPICAL CHINESE RESTAURANT

License Type: Permanent Food Service

7991 BIRD RD, MIAMI 331556750

Inspection Date: 05/10/2022

Inspection Number: 3165598

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
 Observed 2 gas tanks by water heater next to walk in freezer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612932 EL TAPATIO ORIGINAL
 License Type: Permanent Food Service 7900 103 ST STE 32, JACKSONVILLE 32210

Inspection Date: 05/11/2022 Inspection Number: 3178171 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MERCER, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One has grill tank stored inside near back door. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2651965 THE FRIED EGG
 License Type: Mobile Food Dispensing Vehicle 5960 RICHARD ST, JACKSONVILLE 32216

Inspection Date: 05/09/2022 Inspection Number: 1246927 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Red fire extinguisher on truck in the red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613228 ROD'S CRAB SHACK
 License Type: Permanent Food Service 1301 MONUMENT RD #13, JACKSONVILLE 32225

Inspection Date: 05/10/2022 Inspection Number: 3169574 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Four propane tanks in closet area. Operator had tanks removed. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616025 KAHVE
 License Type: Permanent Food Service 5907 ROOSEVELT BLVD UNIT 400, JACKSONVILLE 32244

Inspection Date: 05/11/2022 Inspection Number: 3185011 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has small flat top grill in kitchen area but does not have any hood system in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905881 WESTIN HARBOUR ISLAND BLUE HARBOUR RESTAURANT
 License Type: Permanent Food Service 725 S HARBOUR ISLAND BLVD, TAMPA 33602

Inspection Date: 05/13/2022 Inspection Number: 3186943 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EHLERS, MICHAEL

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired 10 Feb 2022. They were already inspected and cited 04 March 2022.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3905882 WESTIN HARBOUR ISLAND BANQUET
 License Type: Permanent Food Service 725 S HARBOUR ISLAND BLVD, TAMPA 33602

Inspection Date: 05/13/2022 Inspection Number: 3186685 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EHLERS, MICHAEL

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired 10 Feb 2022. They were already inspected and cited 04 March 2022.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3905883 WESTIN HARBOUR ISLAND EMPLOYEE LOUNGE
 License Type: Permanent Food Service 725 S HARBOUR ISLAND BLVD, TAMPA 33602

Inspection Date: 05/13/2022 Inspection Number: 3185662 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EHLERS, MICHAEL

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired 10 Feb 2022. They were already inspected and cited 04 March 2022.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3918039 HOME 2 SUITES TAMPA USF
 License Type: Permanent Food Service 11606 MCKINLEY DRIVE, TAMPA 33612

Inspection Date: 05/11/2022 Inspection Number: 3091682 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CESAR, RACHEL

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Establishment awaiting final copy of boiler certificate after inspection on 4/29. **Corrective Action Taken**

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4606083

VILLAGE WALK BAR & GRILLE

License Type: Permanent Food Service

15301 LATITUDE DR # 500, BONITA SPRINGS 34135

Inspection Date: 05/12/2022

Inspection Number: 3181197

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOMKOWSKI, DANIEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks larger than 2.7 pounds located inside back door to kitchen. Operator moved both canisters to outside of door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301836

DISTRICT TABLE & BAR

License Type: Permanent Food Service

4665 SE DIXIE HWY, STUART 34997

Inspection Date: 05/10/2022

Inspection Number: 3143690

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Baby fryer not under hood system.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814122 FARM & HAUS
 License Type: Permanent Food Service 3201 CORRINE DRIVE SUITE 1, ORLANDO 32803

Inspection Date: 05/11/2022 Inspection Number: 3181484 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: VALERIO, GRACE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - Flat grill top.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808867 LA LECHONERA EL BARRIO
 License Type: Permanent Food Service 435 N SEMORAN BLVD, ORLANDO 32807

Inspection Date: 05/11/2022 Inspection Number: 3182097 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher at entry into cooking area. - From follow-up inspection 2022-05-11: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher at entry into cooking area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809227 MOMA'S UNWIND CAFE
 License Type: Permanent Food Service 1800 PEMBROOK DR UNIT 185, ORLANDO 32810

Inspection Date: 05/10/2022 Inspection Number: 3178642 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Grease buildup on wall and ceiling above stove, facility cooks Philly cheese steaks, item listed on	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811554

PROVISIONS AND BUZZ CO

License Type: Permanent Food Service

4868 NEW BROAD ST, ORLANDO 32814

Inspection Date: 05/11/2022

Inspection Number: 3154342

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

47-02-4

Cover missing on switch by soda fountain behind bar. . For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805718

KIMONOS

License Type: Permanent Food Service

1200 EPCOT RESORT BLVD, LAKE BUENA VISTA 32830

Inspection Date: 05/13/2022

Inspection Number: 3167113

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only./kitchen prep area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6021582

FEDERATION CCRC OPERATIONS CORP- BISTRO

License Type: Permanent Food Service

21036 95TH AVENUE SOUTH, BOCA RATON 33428

Inspection Date: 05/06/2022

Inspection Number: 3185579

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEWIS, LYNDEN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6217167

SANTA FE MEXICAN GRILL

License Type: Permanent Food Service

800 CLEARWATER LARGO, LARGO 33770

Inspection Date: 05/11/2022

Inspection Number: 3176510

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Not Complied

Inspector Name: MAJEWSKI, JEREMY

Violation Code ObservationViolation Citation49-05-4 - From initial inspection : Can of gasoline in kitchen. Kitchen manager removed
Corrected On-Site **Repeat Violation** - From follow-up inspection
2022-05-11:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

49-05-4 Can of gasoline in kitchen. Kitchen manager removed **Corrected On-Site**
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215683

AMICIS CATERED CUISINE

License Type: Catering

205 MARLBOROUGH ST., OLDSMAR 34677-3105

Inspection Date: 05/10/2022

Inspection Number: 1120911

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher (class K) gauge in red zone near kitchen hand wash
sink . For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6308061

CHINA GARDEN

License Type: Permanent Food Service

1527 BARTOW RD, LAKE LAND 33801

Inspection Date: 05/12/2022

Inspection Number: 3150640

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only.
K class extinguisher blocked by prep table on cook line

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400910

STEAMBOAT WILLIES

License Type: Permanent Food Service

309 SAINT JOHNS AVE, PALATKA 32177

Inspection Date: 05/12/2022

Inspection Number: 3174093

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Observed propane tanks in secondary storage area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502286 CANTINA LOUIE
 License Type: Permanent Food Service 10870 US HWY 1 N STE 110, PONTE VEDRA 32081

Inspection Date: 05/09/2022 Inspection Number: 3178618 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked rear exits.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6502258 VALLEY SMOKE RESTAURANT
 License Type: Permanent Food Service 11 S ROSCOE BLVD, PNTE VDRA BCH 32082

Inspection Date: 05/11/2022 Inspection Number: 3170069 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROZIER, TORRANCE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer used for chicken skin not under a hood	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501252 AGUSTIN INN
 License Type: Permanent Food Service 29 CUNA ST, SAINT AUGUSTINE 32084

Inspection Date: 05/09/2022 Inspection Number: 3113486 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MAKOWSKI, JARED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment used a griddle to cook eggs and sausages without a hood. Visible grease laden vapors in	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100228

BURGER KING #9952

License Type: Permanent Food Service

1575 OHIO AVE S, LIVE OAK 32060

Inspection Date: 05/11/2022

Inspection Number: 3187351

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Overcharged, near walk in cooler

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406959

SOUL FOODS

License Type: Permanent Food Service

456 DR MARTIN LUTHER KING JR BLVD, DAYTONA BEACH 32114

Inspection Date: 05/12/2022

Inspection Number: 3176983

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407073

MCDONALD'S 34816

License Type: Permanent Food Service

3181 SR 44, NEW SMYRNA BEACH 32168

Inspection Date: 05/10/2022

Inspection Number: 3124656

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.

-rear exit door blocked by otherwise movable equipment/stack of bread racks on wheels during inspection. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7601724

KFC F569056

License Type: Permanent Food Service

2482 US HWY 331 S, DEFUNIAK SPRINGS 32435

Inspection Date: 05/09/2022

Inspection Number: 3173358

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near 3 compartment sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.