

Broward County

License Number: 1622425

SAND BAR

License Type: Permanent Food Service

1350 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 05/16/2022

Inspection Number: 3187951

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STEUBER, RYAN

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621073

POPEYES CHICKEN AND BISCUITS

License Type: Permanent Food Service

7050 W COMMERCIAL BLVD, LAUDERHILL 33313

Inspection Date: 05/18/2022

Inspection Number: 3188033

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001323

FRESH FROM YIANNIS KITCHEN

License Type: Permanent Food Service

1831 GOLDEN EAGLE WAY #29, FLEMING ISLAND 32003

Inspection Date: 05/17/2022

Inspection Number: 3141082

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with suppression system in disrepair. Notified Fire AHJ. For reporting purposes only.
Pull cord on wall for fire suppression system is hanging down.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2337273 CITIZENM MIAMI BRICKELL
 License Type: Permanent Food Service 11 SE 10TH STREET, MIAMI 33131

Inspection Date: 05/18/2022 Inspection Number: 3183558 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. At the time of the inspection observed establishment has three boilers with input rating of 700,000 btu. No boiler certificate provided.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2312591 VALERIE'S CAFE
 License Type: Permanent Food Service 2148 NW 17 AVE #2, MIAMI 33142

Inspection Date: 05/13/2022 Inspection Number: 3163238 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: SAENZ, HILDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at the right side of the main entrance. - From follow-up inspection 2022-05-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334928 PISCO Y NAZCA CEVICHE GASTROBAR
 License Type: Permanent Food Service 8405 MILLS DR, SUITE 206, MIAMI 33183

Inspection Date: 05/20/2022 Inspection Number: 3169806 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Located inside employee bathroom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613016

WASABI SUSHI FANG

License Type: Permanent Food Service

1650 SAN PABLO RD S #5, JACKSONVILLE 32224

Inspection Date: 05/18/2022

Inspection Number: 3177003

Inspection Type: Routine - Food

Inspection Disposition: Emergency
order recommended

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher hanging on wall next to back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615870

CUP OF DREAMS

License Type: Permanent Food Service

1079 ATLANTIC BLVD SUITE 1 AND 2, ATLANTIC BEACH 32233

Inspection Date: 05/19/2022

Inspection Number: 3123105

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, MAYRA

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917541 FABRICA WOODFIRED PIZZA
 License Type: Permanent Food Service 142 S MERIDIAN AVE, TAMPA 33602

Inspection Date: 05/17/2022 Inspection Number: 3178313 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Small countertop fryer in back area. No hood system. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918796 JUNMAI STATION
 License Type: Permanent Food Service 325 N FLORIDA AVE STE C, TAMPA 33602

Inspection Date: 05/17/2022 Inspection Number: 3142583 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	- From initial inspection : Increase in seating from 0 to 9. For reporting purposes only. - From follow-up inspection 2022-05-17: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918693 MADELYN'S BAKERY
 License Type: Permanent Food Service 904 W WATERS AVE UNIT C D E, TAMPA 33604

Inspection Date: 05/16/2022 Inspection Number: 3111939 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: COLEMAN, TONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Using table top fryers and frying eggs on stove. - From follow-up inspection 2022-03-11: **Time Extended** - From follow-up inspection 2022-05-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918377 POKEWORKS 004
 License Type: Permanent Food Service 2223 N WEST SHORE BLVD STE 230-B, TAMPA 33607

Inspection Date: 05/16/2022 Inspection Number: 3139386 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	- From initial inspection : Flammables stored near a source of ignition. For reporting purposes only. 5 gallon propane tank stored next to hot water heater. - From follow-up inspection 2022-03-15: **Time Extended** - From follow-up inspection 2022-05-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912268 THINH AN KITCHEN & TOFU
 License Type: Permanent Food Service 8104 W WATERS AVE, TAMPA 33615

Inspection Date: 05/18/2022 Inspection Number: 3182990 Inspection Type: Food-Licensing Inspection Inspection Disposition: Call Back - Complied
 Inspector Name: ZHANG, JACKY

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2022-04-21: **Time Extended** - From follow-up inspection 2022-04-25: **Time Extended** - From follow-up inspection 2022-05-18: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3917791 LOLIS 2 LLC
 License Type: Permanent Food Service 10011 W HILLSBOROUGH AVE, TAMPA 33615

Inspection Date: 05/16/2022 Inspection Number: 3161792 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: KLUSENDORF, JEANNE

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3951676 TACO'S EL TUZO
 License Type: Mobile Food Dispensing Vehicle 7601 CAUSEWAY BLVD, TAMPA 33619

Inspection Date: 05/19/2022 Inspection Number: 1243397 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MOULDER, BRITTANY

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed 2 mini fryers on prep table

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4501823

HURRICANE DOCKSIDE GRILL

License Type: Permanent Food Service

3351 W BURLEIGH BLVD, TAVARES 32778

Inspection Date: 05/20/2022

Inspection Number: 3154048

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Type k inside prep area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606919 LUMBER AXE
 License Type: Permanent Food Service 2158 COLONIAL BLVD UNITS 1 & 2, FORT MYERS 33907

Inspection Date: 05/18/2022 Inspection Number: 3180355 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Dry storage.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606230 VIKINGOS
 License Type: Permanent Food Service 26880 OLD US 41 NELSON PLAZA, BONITA SPRINGS 34135

Inspection Date: 05/20/2022 Inspection Number: 3174811 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: DOMKOWSKI, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks stored in enclosed prep room behind main kitchen. - From follow-up inspection 2022-05-20: 2 propane tanks stored in enclosed prep room behind main kitchen. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks stored in enclosed prep room behind main kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402727

A SLICE OF PARADISE

License Type: Permanent Food Service

24458 OVERSEAS HWY, SUMMERLAND KEY 33042

Inspection Date: 05/17/2022

Inspection Number: 3180933

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

In kitchen Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811461 POM POM'S TEAHOUSE & SANDWICHERIA
 License Type: Permanent Food Service 67 N BUMBY AVE, ORLANDO 32803

Inspection Date: 05/19/2022 Inspection Number: 3126433 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Inspector Name: VALERIO, GRACE Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - During inspection observed one pan burner used in the back to cook soups. - From follow-up inspection 2022-05-19: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808867 LA LECHONERA EL BARRIO
 License Type: Permanent Food Service 435 N SEMORAN BLVD, ORLANDO 32807

Inspection Date: 05/16/2022 Inspection Number: 3182097 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Inspector Name: HICKS, GEORGE RANDY Extension given, pending

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher at entry into cooking area. - From follow-up inspection 2022-05-11: **Time Extended** - From follow-up inspection 2022-05-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813927 WILLIES PINCHOS
 License Type: Permanent Food Service 1718 N GOLDENROD RD #2, ORLANDO 32807

Inspection Date: 05/18/2022 Inspection Number: 3181952 Inspection Type: Routine - Food Inspection Disposition: Warning
 Inspector Name: HICKS, GEORGE RANDY Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer in dining side of operation.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815266 KOOK'N WITH KIM
 License Type: Permanent Food Service 307 WEST KENNEDY BOULEVARD, ORLANDO 32810

Inspection Date: 05/18/2022 Inspection Number: 3176311 Inspection Type: Routine - Food Inspection Disposition: Inspection
 Inspector Name: FICHTER, GARRICK Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank larger than 2.7 lbs inside kitchen. Operator moved outside **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5812891 S & A RESTAURANT
 License Type: Permanent Food Service 6319 SILVER STAR ROAD, ORLANDO 32818

Inspection Date: 05/17/2022 Inspection Number: 3173764 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher hanging at entrance to kitchen from dining area is in the red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815280 BISTRO PARADISE RESTAURANT & BAR
 License Type: Permanent Food Service 737 N APOPKA VINELAND RD STE 100, ORLANDO 32818

Inspection Date: 05/19/2022 Inspection Number: 3175968 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: GREENE, MARVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2022-05-19: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5905978 INTERMISSION FOOD COURT
 License Type: Permanent Food Service 1811 W WEST BUENA VISTA DR, BAYLAKE 32830

Inspection Date: 05/20/2022 Inspection Number: 3160586 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./two boiler certificates expired. 136764, 136765/both expired 2/28/22.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5907980 WORLD PREMIER
 License Type: Permanent Food Service 1991 W BUENA VISTA DR, LAKE BUENA VISTA 32830

Inspection Date: 05/20/2022 Inspection Number: 3173887 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./one boiler certificate expired/136770, expired 2/28/22.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6020760

TASTE OF THE ISLANDS YAAD STYLE CUISINES

License Type: Permanent Food Service

1097 N MILITARY TRL, WEST PALM BEACH 33409

Inspection Date: 05/18/2022

Inspection Number: 3187723

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: MULERO, JONATHAN

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216428 400 BEACH SEAFOOD AND TRAPHOUSE
 License Type: Permanent Food Service 400 BEACH DR STE 120, ST. PETERSBURG 33701

Inspection Date: 05/17/2022 Inspection Number: 3175233 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in storage room. For reporting purposes only. Propane tank remove to outside area. **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 6217638 11 CHICKS WHOLESALERS DIV
 License Type: Permanent Food Service 199 DR MLK JR ST N, ST. PETERSBURG 33701

Inspection Date: 05/19/2022 Inspection Number: 3184043 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Exit door in kitchen is blocked by steam table. - From follow-up inspection 2022-05-19:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door in kitchen is blocked by steam table.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6208560 BURGER KING #4010
 License Type: Permanent Food Service 32375 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 05/18/2022 Inspection Number: 3188090 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BEACHAM, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only Electric convection oven. Some smoke present from cooking hamburgers in oven.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904986 MEDELLIN BURGER
 License Type: Permanent Food Service 1349 E ALTAMONTE DR STE 1011, ALTAMONTE SPRINGS 32701

Inspection Date: 05/16/2022 Inspection Number: 3180331 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, LESLIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. -small tabletop fryer not under hood suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905252 BROKEN SPOON
 License Type: Permanent Food Service 120 INTERNATIONAL PKWY, SUITE 140, HEATHROW 32746

Inspection Date: 05/17/2022 Inspection Number: 3176224 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905099 THE TENNESSEE TRUFFLE
 License Type: Permanent Food Service 125 W 1 ST, SANFORD 32771

Inspection Date: 05/18/2022 Inspection Number: 3173742 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer not under hood. Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905231 TORO'S BITES & BAR
 License Type: Permanent Food Service 3848 S ORLANDO DR UNIT 102, SANFORD 32773

Inspection Date: 05/17/2022 Inspection Number: 3111848 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer and grill added to the counter top , no hood system, ansul system or k class fire extinguisher present	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900781

WONDERFUL HOUSE

License Type: Permanent Food Service

895 FOX VALLEY DRIVE, SUITE 121, LONGWOOD 32779

Inspection Date: 05/17/2022

Inspection Number: 3171275

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. At the plug for the stand up freezer in the prep area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407269 PANDA EXPRESS #2470
 License Type: Permanent Food Service 2310 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 05/17/2022 Inspection Number: 3187843 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. -front entrance locked with chain/type and pad lock. Person in charge states lock is broken. Manager states has a work order in and expecting them today. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407565 PONCHO'S TACOS & ICE CREAM
 License Type: Permanent Food Service 201 SEABREEZE BLVD, DAYTONA BEACH 32118

Inspection Date: 05/17/2022 Inspection Number: 3187933 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7402552 JBS FISH CAMP
 License Type: Permanent Food Service 859 POMPANO AVE, NEW SMYRNA BEACH 32169

Inspection Date: 05/20/2022 Inspection Number: 3169894 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-03-4	Flammables stored/debris present in boiler room. For reporting purposes only. Cardboard and paper	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.