

Brevard County

License Number: 1501521 SQUID LIPS
 License Type: Permanent Food Service 2200 S ORLANDO AVE, COCOA BEACH 32931

Inspection Date: 05/23/2022 Inspection Number: 3169394 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Extension given, pending
 Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke causing heavily soiled walls and ceiling behind char grill. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2022-05-23: No change **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1503858 CAPTAIN J'S
 License Type: Permanent Food Service 211 E. COCOA BEACH CAUSEWAY, COCOA BEACH 32931

Inspection Date: 05/24/2022 Inspection Number: 3175237 Inspection Type: Routine - Food Inspection Disposition: Administrative
 complaint recommended
 Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. By double upright cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1623652

CHAMPET RESTAURANT AND BAR

License Type: Permanent Food Service

7920 PINES BLVD, PEMBROKE PINES 33024

Inspection Date: 05/25/2022

Inspection Number: 3188378

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone by wait station . For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone by wait station . For reporting purposes only. - From follow-up inspection 2022-05-26: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102750 BICE
 License Type: Permanent Food Service 300 FIFTH AVE SOUTH, NAPLES 34102

Inspection Date: 05/26/2022 Inspection Number: 3156666 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DILLON, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed the fire exit is locked by the bread station in the kitchen area. Operator unlocked the fire exit door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103266 AFSONA
 License Type: Permanent Food Service 300 TAMIAMI TR N, NAPLES 34102

Inspection Date: 05/27/2022 Inspection Number: 3181666 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DILLON, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the back door is blocked to the back alley. Operator removed the equipment blocking the back door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	Exit door locked. For reporting purposes only. Observed the back exit door was locked to the back alley. Operator unlocked the back door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103692 INDUSTRY BEER AND BARBECUE
 License Type: Permanent Food Service 1040 COLLIER CENTER WAY STE 10-11, NAPLES 34110

Inspection Date: 05/26/2022 Inspection Number: 3161852 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DOMKOWSKI, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 12 propane tanks located inside building by back garage exit.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2359027 EMYLY AYALA GALEANO
 License Type: Mobile Food Dispensing Vehicle 24798 SW 129 AVE, MIAMI 33033

Inspection Date: 05/25/2022 Inspection Number: 1248887 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327925 SUITE PANTRY BEV
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3168196 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2327927 FLAGSHIP NORTH
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3166637 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2327928 UPPER BALCONY PANTRY 418
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3171715 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 123051, 123052, 123053, 123054, 123312. Exp 01/13/2022	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2327930 STAND 406
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3169536 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2327932 FLAGSHIP SOUTH
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3171517 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 123051, 123052, 123053, 123054, 123312. Exp 01/13/2022	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2333004 BAR 319
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3169571 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 123051, 123052, 123053, 123054, 123312. Exp 01/13/2022	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2333899 FLAGSHIP NORTH LOUNGE
 License Type: Permanent Food Service 601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022 Inspection Number: 3171897 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2333900

FLAGSHIP SOUTH LOUNGE

License Type: Permanent Food Service

601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022

Inspection Number: 3166068

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. 123051, 123052, 123053, 123054, 123312. Exp
01/13/202261C-1.004(10) FAC Reporting: (10) Heating and
ventilation - The heating and ventilation system shall be
kept in good repair or be installed to maintain a
minimum of 68 degrees Fahrenheit throughout the
building. The insurance inspectors boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers and shall be
posted in the boiler room. For reporting purposes only.

License Number: 2335253

601

License Type: Permanent Food Service

601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 05/23/2022

Inspection Number: 3153534

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.61C-1.004(10) FAC Reporting: (10) Heating and
ventilation - The heating and ventilation system shall be
kept in good repair or be installed to maintain a
minimum of 68 degrees Fahrenheit throughout the
building. The insurance inspectors boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers and shall be
posted in the boiler room. For reporting purposes only.

DeSoto County

License Number: 2400307

RED ZONE LLC

License Type: Permanent Food Service

307 S ALABAMA AVE, ARCADIA 34266

Inspection Date: 05/25/2022

Inspection Number: 3170941

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed exit door beside mens restroom locked.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608646 MARKET PLACE #3
 License Type: Permanent Food Service 6909 RAMONA BLVD, JACKSONVILLE 32205

Inspection Date: 05/21/2022 Inspection Number: 3174412 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Both by cook line **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614931 SAFE HARBOR RESTAURANT
 License Type: Permanent Food Service 4378 OCEAN ST #3, ATLANTIC BEACH 32233

Inspection Date: 05/27/2022 Inspection Number: 3121567 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By handsink in large prep room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Three in ice machine room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613661 HOMEWOOD SUITES BY HILTON JACKSONVILLE-SOUTH/ST. JOHN'S CENTER
 License Type: Permanent Food Service 10434 MIDTOWN PARKWAY, JACKSONVILLE 32246

Inspection Date: 05/26/2022 Inspection Number: 3104806 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired 12-12-21	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Escambia County

License Number: 2705835

FISHERMAN'S CORNER RESTAURANT

License Type: Permanent Food Service

13486 PERDIDO KEY DR, PENSACOLA 32507

Inspection Date: 05/23/2022

Inspection Number: 3185573

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917506 DAILY DOSE COFFEE HOUSE AND EATERY
 License Type: Permanent Food Service 302 KNIGHTS RUN # 130, TAMPA 33602

Inspection Date: 05/23/2022 Inspection Number: 3181046 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Countertop gas burner used to cook food. Sandwich press also used which creates vapors.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	Increase in seating from 0 to 5. For reporting purpose only.'	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917847 HONDURAS RESTAURANT
 License Type: Permanent Food Service 428 W WATERS AVE, TAMPA 33604

Inspection Date: 05/24/2022 Inspection Number: 3178523 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KLUENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918138 ROSE BAR TAMPA
 License Type: Permanent Food Service 122 S HOWARD AVE, TAMPA 33606

Inspection Date: 05/24/2022 Inspection Number: 3180101 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KLUENDORF, JEANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4508451

EDUARDO'S LOKOS TACOS LLC

License Type: Permanent Food Service

226 W ALFRED ST, TAVARES 32778

Inspection Date: 05/26/2022

Inspection Number: 3157550

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: COREY, DEREK

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 -empty cardboard boxes and prep cart blocking path **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4 - From initial inspection : Marked exit/path to marked exit blocked. For reporting
 purposes only.
 -empty cardboard boxes and prep cart blocking path **Corrected On-Site** -
 From follow-up inspection 2022-05-27:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4508481

PUDDLE JUMPERS

License Type: Permanent Food Service

111 W RUBY ST, TAVARES 32778

Inspection Date: 05/23/2022

Inspection Number: 3154301

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: COREY, DEREK

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 -multiple trash cans blocking exit path in kitchen **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606606

BEGONIA'S RESTAURANT & PIZZERIA INC

License Type: Permanent Food Service

2215 WINKLER AVE STE C, FORT MYERS 33901

Inspection Date: 05/24/2022

Inspection Number: 3188258

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed missing outlet cover in prep room near stainless steel reach in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105156

MCGRATHS IRISH ALE HOUSE

License Type: Permanent Food Service

8110 LAKEWOOD MAIN ST, LAKEWOOD RANCH 34202

Inspection Date: 05/26/2022

Inspection Number: 3182548

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone to the left of rear kitchen door to the right of the mop sink area. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5105509

MICHELANGELO PIZZA

License Type: Permanent Food Service

2957 UNIVERSITY PKWY, SARASOTA 34243

Inspection Date: 05/23/2022

Inspection Number: 3178932

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone to the left of the rear kitchen door. For reporting purposes only. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402069

BURGER KING #7133

License Type: Permanent Food Service

5400 OVERSEAS HWY, KEY WEST 33040

Inspection Date: 05/25/2022

Inspection Number: 3187805

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: WHITEHURST, SCOTT

Violation Code ObservationViolation Citation45-02-4 By the. Ack door Portable fire extinguisher gauge in red zone. For reporting
purposes only.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 5428353

SONIC DRIVE-IN

License Type: Permanent Food Service

2312 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 05/24/2022

Inspection Number: 3146131

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed
boxes blocking the rear exit door. **Corrected On-Site**509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Orange County

License Number: 5803835

SHERATON ORLANDO NORTH GRANFE CAFE & LOUNGE& LINK

License Type: Permanent Food Service

600 NORTH LAKE DESTINY DR, MAITLAND 32751

Inspection Date: 05/25/2022

Inspection Number: 3188498

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Boilers were inspected 3/30/22 both boilers did not pass inspection

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815181

THE HAMPTON SOCIAL

License Type: Permanent Food Service

9101 INTERNATIONAL DR #1200, ORLANDO 32819

Inspection Date: 05/26/2022

Inspection Number: 3171285

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside
of the building. For reporting purposes only. At the back door area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808566

JALEO & PEPE BY JOSE ANDRES

License Type: Permanent Food Service

1482 E BUENA VISTA DR FLOOR 2, LAKE BUENA VISTA 32830

Inspection Date: 05/25/2022

Inspection Number: 3171222

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MANTI, KATHRYN

Violation Code ObservationViolation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.
Near tall boy before dish machine

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019165 TRUMP NATIONAL GOLF CLUB JUPITER MAIN KITCHEN
 License Type: Permanent Food Service 115 EAGLE TREE TER, JUPITER 33477

Inspection Date: 05/26/2022 Inspection Number: 3126336 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PALMER, TARA

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only. Expired 04/08/20

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6019166 TRUMP NATIONAL GOLF CLUB JUPITER OASIS
 License Type: Permanent Food Service 115 EAGLE TREE TER, JUPITER 33477

Inspection Date: 05/26/2022 Inspection Number: 3095334 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PALMER, TARA

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only. Expired 4/18/20.

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6019168 TRUMP NATIONAL GOLF CLUB JUPITER EDR
 License Type: Permanent Food Service 115 EAGLE TREE TER, JUPITER 33477

Inspection Date: 05/26/2022 Inspection Number: 3120101 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PALMER, TARA

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only. Expired 04/18/20

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6019169 TRUMP NATIONAL GOLF CLUB JUPITER MEN LOUNGE
 License Type: Permanent Food Service 115 EAGLE TREE TER, JUPITER 33477

Inspection Date: 05/26/2022 Inspection Number: 3126327 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PALMER, TARA

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
 For reporting purposes only. Expired 04/18/20

Violation Citation

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6021519

TRUMP NATIONAL GOLF CLUB JUPITER

License Type: Permanent Food Service

115 EAGLE TREE TERRACE, JUPITER 33477

Inspection Date: 05/26/2022

Inspection Number: 3101928

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PALMER, TARA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. Expired 04/18/20.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6005698

BURGER KING 3197

License Type: Permanent Food Service

5080 W ATLANTIC AVE, DELRAY BEACH 33484

Inspection Date: 05/25/2022

Inspection Number: 3181845

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire
extinguisher located next to office door in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100013

LATIN JAPAN

License Type: Permanent Food Service

1932 US HWY 19, HOLIDAY 34691

Inspection Date: 05/25/2022

Inspection Number: 3180341

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.
Back door locked **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214876

ST PETERSBURG YACHT CLB BALLRM

License Type: Permanent Food Service

11 CENTRAL AVE, ST PETERSBURG 33701

Inspection Date: 05/25/2022

Inspection Number: 3188430

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

49-02-4

Flammables stored/debris present in upstairs kitchen. For reporting purposes only.
Butane lighter fluid stored in kitchen next to ice machine.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Polk County

License Number: 6300357

STEAK N SHAKE

License Type: Permanent Food Service

819 E MEMORIAL BLVD, LAKELAND 33801

Inspection Date: 05/26/2022

Inspection Number: 3158596

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no working hood suppression system. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2022-05-26: Reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no working hood suppression system. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903618

RAMADA

License Type: Permanent Food Service

150 DOUGLAS AVE, ALTAMONTE SPRINGS 32714

Inspection Date: 05/27/2022

Inspection Number: 3107086

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
-boiler certificate 094799 expired 4/16/2020.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6905231

TORO'S BITES & BAR

License Type: Permanent Food Service

3848 S ORLANDO DR UNIT 102, SANFORD 32773

Inspection Date: 05/24/2022

Inspection Number: 3111848

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer and grill added to the counter top , no hood system, ansul system or k class fire extinguisher present - From follow-up inspection 2022-05-24: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502017

YOBE COBBLESTONE

License Type: Permanent Food Service

200 COBBLESTONE DR STE 103, SAINT AUGUSTINE 32086

Inspection Date: 05/25/2022

Inspection Number: 3186299

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MAKOWSKI, JARED

Violation Code ObservationViolation Citation

46-04-4 Exit door locked. For reporting purposes only. Back door locked with metal bar that prevents emergency egress. Discussed with operator to remove bar during operating hours.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6502292

ST AUGUSTINE HOTEL & SUITES

License Type: Permanent Food Service

475 COMMERCE LAKE DR, SAINT AUGUSTINE 32095

Inspection Date: 05/26/2022

Inspection Number: 3188038

Inspection Type: Complaint Partial

Inspection Disposition: Warning Issued

Inspector Name: PERKINS, MARC

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

St. Lucie County

License Number: 6605169

JAMAICAN JERK DELI

License Type: Permanent Food Service

2545 US HWY 1, FORT PIERCE 34982

Inspection Date: 05/23/2022

Inspection Number: 3188265

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Small fryer on counter educated called AHJ called left message educated operator

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407753

TIN & TACO

License Type: Permanent Food Service

102 S COOPER ST, NEW SMYRNA BEACH 32169

Inspection Date: 05/25/2022

Inspection Number: 3184608

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to cookline handsink ****Repeat Violation**** - From follow-up inspection 2022-05-25: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7602201

VILLAGE DOOR SEASCAPE

License Type: Permanent Food Service

60 SEASCAPE DRIVE, MIRAMAR BEACH 32550

Inspection Date: 05/23/2022

Inspection Number: 3188281

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tank near ice maker and oven.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.