

Dade County

License Number: 2336286 7TH CAFE
 License Type: Permanent Food Service 1951 NW 7 AVE UNIT 190, MIAMI 33136

Inspection Date: 06/07/2022 Inspection Number: 3188975 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed in the back cook area: establishment has a hood installed without the fire suppression system. Observed a flat top grill, a charbroil grill and a grease fryer toasting buns in the back kitchen area during inspection. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336009 CENTERPLATE
 License Type: Permanent Food Service 1901 CONVENTION CENTER DRIVE, MIAMI BEACH 33139-1820

Inspection Date: 06/09/2022 Inspection Number: 3181890 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BROWN, JARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler with jurisdiction number 096978 expired on 09/05/19	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2615282

CATULLO'S ITALIAN

License Type: Permanent Food Service

1650 SAN PABLO RD S, #2, JACKSONVILLE 32224

Inspection Date: 06/06/2022

Inspection Number: 3177083

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Single propane tank larger than 2.7 pounds stored inside building next to back door. Manager properly stored outside building ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3450034

JO'S PLACE

License Type: Mobile Food Dispensing Vehicle

15176 SE 99TH WAY, WHITE SPRINGS 32096

Inspection Date: 06/06/2022

Inspection Number: 1238851

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917638 SARKU JAPAN
 License Type: Permanent Food Service 459 BRANDON TOWN CENTER, WESTFIELD BRANDON, BRANDON 33511

Inspection Date: 06/09/2022 Inspection Number: 3169938 Inspection Type: Routine - Food Inspection Disposition: Call Back -
 Inspector Name: MOULDER, BRITTANY Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2022-06-09: Observed fryers on prep table across from ice machine **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3953212 TAQUERIA LAS PALMAS
 License Type: Mobile Food Dispensing Vehicle 8811 GUNN HWY, ODESSA 33556

Inspection Date: 06/09/2022 Inspection Number: 1244041 Inspection Type: Routine - Food Inspection Disposition: Warning
 Inspector Name: SILVERWOOD, JANNETTA Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810528 OOTOYA SUSHI.LOUNGE
 License Type: Permanent Food Service 621 E CENTRAL BLVD, ORLANDO 32801

Inspection Date: 06/07/2022 Inspection Number: 3181052 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 6 propane tanks stored in garage in dry storage area **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5854837 CHEF JEAN CUISINE
 License Type: Mobile Food Dispensing Vehicle 1206 W ROBINSON ST, ORLANDO 32805

Inspection Date: 06/09/2022 Inspection Number: 1243625 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BUCKNER, ELLIOT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Tank inside mobile unit. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815148 THE COMMISSION BEER CHAMBER
 License Type: Permanent Food Service 2230 CURRY FORD RD, ORLANDO 32806

Inspection Date: 06/07/2022 Inspection Number: 3124295 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Door marked as Exit, has drink coolers in front door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814743 LA BELLE
 License Type: Permanent Food Service 7400 SOUTHLAND BLVD SUITE 108, ORLANDO 32809

Inspection Date: 06/07/2022 Inspection Number: 3189292 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811663 DOMINO'S PIZZA #5121
 License Type: Permanent Food Service 5389 S KIRKMAN RD, ORLANDO 32819

Inspection Date: 06/07/2022 Inspection Number: 3117655 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ARANA, MIRIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in dish room . Gas power pressure washer. For reporting purposes only. **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 5803571 HILTON ANDIAMOS
 License Type: Permanent Food Service 1751 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830

Inspection Date: 06/06/2022 Inspection Number: 3108621 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./all three boiler certificates expired.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5813972 STK ORLANDO LLC LOWER & MAIN LEVELS
 License Type: Permanent Food Service 1580 E BUENA VISTA DR SUITE C-17, LAKE BUENA VISTA 32830

Inspection Date: 06/07/2022 Inspection Number: 3188964 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by copier machine	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6009232

FARMER'S TABLE EXPRESS

License Type: Permanent Food Service

1901 N MILITARY TRL, BOCA RATON 33431

Inspection Date: 06/10/2022

Inspection Number: 3186163

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Operator has reports stating inspection was done. Certificate not issued. Operator will look into situation **Corrective Action Taken**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

