

Broward County

License Number: 1619598

CAFE MINAS

License Type: Permanent Food Service

1680 W HILLSBORO BLVD, DEERFIELD BEACH 33442

Inspection Date: 06/14/2022

Inspection Number: 3189047

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOPEZ, BREONNTE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed behind front counter.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1801147

CHILI'S SOUTHWEST GRILL & BAR

License Type: Permanent Food Service

1471 TAMIAMI TRL, PORT CHARLOTTE 339481069

Inspection Date: 06/13/2022

Inspection Number: 3189680

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: WALTER, KAYLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed missing outlet cover on cookline under hood system, and missing cover on electrical box under dish machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Observed missing outlet cover on cookline under hood system, and missing cover on electrical box under dish machine. - From follow-up inspection 2022-06-17: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2103713

FRANKLIN SOCIAL

License Type: Permanent Food Service

5926 PREMIER WAY #100, NAPLES 34109

Inspection Date: 06/15/2022

Inspection Number: 3163984

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code Observation

Violation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330040 WINGSTOP RESATURANT
 License Type: Permanent Food Service 21317 NW 2 AVENUE, MIAMI 33169

Inspection Date: 06/16/2022 Inspection Number: 3189915 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exterior of door marked exit is blocked by boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2360256 LA CHAMA FOOD
 License Type: Mobile Food Dispensing Vehicle 12491 SW 130 ST, MIAMI 33186

Inspection Date: 06/17/2022 Inspection Number: 1250135 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2359835 JH CARNE EN VARAU A LA LLANERA 5
 License Type: Mobile Food Dispensing Vehicle 17721 SW 104 ST, MIAMI 33196

Inspection Date: 06/10/2022 Inspection Number: 1244099 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900819

RUSWALD THEATRES

License Type: Permanent Food Service

5011 N U S HWY 41, RUSKIN 335723501

Inspection Date: 06/15/2022

Inspection Number: 3131126

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CRUZ, JABULANI

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Cooking burgers on flattop grill- discussed using oven to cook

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5150455

TAQUERIA MI REINA

License Type: Mobile Food Dispensing Vehicle

1880 63RD AVE E, BRADENTON 34203

Inspection Date: 06/14/2022

Inspection Number: 1248630

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AUBIN, GARY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee.
 Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810246 SONIC DRIVE-IN
 License Type: Permanent Food Service 5399 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 06/14/2022 Inspection Number: 3111607 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: ARANA, MIRIAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by water vaccum.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814683 CHIPOTLE MEXICAN GRILL
 License Type: Permanent Food Service 11513 REGENCY VILLAGE DR, ORLANDO 32821

Inspection Date: 06/14/2022 Inspection Number: 3189686 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: PASIECKI, VICTORIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Hole in wall with exposed uncapped wires, far right side of cookline near table - From follow-up inspection 2022-06-14: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Hole in wall with exposed uncapped wires, far right side of cookline near table	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5906291

CHARLEY'S WINGS AND PHILLY STEAKS

License Type: Permanent Food Service

3250 W VINE ST, KISSIMMEE 34741

Inspection Date: 06/17/2022

Inspection Number: 3152455

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6252174 SAFETY TACOS CORP
 License Type: Mobile Food Dispensing Vehicle 1188 KAPP DRIVE, CLEARWATER 33765

Inspection Date: 06/17/2022 Inspection Number: 1249932 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KLINGENSMITH, DESIREE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Hanging near door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6208925 EAST LAKE CAFE
 License Type: Permanent Food Service 3430 EAST LAKE RD, PALM HARBOR 34685

Inspection Date: 06/13/2022 Inspection Number: 3186246 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KLINGENSMITH, DESIREE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone - class K For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216005 BARFLY - SALTWATER GRILL
 License Type: Permanent Food Service 100 MAIN ST STE 101, SAFETY HARBOR 34695

Inspection Date: 06/16/2022 Inspection Number: 3183341 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: POWELL, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 7 blue rhino propane tanks present in the dish pit area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905371

ICE SPOT

License Type: Permanent Food Service

237 WHEELHOUSE LANE STE 1305, LAKE MARY 32746

Inspection Date: 06/15/2022

Inspection Number: 3189809

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. At the prep kitchen a trash can is blocking the exit

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501082

LLAMA RESTAURANT

License Type: Permanent Food Service

415 ANASTASIA BLVD, SAINT AUGUSTINE 32080

Inspection Date: 06/16/2022

Inspection Number: 3184658

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.
Walk in cooler door has no escape handle on inside of door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.