

Brevard County

License Number: 1504451

CHILI'S MERRITT ISLE FL #388

License Type: Permanent Food Service

530 MERRITT IS CSWY, MERRITT ISLE 32952

Inspection Date: 06/22/2022

Inspection Number: 3141152

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by rear door has gauge in red

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1611844

SANTA BARBARA COFFEE SHOP

License Type: Permanent Food Service

2653 DAVIE BLVD, FORT LAUDERDALE 33312

Inspection Date: 06/20/2022

Inspection Number: 3190107

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MCKINNEY, JOHN

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Stored between water heater and freezer at back of kitchen.
Operator moved tank outside. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623519

FIRST WATCH RESTAURANT #133

License Type: Permanent Food Service

3644 W HILLSBORO BLVD, DEERFIELD BEACH 33442

Inspection Date: 06/21/2022

Inspection Number: 3190145

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DUNLEAVY, BRENDAN

Violation CodeObservationViolation Citation

45-06-4

Portable fire extinguisher next to ice machine is inaccessible (on the floor).For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334644 POLLO TROPICAL
 License Type: Permanent Food Service 23200 SW 112 AVE, HOMESTEAD 33032

Inspection Date: 06/20/2022 Inspection Number: 3190216 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PICO, JORGE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
 Observed two garbage cans blocking the exit door.
 Operator moved the garbage cans **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329107 SETAI SOUTH BEACH
 License Type: Catering 2001 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 06/22/2022 Inspection Number: 1120232 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HODGE, KRISTEN

Violation Code ObservationViolation Citation

48-01-5 - From initial inspection : No current insurance inspector boiler report or expired boiler certificate available for boiler. For reporting purposes only. Observed boiler jurisdiction number's 133619 expired 5/20/21; 093572; 093573; 093674 All expired 5/8/2021 **Repeat Violation** - From follow-up inspection 2022-06-22: **Time Extended**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2360279 LA FLOR DE LOTO 2
 License Type: Mobile Food Dispensing Vehicle 2732 SW 137TH AVE, MIAMI 33175

Inspection Date: 06/21/2022 Inspection Number: 1250203 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued
 Inspector Name: LEIDECKER, EDILMA

Violation Code ObservationViolation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337316 CHIKIN DORAL LLC
 License Type: Permanent Food Service 9420 NW 41 ST UNIT 111, DORAL 33178

Inspection Date: 06/23/2022 Inspection Number: 3190467 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
 Observed two boilers with an input rating of 650,000 btu. No boiler certificate available.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Escambia County

License Number: 2706081

NICK'S BOATHOUSE

License Type: Permanent Food Service

455 W MAIN STREET, PENSACOLA 32502

Inspection Date: 06/24/2022

Inspection Number: 3190762

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BARNARD, JOHN

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Upon inspection observed frayed wire hard wired into wall right side of hand washing sink in prep area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105310

EL SAUSSIE

License Type: Permanent Food Service

4211 20 ST, VERO BEACH 32960

Inspection Date: 06/24/2022

Inspection Number: 3190681

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 tanks inside kitchen, manager moved outside ****Corrected On-Site**** ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606451

BERNWOOD GRILLE & CATERING CO

License Type: Permanent Food Service

25221 BERNWOOD DR, BONITA SPRINGS 34135

Inspection Date: 06/24/2022

Inspection Number: 3174816

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DOMKOWSKI, DANIEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks stored by table under gas grill in front of establishment. Operator moved to outside of building.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808408 WENDY'S #5799
 License Type: Permanent Food Service 13480 S AOPKA VINELAND RD, ORLANDO 32821

Inspection Date: 06/23/2022 Inspection Number: 3190591 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVIS, DAVID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - mop bucket, hand truck - operator removed items **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813146 BUFFALO WILD WINGS 545
 License Type: Permanent Food Service 10761 INTERNATIONAL DRIVE, ORLANDO 32821

Inspection Date: 06/24/2022 Inspection Number: 3190636 Inspection Type: Quality Assurance Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only./ empty's boxes **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806126 DENNY'S #6366
 License Type: Permanent Food Service 11915 E COLONIAL DR, ORLANDO 32826

Inspection Date: 06/23/2022 Inspection Number: 3190496 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended
 Inspector Name: VAZQUEZ, JULITZA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Chairs in front of exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911668

GRAND HOTEL KISSIMMEE - BREAKFAST

License Type: Permanent Food Service

3104 PARKWAY BOULEVARD, KISSIMMEE 34747

Inspection Date: 06/23/2022

Inspection Number: 3190054

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pinellas County

License Number: 6213045

DON CESAR - MARITANA

License Type: Permanent Food Service

3400 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 06/23/2022

Inspection Number: 3179682

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. Boiler certificates expired.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6213363

DON CESAR - SOCIETY TABLE

License Type: Permanent Food Service

3400 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 06/23/2022

Inspection Number: 3179652

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Sarasota County

License Number: 6805244

SUPER BUFFET

License Type: Permanent Food Service

5471 FRUITVILLE RD, SARASOTA 34232

Inspection Date: 06/22/2022

Inspection Number: 3186193

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Left rear exit door blocked with equipment. Employee removed equipment.
 Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.